#### Building Simulation 2009 University of Strathclyde, Glasgow 27th - 30th July

# CONTROL STRATEGIES FOR MANAGING ENERGY IN A BUILDING MOCK-UP

Julien Eynard, Benjamin Paris, Stéphane Grieu, Thierry Talbert & Frédérik Thiéry ELIAUS Laboratory, University of Perpignan, Perpignan, France

Tuesday 29<sup>th</sup> July 2009, 09:20 am

COC1: Simulation Assisted Control and Control Strategy Development





Glasgow



#### Summary

- Introduction
- Simulation of a building mock-up
- Control strategies
- PID control
- MPC-PID control
- Fuzzy-PID control
- Results
- Conclusion and perspectives



Simulation

Control

PID

### Introduction

- Building and energy
  - 46% of total energy consumption in France
  - 25% of greenhouse gases emissions
  - Need to save fossil energies
    - Development of more efficient control strategies



**Fuzzy-PID** 

**MPC-PID** 

**Results** 

Conclusion



Control

**MPC-PID** 

**Fuzzy-PID** 

**Results** 

Conclusion

PID

# Simulation of a building mock-up

- Fabrication of a building prototype
  - Scale: 1/24 (120 m<sup>2</sup>)
  - Material: Plasterboard, tile floor, polystyrene and polyane
  - Complete, versatile and easy to install instrumentation
- Development of a monitoring system (ARM9, data acquisition and control)
  - 8 sensors for temperature acquisition
  - 2 energy sources available for heating :
    - Renewable (Main source)
    - Fossil (Extra source)







Simulation

Control

PID

**MPC-PID** 

Fuzzy-PID

Results

Conclusion

## Simulation of a building mock-up

- Modelling
  - Experimental acquisitions
  - Choice of an overall equation structure
  - Formalization of <sup>m</sup> the identification problem (prediction-error minimization)



$$T_{i}(k+1) = \alpha_{i}.T_{i}(k) + \beta_{i1}.u_{1}^{\rho_{i1}}(k) + \beta_{i2}.u_{2}^{\rho_{i2}}(k) + \gamma_{i}.T_{out}(k)$$

$$\min_{\alpha,\beta_{1},\beta_{2},\rho_{1},\rho_{2},\gamma} \left[ J = \sum_{k=1}^{N} \left( T_{mes} \left( k \right) - T_{mod} \left( k \right) \right)^{2} \right]$$



Control

**Results** 

PID

# Simulation of a building mock-up

- **Results of Identification** 
  - Curve-fitting between experimental and modeled data
  - → Coherent results : mean of all curve-fitting is more than 90%





Simulation

PID

**MPC-PID** 

**Fuzzy-PID** 

**Results** 

Conclusion

### **Control strategies**

- Control scenario specifications
  - Based on occupancy scenarios and temperature set point (THCE 2005)
  - Criteria specifications
    - Temperature set-point
    - Fossil consumption
    - Global performance







# **PID control**

- Simulation
- Control
- PID
- MPC-PID
- Fuzzy-PID
- **Results**
- Conclusion

 PID is a classical controller



- Heating power repartition
- Optimal PID
  - Optimization of PID gains (K, K<sub>i</sub>, K<sub>d</sub>)
  - Maximization of  $I_P$

 $\begin{cases} x_{i}(k) = x_{i}(k-1) + K_{i} \cdot (T_{sp}(k) - T_{m}(k)) \\ x_{d}(k) = K_{d} \cdot x_{d}(k-1) + (T_{m}(k-1) - T_{m}(k)) \\ u(k) = K_{p} \cdot (c(k) - y(k) + x_{i}(k) + x_{d}(k)) \\ u_{sat_{PID}}(k) = u_{PID}(k) \\ if (u_{PID}(k) > U_{max}(k)) then u_{sat_{PID}}(k) = U_{max} \\ if (u_{PID}(k) < 0) then u_{sat_{PID}}(k) = 0 \\ x_{i}(k) = x_{i}(k) + (T_{e}/K.T_{aw}) \cdot (u_{sat_{PID}}(k) - u(k)) \end{cases}$ 

 $\max_{K,K_{i},K_{d}} \left( I_{p} = I_{C} - \mathscr{H}_{EF} \right)$ s.a. {thermal equations PID controller



Simulation

Control

**Fuzzy-PID** 

**Results** 

Conclusion

PID

### **MPC-PID** control

- Model Predictive Control
- Online minimization of a quadratic cost J
- Optimal MPC
  - Optimization of  $\omega$
  - Maximization of  $I_P$

 $\max_{\omega} \left( I_p = I_c - \%_{FE} \right)$ 

under constrains:

s.a.  $\begin{cases} \text{thermal equations} \\ \text{Best PID controller} \\ \text{MPC controller} \end{cases}$ 



 $\min_{\Delta u(k/k),\cdots,\Delta u(k+c-1/k)}$ 



 $\begin{cases} model equations \\ PID control equations \\ U_{REmin} \leq U_{RE(k+i/k)} \leq U_{REmax} \\ U_{FEmin} \leq U_{FE(k+i/k)} \leq U_{FEmax} \\ \Delta u(k+h) = 0, \quad h = \{c, \dots, p-1\} \end{cases}$ 



- Simulation
- Control
- PID
- **MPC-PID**
- Fuzzy-PID
- **Results**
- Conclusion

#### **Fuzzy-PID control**

- Fuzzy logic controller
  - Fuzzification
  - Inference
  - Defuzzification
- Optimal Fuzzy-PID
  - Optimization of fuzzy gains (K<sub>RE</sub>, K<sub>FE</sub>)
  - Maximization of  $I_{P}$  $\max_{K_{RE},K_{FE}} (I_{p} = I_{C} - \%_{EF})$





Simulation

Control

**MPC-PID** 

PID

### **Optimization results**

- PID: 521 Wh.m<sup>-2</sup> of fossil energy
- Fossil energy saving
  MPC-PID: 140 Wh.m<sup>-2</sup>
  - Fuzzy-PID: 51 Wh.m<sup>-2</sup>

	E <sub>RE</sub> [Wh.m <sup>-2</sup> ]	E <sub>FE</sub> [Wh.m <sup>-2</sup> ]	% <sub>fe</sub> [%]	Ι <sub>c</sub> [%]	І <sub>Р</sub> [%]
Office temperature set-point					
PID	7494	521	6,5	72,0	65,5
MPC	7339	381	4,9	73,6	68,7
FLC	7731	470	5,7	72,4	66,7





# **Results and discussion**

- Introduction
- Simulation
- Control
- PID
- **MPC-PID**
- Fuzzy-PID
- Results
- Conclusion

- PID
  - Very easy development and implementation
  - Good results if optimized
- MPC-PID
  - Hard development (need an linear internal model)
  - Need an on-line optimizer (fast processor)
  - Best results (27% of fossil energy saving)
- Fuzzy-PID
  - Not very difficult to develop
  - Easy to implement
  - Interesting results (10% of fossil energy saving)



- Simulation
- Control
- PID
- **MPC-PID**
- Fuzzy-PID
- **Results**

Conclusion

# **Conclusion and perspectives**

- Conclusion
  - Modelling of a building mock-up
  - Definition of criteria for the control strategies
  - Performance comparison of different kind of optimal controllers (PID, MPC-PID, FLC-PID)
  - Results: significant fossil energy saving
- Perspectives
  - Enforce the controllers to the mock-up
  - Extend to a real building on a scale of 1/1



# The End

Thank you for your attention

Please feel free to ask any questions

#### CONTROL STRATEGIES FOR MANAGING ENERGY IN A BUILDING MOCK-UP



