

Determination of the capacitance of long transformer oil gaps with insulating barriers

Fettouma Guerbas, M. Zitouni, A. Boubakeur, Abderrahmane Beroual

▶ To cite this version:

Fettouma Guerbas, M. Zitouni, A. Boubakeur, Abderrahmane Beroual. Determination of the capacitance of long transformer oil gaps with insulating barriers. ISH, Aug 2013, Séoul, South Korea. pp.PE-51. hal-00921842

HAL Id: hal-00921842 https://hal.science/hal-00921842

Submitted on 24 May 2019

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers. L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

DETERMINATION OF THE CAPACITANCE OF LONG TRANSFORMER OIL GAPS WITH INSULATING BARRIERS

F. Guerbas¹, M. Zitouni², A. Boubakeur³ et A. Beroual⁴ ¹ LSEI Laboratory, USTHB University, BP 32 El Alia 16111, Bab Ezzouar, Algiers, Algeria ² Université Ziane Achour, Djelfa, 17000, Algeria ³ L.R.E. / Laboratoire de Haute Tension, Ecole Nationale Polytechnique, 10 Avenue Pasteur Hassen Badi, BP 182, El Harrach, Alger, Algeria ⁴ Laboratoire d'Ampère, CNRS UMR 5005, Ecole Centrale de Lyon, University of Lyon, 36, Avenue Guy de Collongue, 69134 Ecully, France * E-mail : f_guerbas@yahoo.fr

Abstract: This work is aimed at the effect of insulating barriers on the variation of the capacitance of long transformer oil gap systems submitted to AC Voltage. The tests are carried out in point-plane electrode arrangement by considering the influence of the parameters of barriers such as its position with respect to the electrodes and its thickness. The capacitances of the system with barrier and that one without barrier are compared. It's shown that the evolution of the pre-breakdown charge versus the applied voltage has a capacitive behavior. The insertion of barrier increases the capacitance of the system resulting in a decrease of the impedance of the system. The determination of the capacitance provides a correlation between the electrical charge and the dielectric strength.

1 INTRODUCTION

It is well known that the dielectric strength of divergent long oil gaps is significantly increased by the insertion of an insulating solid material into the electrodes gaps [1-8]. This is due to the fact that the barrier acts as a geometrical obstacle for the disruptive discharge by extending the discharge trajectory [1, 2, 4 - 6]. The efficiency of barrier (i.e., the improvement degree) depends on many parameters. And the physicochemical mechanisms responsible of this improvement are far from being understood. The understanding of these mechanisms passes through the understanding of the pre-breakdown phase and the parameters characterizing it.

This paper deals with the influence of the insulating barrier on the pre-breakdown charge and the capacitance of long oil point-plane gaps. The main investigated parameters are the effects of applied voltage, the electrodes gap, the barrier position and its thickness. The capacitances of the system with barrier to that one without the barrier are also analyzed; and the equivalent impedance of the system without barrier is also deduced.

2 Experimental Set Up

The experimental set up consists of a high voltage test transformer 300kV/50kVA/50Hz, a capacitive voltage divider and a transparent test cell of 175 litres volume (Figure 1). The test cell is made of Plexiglas (700mm×500mm×500mm). It contains a point-plane electrode arrangement mounted horizontally (Figure 2). The point electrode is made up of brass and has a radius of curvature of 6 mm.



Figure 1: photograph of test cell



The plane electrode is made up of steel and has a circular shape of 35 cm diameter. The electrode gap varies between 1 and 12 cm. The insulating

barriers have a circular shape and are made of

Presspahn (ϵ_r =3) (Figure3). Two thicknesses (2 and 4 mm) of barrier are considered. The barrier is mounted vertically between the electrodes and sustained by thin insulating threads. The barrier surface is cleaned with isopropyl alcohol. The mineral oil we used is of naphthenic type; it is subjected to rigorous conditions of storage in sealed drums for protection against degradation and humidity environment. The pre-breakdown charge is measured through a capacitance of 0.02 μ F, inserted between the plane electrode and the earth; it is connected to a storage oscilloscope. The value of the pre-breakdown charge reported on the different curves represents an average value on a series of six measurements. The position of the barrier is defined by the ratio "/d" (Figure 2) where 'a' is the point-barrier distance and "d" is the point-plane gap.



Figure 3: Scheme of barrier

3 Experimental results and discussion

Figures 4 and 5 show the effect of insulating barrier on pre-breakdown charge for different position of the barrier. For a given electrode gap and diameter of barrier, the pre-breakdown charge increases with applied voltage for all position of the barrier. This evolution of charge shows that the oil gap has a capacitive behavior. Therefore, the position of the barrier in the oil gaps does not influence the pre-breakdown charge, except for the position a/d = 0, where the barrier is in contact with the electrode point. In this case, the prebreakdown charge is higher than those ones for other positions especially when the applied voltage is higher than 15kV. This fact can be explained by the accumulation of a large amount of charge on the surface of the barrier [9].

The capacitance of the point-barrier-plane gap length is deduced from the charge-applied voltage characteristics. It is observed that the capacitance is practically constant for all position of the barrier except when the barrier is very close to the point electrode (Figures 6 to 9). This result may relate to the structure of the material of the barrier.



Figure 4: Pre-breakdown charge *vs.* the applied voltage for different positions of the barrier; d=12cm, e=2mm, D=20cm



Figure 5: Pre-breakdown charge *vs.* the applied voltage for different positions of the barrier; d=12cm, e=4mm, D=20cm



Figure 6: Variation of the capacitance *vs.* the applied voltage for different positions of the barrier; D=20cm, d=12cm, e=2mm

Figures 10 and 11 show the variation of the capacitance versus the electrode gaps for different positions of the barrier. It appears from these curves that the capacitance of the system decreases when the electrode gaps increase. The higher value of the capacitance is obtained at

a/d=0; this indicates an increase of the charge amount.



Figure 7: Variation of the capacitance *vs.* the applied voltage for different positions of the barrier, D=20cm, d=12cm, e=4mm



Figure 8: Variation of the capacitance *vs.* the applied voltage for different positions of the barrier, D=20cm, d=8cm, e=2mm



Figure 9: Variation of the capacitance *vs.* the applied voltage for different positions of the barrier, D=20cm, d=8cm, e=4mm

As shown in Figures 12 and 13, the variation of the barrier thickness leads to the increase of the capacitance of the point-barrier-plane, thereby to the decrease of the impedance (Figure 14). The

maximum value appears at the smallest the electrodes gap. As a result, the increase of the presspahn thickness strongly depends upon the surface charge accumulation [10].



Figure 10: Variation of the capacitance *vs.* the electrodes gap for different positions of the barrier, D=20cm, U=35k, e=4mm



Figure 11: Variation of the capacitance *vs.* the electrodes gap for different positions of the barrier, D=20cm, U=35kV, e=2mm



Figure12: Variation of the capacitance *vs.* the electrodes gap for two different thickness, D=20cm, U=5kV, a/d=0.

A comparison between the system with barrier and that one without barrier has been performed. Figure 15 depicts the variation of the capacitance

versus the applied voltage for both systems. The insertion of the barrier in a point-plane electrode arrangement increases the impedance of the system resulting in a decrease of the capacitance of the system.



Figure 13: Variation of the capacitance *vs.* the electrodes gap for two different thicknesses; D=20cm, U=15kV, a/d=0



Figure 14: Variation of the impedance *vs.* the electrodes gap for two different thicknesses; D=20cm, a/d=0, U=15kV



Figure 15: variation of the capacitance *vs.* the applied voltage for system with and without barrier, e=2mm, d=12cm, D=10cm

4 Conclusion

This work shows that the insertion of an insulating barrier in divergent oil gaps decreases significantly the pre-breakdown charge. This decrease depends on the applied voltage and the barrier thickness. On the other hand, the evolution of the charge versus the applied voltage for both systems with and without barrier shows that the oil gap has a capacitive behavior. The insertion of the barrier increases significantly the impedance and decreases the capacitance of the system. This is of interest for electrical insulation design.

5 **REFERENCES**

- [1] Z. Zouaghi and A. Beroual, Discharge Structure and Dielectric Strength of Long Oil Gaps in Presence of an Insulating Barrier, IEEE Annual Report, Conference on Electrical Insulation and Dielectric Phenomena, Minneapolis, Minnesota, U.S.A., October 19-22, 1997, pp. 660-663
- [2] A. Zouaghi and A. Beroual, Barrier Effect on the Dielectric Strength of Oil Gaps under DC Voltage, 1998 IEEE International Symposium on Electrical Insulation, Arlington, Virginia, USA, 7 - 10 June, 1998, pp. 640-643
- [3] A. Zouaghi and A. Beroual, Barrier Effect on the Time Lag to Breakdown of Transformer Oil Gaps under Lightning Impulse Voltage, IEEE Annual Report, 1998 Conference on Electrical Insulation and Dielectric Phenomena, Atlanta, Georgia, USA, October 25-28, 1998, pp.444-447
- [4] A. Beroual and A. Zouaghi, Barrier Effect on Prebreakdown and Breakdown Phenomena in Long Oil Gaps under Lightning Impulse Voltages, Archives of Electrical Engineering, N°3, 1999, pp. 305-321
- [5] L. Kebbabi and A. Beroual, Optical and Electrical Investigations on Creeping Discharges over Solid/Liquid Interface under Lightning Impulse Voltage, IEEE Trans. Dielectrics and Electrical Insulation, Vol. 13, No. 3, 2006, pp. 565-571
- [6] F. Guerbas, M. Zitouni, A. Boubakeur and A. Beroual, *Barrier Effect on Breakdown of Point* – *Plane Oil gaps under AC Voltage*, IET Generation, Transmission & Distribution Vol. 4, Issue 11, pp. 1245 – 1250, November 2010
- [7] F. Guerbas, A. Boubakeur and A. Beroual, Prebreakdown Current in Long Transformer Oil Gaps with Insulating Barrier under AC Voltage, 2011 IEEE Conference on Electrical Insulation and Dielectric Phenomena, Cancun, Mexico, October 16 – 21, 2011

- [8] F. Guerbas, M. Zitouni, A. Boubakeur and A. Beroual, Barrier diameter effect on the behaviour of transformer oil submitted to AC Voltage, 2012 International Conference on High Voltage Engineering and Application, 17 -20 September, 2012, Shanghai, China
- [9] F. Guerbas, A. Boubakeur and A.Beroual, Influence d'une barrière isolante sur la charge de pré-claquage de l'huile de transformateur sous tension Alternative, Algerian Journal Of Technology, AJOT, Algeria, pp. 165-169, 2011
- [10] F. Guerbas, Influence des barrières sur la rigidité diélectrique de l'huile minérale, PhD Thesis, Ecole Nationale Polytechnique d'Alger, Algeria, 2011