

Friction-corrosion of AISI 316L/bone cement and AISI 316L/PMMA contacts: ionic strength effect on tribological behaviour

Jean Geringer, Fouad Atmani, Bernard Forest

▶ To cite this version:

Jean Geringer, Fouad Atmani, Bernard Forest. Friction-corrosion of AISI 316L/bone cement and AISI 316L/PMMA contacts: ionic strength effect on tribological behaviour. 17th International Conference on Wear Of Materials (WOM 2009), 2009, Las Vegas, United States. p.12. hal-01063441

HAL Id: hal-01063441 https://hal.science/hal-01063441

Submitted on 12 Sep 2014

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers. L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

Elsevier Editorial System(tm) for Wear of Materials 2009 Special Issue Manuscript Draft

Manuscript Number:

Title: Friction-corrosion of AISI 316L/bone cement and AISI 316L/PMMA contacts: ionic strength effect on tribological behaviour

Article Type: Case Study / Test Methods

Keywords: Friction-corrosion; AISI 316L; PMMA; Bone cement; Ionic strength

Corresponding Author: Dr. Jean Geringer,

Corresponding Author's Institution: ENSM-SE

First Author: Jean Geringer, Assistant professor

Order of Authors: Jean Geringer, Assistant professor; Jean Geringer; Fouad Atmani; Bernard Forest, Professor

Abstract: Wear phenomena understanding of implants is a challenge: friction-corrosion of biomaterials, which constitute orthopaedic implants, is a significant issue concerning the aseptic loosening. This work aims at studying AISI 316L/bone cement friction which is a tribological problem related to hip joint cemented prostheses. This study focuses on the ionic strength effect on the tribological behaviour of 316L/bone cement and 316L/PMMA contacts. PMMA, poly(methylmethacrylate), can be considered as a model material for bone cement because of vicinity of mechanical properties and PMMA transparency. Pin on disk friction tests were investigated, in different media with NaCl concentration increasing. Friction coefficient and free corrosion potential of 316L sample were monitored. Moreover, SEM-FEG and microraman spectroscopy analyses were investigated on samples surfaces. Friction coefficient evolution according to ionic strength, for 316L/bone cement and 316L/PMMA contacts, are opposite. Indeed, when the ionic strength increases, the friction coefficient growths (decreases), for 316L/PMMA contact (for 316L/bone cement contact). The free corrosion potential decreases in both cases but more drastically for 316L/PMMA contact with ionic strength increasing. One might suggest that ions adsorption on 316L and PMMA surfaces involves attraction between surfaces in contact. On the contrary, ions adsorption on bone cement has no effect in terms of surface attraction forces, the gap between surfaces is too big due to roughness of bone

cement. If ions concentration increases, the tribofilm viscosity between 316L and bone cement could increase. Attraction forces between surfaces are the less significant phenomenon compared to lubricant effect of tribofilm, 316L/bone cement contact. SEM-FEG analysis highlighted principally deep grooves on 316L surface, corrosive wear after destruction of passive film by friction. Finally microraman spectroscopy results, on metal surface, show principally Fe3O4 and Cr2O3 oxides deposits. Further investigations are in progress for understanding surfaces interactions during friction.

Friction-corrosion of AISI 316L/bone cement and AISI 316L/PMMA contacts: ionic strength effect on tribological behaviour

J. Geringer^{a*}, F. Atmani^a, B. Forest^a

^a Ecole Nationale Supérieure des Mines de Saint-Etienne, UMR CNRS 5146, 158, cours Fauriel F-42023 Saint-Etienne Cedex 2

Received Date Line (to be inserted by Production) (8 pt)

Abstract

1 2

3

4

5 6 7

8 9 10

11 12

13 Wear phenomena understanding of implants is a challenge: friction-corrosion of biomaterials, which constitute orthopaedic 14 implants, is a significant issue concerning the aseptic loosening. This work aims at studying AISI 316L/bone cement friction 15 which is a tribological problem related to hip joint cemented prostheses. This study focuses on the ionic strength effect on the tribological behaviour of 316L/bone cement and 316L/PMMA contacts. PMMA, poly(methylmethacrylate), can be considered 16 as a model material for bone cement because of vicinity of mechanical properties and PMMA transparency. Pin on disk 17 friction tests were investigated, in different media with NaCl concentration increasing. Friction coefficient and free corrosion 18 potential of 316L sample were monitored. Moreover, SEM-FEG and microraman spectroscopy analyses were investigated on 19 samples surfaces. Friction coefficient evolution according to ionic strength, for 316L/bone cement and 316L/PMMA contacts, 20 are opposite. Indeed, when the ionic strength increases, the friction coefficient growths (decreases), for 316L/PMMA contact 21 (for 316L/bone cement contact). The free corrosion potential decreases in both cases but more drastically for 316L/PMMA 22 contact with ionic strength increasing. One might suggest that ions adsorption on 316L and PMMA surfaces involves attraction 23 between surfaces in contact. On the contrary, ions adsorption on bone cement has no effect in terms of surface attraction 24 forces, the gap between surfaces is too big due to roughness of bone cement. If ions concentration increases, the tribofilm 25 viscosity between 316L and bone cement could increase. Attraction forces between surfaces are the less significant 26 phenomenon compared to lubricant effect of tribofilm, 316L/bone cement contact. SEM-FEG analysis highlighted principally deep grooves on 316L surface, corrosive wear after destruction of passive film by friction. Finally microraman spectroscopy 27 results, on metal surface, show principally Fe₃O₄ and Cr₂O₃ oxides deposits. Further investigations are in progress for 28 understanding surfaces interactions during friction. 29

31 Keywords: Friction-corrosion, AISI 316L, Bone cement, PMMA, Ionic strength

³³³⁴ 1. Introduction

Lifetime of orthopaedic implants is a health issue because of people ageing. 800,000 hip prostheses are implanted in Europe and the same order of magnitude in USA. Two ways of implanting femoral stems are available. First, femoral stem can be inserted in the femoral bone. Second, it can be inserted with bone cement between material constituting femoral stem and bone. Sir John Charnley was the first surgeon who fixed a femoral

*Corresponding author. Tel.: +33 477 426 688; fax: +33 477 421 p57.

E-mail address:geringer@emse.fr (J. Geringer)

47 48

30

32

35 36

37 38

39

40 41

stem with a bone cement based on poly (methylmethacrylate) composition [1]. Numerous formulae of acrylic polymers and co-polymers have been developed since 70's [2].

The cemented hip replacement allows tolerating not precise placement. Moreover, mechanical properties between stem materials, for instance AISI 316L, and bone cement are drastically different. After the implantation, stem and cement are composites materials. Stiffest material, metal, bears most of the load and the upper part of the femoral bone is unloaded, stress shielding phenomena. The bone cement layer plays the role of 'bumper' between metal and bone. It levels the peaks force during human gait. Unfortunately, the bone cement causes problems because of polymerization step in human body, temperature increase, and debonding between metal stem and plastic bone cement, due to stress shielding too. Investigating the load transfer at the interface is a challenging goal because hip implants lifetime depends on this phenomenon [3].

After debonding, fretting, friction under small displacements, occurs. The displacements amplitude is,
 approximately, equal to 50 μm. It depends on the stem zone [4,5]. Calculations were made with contact femoral
 stem made of metal alloy and bone. As mechanical properties of bone are close to the ones of bone cement, one
 might expect that displacement for 316L/bone cement contact is close to the one of 316L/femoral bone contact.
 These low amplitude micromotions occur at the stem-cement interface *in vitro* [6].

Many investigations were carried out to understand the particular fretting between bone cement and 316L in a physiological liquid. It is worth noting that poly(methylmethacrylate), PMMA, mechanical properties are similar to the ones of bone cement except the porosity. Due to the PMMA transparency, studying the 316L/PMMA fretting provides additional scientific comments compared to bone cement/316L contact [7,8]. Moreover, different assumptions have been mentioned to link experimental describing and physical phenomena occurring during fretting. This work focuses on understanding attraction and repulsion phenomena according to solution composition changes. One paid attention on electrokinetical potential submitted to ions charges of the so-called electrical double layer on the materials surface [9]. During fretting, numerous phenomena are involved for constituting the nanometric lubricant film between two materials in contact: for instance, ions concentrations of the medium, iron and protons concentrations due to metal corrosion, hydrogen release (specific to fretting degradation), etc.

Fretting degradations involve high corrosion rate of metal and hydrogen release compared to friction. To separate numerous parameters contribution, it has been decided to investigate friction corrosion of 316L against PMMA and bone cement in Ringer solution and in 1:1 ions solutions, i.e. solutions constituting with NaCl. This medium is simplified compared to physiological liquid. The phenomena interpretation is too complex when one considers physiological liquid, it means that proteins and many different ions act for constituting the double layer on materials surface. It is the reason why only Ringer and NaCl solutions were investigated; ionic strength,

 $\begin{array}{l} 39 \quad I = \sum_{i} z_i^2 C_i \text{ , will be controlled.} \\ 40 \end{array}$

 $I = \sum_{i} z_i^2 C_i$

I: ionic strength; z_i : ion charge; C_i : ion concentration.

This study aims at investigating and understanding ionic strength effect, following friction coefficient during friction tests. Many friction tests were carried out with biomaterials in different solutions. However, the friction coefficient could differ according to the ionic concentration of the friction medium. Highlighting the ionic strength role in wear tests could be an interesting point of view to better understand the solution constitution. Moreover, the ionic strength could play a role concerning the double layer constitution and finally the attraction – repulsion mechanisms during friction.

2. Test materials and experimental techniques

2.1. Materials and tests specimens

The AISI 316L SS (Z2CND17-12), medical quality, is a stainless steel with improved cleanliness and very low carbon content, chemical composition in Table 1. Manufacturing this alloy was in conformity with ISO standards 5832-1.

Elements	Cr	Ni	Mo	Mn	Si	Cu	С	Р	S	Fe
Composition (% w/w)	17.40	13.00	2.60	1.73	0.66	0.10	0.02	0.02	< 0.01	Bal.
Table 1. chemical composition of 2161 stainloss staal										

 Table 1: chemical composition of 316L stainless steel

The metallic sample was a disk of 35 mm diameter and 5 mm thickness. Polishing of the face in contact with the solution was carried out thanks to grid paper from 380 to 4000, diamond solution from 3 μ m to ¹/₄ μ m. Finally the last step was polishing with colloidal silica, particles of 0.06 μ m diameter. AISI 316L SS samples were washed in ultrasonic bath with ethanol and rinsed with desionised water.

PMMA, thermoplastic material, Perspex[®], was polished with diamond solution from 3 μ m to ¹/₄ μ m and colloidal silica. Samples were washed with Neutracon Deacon[®] soap and rinsed with desionised water. PMMA and bone cement sample were parallelepipeds of 6x6x12 mm. Only the face of 6x6 mm was polished.

Bone cement was Palacos R40[®]. A specific mould made of polyethylene has been used to manufacture samples. Due to porosity, samples were not polished because pores play the role of diamond solution tank during friction process.

2.2. Mechanical properties

Table 2 shows mechanical properties of materials, AISI 316L, PMMA and bone cement.

Mechanical properties	Poisson's ratio	Young's modulus (GPa)	Yield stress (MPa)	Ultimate tensile strength (MPa)	K _{IC} (MPa.√m)	Hardness
316L	0.30	197	280	635	55	155 (Vickers)
PMMA	0.39	2.5	65	75	1.3	21 (µVickers)
Bone cement	0.38-0.46***	2.5*		24-60*	1.51**	

 Table 2: mechanical properties of tested materials, * [10], ** [11], *** [12], the other values were obtained by appropriated tests.

Mechanical properties analysis highlights friction tests, i.e. 316L/PMMA or 316L/bone cement, were carried out with hard, stainless steel, and soft materials, PMMA and bone cement.

۱.	2 2	Γ · · ·	1 .
·	/ 1	Friction	aevice
	2.2.	1 11011011	acrice

The friction device was shown on Figure 1. Normal load equal to 19 N was applied by dint of calibrated rod fixed on the support. One paid attention on alignment and parallelism of pin support, disk and the support of the weight applying the normal load. The pin, made of PMMA or bone cement, was drastically pushed in the pin support to respect the alignment between pin and disk during friction test. According to the rotation direction of the pin, normally, the support would rotate in the opposite direction of the load transducer. It is the reason why an anchor link allows the very close contact between the support and the load transducer. Consequently, the actual tangential load, therefore the friction coefficient, was monitored when the pin is in front of the load transducer, i.e. the pin center is in front of the symmetry axis of the transducer.



Figure 1: Friction test device; a) device image; b) scheme of pin-disk assembly.

It was calibrated and the linear evolution of load vs. voltage was verified (correlation coefficient, r^2 , equal to 0.999). Voltage was monitored thanks to Agilent 34970A voltmeter. It is worth noting that the electrical insulating was a key point of the device to monitor the electrode potential made of stainless steel, only the face in contact with the pin was in contact with the solution, due to insulating paint on the other faces of the metal disk. The tests frequency was of 1 Hz, i.e. 1 round per minute for the pin.

2.4. Test solutions

 To investigate the ionic strength effect during friction, the medium was a solution of NaCl from 10^{-3} , 10^{-2} , 10^{-1} to 1 mol.L⁻¹, i.e a gap of three magnitude orders. From 10^{-3} to 1 mol.L⁻¹, the ionic strength is equal to the concentration for NaCl solution. Tests were carried out too with Ringer solution, Table 3; it was used to simulate the physiological liquid. Ionic strength of the Ringer solution is of $1.53.10^{-1}$ mol.L⁻¹.

Concentration (g.L ⁻¹) 8.50 0.25 0.22 0.15 Table 3: composition of Ringer solution Solutions were prepared from desionised water (18.2 M Ω .cm at 25 °C) and used at room temperature ± 2 °C, under natural aeration.											
 Table 3: composition of Ringer solution Table 3: composition of Ringer solution Solutions were prepared from desionised water (18.2 MΩ.cm at 25 °C) and used at room temperature ± 2 °C, under natural aeration. 											
14 15 16 17 Solutions were prepared from desionised water (18.2 MΩ.cm at 25 °C) and used at room temperature 18 19 ± 2 °C, under natural aeration. 20 21 22 a c =											
Solutions were prepared from desionised water (18.2 M Ω .cm at 25 °C) and used at room temperature ± 2 °C, under natural aeration.	rable 5. composition of Kinger solution										
Solutions were prepared from desionised water (18.2 M Ω .cm at 25 °C) and used at room temperature 18 19 20 21 22 24 25 25 20 21 22 24 25 25 25 25 20 21 22 22 24 25 25 25 25 25 25 25 25 25 25											
bounded at room destonated water (10.2 million at 25 °C) and used at room temperature 18 19 ± 2 °C, under natural aeration. 20 21 22 22 22 22 22 22 22 22 22	• 22										
 ± 2 °C, under natural aeration. 20 21 22 24 25 26 27 28 29 20 20 21 21 22 24 25 26 27 28 29 29 20 20 21 21 22 23 24 25 26 27 27 28 29 21 20 21 22 24 25 26 27 27 28 29 29 20 20 21 21 22 24 25 26 27 27 28 29 29 20 20 20 21 21<!--</td--><td colspan="7">solutions were prepared nom desionised water (10.2 Wiszem at 25 °C) and used at room temperature, 22</td>	solutions were prepared nom desionised water (10.2 Wiszem at 25 °C) and used at room temperature, 22										
20 21 22											
21 22											
2.5. Experimental techniques											
24											
²⁵ Roughness measurements were carried out on PMMA and 316L surfaces, with 2D Talvsurf profilom	eter.										
26	,										
During friction, the free corrosion potential of stainless steel disk was monitored thanks to a Radiome											
analytical PGP 201 potentiostat. The saturated calomel reference electrode (SCE) was employed as a pote	ntial										
reference E segual to 244 mV at 25 °C											
Worn surfaces of stainless steel were observed with a classical Scanning Electron Microscope (SE) JMS 840 JEOL. Worn surfaces of PMMA and debris on stainless steel were analyzed with a Scanning Electro Microscope with a Field Electron Gun (SEM-FEG) JEOL 6500. Analyses of PMMA surfaces and debris, with the											
						apparatus, become possible because voltage is lower than the one of classical SEM.					
						Raman spectroscopy was investigated to characterize oxides on stainless steel produced 1					
Especially, the microraman spectroscopy, was performed using Senterra TM Raman spectrometer, Brucker. The											
laser power was 20 mW. The excitation wave length was of 532 nm. The microscope, to locate degradations zone											
and thin oxides denosit was Olympus RV series ontical microscope. Raman Spectra allows identifying share											
44 and thin oxides deposit, was orympus by series optical incroscope. Raman opecial anows identifying even	neur										
45											
47											
48 5											
49											

and structural thin oxides films on stainless steel after friction tests. The space resolution of laser beam is 15x15 μm. It is worth noting that IR spectrometer with grazing incidence was investigated without significant results.

3. Experimental results and discussion

3..1 Tests samples and Ra measurements

Friction tests were investigated for 5 solutions. For 316L-PMMA samples, 5 tests were carried out according to 5 different tests durations, i.e. 1,000, 5,000, 10,000, 20,000 and 80,000 seconds. Therefore, 25 friction tests were carried out. This road map allows testing repeatability of Ra, roughness, friction coefficient and free corrosion potential measurements. For 316L-bone cement, one test duration was of 80,000 seconds.

8 9 10		Ra / μm	Standard deviation Ra/ μm	Curvature Radius, CR / µm	Standard deviation, CR / μm
11 12 12	316L	0.015	0.005	6.7	3.3
13	PMMA	0.07	0.02	11.1	5.0

Table 4: roughness and curvature radius of materials surfaces, PMMA and AISI 316L SS; means of 25 samples.

Table 4 presents roughness and curvature radius of materials friction surfaces, PMMA and AISI 316L stainless steel. It is worth noting that 316L roughness is lower than the value recommended by hip manufacturing ISO standards, 0.05 µm. Investigations were carried out to test roughness, Ra, and/or curvature radius, CR, influence on friction coefficient. Ra and CR have no significant effect on friction coefficient.

Ra of bone cement sample is of $2.5 \pm 0.4 \,\mu\text{m}$, mean of 4 samples.

3.2. 316L/PMMA contact

31 3.2.1. Friction coefficient and Open Circuit Potential

Figure 2 a) shows the typical evolution of friction coefficient vs. time for test duration of 80,000 cycles, NaCl concentration of 1 mol.L⁻¹. At the test beginning, friction coefficient is higher than the one after 5,000 cycles due to the running-in period to accommodate surfaces in contact.



Figure 2: a) friction coefficient variation according to the time, NaCl 1 mol.L⁻¹ solution, 80,000 cycles of test, i.e.80,000 seconds; b) free corrosion potential or Open Circuit Potential, OCP, and friction coefficient, NaCl 10⁻³ mol.L⁻¹, 1,000 cycles of test; E₀: OCP at the friction beginning; E_{gap}: OCP drop at the test beginning; E_{m, 500}: mean value of OCP of 500 first seconds during friction; E_{end}: OCP at the end of friction test; Normal load is equal to 19 N.

Figure 2 b) highlights the free corrosion potential or open circuit potential, OCP, evolution according to the time. Friction coefficient is reported on the same graph. Test conditions were: NaCl concentration of 10^{-3} $mol.L^{-1}$, test duration of 1,000 cycles. At the friction beginning, OCP falls to negative values. Due to degradation of oxides film on stainless steel surface during friction, metal dissolution occurs, i.e. the anodic reaction. Oxygen is dissolved in solution, thus the cathodic reaction is the oxygen reduction. Finally, the mixed potential decreases. During friction, OCP is lower than the one before friction test. At the end of the test, the OCP increases up to the initial value before the test. Frequently, the final OCP was lower than E_0 . Due to mechanical degradations and PMMA debris deposit, metal surface is different from the pristine surface.

According to results shown on figure 3, for each ionic strength, the mean value of the friction coefficient decreases when the test duration increases. At the friction beginning, the running-in period involves high dissipated energy between surfaces in contact. After 5,000 cycles of friction, debris are produced and the third body can play the role of bumper and lubricant interface. Consequently, the friction coefficient decreases. Moreover, the friction coefficient increases according to the ionic strength. One might expect attraction between surfaces in contact is better. However, when ionic concentration growths, solution viscosity increases too. This phenomenon could be account for increasing of friction coefficient according to ionic strength.

Figure 4 shows the mean value of open circuit potential during the 500 first cycles, $E_{m, 500}$, and the drop of free corrosion potential, E_{gap} . It has been decided to present only these results, i.e. $E_{m, 500}$ and E_{eap} . Indeed, OCP evolution, after 500 cycles, highlights high discrepancy between two tests for the same

NaCl concentration. PMMA debris adsorption can perturb the OCP evolution due to debris barrier on 316L surface avoiding metal dissolution.



Figure 3: friction coefficient evolution according to the ionic strength for different test duration; 1 cycle is equal to 1 second; mean values; the discrepancy corresponds to the standard deviation.



Figure 4: E_{m, 500}, mean value of open circuit potential vs. ECS from the friction beginning to 500th cycle (absolute values);
 E_{gap}, OCP drop at the test beginning (absolute values); evolutions according to the ionic strength, the discrepancy corresponds to the standard deviation.

 $E_{m, 500}$ increases according to the ionic strength; the same evolution is shown for E_{gap} . E_{gap} is higher than $E_{m, 500}$. This difference is probably due to oxygen diffusion equilibrium concerning the kinetic of the cathodic reaction.

This particular evolution of potential shift is in accordance with increasing of friction coefficient vs. ionic strength. The contact between surfaces, at high ionic strength, is closer than the one at low high ionic strength. This attempt is consistent with the attraction phenomenon. If viscosity plays a role, the free corrosion potential does not decrease. The viscosity can not be account for oxides layer destruction. This conclusion was highlighted in [13].

Moreover, when chlorides concentration increases in a medium, the passive film of stainless steel is easily disrupted [14]. This phenomenon could be account too for increasing OCP drop when friction starts.

3.2.2. Microstructure surface observations

Figure 5 presents materials samples surfaces submitted to friction tests of 80,000 cycles. SEM images, for 316L samples, exhibit grooves, thickness of 1 mm, are more and more deep and inhomogeneous with the ionic strength increasing. These results are consistent with the friction coefficient and OCP increasing according to the ionic strength, as described above. It is worth noting that, at 1 M of NaCl concentration, the image shows degradations zones less localized than at 10⁻³ M. The corrosion damages are not localized in grooves, therefore one might expect that more generalized corrosion occurs due to high chlorides concentration.



Figure 5: SEM and SEM-FEG images of 316L and PMMA for different ionic strengths; test duration of 80,000 cycles.

SEM-FEG images, PMMA samples, show degradations surfaces after 80,000 cycles. At 10^{-3} M, grooves are thin, less than 1 μ m. At 10^{-2} M, the PMMA surface exhibits debris plaques pulled out and a crack. These elements point out the hypothesis that surfaces attraction forces, due to double layer composition, could be account for friction coefficient increasing. With ionic strength increasing, dissipated energy during friction is more and more high, thus cracks on polymers can occur. At 10^{-1} M, grooves are less and less homogeneous. PMMA debris are produced from PMMA surface. At 1 M, grooves are deepest and third body is inserted in one of them.

PMMA degradations, figure 5, are too consistent with OCP and friction coefficient increasing. Images of Ringer solution tests will not be presented in this work. However, in a few words, it is worth noting that degradations on PMMA and 316L are more difficult to figure out. Due to multiple ions in Ringer solution, attraction and friction phenomena are difficult to identify.

3.2.3. Microraman spectroscopy on 316L surfaces

Identifying oxides layer on 316L surface after friction test was a goal of this tudy. Figure 6 a) shows an image obtained from microscope used with the microraman spectrometer. It exhibits rust on 316L surface. Figure 6 b) presents Raman spectra of pristine surface of 316L, i.e. without friction; P14, P15 and P17 zones, worn surfaces. Each spectrum highlights a particular oxides types. All spectra were interpreted according to reviewing and results provided by [16].



Spectra were not complete to highlight main results. 316L pristine surface shows no typical oxides because of thin thickness of layer. P14 zone exhibits Fe_3O_4 (684.5 cm⁻¹) and α -Fe₂O₃ (276.5 & 219 cm⁻¹). P15

zone shows Cr_2O_3 (150, amorphous phase & 688.5 cm⁻¹) or $FeCr_2O_4$ (688.5 cm⁻¹) and Fe_3O_4 . Da Cunha Belo *et al.* suggests, due to laser power (higher than 6 mW), the following reaction can occur:

 α -Cr₂O₃+Fe₃O₄ $\longrightarrow \alpha$ -Fe₂O₃+FeCr₂O₄. The spectrum points out if FeCr₂O₄ is identified, α -Cr₂O₃ and Fe₃O₄ were on 316L surface. These oxides were formed after metal dissolution. P17 zone exhibits same oxides than P15 zone. The same oxides types were identified for 316L surface wearing by bone cement samples. Linking with orthopaedic fields, these oxides could be assimilated by bone cells around a femoral stem where friction occurs between stem and bone cement.

3.3. 316L/PMMA and 316L/bone cement contacts comparison

This work aims at understanding if friction behaviour of 316L/PMMA contact is the same than the one of 316L/bone cement contact. As PMMA was considered as a model material of bone cement, both contacts do involve the same friction behaviour? Figure 7 shows the behaviour is opposite. The friction coefficient of 316L/bone cement decreases according to the ionic strength. The contact pressure, in our tests, is of 1.58 MPa. It is worth noting that results of figure 6 are in the same order of magnitude of results from [15].



Figure 7: friction coefficient, mean value of 80,000 cycles, evolution vs. ionic strength for 316L/PMMA and 316L/bone cement contacts;

Moreover, the OCP evolution, figure 8, shows that 316L degradations, for 316L/bone cement, are more drastic than the ones, for 316L/PMMA contact. E_{gap} or $E_{m, 500}$ increase, for both contacts, according to the ionic strength.



Figure 8: E_{m, 500}, mean value of open circuit potential vs. ECS from the friction beginning to 500th cycle (absolute values), the standard deviation is calculated from 500 measured values; E_{gap}, OCP drop at the test beginning (absolute values), the standard deviation was calculated from all tests (1,000 to 80,000 cycles) 316L/PMMA, no standard deviation was calculated, only one test at 80,000 cycles was available for 316L/bone cement contact; evolutions according to the ionic strength.

One might expect that the dissolution of metal is submitted to chlorides concentration influence. Chlorides allow disrupting of passive films and promoting the metal dissolution due to driving force of metallic complexes forming. 316L OCP, 316L/bone cement contact, is slightly higher than the one of 316L/PMMA contact. Bone cement roughness could be account for this OCP drop increasing. The friction coefficient evolution for 316L/PMMA could be governed by attraction forces between surfaces, under conditions of weak roughness. Ionic strength and roughness are significant parameters if considering further studies of friction especially in the case of biomaterials friction.

$\frac{30}{31}$ 5. Conclusion

PMMA was considered as a model material of bone cement in previous studies under friction. PMMA
 was usually well polished because of benefiting of its transparency. On the contrary, bone cement sample were
 rough, hip implantation conditions. 316L surfaces were well polished as femoral stem of hip prosthesis.

39 316L/PMMA and 316L/bone cement friction behaviour are similar in the terms of metal dissolution.
40 41 OCP decreases when ionic strength increases. Chlorides concentration increasing involve disrupting of passive 42 film and metal dissolution due to driving force of metal complexes forming. OCP drop, for 316L/bone cement, is

higher than the one for 316L/PMMA. High roughness of bone cement sample promotes oxides film destruction, thus the metal dissolution and finally the OCP drops towards negative values.

Friction coefficient evolutions, for both contact types, are dissimilar. Friction coefficient of 316L/PMMA (bone cement) contact increases (decreases) when the ionic strength increases. One may suggest that attraction between 316L and PMMA could occur and is reinforced when ionic strength increases. Consequently, dissipated energy during friction is high and the friction coefficient increases. The tribofilm, PMMA and/or rust debris and solution, could be more viscous, locally, and involve high friction coefficient. When roughness is higher than 1 μ m, bone cement samples, no attraction between surfaces occurs. Additional investigations have to be carried out to better understand 316L/bone cement friction.

Finally, concerning 316L/PMMA contact, microstructures analyses point out when the ionic strength increases, grooves on 316L and PMMA are more and more deep. Concerning 316L surfaces at 1 M of ionic strength, signs of generalized corrosion, as pittings, appear. According to tests conditions, 316L dissolution occurs and typical oxides were identified after friction thanks to microraman spectroscopy.

Additional works are in progress: same methodology with others 1:1 salts, KCl for instance; investigating of fretting corrosion behaviour to understand attraction phenomenon between surfaces in contact; and modelling, in terms of disjoining pressure, attraction between surfaces in contact during friction.

Acknowledgements

The authors are grateful to J-C. Boulou, Bruker Optics, for the opportunity to interpret spectra provided by SenterraTM Raman spectrometer.

References

- [1] K.D. Kühn, R. Specht, Le ciment acrylique osseux: historique, caractéristiques et propriétés physiques, Maîtrise orthopédique, 126 (2003) 6-13.
- Mathise of hopedique, 120 (2003) 6-13.
 [2] G. Lewis, Properties of acrylic bone cement: State of the art review, Journal of Biomedical Materials Reserach
 Part B ; Applied Biomaterials, 38 (1997) 155-182.
- [3] M.A. Perez, J. Grasa, J.M. Garcia-Aznar, J.A. Bea, M. Doblaré, Probabilistic analysis of the influence of the bonding degree of the stem-cement interface in the performance of cemented hip prostheses, Journal of Biomechanics 39 (2008) 1859-1872.
- [4] PJ. Rubin, PF. Leyvraz, LR. Rakotomanana, Interet de la modelisation numerique dans l'évaluation pre clinique d'une prothese femorale de hanche, Maîtrise orthopédique 93 (2000) 22-27.
- [5] PJ. Rubin, RL Rakotomanana, PF. Leyvraz, PK Zysset, A Curnier, JH Heegaard, Frictionnal interface
 micromotions and anisotropic stress distribution in a femoral total hip component, Journal of Biomechanics 26 (1993) 725-739.
- [6] H. Zhang, L.T. Brown, L.A. Blunt, X. Jiang, S.M. Barrans, Understanding initiation and propagation of fretting wear on the femoral stem in total hip replacement, Wear (2008) in press
- [7] B. Trischler, B. Forest, J. Rieu, Fretting corrosion of materials for orthopaedic implants: a study of a metal/polymer contact in an artificial physiological medium, Tribology International 32 (1999) 587-596.

[8] J. Geringer, B. Forest, P. Combrade, Wear analysis of materials used as orthopaedic implants, Wear 261 (2006) 971-979.

[9] J. Geringer, B. Forest, P. Combrade, Fretting-corrosion of materials used as orthopaedic implants, Wear 259 (2005) 943-951.

[10] G. Lewis, S. Mladsi, Effect of sterilization method on properties of Palacos[®] R acrylic bone cement, Biomaterials 19 (2008) 117-124.

[11] G. Lewis, Apparent fracture toughness of acrylic bone cement: effect of test specimen configuration and sterilization method, Biomaterials 20 (1999) 69-78.

[12] J.F Orra, N.J Dunne, J.C Quinn, Shrinkage stresses in bone cement, Biomaterials 24 (2003) 2933-2940.

[13] F.P Bowden, D. Tabor, The friction and lubrication of solids, Clarendon press, Oxford, 1986.

[14] D.D. Macdonald, Passivity-the key to our metals-based civilization, Pure Appl. Chem. 71 (1999) 951-978

¹ [15] N. Nuno, R. Groppetti, N. Senin, Static coefficient of friction between stainless steel and PMMA used in
 ² cemented hip and knee implants, Clinical Biomechanics 21 (2006) 956–962

³ [16] M. Da Cunha Belo, M. Walls, N.E. Hakiki, J. Corset, E. Picquenard, G. Sagon, D. Noel, Composition
 ⁴ structure and properties of the oxide films formed on the stainless steel 316L in a primary type PWR environment,
 ⁵ Corrosion Science 40 (1998) 447-463.

,