



HAL
open science

Optimal power dispatching strategies in smart-microgrids with storage

Rémy Rigo-Mariani, Bruno Sareni, Xavier Roboam, Christophe Turpin

► **To cite this version:**

Rémy Rigo-Mariani, Bruno Sareni, Xavier Roboam, Christophe Turpin. Optimal power dispatching strategies in smart-microgrids with storage. *Renewable and Sustainable Energy Reviews*, 2014, vol. 40, pp. 649-658. 10.1016/j.rser.2014.07.138 . hal-01064368

HAL Id: hal-01064368

<https://hal.science/hal-01064368>

Submitted on 16 Sep 2014

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.



Open Archive TOULOUSE Archive Ouverte (OATAO)

OATAO is an open access repository that collects the work of Toulouse researchers and makes it freely available over the web where possible.

This is an author-deposited version published in : <http://oatao.univ-toulouse.fr/>
Eprints ID : 11997

To link to this article : doi:10.1016/j.rser.2014.07.138
URL : <http://dx.doi.org/10.1016/j.rser.2014.07.138>

To cite this version : Rigo-Mariani, Rémy and Sareni, Bruno and Roboam, Xavier and Turpin, Christophe Optimal power dispatching strategies in smart-microgrids with storage. (2014) Renewable and Sustainable Energy Reviews, vol. 40 . pp. 649-658. ISSN 1364-0321

Any correspondence concerning this service should be sent to the repository administrator: staff-oatao@listes-diff.inp-toulouse.fr

Optimal power dispatching strategies in smart-microgrids with storage

Rémy Rigo-Mariani*, Bruno Sareni, Xavier Roboam, Christophe Turpin

LAPLACE, UMR CNRS-INPT-UPS, ENSEEIHT, 2 Rue Camichel, 31 071 Toulouse, France

A B S T R A C T

With the development of decentralized power sources based on renewable energy, power grids need smarter operations to be run properly. This paper investigates different procedures for the optimal power dispatching of a grid-connected prosumer with an energy storage consisting in a high speed flywheel. An off-line optimal scheduling for the day ahead aims at minimizing the cost with regards to the daily energy rates and considering the forecasts for both consumption and production. That dispatching is performed thanks to global optimization procedures based on a trust-region method or on a niching genetic algorithm. Another approach using step by step optimization and exploiting an original self-adaptive dynamic programming strategy is also developed. The paper discusses the performance of all the considered methods with regards to the obtained results and the computational time.

Keywords:

Smart-grids
Optimal power dispatching
Trust region algorithm
Genetic algorithms
Particle swarm
Dynamic programming

Contents

1. Introduction	649
2. Power flow model of the microgrid	650
2.1. Considered microgrid and constraints	650
2.2. Equations and degrees of freedom	651
2.3. Storage efficiency	651
2.4. Input variables	652
3. Optimal power dispatching problem	652
4. Approaches for solving the optimal dispatching problem	653
4.1. Global optimization of power flows	653
4.2. Global optimization with a sampled problem	653
4.2.1. Graph representation and Bellman-Ford algorithm	653
4.2.2. Undetermined SOC levels	654
4.2.3. Transition optimization	654
4.2.4. Self-adaptive DP	655
5. Simulations and results	656
5.1. Performance and computational time of the power dispatching procedures	656
5.2. Storage benefits	656
6. Conclusions	657
Acknowledgment	657
References	657

1. Introduction

Global energy consumption has increased by 50% since the 90's and is expected to keep going up with a ratio of 1.6% per year due to the growing population on earth and the new needs that have

* Corresponding author: Tel.: +33 5 34 32 23 56.

E-mail address: remy.rigo-mariani@laplace.univ-tlse.fr (R. Rigo-Mariani).




Fig. 1. Considered microgrid (a) and graph representation (b).

emerged [1]. To face that increasing demand of electrical power in compliance with the liberalization of the electricity market and the need of reducing CO₂ emissions, many distributed energy resources have appeared and especially the generation systems that utilize renewable energy sources. Thus, distribution networks evolve towards more meshed structures, and they are likely to become associations of a large number of “microgrids” combining both consumption and production and interacting with the main grid [2]. Due to the stochastic nature of those generations, it requires smarter operations to keep feeding loads in a supply-on-demand system. The improvements in storage technologies allow those operations with a more flexible and reliable management of energy [3]. Renewable energy sources associated with storage units are then considered like active distributed generators, one of the fundamental elements of the “Smart Grid” concept [4]. Adding a storage device deeply questions the most widely used model that consists in selling all the highly subsidized production at important prices and buying the whole consumption. It also allows the owners of microgrids to optimize the power exchanged with the main grid in compliance with the electricity market and the forecasts for the day ahead [5]. Thus, more and more methods based on optimization algorithms are developed to perform the optimal scheduling of power flows within the hybrid electrical systems with load, production and storage [6,7]. In the microgrid considered in this study, all the components are connected through a DC bus (Fig. 1a) with the following data:

- **Consumption:** A building with a maximum contractual power of 156 kW.
- **Production:** Solar PV arrays with a total capacity of 175 kWp.
- **Storage:** A 100 kW/100 kWh storage consisting in ten 10 kW/10 kWh high speed flywheels.

In this paper, an off-line optimal power dispatching problem is introduced with the aim of minimizing global energy cost, considering the forecasts for consumption and production and the possible constraints imposed by the main grid operator. The second section describes the power flow model used to represent the system and the corresponding equations. Then, the next part refers to the proposed optimization methods using an evolutionary algorithms or a trust region strategy that both consider the global load consumption and the PV production over the day. A step by step optimization based on basic Dynamic Programming

(DP) is also presented and an original self-adaptive DP is developed. Finally, some results performed with the various algorithms are exposed and discussed, especially in terms of reliability, efficiency and computational time.

2. Power flow model of the microgrid

2.1. Considered microgrid and constraints

Voltages and currents are not considered so far. The study refers to the optimization of active power flows p_i which appear to be a widely used formulation for such a problem [8,9]. A nomenclature of all the used symbols is given in Table 1. Eleven power flows are identified to entirely characterize the system at each time step.

- p_1 : power flowing through the consumption meter
- p_2 : power flowing between the DC bus and the consumption branch after the converter
- p_3 : power flowing between the DC bus and the consumption branch before the converter
- p_4 : power flowing between the storage and the DC bus after the converter
- p_5 : power flowing between the storage and the DC bus before the converter
- p_6 : power flowing between the production branch and the rest of the DC bus
- p_7 : effective solar production after the converter
- p_8 : effective solar production before the converter
- p_9 : derating of the solar production in case of microgrid congestion (section 2.2)
- p_{10} : power flowing through the production meter before the converter
- p_{11} : effective production sold

Due to the grid policy, three system constraints have to be fulfilled at each time step t :

- $P_p(t) \geq 0$: the power cannot return to the grid through the consumption meter.
- $P_s(t) \geq 0$: the main grid cannot feed the DC bus through the production meter.

Table 1
Nomenclature of the used symbols.

P_{load}	Consumed power	kW
P_{prod}	solar PV production	kW
P_i	power flows used to characterize the system (Section 2.1)	kW
P_p	power flowing through the consumption meter	kW
P_s	power flowing through the production meter	kW
P_{st}	power flowing from/to the storage unit	kW
P_{FS}	power flowing from/to the flywheel taking account of device losses	kW
P_{st_min}	lower and upper bounds for P_{st}	kW
P_{st_max}		
E_{FS}	maximum stored energy in the storage unit	kWh
K_{FS}	self-discharge coefficient of the flywheels (Section 2.3)	kWh/h
η_{FS}	flywheels efficiency depending on the exchanged power	-
SOC	state of charge of the storage unit	%
SOC_{min}	lower and upper bounds for the SOC level	%
SOC_{max}		
SOC_{start}	initial and final daily values for the SOC level	%
SOC_{end}		
P_{grid}	power flowing between the main grid and the microgrid	kW
P_{grid_min}	lower and upper bounds for P_{grid} possibly set by the power supplier	kW
P_{grid_max}		
$\eta_{CVS,i}$	efficiency of the i th converter in the graph representation (Fig. 1b)	-
ΔP_{pv}	solar production derated in case of microgrid congestion (Section 2.2)	kW
$C_{purchase}$	instantaneous cost for the purchased energy	€/kWh
C_{sale}	instantaneous cost for the sold energy	€/kWh
t	time step	h
\mathbf{P}_{ref}	matrix with the scheduled controls for the degrees of freedom	kW
$C(\mathbf{P}_{ref})$	daily cost to be minimized by the optimization algorithm	€
\mathbf{C}_{nl}	vector with the non linear constraints of the optimization problem	-

- $P_{prod_c}(t) \geq 0$: the storage cannot be discharged through the production meter.

A particular attention is attached to the grid power $P_{grid}(t)$ which should comply with requirements possibly set by the grid operator P_{grid_min} and P_{grid_max} :

$$P_{grid}(t) = P_p(t) - P_s(t) \quad (1)$$

$$P_{grid_min}(t) < P_{grid}(t) < P_{grid_max}(t) \quad (2)$$

2.2. Equations and degrees of freedom

Equations are generated using the graph theory and an incidence list to describe the system with particular equations corresponding to each type of node [10]. In Fig. 1b, the black arrows between nodes represent sign conventions for power flows while the possible directions (mono or bi-directional) are illustrated by the dotted arrows. Three degrees of freedom are required to control the whole system (Fig. 1a):

- $P_{st}(t)$: the power flowing from/to the storage unit
- $P_{prod_c}(t)$: the power flowing from the solar PV arrays to the common DC bus
- $\Delta P_{pv}(t)$: denotes the possibility to decrease the solar PV production (MPPT derating) in order to fulfill grid constraints, in particular when the power supplier does not allow (or limits) injection of the solar PV production to the main grid (P_{grid_min}). For instance, if the flywheels are fully charged while production is greater than consumed energy and if no injection is allowed

to the grid, a part of the produced energy should be wasted to fulfill the main grid constraints.

Those degrees of freedom being set from a management process, all power flows in the microgrid can be expressed from the consumption $P_{load}(t)$ and production $P_{prod}(t)$ and from the input data, i.e. $\eta_{CVS,i}$ (typically $\eta_{CVS,i} = 95\%$) the efficiency related to the power converter corresponding to the node i . From the graph representation, subsequent equations can be derived:

$$p_1(t) = P_{load}(t) - p_2(t) \quad (3)$$

$$p_2(t) = p_3(t) + \left(1 - \frac{1}{\eta_{CVS,3}}\right) \cdot \max(0, -p_3(t)) + (\eta_{CVS,3} - 1) \cdot \max(0, p_3(t)) \quad (4)$$

$$p_3(t) = p_4(t) + p_6(t) \quad (5)$$

$$p_4(t) = p_5(t) + \left(1 - \frac{1}{\eta_{CVS,5}}\right) \cdot \max(0, -p_5(t)) + (\eta_{CVS,5} - 1) \cdot \max(0, p_5(t)) \quad (6)$$

$$p_7(t) = \eta_{CVS,8} \cdot p_8(t) \quad (7)$$

$$p_8(t) = P_{prod}(t) - p_9(t) \quad (8)$$

$$p_{10}(t) = p_7(t) - p_6(t) \quad (9)$$

$$p_{11}(t) = \eta_{CVS,11} \cdot p_{10}(t) \quad (10)$$

Note that in (4) and (6) the power flows through converters are bidirectional. Two cases are identified depending on the direction of the flows to determine how the corresponding converter efficiency $\eta_{CVS,i}$ has to be considered. That is performed using the max function:

$$\begin{cases} \max(a, b) = a & \text{if } a \geq b \\ \max(a, b) = b & \text{if } a < b \end{cases} \quad (11)$$

The next sections only refer to the flows P_p , P_s , P_{grid} and the degrees of freedom that are the truly interesting powers in term of management.

2.3. Storage efficiency

The storage losses are computed versus the state of charge SOC (in %) and the power P_{st} using a function $P_{loss}(SOC)$ and calculating the efficiency with a fourth degree polynomial interpolation $\eta_{FS}(P_{st})$ as shown in (11). Interpolations are extracted from experimental measurements provided by the manufacturer. Note that due to confidentiality constraints, no additional information related to quantitative data have been allowed to be provided. Both P_{loss} and η_{FS} functions are also extracted from measurements provided by the manufacturer. Another coefficient K_{FS} (in kW) is also introduced to estimate the self-discharge of the flywheels when they are not used [11]. Once the overall efficiency is computed, the true power P_{FS} associated with the flywheel is calculated as well as the SOC evolution using the maximum stored energy E_{FS} (here 100 kWh), the time step Δt (typically 1 h for the off-line optimization) and the control reference p_5 .

$$\begin{cases} P_{st}(t) < 0 \rightarrow P_{FS}(t) = P_{st}(t) \times \eta_{FS}(-P_{st}(t)) \\ P_{st}(t) > 0 \rightarrow P_{FS}(t) = P_{st}(t) / \eta_{FS}(P_{st}(t)) \end{cases} \quad (12)$$

Thus, when a power p_5 is required from the storage (i.e. $p_5 > 0$), the actual power P_{FS} including the flywheels losses is computed to estimate the loss of stored energy that have to be decreased to the discharge power. The same process is performed when p_5 becomes negative for storage charging. If no power flows from/to the flywheels, the loss of stored energy is limited to the self-




Fig. 2. Typical forecasted (a) consumption and production and (b) energy prices .

discharge coefficient:

$$\begin{cases} P_{st}(t) \neq 0 \rightarrow SOC(t + \Delta t) = SOC(t) - \frac{P_{st}(t) \times \Delta t}{E_{FS}} \times 100 \\ P_{st}(t) = 0 \rightarrow SOC(t + \Delta t) = SOC(t) - \frac{K_{ES} \times \Delta t}{E_{FS}} \times 100 \end{cases} \quad (13)$$

The energy management strategy must ensure that both power and energy bounds are fulfilled with regards to storage power limits, i.e. $P_{st_min} = -100$ kW and $P_{st_max} = 100$ kW. With a storage assumed to be charged at $SOC_{start} = 50\%$ at the beginning of the day, the solving procedures should fulfill both upper and lower energy limits (i.e. $SOC_{min} = 0\%$ and $SOC_{max} = 100\%$) while ensuring a final value $SOC_{end} = 50\%$.

2.4. Input variables

The energy management strategy is based on consumption and production forecasts similar to the example depicted in Fig. 2a. The consumption profile is computed using measurements performed on the microgrid site and the production forecast uses a geophysical model considering among other the incidence and orientation of the solar PV arrays [12,13] as well some estimation of the radiated energy on the microgrid site for the corresponding day.

The energy prices result from one of the fares proposed by the French main energy supplier. The purchase cost $C_{purchase}$ has night and daily values with 0.10 €/kWh from 10 p.m. to 6 a.m. and 0.17 €/kWh for the other time steps. An average fare of $C_{sale} = 0.10$ €/kWh is also considered for the production meter (Fig. 2b). Finally, an additional grid power constraints is introduced with $P_{grid_max} = 0$ kW between 7 p.m. and 10 p.m. with the aim of imposing the microgrid autonomous operation during this period. Otherwise the bounds are set to high values (typically 10^3 kW). Without storage device and optimal management, all the consumption is purchased from the grid while the PV production is sold. The resulting cost for that initial situation (noted Init) is 28.39 €. If the self-consumption of the production is considered, the generated energy feeds the loads and the surplus is sold. In that case (noted SelfCons) the overall cost is of 5.82 €. Note that in both situations the previous grid constraints cannot be fulfilled by the microgrid.

3. Optimal power dispatching problem

The problem consists in planning, for each hour of a 24h-period, the best power dispatching that ensures the minimal energy cost of the microgrid while complying with the grid requirements. The decision variables computed in a vector \mathbf{P}_{ref} are the degrees of freedom defined in the previous section

according to upper and lower bounds respectively computed in vectors \mathbf{u}_b and \mathbf{l}_b . Those bounds can be expressed using a vector \mathbf{J}_{24} composed of 24 values equal to one. With a time step of 1 h, the total number of decision variables is 72.

$\mathbf{P}_{ref} = [P_5(t) \ P_6(t) \ P_9(t)]$ with $t \in [0..24$ h], noted

$$\mathbf{P} = [\mathbf{P}_5 \ \mathbf{P}_6 \ \Delta \mathbf{P}_9]$$

$$\mathbf{l}_b = [P_{st_min} \cdot \mathbf{J}_{24} \ 0 \cdot \mathbf{J}_{24} \ 0 \cdot \mathbf{J}_{24}]$$

$$\mathbf{u}_b = [P_{st_max} \ \mathbf{J}_{24} \ \eta_{CVS,8} \cdot P_{prod} \ P_{prod}] \quad (14)$$

The overall cost to be optimized is the difference between the sold and purchased energies during the day obtained by calculating the flows P_p and P_s all along the simulated period (typically 24 h) for a set of parameters \mathbf{P}_{ref} :

$$C(\mathbf{P}_{ref}) = \sum_{t=0}^{24} C_{purchase}(t) \cdot P_p(t) - C_{sale} \cdot P_s(t) \text{ with } \Delta t = 1 \text{ h} \quad (15)$$

Some constraints in the microgrid are implicitly included in the bounds previously defined. Additional constraints are added in order to fulfill all power flow requirements defined in Section 2. Eq. (16) allows controlling the powers through the meters that have both to remain positive with the given convention and set the two corresponding constraints CP_p and CP_s .

$$\begin{cases} CP_p = \sum_{t=0}^{24h} \max(0, -P_p(t))^2 \\ CP_s = \sum_{t=0}^{24h} \max(0, -P_s(t))^2 \end{cases} \quad (16)$$

The possible bounds set by the grid operator for P_{grid} are considered by summing all the overshoots. The negative and positive deviations are computed in constraints CP_{grid}^- and CP_{grid}^+ .

$$\begin{cases} CP_{grid}^+ = \sum_{t=0}^{24h} \max(0, P_{grid}(t) - P_{grid_max}(t))^2 \\ CP_{grid}^- = \sum_{t=0}^{24h} \max(0, P_{grid_min}(t) - P_{grid}(t))^2 \end{cases} \quad (17)$$

The three last limits refer to the use of the storage unit. Indeed the SOC has to remain between its lower and upper bounds and return at a given value at the end of the day (i.e. $t = 24$ h). The corresponding constraints are noted $CSOC^-$, $CSOC^+$ and $CSOC_{end}$.

$$\begin{cases} CSOC_{end} = SOC(24h) - SOC_{end} \\ CSOC^+ = \sum_{t=0}^{24h} \max(0, SOC(t) - SOC_{max})^2 \\ CSOC^- = \sum_{t=0}^{24h} \max(0, SOC_{min} - SOC(t))^2 \end{cases} \quad (18)$$





Fig. 4. Dynamic Programming – (a) Computation of the predecessors and (b) optimal path rebuilt.



Instantaneous fictive values in kW

$$P_{prod}(t) = 0, P_{cons}(t) = 30 \text{ et } P_{res_max}(t) = 15 \Rightarrow \Delta P_{PV}(t) = P_{prod_ch}(t) = 0 \text{ kW et } P_{st}(t) = 15$$

Fig. 5. Towards undetermined SOC levels.

the instantaneous controls of the power flows which relate to the degrees of freedom that allow to follow the optimal path.

4.2.2. Undetermined SOC levels

Moving from one SOC level to another consists in finding the best instantaneous degrees of freedom $P_{st}(t)$, $P_{prod_c}(t)$ and $\Delta P_{PV}(t)$ that ensure the transition with the lowest cost. Note that a transition between two pre-determined states of charge implicitly imposes the power value flowing through the storage unit $P_{st}(t)$. However, in some cases, this can lead to the non-fulfilment of the grid constraints and the impossibility to ensure the transition. The resulting cost would be penalized. Fig. 5 illustrates a case with fictive values without considering losses. In this example, there is no production and the grid operator imposes a consumption to a given value $P_{grid}(t)$ different from $P_{load}(t)$. Thus $P_{prod_c}(t) = \Delta P_{PV}(t) = 0$ and then $P_{st}(t)$ should feed the difference $P_{grid}(t) - P_{load}(t)$. That value does not necessary comply with the transition between two predetermined states of charge and a non convergence of the algorithm could occur.

The previous algorithm is then modified with the aim of relieving the storage constraints by considering a space search $\pm \delta$ around a predetermined SOC. The initial value of δ is set to $\Delta SOC/2$ and is progressively reduced in case of non-convergence (typically $\delta \leftarrow \delta/2$). In the example given in Fig. 5, moving towards undetermined SOC levels allows ensuring the transition starting from a SOC equal to 40% and could avoid a non convergence of the overall Dynamic Programming algorithm.

4.2.3. Transition optimization

As already said, studying a transition between two states M and M' consists in minimizing the cost while adapting the state of charge for the next time step. This is performed using the trust region algorithm with a simpler problem than in the case with the global dispatching in so far as the number of decision variables simply equals here the number of degrees of freedom (i.e., three in the studied case). The bounds associated with the degrees of freedom as well as the grid constraints are expressed using the instantaneous values of the consumption and production. The storage constraints defined in (18) are modified in order to comply with the studied transition and adapt the SOC at the following state with $SOC' \pm \delta$:

$$\begin{aligned} CSOC^+(t) &= \max(0, SOC(t+\Delta t) - SOC' + \delta) \\ CSOC^-(t) &= \max(0, -SOC' - \delta - SOC(t+\Delta t)) \end{aligned} \quad (22)$$

Finally, the local optimal dispatching problem to be solved at each time step can be expressed as:

$$\begin{aligned} \mathbf{P}_{ref}(t) &= [P_{st}(t) \quad P_{prod_c}(t) \quad \Delta P_{PV}(t)] \\ \mathbf{lb} &= [P_{st_min} \quad 0 \quad 0] \\ \mathbf{ub} &= [P_{st_max} \quad \eta_{CVS,8} \cdot P_{prod}(t) \quad P_{prod}(t)] \\ \mathbf{P}_{ref}^*(t) &= [P_{st}^*(t) \quad P_{prod_c}^*(t) \quad \Delta P_{PV}^*(t)] = \underset{\mathbf{P}_{ref}(t)}{\text{argmin}} (C_{purchase}(t) \cdot P_a(t) - C_{sale}(t) \cdot P_s(t)) \\ \text{with } \mathbf{C}_{nl}(\mathbf{P}_{ref}(t)) &= [CP_a(t) \quad CP_s(t) \quad CSOC^+(t) \quad CSOC^-(t) \\ &\quad \times CP_{grid}^-(t) \quad CP_{grid}^+(t)] \leq 0 \end{aligned} \quad (23)$$




Fig. 6. DP results for different SOC level of accuracy: (a) Cost and CPU time – (b) Storage energy.




Fig. 7. Illustration of the self-adaptive Dynamic Programming.

Table 2

Performance of the trust-region reflective algorithm on the dispatching problem.

	P_{ref0}^1	P_{ref0}^2	P_{ref0}^3	P_{ref0}^4
Starting point	$[P_{load} P_{prod} P_{prod}]$	$[P_{load} 0 J_{24} 0 J_{24}]$	$[0 J_{24} 0 J_{24} 0 J_{24}]$	$[0 J_{24} P_{prod} 0 J_{24}]$
Convergence	no	yes	no	yes
C (P_{ref}^*) (in €)	x	4.09	x	6.63
CPU time	33 s	24 s	1 s	16 s

Table 3

Performance of the clearing algorithm on the dispatching problem.

	1000	5000	10,000	25,000	50,000
Number of generations	1000	5000	10,000	25,000	50,000
Cost – Average Values (€)	3.80 ± 1.08	1.62 ± 0.95	1.25 ± 0.81	0.96 ± 0.52	0.87 ± 0.38
Cost best values (€)	2.53	1.11	0.79	0.69	0.66
Average CPU Time (s)	6 min	35 min	1 h 10 min	2 h 45 min	5 h 30 min

Table 4

Performance of the particle swarm algorithm on the dispatching problem.

	1000	5000	10,000	25,000	50,000
Number of Generations	1000	5000	10,000	25,000	50,000
Cost -Average Values (€)	23.63 ± 23.96	19.04 ± 19.51	18.79 ± 19.89	17.86 ± 19.75	17.80 ± 19.81
Cost – best values (€)	9.35	6.48	4.99	4.90	4.90
Average CPU Time (s)	3 min	15 min	30 min	1 h 15 min	2 h 30 min

4.2.4. Self-adaptive DP

The DP returns good solutions but some preliminary results shows that its efficiency and convergence strongly depends on ΔSOC and δ . As shown in Fig. 6a, the cost is improved with the

reduction of ΔSOC while the computational time required to obtain the optimal solution is drastically increased. Note that the trajectories obtained for different values of ΔSOC shows the same energy balance of the storage which is discharged at the beginning

of the day. Then the SOC increases when there is a great amount of solar production during the day. From 7 p.m. to 9 p.m., the flywheels are used to fulfill the grid constraints before returning to the desired state of charge at the end of the day. That optimal energetic behavior is found with great ΔSOC . Indeed, decreasing the discretization allows reducing the cost by optimizing the losses within the elements of the microgrid.

In order to get the best solution corresponding to the finest SOC sampling without a prohibitive CPU time, a self-adaptive DP (SDP) has been developed. At first, a basic DP is performed with a coarse ΔSOC . Then, a space search is defined around the obtained solution meaning that the number of possible states is reduced around the optimal profile. Afterwards, a new DP is computed considering the reduced search space with a smaller ΔSOC . As illustrated in Fig. 7, the self-adaptive DP consists in a succession of basic DP optimizations starting with a large ΔSOC and decreasing it to smaller values. At each iteration, the search space is reduced by considering a new area around the optimal path. Then, this area is refined by discretizing it with a smaller value of ΔSOC (typically $\Delta SOC = \Delta SOC/2$).

5. Simulations and results

5.1. Performance and computational time of the power dispatching procedures

In this section, the results obtained with the different procedures are compared with regard to the cost function value and the

Table 5
Results obtained with the basic and self-adaptive DP.

ΔSOC	20%	15%	10%	5%	2%	1%	SDP
Cost (€)	4.02	2.09	1.52	0.64	-0.56	-0.65	-0.17
CPU time	30 s	50 s	1 min 30 s	5 min	45 min	2 h 15 min	10 min

Table 6
Costs analysis for different cases.

	Init	SelfCon	P_{refSDP}
Purchased energy (€)	95.48	39.18	23.43
Sold energy (€)	66.09	33.36	25.60
Constraint fulfillment	no	no	yes
TOTAL (€)	28.39	5.82	-0.17

computational time. All tests are performed by considering a time step of 1 h and with the production and consumption profiles defined in Section 2. Table 1 shows the outputs of the trust region reflective algorithm with a maximum number of iterations equal to 150. Four starting points P_{ref0}^i are considered. They do not necessarily fulfill the constraints and correspond to various assumptions such as providing all the consumption though the storage for instance. The convergence only occurs in half of the cases and the obtained results depend on the starting points (Table 2).

Tables 3 and 4 show the best results obtained by the nature inspired metaheuristics (i.e. clearing and PSO) after 10 independent runs. Average values with 95 % level of confidence as well as the best results are presented. Performances become greater with high numbers of generations with a population size equal to 100 elements in the two algorithms. Both strategies are more reliable than the trust-region method with better accuracy for the genetic algorithm but their CPU time up to 2 h is rather expensive.

The self-adaptive DP gives the best results with a good accuracy and a reduced computational time (Table 5). A solution with accuracy of $\Delta SOC = 1\%$ is finally reached after 10 min instead of 2 h with the basic DP. It should be noted that the small deviation on the cost between the basic DP with $\Delta SOC = 1\%$ and the self-adaptive DP can be explained by different optimal paths found due to distinct values of δ around SOC levels during the search.

5.2. Storage benefits

Performance is now studied with regard to the optimal power profiles found with the solution returned by the SDP and noted P_{refSDP} . Fig. 8a shows that the grid power fulfills the constraints between 7 p.m. and 9 p.m. The storage is discharged at the beginning of the day in order to lower the cost when prices are higher (after 6 a.m.). Then the solar production feeds the loads and charges the flywheels. At the end of the day the storage is fully used to satisfy the constraints before returned to the desired value SOC_{end} (Fig. 8b).

The optimal power sharing obtained with the SPD is illustrated in Fig. 9 with few of energy purchased from the grid during the daily hours. The high amount of PV production is self-consumed in the loads and the storage. The surplus is even sold to the grid to get an additional benefit with a negative final electrical bill ($C_{elec}(P_{refSDP}) = -0.17$ €).




Fig. 8. Optimal profiles for P_{refSDP} : (a) P_a and (b) SOC.




Fig. 9. Optimal power sharing with SPD – (a) Power flowing to the loads (b) powers flowing from the PV panels.

The cost analysis of the solution P_{refSDP} is now compared with the electrical bills corresponding to the cases Init and SelfCon. The best cost corresponds to a case with storage and optimal management (Table 6). Less production is sold but the self-consumption allows reducing the bill by lowering the purchased energy when prices are higher. Note that with no storage the grid constraints cannot be fulfilled. This could lead to pay additional penalties to the grid operator. On the contrary encouraging the constraints fulfillment with additional benefit could allow justifying the implementation of a storage unit whose cost has not been considered so far in the study.

6. Conclusions

In this paper, various optimization approaches have been compared in order to perform the optimal dispatching of power flows in a grid connected smart system involving loads, decentralized sources of renewable energy (solar PV panels) and flywheels as storage unit. In particular, an original self-adaptive method based on DP has been developed to enhance the performance in terms of cost with rapid convergence. For the given hypothesis and constraints relative to grid consumption and solar PV production, this method was revealed more efficient than a classical trust-region based approach and a evolutionary algorithms. All investigated procedures take account of the forecasts of consumption and production and aim at generating the best power dispatching for the day ahead. In real-time, an additional control has to be performed so as to ensure the predicted efficiency by correcting the possible forecast errors as described in [14]. Further works will also investigate the generalization of the approach for more complex microgrid architectures including other parameters, e.g. multiple energy storages of different nature (flywheels, electrolyzer-fuel cell association, batteries), various energy rates related to the cost of the grid power depending on the target load (storage charge or consumer feeding) and other grid services such as peak shaving or grid disconnection. Finally, additional studies will focus on the coupling between the sizing of the storage and the energy management aiming at optimizing the tradeoff between the cost of the storage systems and the reduction of the microgrid energy consumption by considering simulations over a longer period of time.

Acknowledgment

This study has been carried out in the framework of the SMART ZAE national project. The authors thank the project leader INEO-

SCLE-SFE and partners LEVISYS and CIRTEM for their support and Colomiers high school for providing the data of solar irradiation. The SMART ZAE project is supported by ADEME (Agence de l'Environnement et de la Maîtrise de l'Energie)

References

- [1] Conti J, Holtberg PD, Beamon JA, Napolitano SA, Schaal AM, Turnure JT. Annual energy outlook. US energy information administration; 2011. Available at: <http://www.eia.gov>.
- [2] Celli G, Pilo F, Pisano G, Allegranza V, Cicoria R, Iaria A. Meshed vs. radial MV distribution network in presence of large amount of DG. Power Systems Conference and Exposition IEEE PES; 2004.
- [3] Yeleti S, Fu S. Impacts of energy storage on the future power system. North American Power Symposium (NAPS) 2010; 1–7.
- [4] Lu D, François B. Strategic framework of an energy management of a microgrid with a photovoltaic-based active generator. ELECTROMOTION, EPE Chapter 'Electric Drives' Joint Symposium; 2009, Lille, France.
- [5] Colson CM. A Review of Challenges to Real-Time Power Management of Microgrids. IEEE Power & Energy Society General Meeting 2009;1–8.
- [6] Banos R, Manzano-Agugliarob F, Montoyab FG, Gila C, Alcaydeb A, Gomezc J. Optimization methods applied to renewable and sustainable energy: A review. Renewable and Sustainable Energy Reviews 2011;15:1753–66.
- [7] Erdinc O, Uzunoglu M. Optimum design of hybrid renewable energy systems: Overview of different approaches. Renewable and Sustainable Energy Reviews 2012;16:1412–25.
- [8] Nottrott A, Kleissl J, Washom B. Storage dispatch optimization for grid-connected combined photovoltaic-battery storage systems. Power and Energy Society General Meeting, IEEE 2012;1–7.
- [9] Bagherian A, Moghaddas SM. A developed energy management system for a microgrid in the competitive electricity market. IEEE Bucharest Power Tech Conference; 2009.
- [10] Harris JM, Hirst JL, Mossinghoff MJ. Combinatorics and Graph Theory. 2nd EditionSpringer; 2000.
- [11] Hadjipaschalis I, Poullikkas A, Efthimiou V. Overview of current and future energy storage technologies for electric power applications. Renew Sustain Energy Rev 2009;13:1513–22.
- [12] Darras C, Sailler S, Thibault C, Muselli M, Poggi P, Hogue J, et al. Sizing of photovoltaic system coupled with hydrogen/oxygen storage based on the ORIENTE model. Int J Hydrog Energy 2010;35:3322–32.
- [13] Mehdaoui A, Sadok M, Chikhi SA, Mammeri A. Gain énergétique entre deux configurations de système de pompage d'eau photovoltaïque Application au site d'Adrar. Rev Energies Renouv 2010;13:571–82.
- [14] Rigo-Mariani R, Sareni B, Roboam X, Astier S, Steinmetz JG, Cahuet E. Off-line and On-line power dispatching strategies for a grid connected commercial building with storage unit. In: IFAC Power Plant and Power System Control; 2012.
- [15] Kanchev H, Lu D, Colas F, Lazarov V, François B. Energy management and operational planning of a microgrid with a PV-based active generator for smart grid applications. IEEE Trans Ind Electron 2011;58.
- [16] Sechilariu M, Wang B, Locment F. Building integrated photovoltaic system with energy storage and smart grid communication. IEEE Trans Ind Electron 2013;60:1606–18.
- [17] Manjili YS, Vega R, Jamshidi M. Cost-efficient environmentally-friendly control of micro-grids using intelligent decision-making for storage energy management. Intell Autom Soft Comput 2013;19:649–70.

- [18] Bradbury K, Pratson L, Patiño-Echeverri D. Economic viability of energy storage systems based on price arbitrage potential in real-time U.S. electricity markets. *Appl Energy* 2014;114:512–9.
- [19] Coleman TF, Li Y. An interior trust region approach for nonlinear minimization subject to bounds. *SIAM J Optim* 1996;6:418–45.
- [20] Petrowski A. A clearing procedure as niching method for genetic algorithms. In: Proceedings of IEEE evolutionary computation; 1996: p. 798–803.
- [21] Kennedy J, Eberhart R. Particle swarm optimization. In: IEEE Proceedings of the international conference on neural networks; 1995: p. 1942–8.
- [22] Phuangpompitak N, Tia S, Prommee W, Phuangpompitak W. A study of particle swarm technique for renewable energy power systems. In: International conference on energy and sustainable development: issues and strategies (ESD); 2010: p. 1–6.
- [23] Riffoneau Y, Bacha S, Barruel F, Ploix S. Optimal power flow management for grid connected PV systems with batteries. *IEEE Trans Sustain Energy* 2011;2:309–19.
- [24] Bertsekas P. *Dynamic programming and optimal control*. 2nd Edition, Athena Scientific; 2000.