

FAULT DETECTION AND DIAGNOSIS USING A HYBRID DYNAMIC SIMULATOR: APPLICATION TO INDUSTRIAL RISK PREVENTION

Nelly Olivier-Maget, Gilles Hetreux

▶ To cite this version:

Nelly Olivier-Maget, Gilles Hetreux. FAULT DETECTION AND DIAGNOSIS USING A HYBRID DYNAMIC SIMULATOR: APPLICATION TO INDUSTRIAL RISK PREVENTION. MOSIM 2014, 10ème Conférence Francophone de Modélisation, Optimisation et Simulation, Nov 2014, Nancy, France. hal-01166664

HAL Id: hal-01166664 https://hal.science/hal-01166664

Submitted on 23 Jun 2015

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers. L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

FAULT DETECTION AND DIAGNOSIS USING A HYBRID DYNAMIC SIMULATOR: APPLICATION TO INDUSTRIAL RISK PREVENTION

N. OLIVIER-MAGET

G. HETREUX

Laboratoire de Génie Chimique, UMR-5503 (INPT/CNRS/UPS), 4, Allée Emile Monso, BP 84234, F-31432 Toulouse, France nelly.olivier@ensiacet.fr, gilles.hetreux@ensiacet.fr

ABSTRACT: The main tool for the development of hazardous chemical syntheses in the field of fine chemicals and pharmaceuticals remains the batch reactor. Nevertheless, even if it offers the required flexibility and versatility, this reactor presents technological limitations. In particular, poor transfer of the heat generated by exothermic chemical reactions is a serious problem with regard to safety. In this context, a simple failure is considered as prejudicial. So, fault detection and diagnosis are studied with a particular attention in the scientific and industrial community. The major idea is that the fault must not be undergone but must be controlled. So, this work presents a fault detection and isolation methodology for the monitoring of Hybrid Dynamic Systems. The developed methodology rests on a mixed approach which combines a model-based method for the fault detection and an approach based on data (pattern matching) for the identification of fault(s). It is integrated within a hybrid dynamic simulator. In this paper, the approach is tested during the operation of an exothermic reaction. The major risk of this system is a cooling failure. The objective of the present work is to detect and diagnosis a fault, before it becomes more serious. In this purpose, two simulations are studied, during which a fault of the material feed and a fault of the energy feed are respectively introduced.

KEYWORDS: Fault Detection and Isolation, Extended Kalman Filter, Dynamic Hybrid Simulation, Object Differential Petri Nets Hybrid, Risk assessment

1 INTRODUCTION

Batch and semi-batch processes play an important role in the pharmaceutical and fine chemical process industry. They are the prevalent production modes for low volumes of high added value products. Such systems are characterized not only by a small scale flexible production, but also by complex chemical reaction (Grau et al., 2000). Generally, these processes are complex and not entirely known. For this reason, batch or fed-batch reactors are frequently used for the development of hazardous chemical synthesis. Even if it offers the required flexibility and versatility, this reactor has technological limitations. Particularly, during the exothermic chemical reactions, the poor heat transfer can become a serious safety problem (Stoessel, 2008).

Numerous methods of risk analysis such as HAZOP (International standard IEC 61882) can be exploited for the identification of the main events or potentially dangerous deviations. Then, corrective measures can be taken in order to improve the process safety. However, these studies cannot prevent the occurrence of failures during the chemical reaction. For instance, these failures can be due to the malfunction of a sensor or of an actuator. There are also the structural changes, which refer to changes in the process itself (Venkatasubramanian et al., 2003). These failures occur due to hard failures in equipment, such as a stuck valve, a broken or leaking pipe.

Consequently, fault detection and diagnosis are the purpose of a particular attention in the scientific and industrial community. The major idea is that the defect must not be undergone but must be controlled. Nowadays, these subjects remain a large research field. The literature quotes as many fault detection and diagnosis methods as many domains of application (Chang and Chen, 2011; Venkatasubramanian, et al., 2003). A notable number of works has been devoted to fault detection and isolation, and the techniques are generally classified as:

- Methods without models such as quantitative process history based methods (neural networks (Venkatasubramanian, et al., 2003), statistical classifiers (Anderson, 1984)), or qualitative process history based methods (expert systems (Venkatasubramanian, et al., 2003)),

- Model-based methods which are composed of quantitative model-based methods (such as analytical redundancy (Chow and Willsky, 1984), parity space (Gertler and Singer, 1990), state estimation (Willsky, 1976), or fault detection filter (Franck, 1990)) and qualitative model-based methods (such as causal methods: digraphs (Shih and Lee, 1995), or fault tree (Venkatasubramanian, et al., 2003)).

In this paper, the proposed approach to fault detection and isolation is a model-based approach, applied to chemical processes. The first part of this communication focuses on the main fundamental concepts in the field of a batch reactor and of runaway scenarios. Next, the studied reaction is presented. This is the oxidation of sodium thiosulfate with hydrogen peroxide. Then, its protocol is underlined. The third part illustrates the proposed model-based diagnosis approach. It uses the extended Kalman Filter, in order to generate a fault indicator. The high robustness and real-time ability of observer is well-known for industrial applications (Ding, 2014). Next, this approach is enlightened exploited through the simulation of an exothermic reaction monitoring. Finally, section 5 summarizes the contributions and achievements of the paper and some future research works are suggested.

2 EXOTHERMIC CHEMICAL REACTION

The implementation of chemical reactions in batch or semi-batch reactors is strongly limited by the constraints linked to the dissipation of the heat generated by the reactions. Thus, this implementation can be made only after a complete risk analysis has been conducted to guarantee its safety, and the quality of its products (Chetouani et al., 2003). Consequently, we must firstly identify the risk in a chemical reactor. The main risk consists of a runaway scenario.

2.1 Runaway scenario



Figure 1: Runaway scenario

R. Gygax (1988) proposed the following runaway scenario. He considers the case where a complete cooling failure occurs (Figure 1):

- The reactor is initially at the process temperature $T_{P_{e}}$
- Next, at t=t₀, the cooling stops and so the temperature increases due to the completion of the reaction. This temperature increase depends on the process conditions (Stoessel, 2008).

- A level called the Maximum Temperature of the Synthesis Reaction (MTSR) can be reached. At this temperature, a secondary decomposition reaction may be initiated, and the temperature of the mixture increases to reach the final temperature T_{END} .

The runaway reaction can be induced by an increase of the reaction rate (in other words, of the heat production) or by a decrease of the cooling capacity. A heat increase may be initiated either by an increase of the concentrations (causes: feeding, evaporation...), either by a catalytic acceleration (origins: reactive specificities, autocatalysis...), or by a temperature rise (reasons: reaction heat, energy adding).

A cooling capacity decrease may come from a decrease of the mixing efficiency (stopping of the stirring motor...), from a decrease of the heat transfer (causes: viscosity increase, etc.), from a quantity or potential increase (for example, due to the use of important quantities), or by a decrease of the power of the cooling system (origins: failures on the cooling system).

The objective of this research work is so to prevent the reaction runaway by detecting the abnormal behaviour and diagnosing the causes of this behaviour.

2.2 Choice of the reaction

The chosen reaction is a very exothermic oxidoreduction one, the oxidation reaction of sodium thiosulfate $Na_2S_2O_3$ by hydrogen peroxide H_2O_2 (Chetouani, 2004). Because of its characteristics, this reaction is particularly exploited for safety study (Xaumier et al., 2002; Chetouani et al., 2003; Prat et al., 2005; Benaissa et al., 2008; Benkouider et al., 2012). The stoechiometric scheme is:

 $Na_2S_2O_3 + 2 H_2O_2 \rightarrow \frac{1}{2} Na_2S_3O_6 + \frac{1}{2} Na_2SO_4 + 2 H_2O$

This liquid homogeneous reaction is irreversible, fast, and highly exothermic (Lo and Cholette, 1972). The kinetics can be described by:

$$r = k \cdot [Na_2S_2O_3] \cdot [H_2O_2] \quad \text{with } k = k_0 \cdot \exp\left[\frac{-E_a}{R \cdot T}\right] (1)$$
$$k_0 = 2 \cdot 10^{10} \text{ L.mol}^{-1} \text{ s}^{-1} \text{ and } E_a = 6.82 \cdot 10^4 \text{ J.mol}^{-1}.$$

The reaction heat is $\Delta H_r = -586.2 \text{ kJ.mol}^{-1}$. Some hypotheses are stated:

- The reactor is perfectly mixed with a homogeneous temperature in the reaction mixture;
- The feeding of the reactive does not induce volume contraction;
- The heat capacity and the density of pure components are constant in the range of the considered temperatures;
- The physico-chemical properties of the mixture are constant;
- The chemical reaction is performed in a pseudohomogeneous medium;

- The thermal losses between the reaction mixture and the ambient surroundings can be neglected.

		Material feed 1	Material feed 2
	$Na_2S_2O_3$	15%	-
Weight percent	H_2O_2	-	30%
	H_2O	75%	70%
Temperature (K)		293.15	333.15
Flowrate (L.h ⁻¹)		120.9	31.2

	Table	1:	0	perating	Con	ditions
--	-------	----	---	----------	-----	---------

The process consists of a standard batch reactor of 100L, connected with a cooling system. The water utility fluid is provided at a temperature of 288.15K. The tank is filled by two material feeds. The aqueous sodium thiosulfate is introduced through the main inlet process fluid. In order to avoid a possible side reaction, H_2O_2 is in excess. The weight percent in the inlet flows are 15% for Na₂S₂O₃ and 30% for H_2O_2 . The instrumentation of the process is composed of two temperature sensors (mixture and utility fluid), two flow sensors (the reactor feeding flow rate and the utility fluid flow rate). In normal functioning, the operating conditions of a typical oxidation reaction are summarized in Table 1.

2.3 Protocol

A typical operation of a batch or semi-batch reactor consists of the tracking of an a priori defined temperature profile. In the case of an exothermic reaction, three distinct steps are involved: preheating, reaction, and cooling (Xaumier et al., 2002). The reactor temperature is controlled by manipulating the flowrate of the utility fluid. Figure 2 represents the experimental set up used in this study.

The process recipe is composed of several steps:

- A feeding step of Na₂S₂O₃ during 1200 seconds,
- A heating step to increase the temperature of the mixture from 293.15 K to 333.15 K,

- An other feeding step of H₂O₂ during 1200 seconds, with a constant temperature 333.15 K,
- A constant temperature step (the reaction step) at 333.15 K during 4800 seconds.



Figure 2: Semi-batch process

2.4 Risk assessment

The risk management is a major requirement in the industrial context: a major accident is unacceptable. Identifying risks is essential for ensuring the safe design and operation of a process. Several techniques are available to analyse hazardous situations (Marhavilas et al., 2011). Among them, the HAZard and OPerability study (HAZOP) is a well-known technique for studying the hazards of a system (Benaïssa et al., 2008) and its operability problems (International Standard IEC 61882.2001).

Section	Guide word	Deviation	Nb	Causes	Consequences
Reactor	More	More flow rate	1	Malfunction of the valves V1a or V2 (for example they remains totally opened)	 Accumulation of reagents Increase of the reaction speed Increase of the reactor temperature Runaway
			2	Malfunction of the controller FC1 or FC2 (for example detection of a wrong value more important)	 Accumulation of reagents Increase of the reaction speed Increase of the reactor temperature Runaway
	None Flow		3	Malfunction of the valves V1a or V2 : they are closed	Decrease of the conversion rateProduction loss
			4	Plug in pipe	Decrease of the conversion rateProduction loss
			5	Pipe rupture	Decrease of the conversion rateProduction lossBig leaks of hazardous product
			6	Malfunction of FC1 or FC2: detection of a wrong value (less important)	Decrease of the conversion rateProduction loss

Table 2: HAZOP data sheet sample

The HAZOP team studied each element for deviations and considered their undesirable consequences. The identification of deviations is obtained by combining process parameters (temperature, flowrate, pressure...) with "guide words" (no, more, less, as well as, reverse, etc.). Each deviation is studied and particularly we search how undesirable events can occur in order to have this deviation. The conclusions are resumed in a table, (Freeman et al., 1992). Among all the potential hazards highlighted by the HAZOP method, numerous scenarios could potentially lead to a thermal runaway. So, these scenarios were identified as the most hazardous ones. Table 2 illustrates the result data sheet. It gives a short sample of the analysis carried out on the reactor part.

3 FDI METHODOLOGY

Nowadays, for reasons of safety and performance, monitoring and supervision play an important role in process control. The complexity and the size of industrial systems induce an increasing number of process variables and make difficult the work of operators. In this context, a computer aided decision-making tool seems to be wise. Nevertheless the implementation of fault detection and diagnosis for stochastic system remains a challenging task. Various methods have been proposed in different industrial contexts (Venkatasubramanian et al., 2003). The proposed approach is a model-based approach involving the use of Hybrid Dynamic System simulation.

3.1 Architecture



Figure 3: Supervision Architecture

The research works performed for several years within the PSE (Process System Engineering) research department of the Chemical Engineering Laboratory of Toulouse on process modelling and simulation have led to the development of PrODHyS (Perret et al., 2004; Hétreux et al., 2007). This environment provides a library of classes dedicated to the hybrid dynamic process simulation. Based on object concepts, PrODHyS offers extensible and reusable software components allowing a rigorous and systematic modelling of processes. For this purpose, the simulation model of PrODHyS is used as a reference model to implement the functions of detection and diagnosis. The supervision module must be able to detect the faults of the physical systems (leak, energy loss, etc.) and the faults of the control/command devices (actuators, sensors, etc.). As defined in (De Kleer et al., 1984), our approach is based on the hypothesis that the reference model is assumed to be correct.

The global principle of this system is shown in Figure 3, where the sequence of the different operations is underlined (Olivier-Maget et al., 2008). Moreover, a distinction between the in-line and off-line operations is made. Our approach is composed of three parts: the generation of the residuals, the generation of the signatures and the generation of the fault indicators.

This methodology has been the subject of previous studies (Olivier-Maget et al., 2009a, 2009b). Nevertheless, it must be validated with other systems and other fault types, in order to ensure its genericity. Current work aims at extending the application areas of process safety. So, the studied case concerns he implementation of an exothermic reaction.

3.2 Residual generation

The first part concerns the generation of the residuals (waved pattern in the Figure 3). In order to obtain an observer of the physical system, a real-time simulation is done in parallel. So, a complete state of the system will be available at any time. Thus, it is based on the comparison between the predicted behavior obtained thanks to the simulation of the reference model (values of state variables) and the real observed behavior (measurements from the process correlated thanks to the Extended Kalman Filter).

The main idea is to reconstruct the outputs of the system from the measurement and to use the residuals for fault detection (Mehra and Peschon, 1971, Welch and Bishop, 1995, Simani and Fantuzzi, 2006). A lot of state estimators are developed for nonlinear systems (Banerjee and Jana, 2014). Kalman filtering based observer (Li et al., 2004; Qu et Ahn, 2009), extended Luenberger observer (Zeitz, 1987; Gundale Mangesh and Jana, 2008), sliding nonlinear observer (Biagiola and Figueroa, 2004; Mezouar et al., 2008), particle filtering (Farza et al., 2004; Olivier et al., 2012) are the most important estimators. The current work focuses on the design of an extended Kalman Filter. A description of the extended Kalman filter can be found in (Olivier-Maget et al., 2008). Besides the residual is defined according to the following equation:

$$r_{i}^{r}(t) = \frac{\hat{X}_{i}(t) - X_{i}(t)}{X_{i}(t)} \quad \text{with } i \in \{1, n\}$$
(2)

where X_i is the state variable, \hat{X}_i is the estimated state variable with the extended Kalman Filter and *n* is the number of state variables.

Note that the generated residual $r_i^r(t)$ is relative. As a matter of fact, this allows the comparison of residuals of different variables, since the residual becomes independent of the physical size of the variable.

3.3 Signature generation

The second part is the generation of the signatures (doted pattern in the Figure 3). This is the detection stage. It determines the presence or not of a fault. This is made by a simple threshold $\varepsilon_i(t)$. The generated structure

 $S_i^{rN}(t)$ is denoted by the following equation:

$$S_{i}^{rN}(t) = \frac{Max \left[\left(\left| r_{i}^{r}(t) \right| - \varepsilon_{i}^{r}(t) \right); 0 \right] \right]}{\sum_{k=1}^{n} Max \left[\left(\left| r_{k}^{r}(t) \right| - \varepsilon_{k}^{r}(t) \right); 0 \right] \right]} \quad with \quad i \in \{1, n\}$$

with $\varepsilon'_i(t) = \frac{\varepsilon_i(t)}{X_i(t)}$, where ε_i is the detection threshold.

The value of ε_i is chosen according to the model error covariance matrix of the Extended Kalman Filter (Olivier-Maget, 2007).

3.4 Generation of fault indicator

The last part deals with the diagnosis of the fault (hatched pattern in the Figure 3). The signature obtained in the previous part is compared with the theoretical fault signatures by means of a distance. A theoretical signature $T_{,j}$ of a particular fault *j* is obtained by experiment or in our case, by simulations of the process with different occurence dates of this fault. Then, a fault indicator is generated. For this, two distances have been defined: the relative Manhattan distance and the improved Manhattan distance (Olivier-Maget, 2007).

The first distance is denoted by the following expression:

$$D_{j}^{Mr}(t) = \frac{\sum_{i=1}^{n} \left| S_{i}^{rN}(t) - T_{ij} \right|}{n}$$
(4)

The second distance, which allows the diagnosis of many simultaneous faults, is denoted by the following expression:

$$D_{j}^{Ma}(t) = \frac{\sum_{i=1}^{n} \left| S_{i}^{rN}(t) \times m' - T_{ij} \times n' \right| \cdot T_{ij}}{n'}$$
(5)

where n' is the number of non-zero elements of the theoretical fault signature $T_{,j}$ and m' is the number of non-zero elements of the fault signature $S^{rN}(t)$.

Since both distances are defined in the space interval [0;1], the fault indicators are defined as the complement

to 1 of these distances. An indicator can be viewed as the probability of the occurrence of a particular fault. Next, these generated indicators are exploited to take a diagnosis of the system. For this, we suppose that:

- The minimum value of the indicator, for which the fault can be considered, is 0.68 chosen according to the normal distribution–. This threshold corresponds to the probability at the standard deviation.
- The number of faults, which can simultaneously take place, is limited to three.

4 RESULTS

The advantage of the simulation of the chemical reaction thermal effect is to prevent runaway problems, which can occur experimentally, particularly for such an exothermic reaction (Xaumier et al., 2002). Then, to demonstrate the good performance of the diagnosis methodology, different simulations have been carried out on the hybrid dynamic simulator PrODHyS. Two faults have been introduced:

- *Increase of the flow rate (fault 1):* In this case, 6500 s after the beginning of the reaction, the feed rate of the sodium thiosulfate is multiplied by 2.
- Increase of the jacket temperature (fault 2): 7500 s after the beginning of the reaction, the cooling temperature is increased to 10 °C.

4.1 Adjustments

To perform a monitoring of a process, some off-line adjustments must be made. On the one hand, we need to determine the covariance matrices of the model and measurement disturbances. While the measurement noises are supposed to be well-known by experiments or by the sensor manufacturer, the model disturbances is estimated by an "ensemble method". Numerous simulations have been performed during which a model parameter has been disturbed. This allowed the estimation of statistic distribution of the model mistakes. Then, if the behaviour of the system goes beyond this distribution, its behaviour is abnormal. So, the detection thresholds are determined according to the model disturbances.

On the other hand, the second adjustment is the learning of the incidence matrix. It is based on the same "ensemble" theory. For this, we perform a set of simulations, during which a fault is introduced at different occurrence dates, for each potential state of the hybrid dynamic system (Figure 4).

For this study we consider six faults. These faults are underlined by the HAZOP study. These faults could lead to a thermal runaway:

- Fault 1: The *material feed 1* provides material with a damaged flow rate;
- Fault 2: The *material feed 1* provides material with a damaged composition;

- Fault 3: The *material feed 2* provides material with a damaged flow rate;
- Fault 4: The *material feed 2* provides material with a damaged composition;
- Fault 5: The *energy feed* has a damaged temperature;
- Fault 6: The regulation temperature is damaged.



Figure 4: Learning of the incidence matrix

For example, figure 4 represents the results obtained for the fault 3. The signatures of this fault are presented for different occurence dates. They have the same pattern. The barycenter is estimated and we obtain the theoretic signature of the fault 3. Next, we perform this preliminary study for all the considered faults of the system and the incidence matrix is presented in table 3.

	Fault 1	Fault 2	Fault 3	Fault 4	Fault 5	Fault 6
Temperature (K)	0	0	0	0	0	0
Holdup (mol)	1	0.030239	0.020145	0	0	0
X[Sodium Thiosulfate]	0	0.950786	0	0	0	0
X[Hydrogen Peroxide]	0	0	0	0.289313	0	0.10448
X[Sodium Trithionate]	0	0	0	0	0	0
X[Sodium Sulfate]	0	0	0	0	0	0
X[Water]	0	0.018975	0	0.00103	0	0.000208
Reaction conversion	0	0	0	0	0	0
Cooling power (W)	0	0	0.495869	0.404899	0.009761	0.681392
Fluid Utility Temperature	0	0	0	0	0.049209	0
Fluid Utility Flowrate	0	0	0.483986	0.304758	0.94103	0.21392
		-				

Table 3: Incidence Matrix

Notice that the faults 4 and 6 would be confused, if we work with binary values. The work with real and non binary values aims at distinguishing the importance of the symptoms between a fault with an other one. Therefore, for a particular fault, the normalization allows that the great symptoms are underlined.

4.2 Normal operation

Figure 5 represents the simulated results for a normal operation. It gives the temperature profile of the process mixture, the evolution of the liquid holdup in the reactor, the conversion rate and the characteristics (flow rate and power) of the fluid utility. It must be noticed that the utility fluid flow rate increases during the feeding step of H_2O_2 . It points out that this oxidation reaction is fast and



4.3 Detection

Let us remind that the thresholds for the detection correspond to the model uncertainties obtained by the adjustment of the Extended Kalman filter. Figure 6 shows the detection step. It illustrates the evolution of the residual linked to the utility fluid flow rate. In order to avoid a false diagnosis, the diagnosis step is not launched as far as the symptoms of the abnormal behaviour appear. The abnormal behaviour is only confirmed after it has occurred three times.

Example 1: A fault of the material feed 2 is introduced at t = 6500 s. The material feed 2 provides material with a damaged flow rate (multiplied by 2). From t = 6800 s, the values of the residual underline the abnormal behaviour of the process. The diagnosis is launched at t = 6900 s.

Example 2: A fault of the energy feed is introduced at t = 7500 s. The energy feed has a damaged temperature (increasing of 10 °C). From t = 7600 s, the values of the residual underline the abnormal behaviour of the process. The diagnosis is launched at t = 7700 s.



Figure 6: Residual evolution of the utility fluid flow rate

highly exothermic. We also notice that the conversion is not total (87%).

4.4 Diagnosis

	Example 1	Example 2
Temperature (K)	0	0
Holdup (mol)	0.0210	0
X[Sodium Thiosulfate]	0	0
X[Hydrogen Peroxide]	0	0
X[Sodium Trithionate]	0	0
X[Sodium Sulfate]	0	0
X[Water]	0	0
Reaction conversion	0	0
Cooling power (W)	0.5094	0.0007
Fluid Utility Temperature	0	0.1144
Fluid Utility Flowrate	0.4637	0.8849

Let us notice that the exploited signature in this approach is non binary, in order to quantify the deviation due to the fault.

Table 4: Instantaneous fault signatures of both examples

The residual is then estimated and we obtain the corresponding instantaneous fault signature (Table 4). We compare the instantaneous fault signature (Table 4) with the theoretical fault signatures, by calculating the relative and improved Manhattan distances ((3) and (4)). Then, the fault indicators are generated (Table 5). They correspond to the complement to 1 of these distances.

Example 1: The relative Manhattan indicator detects the presence of the fault 3 with a probability of 99.68%. Nevertheless, the other faults are not eliminated, since their indicators are higher than 0.68 (cf. the point 3.4). In the opposite, with the improved Manhattan indicator, the faults 1, 2, and 5 are eliminated, since their indicators are lower than 0.68. The three remaining possibilities are the faults 3, 4, and 6. This example underlines the importance of using both indicators to be able to conclude. So, by combining the results of the both indicators, we can rule on the presence of the fault 3, since their indicators are the maximums. For this reason, this fault is the most probable. So, the fault is located on the material feed 2. Furthermore, it has been identified: the material feed 2 provides material with a damaged flowrate.

Example 2: The relative Manhattan indicator detects the presence of the fault 5 with a probability of 98.81%. However, none fault is discriminated (all indicators higher than 0,68). With the improved Manhattan indicator, the presence of the fault 5 is distinguished, since the other indicators are lower than 0.68. So, by combining the results of both indicators, we can rule on the presence of the fault 5. Then, the fault is located on the energy feed of the reactor. Furthermore, it has been identified: the cooling energy feed of the reactor has a damaged temperature.

		Fault 1	Fault2	Fault 3	Fault 4	Fault 5	Fault 6
1	Manhattan relative indicator	0.8225	0.8225	0.9968	0.9477	0.9048	0.9502
Example	Manhattan improved indicator	0.0630	0.0954	0.9835	0.8939	0.5435	0.7565
92	Manhattan relative indicator	0.8182	0.8182	0.9063	0.8737	0.9881	0.8572
Example	Manhattan improved indicator	0	0.0947	0.5600	0.6432	0.9439	0.4289

Table :	5: Fa	ult ind	icators
---------	-------	---------	---------

5 CONCLUSION

In this research work, the feasibility of using the simulation as a tool for fault detection and diagnosis is demonstrated. The fault detection and diagnosis approach, developed here, lies on the hybrid dynamic simulator PrODHyS. It is a general method for the detection and isolation of a fault occurrence. Besides, this approach allows the detection of numerous types of fault and has the ability to underline the simultaneous occurrence of many faults.

The works in progress aim at integrating this hybrid dynamic system simulation within a model-based supervision system. The goal is to define a recovery solution following the diagnosis of a default. For this, the results of signatures will be exploited in order to generate qualitative information. For example, with these results, we have the ability to distinguish a simple degradation and a failure. Next, this method will be combined with other diagnosis approaches: the set of the potential faults will be generated according to such methods as classification or case-based reasoning, restricting the search domain (to a part of the process or to a set of potential faults yielding similar symptoms) examined with the model-based technique..

Relating to the operation of exothermic reactions, a novel concept of heat exchangers reactors offers enhanced thermal performances in continuously operating reactors. The experiment results emphasize a significant thermal efficiency: the reactant concentrations and therefore the heat generation can be increased without risk of thermal runaway (Di Miceli Raimondi et al., 2014). The Polysafe ANR project (N° ANR-2012-CDII-0007-01) focuses on the modelling of these reactors in normal and degraded mode, to study the process drift and demonstrate the inherently safer nature of these devices.

REFERENCES

- Anderson, T.W. (1984). An introduction to multivariate statistical analysis, New York: Wiley.
- Banerjee S., A. K. Jana, 2014. High gain observer based extended generic model control with application to a

reactive distillation column, *Journal of Process Control*, 24(4), p. 235–248.

- Benaissa W., N. Gabas, M. Cabassud, D. Carson, S. Elgue, M. Demissy, 2008. Evaluation of an intensified continuous heat-exchanger reactor for inherently safer characteristics, *Journal of Loss Prevention in the Process Industries*, 21(5), p. 528-536.
- Benkouider A.M., R. Kessas, A. Yahiaoui, J.C. Buvat, S. Guella, 2012. A hybrid approach to faults detection and diagnosis in batch and semi-batch reactors by using EKF and neural network classifier, *Journal of Loss Prevention in the Process Industries*, 25(4), p. 694–702.
- Biagiola S.I., J.L. Figueroa, 2004. A high gain nonlinear observer: application to the control of an unstable nonlinear process, *Computers & Chemical Engineering*, 28, p. 1881–1898.
- Chang C.T., C.Y. Chen, 2011. Fault diagnosis with automata generated languages, *Computers and Chemical Engineering*, 35, p. 329–341.
- Chetouani, Y., N. Mouhab, J.M. Cosmao and L. Estel, 2003. Dynamic model-based technique for detecting faults in a chemical reaction, *Process Safety Progress*, 22(3), p. 183-190.
- Chetouani, Y., 2004. Fault detection by using the innovation signal: application to an exothermic reaction, *Chemical Engineering and Processing*, 43, p. 1579-1585.
- Chow, E.Y. and A.S. Willsky, 1984. Analytical redundancy and the design of robust failure detection systems, *IEEE Transactions on Automatic Control*, 29(7), p. 603-614.
- De Kleer, J. and B.C. Williams, 1987. Diagnosing multiple faults, *Artificial Intelligence*, 32, p. 97-130.
- Di Miceli Raimondi N., Olivier-Maget N., Gabas N., Cabassud M., Gourdon C., 2014. Safety enhancement by transposition of the nitration of toluene from semibatch reactor to continuous intensified heat exchanger, *Chemical Engineering Research and Design*, In Press, Corrected Proof, Available online 9 August 2014.
- Ding S.X., 2014. Data-driven design of monitoring and diagnosis systems for dynamic processes: A review of subspace technique based schemes and some recent results, *Journal of Process Control*, 24(2), p. 431–449.
- Farza M., M. M'Saad, L. Rossignol, 2004. Observer design for a class of MIMO nonlinear systems, *Automatica*, 40, p. 135–143.

- Frank, P.M., 1990. Fault diagnosis in dynamic systems using analytical and knowledge-based redundancy a survey and some new results, *Automatica*, 26, p. 459-474.
- Freeman R.A., R. Lee, T.P. McNamara, 1992. Plan HAZOP studies with an expert system, *Chemical Engineering Progress*, p. 28–32
- Gertler, J. and D. Singer, 1990. A new structural framework for parity equation-based failure detection and isolation, *Automatica*, 26, p.381-388.
- Grau, M.D., J.M. Nouguès and L. Puigjaner, 2000. Batch and semibatch reactor performance for an exothermic reaction, *Chemical Engineering and Processing*, 39, p. 141-148.
- Gundale Mangesh M., A.K. Jana, 2008. A comparison of three sets of DSP algorithms for monitoring the production of ethanol in a fed-batch baker's yeast fermenter, Measurement, 41, p. 970–985.
- Gygax, R., 1988. Chemical reaction engineering for safety, Chemical reaction engineering for safety, *Chemical Engineering Science*, 43(8), p. 1759-1771.
- Hétreux, G., R. Théry, N. Olivier-Maget, J.M. Le Lann, 2007. Exploitation de la simulation dynamique hybride pour la conduite de procédés semi-continus, *JESA*, 41(5), p. 585-616.
- Li R., A.B. Corripio, M.A. Henson, M.J. Kurtz, 2004. On-line state and parameter estimation of EPDM polymerization reactors using a hierarchical extended Kalman filter, *Journal of Process Control*, 14, p. 837– 852.
- Lo, S.N. and A. Cholette, 1972. Experimental study on the optimum performance of an adiabatic MT reactor, *The Canadian Journal of Chemical Engineering*, 50, p. 71-80.
- Mahavilas P.K., Koulouriotis D., Gemeni V., 2011. Risk analysis and assessment methodologies in the work sites: On a review, classification and comparative study of the scientific literature of the period 2000-2009, *Journal of Loss Prevention in the Process Industries*, 24(5), p. 477-523
- Mehra, R.K. and J. Peschon, 1971. An Introduction approach to fault detection and diagnosis in dynamic systems, *Automatica*, 5, p. 637-640.
- Mezouar A., M.K. Fellah, S. Hadjeri, 2008. Adaptive sliding-mode-observer for sensorless induction motor drive using two-time-scale approach, *Simulation Modelling Practice and Theory*, 16, p. 1323–1336.

- Olivier B., Huang, I.K. Craig, 2012. Dual particle filters for state and parameter estimation with application to a run-of-mine ore mill, *Journal of Process Control*, 22, p. 710–717.
- Olivier-Maget, N., 2007. Surveillance des Systèmes Dynamiques Hybrides : Application aux procédés, PhD Thesis of the Toulouse University (INSA).
- Olivier-Maget, N., G. Hétreux, J.M. Le Lann and M.V. Le Lann, 2008. Integration of a failure monitoring within a hybrid dynamic simulation environment, *Chemical Engineering and Processing*, 47(11), p.1942-1952.
- Olivier-Maget, N., G. Hétreux, J.M. Le Lann and M.V. Le Lann, 2009a. Model-Based Fault Diagnosis Using a Hybrid Dynamic Simulator: Application to a Chemical Process, Computer Aided Chemical Engineering, 27, p. 1641-1646.
- Olivier-Maget, N., G. Hétreux, J.M. Le Lann and M.V. Le Lann, 2009b. Fault Detection and Diagnosis Based on a Hybrid Dynamic Simulator, published in "The 7th IFAC International Symposium on Fault Detection, Supervision and Safety of Technical Processes", Spain, p. 223-228.
- Perret, J., G. Hétreux and J.M. Le Lann, 2004. Integration of an object formalism within a hybrid dynamic simulation environment, *Control Engineering Practice*, 12(10), p. 1211-1223.
- Qu C.C., J. Hahn, 2009. Process monitoring and parameter estimation via unscented Kalman filtering, *Journal of Loss Prevention in Process Industries*, 22, p. 703–709
- Rawlings J.B., B.R. Bakshi, 2006. Particle filtering and moving horizon estimation, *Computers & Chemical Engineering*, 30, p. 1529–1541.

- Simani, S. and C. Fantuzzi, 2006. Dynamic system identification and model-based fault diagnosis of an industrial gas turbine prototype, *Mechatronics*, 16, p. 341-363.
- Shih, R. and L. Lee, 1995. Use of fuzzy cause-effect digraph for resolution fault diagnosis for process plants, *Industrial and Engineering Chemistry Research*, 34(5), p. 1688-1717.
- Stoessel, F., 2008. Thermal safety of chemical processes, Risk assessment and Process Design, Wiley-VCH, p. 374.
- Venkatasubramanian, V., R. Rengaswamy, K. Yin and S. N. Kavuri, 2003. A review of process fault detection and diagnosis, *Computers & Chemical Engineering*, 27, p. 293-346.
- Welch, G. and G. Bishop, 1995. An introduction to the Kalman filter, Technical Report TR 95-041, University of North Carolina.
- Willsky, A.S., 1976. A survey of design methods for failure detection in dynamic systems, *Automatica*, 12, p. 601 – 611.
- Xaumier, F., M.V. Le Lann, M. Cabassud and G. Casamatta, 2002. Experimental application of nonlinear model predictive control: temperature control of an industrial semi-batch pilot-plant reactor, *Journal of Process Control*, 12(6), p. 687-693.
- Zeitz M., 1987. The extended Luenberger observer for nonlinear systems, *System & Control Letters*, 9, p. 149–156.