



HAL
open science

Improvement of the size estimation of 3D tracked droplets using digital in-line holography with joint estimation reconstruction

N Verrier, N Grosjean, E Dib, L Méès, C Fournier, J-L Marié

► To cite this version:

N Verrier, N Grosjean, E Dib, L Méès, C Fournier, et al.. Improvement of the size estimation of 3D tracked droplets using digital in-line holography with joint estimation reconstruction. 2015. hal-01226210v1

HAL Id: hal-01226210

<https://hal.science/hal-01226210v1>

Preprint submitted on 12 Nov 2015 (v1), last revised 23 Feb 2016 (v2)

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

Improvement of the size estimation of 3D tracked droplets using digital in-line holography with joint estimation reconstruction

N. Verrier¹, N. Grosjean², E. Dib¹, L. Méès², C. Fournier¹, J-L. Marié²

¹ Laboratoire Hubert Curien - UMR 5516-CNRS-Université Jean Monnet- 18 Rue du Professeur Benoît Lauras F-42000 Saint-Etienne, France

² Laboratoire de Mécanique des Fluides et d'Acoustique (LMFA), UMR 5509-CNRS-Ecole Centrale de Lyon, Université Claude Bernard Lyon 1, INSA de Lyon, 36 avenue Guy de Collongue, F-69134 Ecully, France

E-mail: corinne.fournier@univ-st-etienne.fr

16 October 2015

Abstract. Digital holography is a valuable tool for three-dimensional information extraction. Among existing configurations, the originally proposed set-up (i.e. Gabor, or in-line holography), is reasonably immune to variations in the experimental environment making it a method of choice for studies of fluid dynamics. Nevertheless, standard hologram reconstruction techniques, based on numerical light back-propagation are prone to artifacts such as twin images or aliases that limit both the quality and quantity of information extracted from the acquired holograms. To get round this issue, the hologram reconstruction as a parametric inverse problem has been shown to accurately estimate 3D positions and the size of seeding particles directly from the hologram. To push the bounds of accuracy on size estimation still further, we propose to fully exploit the information redundancy of a hologram video sequence using joint estimation reconstruction. Applying this approach in a bench-top experiment, we show that it led to a relative accuracy of 0.13 % (for a 30 μm diameter droplet) for droplet size estimation, and a tracking accuracy of $\sigma_x \times \sigma_y \times \sigma_z = 0.15 \times 0.15 \times 1$ pixels.

PACS numbers: 42.40.-i, 06.30.-k

Keywords: Digital Holography, Inverse Problems, Superresolution, Image reconstruction techniques, Metrology. Submitted to: *Meas. Sci. Technol.*

1. Introduction

Optical diagnostics are reliable tools for fluid dynamics and studies in reactive environments. Their non-invasive nature makes it possible to extract quantitative information from the medium under investigation without disturbance. Among the available techniques, digital in-line holography enables reconstruction of a three dimensional volume from a single interference recording called a hologram. Moreover, unlike off-axis configurations, digital in-line holography is experimentally simple to implement and is almost immune to variations in the experimental environment (e.g. temperature evolution, vibrations), making it a method of choice for medium characterization in severe experimental conditions [1, 2, 3, 4]. The recorded information is usually reconstructed by calculating light back-propagation from the sensor plane to a targeted plane in the volume under study [5, 6], leading to the extraction of three-dimensional information such as the velocity field, and the trajectories [7, 8, 9, 10]. However, hologram reconstruction based on light back-propagation is prone to sampling artifacts and twin image disturbances [11, 12, 13, 14], which limit the signal to noise ratio of the reconstructed holograms, as well as the accuracy of the estimated parameters of the object (3D positions x, y, z , and radius r for particle holography).

In contrast to these light back-propagation reconstruction methods, in certain cases, signal processing tools and their extensions to image processing may enable optimal processing [15]. Instead of transforming the hologram through numerical light back-propagation, the aim here is to find the imaging model parameters that best represent the recorded hologram [16, 17]. These ‘‘Inverse Problems’’ (IP) approaches, which are sometimes referred to as compressive sensing methods [18, 19, 20], makes it possible to increase the accuracy of the reconstruction [21, 22] and to recover signal beyond the physical limits of the imaging sensor [23]. Among IP algorithms, the reconstruction of parametric objects is performed using greedy algorithms, objects are iteratively optimally detected and removed from the original hologram for SNR improvement. Exploiting information redundancy along an imaging sequence makes it possible to further improve the accuracy of the imaging model parameters, thereby performing joint parameter estimation [24, 25] or super resolution [26]. However, the accuracy of the reconstruction is achieved at the cost of computation time. Time processing issues can be solved by considering either software [27, 28] or hardware strategies [29, 30]. However, in this article, we focus on the algorithm that improves accuracy and leave aside problems of computation time.

To test the algorithm in bench-top experiments, we propose to use IP reconstruction algorithm to reconstruct and track droplets delivered, on demand, by a Piezo-Electric (PZT-) injector, using digital in-line holography. The PZT injector used in this experiment generates mono-dispersed water droplets. We consequently exploited the constancy of the radius during the course of the video hologram sequence to improve the accuracy of its measurement. Moreover, the assumption of free-falling objects gives a trajectory model that allowed us to estimate the accuracy of 3D positioning. We

demonstrate that the proposed method is able to perform 3D droplet localization and tracking with an accuracy of $\sigma_x \times \sigma_y \times \sigma_z = 3 \times 3 \times 20 \mu\text{m}^3$ (or $\sigma_x \times \sigma_y \times \sigma_z = 0.15 \times 0.15 \times 1$ pixels), and with an accuracy of $\sigma_r = 39.7$ nm (or 0.13 %) in the radius estimation (for a $30 \mu\text{m}$ water droplet).

2. Data acquisition and pre-processing

2.1. Experimental Setup

Figure 1 shows the in-line holographic setup used for 3D tracking of free-falling droplets. This configuration is similar to that of [31]. The light emitted from a Nd-YVO₄ solid state laser ($\lambda = 532$ nm Millennia IIs Spectra Physics) is low pass filtered and expanded using a $f = 100$ mm focal-length lens associated with an adjustable diaphragm. The




Figure 1. (Color online) Experimental setup for holographic 3D tracking of free-falling droplets.

illumination beam is a spherical diverging wavefront impinging the water droplet jet under investigation. The jet consists of free-falling mono-dispersed water droplets generated by a piezo-electric injector (MJT-AT-01 MicroFab Technologies jetting device, $60 \mu\text{m}$ orifice diameter). Interference between the field diffracted by the droplets and the reference beam (the part of the illumination beam that does not interact with the droplets) are recorded on a 1280×800 pixel CMOS sensor (Phantom V611) with a pixel pitch of $20 \mu\text{m}$ and operating at 6200 frames per second. It should be noted that no collection optics is used for the holographic recording. The pixel fill factor, representing the ratio of the active surface of the pixel to the physical surface of the pixel, can be accounted for in our imaging model according to Ref. [32] and is $\kappa = \kappa_x \times \kappa_y = 0.56$. The axial position of the water droplet is estimated roughly (based on the distance from the injector to the sensor) to be in the $z_{\min} = 0.46$ m to $z_{\max} = 0.48$ m range. To measure image magnification, the injection plane is considered as a reference plane. Magnification in the i^{th} plane G_i was calibrated using a reticle and expressed as $G_i = 1.5 \cdot 10^{-3} \Delta z_i + 1.4735$ (see [33] for details about the calibration

procedure). Here, Δz_i is the algebraic distance between the injection and the i^{th} planes (counted as positive in the light propagation direction). The range $[z_{\min}; z_{\max}]$ is so that $z \gg 4r^2/\lambda$, with r the droplet radius. Under this assumption, the droplets can be viewed as opaque spherical objects and the Huygens-Fresnel integral, which gives the intensity recorded on the imaging sensor, has an analytical solution [34]. The intensity $I_z(x, y)$ recorded for a spherical opaque particle at a distance of z from the imaging sensor is thus given by

$$I_z(x, y) \propto 1 - \frac{1}{\lambda z} \mathcal{F}_{\frac{x}{\lambda z}, \frac{y}{\lambda z}} \{ \vartheta(\xi, \eta) \} \sin \left[\frac{\pi}{\lambda z} (x^2 + y^2) \right] + \left[\frac{1}{\lambda z} \mathcal{F}_{\frac{x}{\lambda z}, \frac{y}{\lambda z}} \{ \vartheta(\xi, \eta) \} \right]^2, \quad (1)$$

where ϑ is the aperture function of the spherical droplet defined as

$$\vartheta(\xi, \eta) = \begin{cases} 1 & \text{if } \sqrt{(\xi - x)^2 + (\eta - y)^2} \leq r, \\ 0 & \text{otherwise} \end{cases}, \quad (2)$$

and (ξ, η) are the coordinates in the aperture (droplet) plane. The Fourier transform of ϑ can be analytically derived and is given by

$$\mathcal{F}_{\frac{x}{\lambda z}, \frac{y}{\lambda z}} \{ \vartheta(\xi, \eta) \} = \pi r^2 \left(\frac{\lambda z}{2\pi r \sqrt{x^2 + y^2}} \right) J_1 \left(\frac{2\pi r \sqrt{x^2 + y^2}}{\lambda z} \right), \quad (3)$$

where J_1 the Bessel function of the first kind. It should be noted that the squared term in Eq. (1) is negligible in our experimental conditions as $\pi r^2 / (\lambda z) \ll 1$. In the case of a diluted sample, optical interaction between particles can be disregarded. Therefore, multiple particles can be considered with an additive intensity model given by

$$I_z(x, y) \propto 1 - \sum_{i=1}^{N_p} \frac{1}{\lambda z_i} \mathcal{F}_{\frac{x}{\lambda z}, \frac{y}{\lambda z}} \{ \vartheta_i(\xi, \eta) \} \sin \left[\frac{\pi}{\lambda z_i} (x^2 + y^2) \right], \quad (4)$$

where N_p is the number of particles to be considered and i is the particle index.

An example of a hologram obtained with the experimental setup shown in Fig. 1 is depicted in Fig. 2. As it can be seen, the contrast of the interference pattern is weak and the illumination beam is not spatially uniform. To avoid these problems, the acquired hologram sequences are pre-processed before being reconstructed.

2.2. Holograms pre-processing

The aim of pre-processing the hologram is to enhance the signal to noise ratio (SNR) of the diffraction pattern. The principles of hologram pre-processing are illustrated in Fig. 3. Using the recorded hologram sequence, it is possible to build a background image by calculating the median of the sequence. For this purpose, the larger the number of acquired frames, the better the background. Here, all 1,000 holograms were used to construct the background image. The constructed background image is then subtracted from the original hologram sequence, leading to an average removed sequence. It can be seen in Fig. 3 that the resulting sequence exhibits better fringe visibility and




Figure 2. Example of an acquired hologram.

background uniformity. Moreover, the background noise (i.e. region of the hologram without interference signal) strongly resembles Gaussian white noise. This aspect will be very useful for the implementation of the proposed reconstruction scheme. This point is discussed in detail in Section 4.




Figure 3. Pre-processing of the acquired hologram sequence.

Once the pre-processing step was complete, the hologram sequence is ready for hologram reconstruction. The proposed method is not based on backpropagation scheme

as is often the case, but relies on inverse problem approaches. The next section is therefore devoted to the description of the reconstruction scheme.

3. Hologram reconstruction using Inverse Problems Approaches

Standard hologram processing methods are based on light back-propagation methods [5]. These aim to calculate the Huygens-Fresnel integral from the recorded hologram giving the intensity of the light field in the object plane [35]. However, as these back




Figure 4. (Color online) Schematic diagram of the reconstruction procedure used for high resolution particle tracking.

propagation methods do not account for signal sampling, they are prone to ghost images [36]. In addition, as far as the in-line holographic configuration is concerned, reconstructed holograms are subject to twin-image disturbances, which drastically reduce the signal to noise ratio (SNR) of the reconstructed image, thereby reducing tracking accuracy. To overcome these problems, rather than back-propagating the hologram, an Inverse Problems (IP) reconstruction scheme can be considered [17, 21, 23, 37]. Assuming additive white Gaussian noise, the aim of this approach is to find the imaging model that best fits the experimental data, in the least-square sense. In our experimental configuration, a parametric imaging model relying on four parameters ($\{x_i, y_i, z_i, r_i\}$, see Eq. (4) for details) was available, and hence a parametric IP reconstruction [17, 21, 23]. Note that astigmatism, which can occur in pipe flow studies, can also be accounted for in the image formation model [38]. More complicated objects or configurations can also be accounted for by considering Maximum A Posteriori approach (MAP) [37, 39, 40]. All these approaches, often referred to as compressive sensing [18, 19, 20], have been shown to lead to optimal signal reconstruction [15, 24].

The reconstruction algorithm used for this tracking study is shown in Fig. 4 and relies on two main steps:

- (i) The individual reconstruction, labeled “Classical IP approach” in Fig. 4. This step is based on the conventional IP reconstruction algorithm proposed in [21, 23], and applied to each hologram. It consists of three sub-steps:
- for each hologram in the acquired sequence a global detection step is performed to roughly estimate the position and size parameters of the objects simultaneously detected in the hologram. Detection of all the particles is performed in parallel by finding the best matching elements in a discrete imaging model dictionary. This sub-step makes it possible to obtain the rough parameters $\{x_i, y_i, z_i, r_i\}_{i=1:N_p}^{\text{Rough}}$ for each of the N_p particles.
 - for each of the N_p particles, a local optimization is performed around the roughly estimated parameters. Here, a trusted region non-linear least squares algorithm is used to minimize the cost function linking the data to the imaging model. In contrast to the previous sub-step in which the parameter space is sampled, the aim of local optimization is to find a sub-pixel estimation of the imaging model parameters $\{x_i, y_i, z_i, r_i\}_{i=1:N_p}^{\text{Optim}}$ in a continuous parameter space.
 - To improve the data SNR, an optional cleaning step can be added.
- At the end of this first main step, the first 3D tracking is obtained as well as a radius estimation.
- (ii) the second main step is labeled “joint reconstruction” in Fig. 4. Here, as initially proposed in [25, 26], the information redundancy along the sequence of holograms is exploited to improve the accuracy of the reconstruction. Two sub-steps are involved:
- for each trajectory (built from the results of the first main step), stack of N_h holograms are built. In our study, the number of holograms is fixed to $N_h = 9$. In order to temporally decorrelate the noise in the acquired sequence, the stacks of holograms are built by randomly picking out N_h hologram from the N_t holograms composing each trajectory [25].
 - for each stack of a given trajectory, a joint reconstruction algorithm is applied. Constant parameters (in our case, droplet radius r), are optimized jointly over the sequence, while the other parameters are again optimized individually for the N_h holograms. In other words, at the end of the joint reconstruction scheme, we obtain one refined estimation of the radius r , and N_t refined values of the 3D particle positions for each hologram stack.

In the remainder of this article, this reconstruction scheme is applied to the tracking and particle sizing of a free-falling water droplet jet. Joint reconstruction with refined estimation of the radius r , is made possible considering r constant over each trajectory or at least over each hologram stack. It should be noted that this procedure can be generalized to other imaging technique, and therefore not limited to holographic imaging, as long as a parametric imaging model is available.

4. Experimental results and data statistics

The experimental setup presented Fig. 1 is used for the holographic acquisition of free-falling water droplets injected with a PZT-injector. The injector can generate mono-dispersed droplets, so our joint reconstruction approach is expected to allow accurate estimation of the injected droplet radius. It should be noted that for a known noise model, the accuracy of the 3D positions of the droplets is driven by the Cramer-Rao lower bound [15] and can be as low as one hundredth of a pixel. Note that the main purpose of this experiment is to validate the performances of our reconstruction algorithm on bench-top experiments.

4.1. Accuracy of the droplet 3D tracking

Tracking is performed on a sequence of $N = 1000$ holograms. Seven to eight particles can be tracked on each hologram. For statistical reasons, only particle trajectories that span at least 200 holograms were considered. Moreover the holograms are cropped in order not to consider object that exit from the injector (these are not spherical and do not corresponds to our image formation model). Therefore, according to the acquired holograms, $N_{\text{traj}} = 15$ trajectories will be processed. For each trajectory, random stacks of $N_h = 9$ holograms are built for the purpose of joint optimization.




Figure 5. (Color online) Example of particle tracking. (a) Parallel tracking of each particle in the hologram (full video sequence is available in Media 1). (b) Extracted 3D-trajectories for all the objects detected.

An example of a hologram sequence is shown in Fig. 5(a) (see Media 1 for the dynamic sequence). Here, white crosses corresponds to the position of the object detected using the first main steps of the reconstruction algorithm (i.e. classical IP reconstruction). A three-dimensional representation of the $N_{\text{traj}} = 15$ is plotted in Fig. 5(b). The coordinates $(x, y) = (0, 0)$ corresponds to the center of the hologram, while the injector is positioned at the top of the hologram (see Fig. 5(a)) and in the top left hand corner of Fig. 5(b). As it can be seen in Fig. 5(b), the extracted 3D trajectories




Figure 6. (Color online) Evolution of the estimated radius in trajectory 11. Results obtained for classical IP reconstruction are in blue, the joint reconstruction estimates are in orange. (a) Evolution of the radius as a function of the image/stack index. (b) Statistical distribution of the estimated values of the radius (Histogram for all the trajectories are given in Media 2).

are only weakly dispersed in both x and z directions. This can be explained by the fact that the imaging sensor is positioned to record the region of droplet injection, limiting the effect of the experimental environment on the droplet trajectories. To assess the accuracy of the 3D trajectory reconstruction, second order polynomial trajectories were fitted to the experimental data [41]. This choice was driven by the free-falling nature of the droplets. Results obtained for the $N_{\text{traj}} = 15$ trajectories are given in Table 1 in the 3rd to 5th columns for the classical IP, and in the 7th to 9th columns for joint reconstruction. From these results, it can be seen that the joint reconstruction process weakly influences the accuracy of the 3D tracking. This result was to be expected as neither x_i , nor y_i , nor z_i are constant throughout the image sequence. Moreover, it shows the low correlation between r and the $\{x, y, z\}$ parameters.

According to the values listed in Table 1, the tracking accuracy, which is in fact the accuracy of the fit of the trajectory (under the assumption of a second order polynomial trajectory), is found to be $\sigma_x \times \sigma_y \times \sigma_z = 3 \times 3 \times 20 \mu\text{m}^3$, corresponding to a tracking accuracy of $0.15 \times 0.15 \times 1$ pixels. It should be noted that we do not assess for the absolute particle position (note that theoretical localization accuracy can be as low as one hundredth of a pixel [15]) but the accuracy of the trajectory fit.

4.2. Accuracy of the estimation of the droplet radius

As the radius is assumed to remain constant over the hologram sequence, its estimate should benefit from our joint reconstruction approach. The accuracy of our radius estimation will be assessed by two quantities: the standard deviation of the estimated radius distribution σ_r , and the standard error of the mean $\sigma_{\bar{r}}$.

Table 1. Data statistics for particle tracking and size estimation using both IP reconstruction and Joint reconstruction

Track ^a	$N_{\text{hpt}} \left(\lfloor \frac{N_{\text{hpt}}}{N_h} \rfloor \right)^b$	$\sigma_x^{\text{IP}}(\mu\text{m})$	$\sigma_y^{\text{IP}}(\mu\text{m})$	$\sigma_z^{\text{IP}}(\mu\text{m})$	$\sigma_r^{\text{IP}}(\mu\text{m})$	$\sigma_r^{\text{IP}}(\text{nm})^c$	$\sigma_x^{\text{Joint}}(\mu\text{m})$	$\sigma_y^{\text{Joint}}(\mu\text{m})$	$\sigma_z^{\text{Joint}}(\mu\text{m})$	$\sigma_r^{\text{Joint}}(\mu\text{m})$	$\sigma_r^{\text{Joint}}(\text{nm})^d$
1	235 (26)	0.11	0.14	19.64	0.26	16.8	0.11	0.13	16.39	0.052	10.3
2	321 (35)	0.08	0.23	17.66	0.29	16.6	0.08	0.21	22.24	0.039	6.6
3	389 (43)	0.10	0.37	15.61	0.27	13.9	0.10	0.37	21.29	0.035	5.4
4	459 (51)	0.28	0.52	19.69	0.26	12.3	0.28	0.57	19.18	0.049	7.1
5	512 (56)	0.45	1.77	19.31	0.25	10.9	0.44	1.71	18.39	0.039	5.2
6	513 (57)	1.13	6.61	24.09	0.25	11.1	1.13	6.61	16.42	0.039	5.1
7	503 (55)	3.49	2.89	20.89	0.24	10.5	3.49	2.88	19.24	0.046	6.2
8	501 (55)	7.75	7.06	20.88	0.24	10.4	7.75	9.11	19.78	0.047	6.4
9	505 (56)	7.45	8.76	21.79	0.26	11.5	7.57	10.13	23.14	0.041	5.4
10	507 (56)	7.29	11.35	20.83	0.25	11.3	7.42	12.69	19.13	0.043	5.8
11	504 (56)	6.16	6.71	19.38	0.24	11.0	6.16	6.75	19.76	0.031	4.2
12	478 (53)	4.21	4.43	20.96	0.19	8.9	4.29	4.68	21.42	0.034	4.7
13	407 (45)	2.84	2.95	18.33	0.11	5.6	2.91	3.03	22.63	0.031	4.5
14	338 (37)	1.43	1.54	20.64	0.12	6.8	1.48	1.98	26.06	0.024	4.1
15	264 (29)	3.54	3.94	21.29	0.13	8.2	3.54	3.87	25.56	0.037	7.1

^aStandard deviations on the x, y, z particle positions $\sigma_{x,y,z}$ are estimated by fitting a theoretical free-falling droplet trajectory; ^b N_{hpt} corresponds to the number of hologram per trajectory; ^cEstimated over the number of holograms of the trajectory; ^dEstimated over the number of hologram stacks for each trajectory as given.

From the standard deviations of both IP and joint reconstruction estimation of the radius σ_r^{IP} , and σ_r^{Joint} , standard errors of the mean are defined as

$$\sigma_{\bar{r}}^{\text{IP}} = \frac{\sigma_r^{\text{IP}}}{\sqrt{N_{\text{hpt}}}}, \quad (5)$$

for the standard error of the mean of r estimated by classical IP reconstruction. Here N_{hpt} is the number of holograms per trajectory. The standard error of the mean (used to assess the accuracy of the estimation of the average) of the radius estimation using joint reconstruction is given by

$$\sigma_{\bar{r}}^{\text{Joint}} = \sigma_r^{\text{Joint}} \sqrt{\left\lfloor \frac{N_h}{N_{\text{hpt}}} \right\rfloor}, \quad (6)$$

where $\left\lfloor \frac{N_h}{N_{\text{hpt}}} \right\rfloor$ is the integer part of the ratio of the number of holograms per stack to the number of holograms per trajectory.

The statistical results of the estimation of the radius using the two reconstruction schemes are listed in Table 1. In addition, to better underline the interest of our joint reconstruction approach, changes in the radius estimation and statistical distribution of the droplet radius are illustrated in Fig. 6. These graphical representation were performed considering the 11th trajectory. In both Figs. 6(a) and (b), results obtained with classical IP reconstruction are plotted in blue, while results obtained with the joint reconstruction approach are plotted in orange. The interest of the random hologram stack construction is clear in Fig. 6(a). As can be seen, the estimated values of the radius are biased at the end of the hologram sequence and noise is clearly visible on the estimation. This behavior is no longer noticeable in the joint reconstruction results where the estimated values are barely scattered around the average estimate. This point is confirmed by the statistical distribution in Fig. 6(b). The results for all the trajectories are given in Media 2. Note that estimates of the radius are less dispersed around the distribution average when a joint reconstruction scheme is used.

Results obtained for the 15 tracks are summarized in Table 1. From these 15 independent trajectories, and considering that the injector generate monodispersed droplet distributions, we can estimate the average standard deviations and standard errors for the two reconstruction methods. As the number of holograms differs from one trajectory to the next, weighted average values are calculated considering

$$\langle \sigma_r^{\text{IP}} \rangle = \sqrt{\frac{\sum_{i=1}^{15} N_{\text{hpt}_i} \sigma_{r_i}^{\text{IP}2}}{\sum_{i=1}^{15} N_{\text{hpt}_i}}} \quad (7)$$

for the classical IP reconstruction, and

$$\langle \sigma_r^{\text{Joint}} \rangle = \sqrt{\frac{\sum_{i=1}^{15} \left\lfloor \frac{N_{\text{hpt}_i}}{N_h} \right\rfloor \sigma_{r_i}^{\text{Joint}2}}{\sum_{i=1}^{15} \left\lfloor \frac{N_{\text{hpt}_i}}{N_h} \right\rfloor}} \quad (8)$$

for the joint reconstruction. Weighted averages on the standard errors were obtained the same way.

Therefore using classical IP reconstruction the radius can be estimated with a standard deviation $\langle\sigma_r^{\text{IP}}\rangle = 0.235 \mu\text{m}$ and a standard error $\langle\sigma_{\bar{r}}^{\text{IP}}\rangle = 11.2 \text{ nm}$, while using a joint reconstruction scheme these values are $\langle\sigma_r^{\text{Joint}}\rangle = 0.0397 \mu\text{m}$ and $\langle\sigma_{\bar{r}}^{\text{Joint}}\rangle = 5.8 \text{ nm}$ resulting in a gain of 5.9 on the standard deviation and 1.9 on the standard error. It should be noted that in the case of white Gaussian noise, if the estimation of the radius computed using classical IP were averaged over $N_h = 9$ holograms instead of performing the joint estimation reconstruction, the maximal gain in the radius estimation would be $\sqrt{N_h} = 3$, which is half of the gain obtained using our method.

These results were obtained in the particular case of digital in-line holography with parametric objects. It should however be noted that more complicated objects can be considered using a regularized MAP reconstruction approach. Moreover, the proposed method is not limited to digital in-line holography but can be generalized to any technique that is based on a reliable physical model.

5. Conclusion

Digital in-line holography was successfully applied to the 3D-tracking and sizing of a free-falling water droplet jet generated by a PZT-injector. Instead of transforming data through Fresnel based light back-propagation calculations, holograms were processed using IP reconstruction. This method makes it possible to obtain 3D position parameters as well as the size of the droplets being investigated. Moreover, by exploiting the information redundancy of a temporal acquisition of holograms, it is possible to improve estimation of at least the parameters that remain constant during the acquisition.

Based on this principle, a joint estimation reconstruction scheme was developed. Accurate estimation of the 3D location of the droplets was intrinsically provided by the classical IP reconstruction algorithm, while the accuracy of the droplet size parameters was achieved by jointly estimating their value over randomly built hologram sequences. This method proved to be less sensitive to measurement biases than the classical IP reconstruction, making it a method of choice for both high resolution tracking and particle sizing.

The proposed joint reconstruction scheme makes it possible to track a 3D droplet jet with an accuracy of $\sigma_x \times \sigma_y \times \sigma_z = 3 \times 3 \times 20 \mu\text{m}^3$ over a field of view of $17 \times 14 \text{ mm}^2$, and also makes it possible to achieve a droplet sizing accuracy of $\langle\sigma_r^{\text{IP}}\rangle = 0.0397 \mu\text{m}$ with a standard error $\langle\sigma_{\bar{r}}^{\text{Joint}}\rangle = 5.8 \text{ nm}$. This results in a gain of a factor 5.9 in standard deviation and 1.9 in standard error compared to classical IP reconstruction.

The proposed method can be used for every imaging technique associated with a known imaging model and can be advantageously used for accurate estimation of redundant parameters in image sequences (e.g. optical properties, mechanical properties ...)

Acknowledgments

The authors are grateful for the financial support of *Université de Lyon* through the Program “*Investissements d’Avenir*” (ANR-11-IDEX-0007), and LABEX PRIMES (ANR-11-LABX-0063). The authors also would like to thank the French National Research Center (CNRS) for supporting this research work through the project DETECTION funded by the call for projects DEFI IMAGIn 2015.

References

- [1] A. R. Jones, M. Sarjeant, C. R. Davis, and R. O. Denham, “Application of in-line holography to drop size measurement in dense fuel sprays,” *Appl. Opt.* **17**, 328–330 (1978).
- [2] S. K. Jericho, J. Garcia-Sucerquia, W. Xu, M. H. Jericho, and H. J. Kreuzer, “Submersible digital in-line holographic microscope,” *Rev. Sci. Instrum.* **77**, 043706 (2006).
- [3] S. Jericho, P. Klages, J. Nadeau, E. Dumas, M. Jericho, and H. Kreuzer, “In-line digital holographic microscopy for terrestrial and exobiological research,” *Planet. Space Sci.* **58**, 701 – 705 (2010).
- [4] M. J. Berg and G. Videen, “Digital holographic imaging of aerosol particles in flight,” *J. Quant. Spectrosc. Ra.* **112**, 1776 – 1783 (2011).
- [5] U. Schnars and W. P. O. Jptner, “Digital recording and numerical reconstruction of holograms,” *Meas. Sci. Technol.* **13**, R85 (2002).
- [6] N. Verrier and M. Atlan, “Off-axis digital hologram reconstruction: some practical considerations,” *Appl. Opt.* **50**, H136–H146 (2011).
- [7] G. Bloch, J. Kuczaty, and T. Sattelmayer, “Application of high-speed digital holographic interferometry for the analysis of temperature distributions and velocity fields in subcooled flow boiling,” *Experiments in Fluids* **55**, 1–12 (2014).
- [8] L. Miccio, P. Memmolo, F. Merola, S. Fusco, V. Embrione, A. Paciello, M. Ventre, P. Netti, and P. Ferraro, “Particle tracking by full-field complex wavefront subtraction in digital holography microscopy,” *Lab Chip* **14**, 1129–1134 (2014).
- [9] S. Talapatra and J. Katz, “Three-dimensional velocity measurements in a roughness sublayer using microscopic digital in-line holography and optical index matching,” *Meas. Sci. Technol.* **24**, 024004 (2013).
- [10] Y. Wu, X. Wu, L. Yao, G. Gréhan, and K. Cen, “Direct measurement of particle size and 3D velocity of a gas–solid pipe flow with digital holographic particle tracking velocimetry,” *Appl. Opt.* **54**, 2514–2523 (2015).
- [11] D. Gabor *et al.*, “A new microscopic principle,” *Nature* **161**, 777–778 (1948).
- [12] L. Onural, “Sampling of the diffraction field,” *Appl. Opt.* **39**, 5929–5935 (2000).
- [13] C. Fournier, C. Ducottet, and T. Fournel, “Digital in-line holography: influence of the reconstruction function on the axial profile of a reconstructed particle image,” *Meas. Sci. Technol.* **15**, 686 (2004).
- [14] L. Onural, “Exact analysis of the effects of sampling of the scalar diffraction field,” *J. Opt. Soc. Am. A* **24**, 359–367 (2007).
- [15] C. Fournier, L. Denis, and T. Fournel, “On the single point resolution of on-axis digital holography,” *J. Opt. Soc. Am. A* **27**, 1856–1862 (2010).
- [16] S. Sotthivirat and J. A. Fessler, “Penalized-likelihood image reconstruction for digital holography,” *J. Opt. Soc. Am. A* **21**, 737–750 (2004).
- [17] S. H. Lee, Y. Roichman, G. R. Yi, S. H. Kim, S. M. Yang, A. van Blaaderen, P. van Oostrum, and D. G. Grier, “Characterizing and tracking single colloidal particles with video holographic microscopy,” *Opt. Express* **15**, 18275–18282 (2007).
- [18] D. J. Brady, K. Choi, D. L. Marks, R. Horisaki, and S. Lim, “Compressive holography,” *Opt. Express* **17**, 13040–13049 (2009).

- [19] S. Lim, D. L. Marks, and D. J. Brady, “Sampling and processing for compressive holography,” *Appl. Opt.* **50**, H75–H86 (2011).
- [20] Y. Rivenson, A. Stern, and B. Javidi, “Compressive fresnel holography,” *J. Display Technol.* **6**, 506–509 (2010).
- [21] F. Soulez, L. Denis, C. Fournier, E. Thiébaud, and C. Goepfert, “Inverse-problem approach for particle digital holography: accurate location based on local optimization,” *J. Opt. Soc. Am. A* **24**, 1164–1171 (2007).
- [22] J. Gire, L. Denis, C. Fournier, E. Thiébaud, F. Soulez, and C. Ducottet, “Digital holography of particles: benefits of the ‘inverse problem’ approach,” *Meas. Sci. Technol.* **19**, 074005 (2008).
- [23] F. Soulez, L. Denis, E. Thiébaud, C. Fournier, and C. Goepfert, “Inverse problem approach in particle digital holography: out-of-field particle detection made possible,” *J. Opt. Soc. Am. A* **24**, 3708–3716 (2007).
- [24] K. I. Mortensen, L. S. Churchman, J. A. Spudich, and H. Flyvbjerg, “Optimized localization analysis for single-molecule tracking and super-resolution microscopy,” *Nat. Methods* **7**, 377–381 (2010).
- [25] N. Verrier, C. Fournier, and T. Fournel, “3D tracking the brownian motion of colloidal particles using digital holographic microscopy and joint reconstruction,” *Appl. Opt.* **54**, 4996–5002 (2015).
- [26] N. Verrier and C. Fournier, “Digital holography super-resolution for accurate three-dimensional reconstruction of particle holograms,” *Opt. Lett.* **40**, 217–220 (2015).
- [27] M. Seifi, C. Fournier, L. Denis, D. Chareyron, and J.-L. Marié, “Three-dimensional reconstruction of particle holograms: a fast and accurate multiscale approach,” *J. Opt. Soc. Am. A* **29**, 1808–1817 (2012).
- [28] M. Seifi, L. Denis, and C. Fournier, “Fast and accurate 3D object recognition directly from digital holograms,” *J. Opt. Soc. Am. A* **30**, 2216–2224 (2013).
- [29] T. Shimobaba, T. Ito, N. Masuda, Y. Ichihashi, and N. Takada, “Fast calculation of computer-generated-hologram on amd hd5000 series gpu and opencl,” *Opt. Express* **18**, 9955–9960 (2010).
- [30] B. Samson, F. Verpillat, M. Gross, and M. Atlan, “Video-rate laser doppler vibrometry by heterodyne holography,” *Opt. Lett.* **36**, 1449–1451 (2011).
- [31] J.-L. Marié, N. Grosjean, L. Méès, and M. Seifi, C. Fournier, B. Barbier, and M. Lance “Lagrangian measurements of the fast evaporation of falling diethyl ether droplets using in-line digital holography and a high-speed camera,” *Axp. Fluids* **55**, 1–13 (2014).
- [32] T. M. Kreis, “Frequency analysis of digital holography,” *Opt. Eng.* **41**, 771–778 (2002).
- [33] M. Seifi, C. Fournier, N. Grosjean, L. Méès, J.-L. Marié, and L. Denis, “Accurate 3D tracking and size measurement of evaporating droplets using in-line digital holography and “inverse problems” reconstruction approach,” *Opt. Express* **21**, 27964–27980 (2013).
- [34] G. Tyler and B. Thompson, “Fraunhofer holography applied to particle size analysis a reassessment,” *J. Mod. Opt.* **23**, 685–700 (1976).
- [35] J. W. Goodman, *Introduction to Fourier optics* (Roberts and Company Publishers, 2005).
- [36] M. Jacquot and P. Sandoz, “Sampling of two-dimensional images: prevention from spectrum overlap and ghost detection,” *Opt. Eng.* **43**, 214–223 (2004).
- [37] A. Bourquard, N. Pavillon, E. Bostan, C. Depeursinge, and M. Unser, “A practical inverse-problem approach to digital holographic reconstruction,” *Opt. Express* **21**, 3417–3433 (2013).
- [38] N. Verrier, C. Fournier, L. Méès, and T. Fournel, “In-line particle holography with an astigmatic beam: setup self-calibration using an “inverse problems” approach,” *Appl. Opt.* **53**, G147–G156 (2014).
- [39] L. Denis, D. Lorenz, E. Thiébaud, C. Fournier, and D. Trede, “Inline hologram reconstruction with sparsity constraints,” *Opt. Lett.* **34**, 3475–3477 (2009).
- [40] L. Denis, D. A. Lorenz, and D. Trede, “Greedy solution of ill-posed problems: error bounds and exact inversion,” *Inverse Problems* **25**, 115017 (2009).
- [41] W. H. Press, S. A. Teukolsky, W. T. Vetterling, and B. P. Flannery, *Numerical recipes in C*, vol. 2 (Cambridge university press Cambridge, 1996).