



Online, Non-Intrusive Composition Measurements of Circulating CO₂ Based Mixtures in an Experimental Heat Pump by Means of Infra-Red Spectroscopy

Paul Bouteiller, Marie-France Terrier, Maria-Isabel Barba-Garrancho, Pascal Tobaly

► To cite this version:

Paul Bouteiller, Marie-France Terrier, Maria-Isabel Barba-Garrancho, Pascal Tobaly. Online, Non-Intrusive Composition Measurements of Circulating CO₂ Based Mixtures in an Experimental Heat Pump by Means of Infra-Red Spectroscopy. 16th International Refrigeration and Air Conditioning Conference, Purdue University, Jul 2016, West Lafayette (IN), United States. pp.2420. hal-01511643

HAL Id: hal-01511643

<https://hal.science/hal-01511643>

Submitted on 21 Apr 2017

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.



Distributed under a Creative Commons Attribution - NonCommercial - ShareAlike 4.0 International License

Online, Non-Intrusive Composition Measurements of Circulating CO₂ Based Mixtures in an Experimental Heat Pump by Means of Infra-Red Spectroscopy

Paul BOUTEILLER¹, Marie-France TERRIER¹, Maria-Isabel Barba-Garrancho², Pascal TOBALY^{1*}

¹CNAM, Laboratory CMGPCE,
292 rue Saint Martin – Case 2D3P21, 75003 Paris, France
paul.bouteiller@cnam.fr; marie-france.terrier@lecnam.net; pascal.tobaly@lecnam.net

²CREVER Grup, Universitat Rovira I Virgili
Països Catalans Avenue, 26 (Campus Sescelades), 43007 Tarragona, Spain
misabel.barba@estudiants.urv.cat

* Corresponding Author

ABSTRACT

Using CO₂ based mixtures as a working fluid in refrigeration and heat pumps is a potential alternative to the use of traditional fluids which are environmentally problematic. In order to investigate the efficiency of such systems, we have designed an experimental heat pump equipped with different measurement devices. In the present article, we will focus on the mixture composition measurement technique. In order to fully understand the behaviour of such a heat pump, it is necessary to measure the composition of the mixture at each point of the cycle. In order to do so, we have used a technique based on infra-red spectroscopy and chemometry. At each point in the loop, we have installed optical cells equipped with transparent windows and optical fibres. The spectra are recorded by a Fourier transform infra-red spectrometer. The mixtures composition is then extracted from the spectra by the partial least squares (PLS) method which is now common in analytical chemistry. But, beforehand, the PLS method has to be calibrated. This is done by recording a statistically meaningful set of spectra on samples of known composition. Then a model can be derived to relate the compositions to the characteristics of the spectra.

The calibration stage can be performed independently on separate well controlled samples. In our case, the calibration has been carried out directly on the experimental loop. To this end, micro sampling devices (ROLSITM) have been installed in different places next to the optical cells. During this calibration process, the composition of the fluid is measured by gas chromatography at varying conditions and compositions along with the recording of the spectra.

Once this calibration is done, the composition can be measured in short times, typically of the order of the second by the spectroscopic technique. This allows for a dynamic analysis of the working conditions.

This article will describe in detail the experimental set up and the calibration process for a mixture of CO₂ and propane on the composition range of interest at temperatures ranging from 263 K (-10 °C) to 393 K (+120 °C) and pressures from 25 to 100 bar and the expected accuracy will be discussed.

1. INTRODUCTION

International protocols and regulations are currently implemented to reduce the impact of human activities on Earth's climate. The objective is reduction of the greenhouse gas effect through limitation of the release in the atmosphere of involved gases. The revision of the European F-gas regulation (2014) establishes quotas for many HFC refrigerants, depending on their Global Warming Potential (GWP). New HFO refrigerants are designed to reduce GWP of synthetic refrigerants, and natural refrigerants are becoming more attractive for commercial refrigeration and heat pumps.

In order to improve the efficiency of heat pumps in central heating production mode, we currently experiment the use of CO₂ based mixtures as refrigerants, with measurements of the circulating fluid composition, for understanding of the mixture behavior in the thermodynamic loop. We currently work on binary mixtures, but ternary mixtures can be studied as well later on. Previous studies have shown that the addition of other chemicals can modify the fluid properties, critical point and equilibrium lines, with sometimes consequences such as reduction of the optimal high pressure or any other way to enhance the coefficient of performance (COP). Mixtures including CO₂ have been widely studied in the context of extraction processes, for petroleum, cosmetic or food industrial

activities for instance (Zancan *et Al.*, 2002), and mostly at higher temperatures. But very few studies are devoted to refrigeration or heat pumps using those mixtures. In the study done by Kim *et Al.* (2007, 2008), CO₂ + propane mixtures were used with the conclusion that the refrigerating efficiency may be improved over that of a pure CO₂ cycle. Simulations of cycles using dimethyl ether (DME) in addition to CO₂ also tend to show performances improvements (Onaka *et Al.*, 2008). CO₂ mixtures with HFCs have also been studied in the field of automotive refrigeration (Meunier *et Al.*, 2005). In the latter study, authors showed significant improvement of the refrigeration cycle COP by, for instance, lowering the required pressure ratio of the compressor. This experimental improvement of the COP was not properly understood as simulations based on REFPROP were rather in contradiction to experimental results, and no measurements of the circulating composition were available. In the present study, our aim is to test CO₂ mixtures in the field of heat pumps applications, especially hot water production for central heating of buildings, with real-time measurement of the composition of the circulating fluid. First, a quick analysis of the literature will show the expected influence of the addition of other compounds to CO₂. Then the experimental bench will be presented, along with the first results for a CO₂ + propane mixture. The detailed methodology for online fluid mixture composition monitoring will take place in the last part of the article.

2. CO₂ BASED MIXTURES

Adding components to R-744 (CO₂) refrigerant will modify its properties and this can be beneficial mostly in two ways. The critical temperature may be moved up so that condensation may occur at temperatures higher than 304 K (31 °C, critical temperature of CO₂) leading to lower temperature variations in the high temperature exchanger. Working pressures are also expected to be lower than with pure CO₂. This may be illustrated for instance in Figure 1, which shows the critical line and some bubble and dew curves for the CO₂ + propane mixture (Niesen and Rainwater, 1990). In Figure 1 we can see that liquid vapor equilibrium takes place for example at 328 K (55 °C) and pressures below 6 MPa. This allows to use a more efficient subcritical cycle for the central heating applications, as they require a lower temperature increase than for domestic hot water production. Of course, it is still possible to operate at higher pressures in a transcritical mode, if greater temperature shifts are required when dealing with domestic hot water production.

In order to increase the critical point, the added compound should be less volatile than CO₂ as for example propane (T_c = 369.89 K). But looking at Figure 2 it can be seen that great amounts of propane must be added in order to reach a sufficient critical temperature for our purposes. For example, if we need a mixture critical temperature of say 328 K, then the composition should be of the order of 50 % CO₂ only. If we want to reduce the amount of the added compound, an even less volatile compound should be used as for instance ethanol (T_c = 514.71 K). As shown in Figure 2, a composition of nearly 90 % CO₂ and only 10 % ethanol will result in the same critical temperature (328 K). However, in the case of ethanol addition, isothermal lines of CO₂ are so heavily modified that temperature glides can reach several tens of kelvins during evaporation and condensation (Secuianu *et Al.*, 2008), and this is an issue. For this particular reason, the architecture of the heat pump would have to be modified so that the added component will circulate through the loop without being stored in the evaporator or in the suction line bottle. When such mixtures are to be tested, previous works can be analyzed, as for example the so-called auto-cascade refrigeration systems (Du *et al.* 2009) or the work of Clodic and Rached (2004).




Figure 1: Bubble and dew curves for CO₂ + propane mixtures (Vicky G. Niesen and James C. Rainwater, 1990)




Figure 2: Critical lines for CO₂ + ethanol mixtures (Data from Galicia-Luna and Ortega-Rodriguez, 2000) and CO₂ + propane mixtures (Data from Niesen and Rainwater 1990)

First candidates for CO₂ based mixtures are presented in Table 1, along with expected effects. The aim is to enhance performances on the high pressure side of the cycle for heat pump applications. All these compounds have critical temperatures above the critical temperature of the CO₂ (304.45 K).

Table 1: Candidates for mixtures and expected effects

Chemicals families	Species	Critical temperature		Critical pressure [bar]	GWP	Drawbacks
		[Kelvin]	[°C]			
Hydrocarbons	Butane	425	151.85	38	3	Flammable
	Propane	369.9	96.75	42.5	20	Flammable
Alcohols	Methanol	512.5	239.35	80.8	Low	Toxic, flammable
	Ethanol	514	240.85	61.4	Low	Flammable
Ethers	Dimethyl ether	400	126.85	52.4	<1	Toxic, flammable
Esters	Methyl acetate	506.6	233.45	47.5		Irritant, flammable

3. EXPERIMENTAL HEAT PUMP APPARATUS

3.1 Bench description

The experimental facility was designed with modularity in mind. Depending on the investigated mixture, the loop can be modified to create new circuits if necessary. The bench measurements and controls are performed using LabView. In its present state, it is limited to a classical one stage loop. It is based on a water to water CO₂ heat pump, built up with commercial R-744 components (Figure 3): variable speed scroll compressor, brazed plate gas cooler, brazed plate evaporator, internal heat exchanger with liquid receiver and an electronic expansion valve. The heat pump loop supplies from 2 to 5 kW of heat output. It is instrumented with thermocouples (carefully recalibrated in our lab), pressure transmitters, two Coriolis flow meters (for mass flow rate and density measurements for both the high and low pressure sides of the cycle), a wattmeter, five in-line flow-cells for near infra-red spectrum measurements and 3 micro-samplers for gas chromatography analysis.




Figure 3: Heat pump loop and experimental bench

3.2 Pure CO₂ heat pump characterization

The experimental heat pump is first characterized using CO₂ only. Maximum efficiencies are determined for two hot water modes:

- Domestic hot water (DHW) production, when water is heated from 283 to 338 K (10 to 65 °C). COP accuracy is here 2 %.
- Central heating (CH) mode, when water is heated from 303 to 308 K (30 to 35 °C). COP accuracy is here 3.6 %.

For both modes, the brine temperature at the inlet of the evaporator is set at 280 K (7° C).

The cycle works as a conventional CO₂ water to water transcritical heat pump. This step allows refining the refrigerant load and control parameters, such as control of the high pressure level through variable speed of the compressor and opening of the electronic expansion valve (EEV) (Kim *et Al.*, 2003). Optimal high pressure is researched. The results obtained with optimized pure CO₂ cycle will be used as a reference for comparison of mixture cycles. Figure 4 shows the performance of the CO₂ heat pump loop. Preliminary runs have shown that the amount of CO₂ loaded into the loop has almost no influence on the maximum achievable COP, but does have an influence on the operating range of the heat pump. Maximum COP in CH and DHW operating modes are respectively 3.2 and 3.4. These are reached with optimal high pressures of 76 and 92 bar.

3.3 Mixtures evaluation

After characterization of the heat pump loop with pure CO₂ refrigerant, binary mixtures are assessed. To load the components of the fluid mixtures into the heat pump loop, it is first vacuum pumped, the less volatile component is loaded, and then CO₂ is injected in the loop to complete the refrigerant charge. Performances of the heat pump with mixtures are assessed using the same central heating mode, and domestic hot water mode, as with pure CO₂. Optimal high pressure level will be sought to obtain maximum COP. If some COP improvements are noticed, compared to the pure CO₂ cycle, the maximum COP is to be researched through variations of the fluid composition and charge.

First results for a CO₂ and propane mixture are available in Figure 4. The amount of propane in this mixture is about 15 % of the total mass.




Figure 4: COPs of the pure CO₂ cycle, and first results for a CO₂ and propane mixture

So far, performances are at least as good as with pure CO₂ in CH mode. DHW mode is still under measurements. In both modes, operating pressures have been reduced significantly. More tests need to be performed to find an optimal composition for the two working modes.

4. COMPOSITION MEASUREMENTS

The heat pump circuit is filled up with CO₂ based mixtures. Overall composition is well known, as the mass of each introduced compound is measured during the process of filling. But to understand the mixture behaviour in the cycle, measurements of the circulating fluid composition are needed. We rely on a non-intrusive in-situ technique which is commonly used in the field of analytical chemistry, namely infrared spectroscopy, coupled with statistical methods known as multivariate calibration (Warmuza and Filzmoser, 2012).

4.1 In-line cells and optical setup

The specific difficulty we are facing is the fact that our samples are under varying pressures and temperatures. To address this problem, we use inline flow cells which are tubes equipped with two high pressure windows through which the light passes. Optical fibers are used to lead the light to these optical cells. Figure 5 illustrates the optical setup on the bench. Modulated light coming from the spectrometer is directed to the cell through optical fibers, and an optical multiplexer allows to select the measurement point. The transmitted light is returned to the spectrometer through optical fibers and a multiplexer. Specific infrared wavelengths are absorbed, depending on the chemicals and their concentrations. It results in absorption spectra, which will be analyzed by a chemometric method.




Figure 5: Optical setup for NIR absorption spectrum acquisitions

Five flowcells are settled on the loop (see Figure 5), where the refrigerant is supposed to be a homogeneous phase:

- Discharge line at the compressor outlet.
- Expansion valve input.
- Two flowcells at the expansion valve output (one for the liquid phase, the other for the gas phase).
- Compressor inlet.

Because of different volatilities of the chemicals, we expect that during unsteady phases, the less volatile component will accumulate in the compressor's sump, in the exchangers, or in the suction line bottle. Also, refrigerant absorption in oil modifies refrigerant mixtures circulating compositions (Charni *et Al.*, 2013). That is why circulating composition is not equal to the introduced mixture composition. The composition measurement method using five flowcells will help to determine the distribution of the different species among the parts of the loop.

4.2 Chemometric methods

Chemometric methods allow real-time composition measurement by analysis of the absorption spectrum (Figure 6). They consist in processing the recorded spectrum of a fluid with unknown composition, using statistical methods like partial least squares (PLS) or principal components regression (PCR) (Warmuza and Filzmoser, 2012). However, it is not a direct measurement method. It should first be carefully calibrated by recording a number of spectra for mixtures of known composition varying in the range of expected compositions and concentrations. These are known as the calibration set or the training set.




Figure 6: Absorption spectra for CO_2 + propane and bands characterization according to Dias *et Al.* (2002)

A specific difficulty in our application of chemometrics is that, for given pressure and temperature, not all compositions exist. It is possible to reproduce (P, T) conditions in equilibrium cells but this would have been too time-consuming. Instead, in order to generate our calibration set, we added micro-samplers next to the flow cells to perform a composition measurement of the fluid mixture by gas chromatography. Micro-samplers are small heated electronic valves that open during a defined time length. A small amount of mixture leaks (and vaporizes if the sample is liquid) and flows into a heated transfer line in which the vector gas (here helium) flows. The sample is then carried to the gas chromatograph column for components separation, and then chemicals are detected by a thermal conductivity detector (TCD). The signal generated by this detector draws peaks (Figure 7) for each compound and the peak area is related to the number of moles of the component in the sample. The gas chromatograph is itself calibrated to determine the relationship between peaks areas and mole numbers, for each chemical species.




Figure 7: Chromatogram for two consecutive samples of a CO₂ and propane mixture

Prior to any COP measurement with a given mixture, a series of runs is performed only to generate a calibration or training set of spectra with known molar fractions and concentrations. Figure 8 shows pressure, temperature and concentration range used so far. Once the heat pump loop is stabilized, spectra are recorded and samples of the mixtures are taken and analysed by chromatography.

Note that the spectroscopic method deals with concentrations of the species while the chromatographic technique only gives access to molar fractions. Hence, the density of the fluid is necessary to relate these quantities. Densities are measured in our experiments by the Coriolis flowmeters. The concentrations of two components A and B are determined as follows:

$$[A] = (d \cdot x_A) / (x_A \cdot M_A + x_B \cdot M_B) \quad (1)$$

$$[B] = (d \cdot x_B) / (x_A \cdot M_A + x_B \cdot M_B) \quad (2)$$

where

[A] = concentration of A (mol/l), d = density (g/l), x = molar fraction (-), M = molar mass (g/mol)




Figure 8: 49 Samples considered for training set, with propane molar fractions from 0 to 0.266

To quickly assess the chemometric method, a first training set of spectra (Figure 8), with known concentrations, has been processed using the quantification software supplied with the NIR spectrometer. We plan to perform a more

specific treatment, using the open source R software. Then a real-time composition measurement tool will be developed. For now, the quantification software can be used to generate models for CO₂ and propane concentrations. To do so, the training set is fed to a Partial Least Square (PLS) algorithm, with a cross validation method. Results for the models generation are detailed in Table 2. A correlation coefficient (R) close to 1 shows the relevance of the spectral data to predict the concentrations.

Table 2: Regression main results

Properties [mol/l]	Squared correlation coefficient (R ²)	Standard error of estimation [mol/l]	Concentrations mean value [mol/l]	Standard error of prediction using cross validation [mol/l]
CO ₂ concentration	0.9986	0.234	7.2	0.317
Propane concentration	0.9893	0.158	1.6	0.202

This first training set shows encouraging results, as prediction of concentrations are reasonable (Figure 9). With more samples and with a more specific treatment of the data, the model should become more accurate. As for today, predictions seem more accurate with high values of concentration. So more precise measurements are expected with liquid phases.




Figure 9: Estimated versus specified concentrations of CO₂ and propane

6. CONCLUSIONS

Characterization of the heat pump has been carried out with pure CO₂. Then a first CO₂ + propane mixture has been introduced, and is currently used to calibrate the chemometric method. So far, the chemometric method shows promising results, and its accuracy should be improved with the amount of collected data. This method already allows us to relate the evolution of the performances to the measured circulating compositions.

This is a first step in a project aiming at the study of CO₂ based mixtures. The addition of little amounts of HFCs, hydrocarbons and other derivatives will be carried out and assessed. Obtained efficiencies will be compared to the pure CO₂ refrigerant cycle performance measured on this apparatus. Mixtures will be compared, based on annual performances in a typical house in different climates.

NOMENCLATURE

[A]	Concentration of A	(mol/l)
COP	Coefficient of Performance	(–)
d	Density	(kg/m ³)
M _A	Molar mass of A	(kg/mol)
x _A	Molar fraction of A	(–)

Subscript

CH	Central Heating
DHW	Domestic Hot Water
GWP	Global Warming Potential
HFC	Hydrofluorocarbon
HFO	Hydrofluoroolefin
PCR	Principal Components Regression
PLS	Partial Least Square
R-744	CO ₂ refrigerant
R-290	Propane refrigerant
TCD	Thermal Conductivity Detector

REFERENCES

- Charni, M., Terrier, M. F., Toubanc, C., Tremeac, B. (2013). Investigation of properties and compatibilities of POE oils/R-290 mixtures. *4th IIR Conference on Thermophysical Properties and Transfer Processes of Refrigerants*, Delft, The Netherlands.
- Clodic, D., Rached, W. (2004). Staged Evaporation System for Refrigerant Blends with Large Temperature Glide. *International Refrigeration and Air Conditioning Conference*. Paper 631.
- Dias, D. T., Medina, A. N., Baesso, M. L., Bento, A. C. (2002). The photoacoustic spectroscopy applied in the characterization of the cross-linking process in polymeric materials. *Brazilian Journal of Physics*, 32, 523-530.
- Du, K., Zhang, S., Xu, W., *et Al.* (2009). A study on the cycle characteristics of an auto-cascade refrigeration system. *Experimental Thermal and Fluid Science*, 33(2), 240-245.
- Kim, J H., Cho, J M., Lee, I H., Lee, J S., Kim, M S. (2007). Circulation concentration of CO₂/propane mixtures and the effect of their charge on the cooling performance in an air-conditioning system. *Int. J. Refrig.*, 30, 43-49.
- Kim, J H., Cho, J M., Kim, M S. (2008). Cooling performance of several CO₂/propane mixtures and glide matching with secondary heat transfer fluid. *Int. J. Refrig.* 31, 800-806.

- Kim, M H., Pettersen, J., Bullard, C W. (2004). Fundamental process and system design issues in CO₂ vapor compression systems. *Progress in Energy and Combustion Science* 30, 119-174.
- Meunier, F., Terrier, M F., Toublanc, C. (2005). Etude expérimentale de mélanges de fluides frigorigènes à base de dioxyde de carbone pour la climatisation automobile, *rapport final concernant le contrat passé entre l'ADEME et le CNAM, convention n°02.66.021 (Mars 2005)*, Paris, France.
- Onaka, Y., Miyara, A., Tsubaki, K., Koyama, S. (2008). Analysis of heat hump cycle using CO₂/DME mixture refrigerant. *International Refrigeration and Air Conditioning Conference*, Purdue.
- Secuianu, C., Feroiu, V., Geana, D. (2008). Phase behavior for carbon dioxide+ethanol system. *Journal of Supercritical Fluids*, 47, 109-116.
- Vicky, G., Niesen & James C. Rainwater. (1990). Critical locus (vapor + liquid) equilibria, and coexisting densities of carbon dioxide+propane at temperatures from 311 K to 361 K. *J. Chem. Thermodynamics*, 22, 777-795.
- Warmusa, K., Filzmoser, P. (2012). *Introduction to multivariate statistical analysis in chemometrics*, CRC Press.
- Zancan, C., et Al. (2002). Extraction of ginger oleoresin with CO₂ and co-solvents, *the Journal of Supercritical Fluids*, 24, 57-76