le c**nam**

Preliminary study of the impact of the filling level on the vaporization of water inside the channel of a smooth plate-type heat exchanger in the context of sorption chillers

Florine GIRAUD, Brice TREMEAC

CMGPCE - EA7341, CNAM, case 2D3P20, 292 rue Saint-Martin, 75141 Paris Cedex 03, France



Content

- Context and background of the study
- Results obtained from previous studies
- Objective of this study
- Experimental results
- Conclusions and Perspectives



Motivations:

- Few compact evaporators used in sorption systems
- Lack of fundamental knowledge about boiling and vaporization phenomena at such low pressure
- Unusual behavior of these evaporators due:
 - to the low vapor density
 - to the hydrostatic pressure

Bubble of centimeter size

Bubble observed inside the channel of the smooth plate-type evaporator at a working pressure of 1.3 kPa (working fluid: water)



 $5 \,\mathrm{cm}$

Influence of the hydrostatic pressure:

- Local pressure could be imposed by varying:
 - \checkmark The height of the liquid level
 - \checkmark The saturation pressure



Influence of the hydrostatic pressure:

- Both result in a non-homogeneity of the boiling environment in:
 - \checkmark pressure,
 - \checkmark saturation temperature,
 - \checkmark subcooling degree,
 - \checkmark subcooling gradient.



Evolution of the saturation temperature in the vessel for a given liquid column height



Influence of the hydrostatic pressure:

→ Impact on thermophysical properties, especially on:



Evolution of the saturation temperature in the vessel for a given liquid column height

Motivations:

✓ understand the behavior of compact plate-type heat exchanger
 ✓ design correctly such evaporators

Vaporization inside the channel of <u>a smooth plate-type evaporator:</u>

- ✓ Thermosyphon configuration
- ✓ Adsorption configuration

Local heat transfer coefficient Visualization <u>Plate-type evaporator behavior</u> <u>at the system scale</u>

Adsorption system of 5 kW (Zeolite 13X)



Experimental test set-up:



Drawing of the experimental setup

- Pump-assisted closedloop thermosyphon → simulate an absorption chiller with different driving pressures ΔP
- Mass flow controller F1 (control the liquid level in the evaporator)
- Given vapor quality at the evaporator inlet



Experimental test set-up:

ISHPC 2017



(C)-

Visualization:

- Bubbles collapse at the inlet of the plate (A)
- Bubbles appear about 5 cm below the free surface (B)
- Evaporation of the liquid film previously created by the (B)breaking of the large bubble (C)



Evaporation of the liquid film : More than 70% of the cooling capacity obtained





Phenomenology:

✓ High H_l means unfavorable condition to set the boiling on but a certain volume of water is needed to induce splashing of liquid up to a significant height



> There is an optimal filling ratio for given operating conditions



Objective of this study

Impact of the filling ratio on:

- \checkmark The evaporator performance
- \checkmark Phenomena observed

Experimental procedure:



Objective of this study

Impact of the filling ratio on:

- \checkmark The evaporator performance
- ✓ Phenomena observed

Experimental procedure:



✓
$$P_{sat}$$
 constant (= 7 mBar)
✓ H_l = 5:2.5:25 cm
✓ T_{fs} = 5:5:20 °C

→ change the superheated refrigerant area and the subcooled refrigerant area

Cooling capacity: No subcooled area 700 $T_{fs} = 20 \degree C$ $\Delta P_{mot} = 16.3 \text{ mBar}$ 600 500 . Q_{cool} (W) 400 300 $T_{fs} = 15$ °C $\Delta P_{mot} = 10.0 \text{ mBar}$ 200 100 0 10 20 30 H_l (cm) $T_{fs} = 10$ °C $T_{fs} = 5 °C$ $\Delta P_{mot} = 1.7 \text{ mBar}$ $\Delta P_{mot} = 5.2 \text{ mBar}$ **ISHPC 2017**



Cooling capacity:



- Increase of Q_{cool} with the increase of T_{fs}.
- For T_{fs} = 15 °C and
 T_{fs} = 20 °C, high influence
 of the filling ratio where
 the subcooling area is null.
- Appearance of highly unsteable phenomena when the subcooled refrigerant area is no null.





Frequency:



- Decrease of bubble frequency with the increase of H_l
- Increase of bubble frequency with the decrease of T_{fs}
- No significant change of trends with the occurrence of a subcooled area

Height up to which the liquid is plashed:



- Increase of H_{proj} with the increase of H_l up to a maximum
- No significant change of trends with the occurence of a subcooled area

ISHPC 2017

Frequency + Height up to which the liquid is plashed

Impact on the heat transfer coefficient



Heat transfer coefficient (falling film):



ISHPC2017 Tokyo



Heat transfer coefficient:





Height up to which the liquid is plashed:

Parameters impacting on the height up to which the liquid is splashed ?

- Location of the bubble

Relation between ΔH and H_{proj} quasi linear

- Volume of the bubble ?
- Growth velocity ?





Conclusions and Perspectives

We observed that:

- ✓ High influence of the filling ratio where the subcooling area is null for T_{fs} = 15 °C and T_{fs} = 20 °C
- \checkmark Impact of (1)-(2) on the cooling capacity

$$\checkmark \blacksquare H_{l} \twoheadrightarrow \left[\blacksquare H_{proj} \\ \backsim f_{bubble} \right]$$

➔ High fluctuations of the heat transfer coefficient



✓ Impact of ∆H on H_{proj}



Conclusions and Perspectives

 \rightarrow Further effort must be done in order to :

 \checkmark Understand phenomena observed



- ✓ Control the bubble frequency and the location of the bubble growth
- ✓ Control conditions to obtain the widest liquid film area

Thank you !



Global heat transfer coefficient





Global heat transfer coefficient



Height up to which the liquid is plashed:



Heat transfer coefficient



ISHPC2017 ATERADINAL SOFTIAL HEAVE CONTINUE Tokyo

Heat transfer coefficient





ISHPC 2017



Inertial effect



Giraud F. et al., 2017. Experimental study of water vaporization occurring inside the channel of a smooth-plate type heat exchanger connected to an adsorber and comparison with trends observed in absorption configuration. International Journal of Refrigeration. vol 77, p. 60-74.









