



HAL
open science

A tool for stability and power sharing analysis of a generalized class of droop controllers for high-voltage direct-current transmission systems

D. Zonetti, Roméo Ortega, J. Schiffer

► **To cite this version:**

D. Zonetti, Roméo Ortega, J. Schiffer. A tool for stability and power sharing analysis of a generalized class of droop controllers for high-voltage direct-current transmission systems. *IEEE Transactions on Control of Network Systems*, 2018, 5 (3), pp.1110-1119. 10.1109/tcns.2017.2687080 . hal-01895479

HAL Id: hal-01895479

<https://hal.science/hal-01895479>

Submitted on 17 Jun 2020

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

A tool for stability and power sharing analysis of a generalized class of droop controllers for high-voltage direct-current transmission systems

Daniele Zonetti, Romeo Ortega and Johannes Schiffer

Abstract—The problem of primary control of high-voltage direct current transmission systems is addressed in this paper, which contains four main contributions. First, to propose a new nonlinear, more realistic, model for the system suitable for primary control design, which takes into account nonlinearities introduced by conventional inner controllers. Second, to determine necessary conditions—dependent on some free controller tuning parameters—for the existence of equilibria. Third, to formulate additional (necessary) conditions for these equilibria to satisfy the power sharing constraints. Fourth, to establish conditions for stability of a given equilibrium point. The usefulness of the theoretical results is illustrated via numerical calculations on a four-terminal example.

I. INTRODUCTION

For its correct operation, high-voltage direct current (hvdc) transmission systems—like all electrical power systems—must satisfy a large set of different regulation objectives that are, typically, associated to the multiple time—scale behavior of the system. One way to deal with this issue, that prevails in practice, is the use of hierarchical control architectures [1]–[3]. Usually, at the top of this hierarchy, a centralized controller called *tertiary control*—based on power flow optimization algorithms (OPFs)—is in charge of providing the inner controllers with the operating point to which the system has to be driven, according to technical and economical constraints [1]. If the tertiary control had exact knowledge of such constraints and of the desired operating points of all terminals, then it would be able to formulate a nominal optimization problem and the lower level (also called *inner-loop*) controllers could operate under *nominal conditions*. However, such exact knowledge of all system parameters is impossible in practice, due to uncertainties and lack of information. Hence, the operating points generated by the tertiary controller may, in general, induce unsuitable *perturbed conditions*. To cope with this problem further control layers, termed *primary* and *secondary control*, are introduced. These take action—whenever a perturbation occurs—by promptly adjusting the references provided by the tertiary control in order to preserve properties that are essential for the correct and safe operation of the system. The present paper focuses on the primary control layer. Irrespectively

of the perturbation and in addition to ensuring stability, primary control has the task of preserving two fundamental criteria: a prespecified power distribution (the so-called *power sharing*) and keeping the terminal voltages near the nominal value [4]. Both objectives are usually achieved by an appropriate control of the dc voltage of one or more terminals at their point of interconnection with the hvdc network [2], [5], [6].

Clearly, a *sine qua non* requirement for the fulfillment of these objectives is the existence of a *stable equilibrium point* for the perturbed system. The ever increasing use of power electronic devices in modern electrical networks, in particular the presence of *constant power devices* (CPDs), induces a highly nonlinear behavior in the system—rendering the analysis of existence and stability of equilibria very complicated. Since linear, inherently stable, models, are usually employed for the description of primary control of dc grids [3], [6], [7], little attention has been paid to the issues of stability and existence of equilibria. This fundamental aspect of the problem has only recently attracted the attention of power systems researchers [8]–[10] who, similarly to the present work, invoke tools of nonlinear dynamic systems analysis, to deal with the intricacies of the actual nonlinear behavior.

The main contributions and the organization of the paper are as follows. Section II is dedicated to the formulation—under some reasonable assumptions—of a reduced, nonlinear model of an hvdc transmission system in closed-loop with standard *inner-loop* controllers. In Section III a further model simplification, which holds for a general class of dc systems with short lines configurations, is presented. A first implication is that both obtained models, which are *nonlinear*, may in general have no equilibria. Then, we consider a generalized class of primary controllers, that includes the special case of the ubiquitous *voltage droop control*, and establish necessary conditions on the control parameters for the existence of an equilibrium point. This is done in Section IV. An extension of this result to the problem of existence of equilibria that verify the power sharing property is carried out in Section V. A last contribution is provided in Section VI, with a (local) stability analysis of a *known* equilibrium point, based on Lyapunov’s first method. The usefulness of the theoretical results is illustrated with a numerical example in Section VII. We wrap-up the paper by drawing some conclusions and providing guidelines for future investigation.

D. Zonetti and R. Ortega are with the Laboratoire des Signaux et Systèmes, 3, rue Joliot Curie, 91192 Gif-sur-Yvette, France. daniele.zonetti@gmail.com, romeo.ortega@lss.supelec.fr

J. Schiffer is with the School of Electronic and Electrical Engineering, University of Leeds, Leeds LS2 9JT, UK, j.schiffer@leeds.ac.uk

Notation. For a set $\mathcal{N} = \{l, k, \dots, n\}$ of, possibly unordered, elements, we denote with $i \sim \mathcal{N}$ the elements $i = l, k, \dots, n$. All vectors are column vectors. Given positive integers n, m , the symbol $0_n \in \mathbb{R}^n$ denotes the vector of all zeros, $0_{n \times m}$ the $n \times m$ column matrix of all zeros, $1_n \in \mathbb{R}^n$ the vector with all ones and \mathbb{I}_n the $n \times n$ identity matrix. When clear from the context dimensions are omitted and vectors and matrices introduced above are simply denoted by the symbols 0, 1 or \mathbb{I} . For a given matrix A , the i -th column is denoted by A_i . Furthermore, $\text{diag}\{a_i\}$ is a diagonal matrix with entries $a_i \in \mathbb{R}$ and $\text{bdiag}\{A_i\}$ denotes a block diagonal matrix with matrix-entries A_i . $x := \text{col}(x_1, \dots, x_n) \in \mathbb{R}^n$ denotes a vector with entries $x_i \in \mathbb{R}$. When clear from the context it is simply referred to as $x := \text{col}(x_i)$.

II. NONLINEAR MODELING OF HVDC TRANSMISSION SYSTEMS

A. A graph description

The main components of an hvdc transmission system are ac to dc power converters and dc transmission lines. The power converters connect ac subsystems—that are associated to renewable generating units or to ac grids—to an hvdc network. In [11] it has been shown that an hvdc transmission system can be represented by a directed graph¹ without self-loops, where the power units—*i.e.* power converters and transmission lines—correspond to edges and the buses correspond to nodes. Hence, a first step towards the construction of a suitable model for primary control analysis and design is then the definition of an appropriate graph description of the system topology that takes into account the primary control action.

We consider an hvdc transmission system described by a graph $\mathcal{G}^\dagger(\mathcal{N}, \mathcal{E})$, where $n = c + 1$ is the number of nodes, where the additional node is used to model the ground node, and $m = c + t$ is the number of edges, with c and t denoting the number of converter and transmission units respectively. We implicitly assumed that transmission (interior) buses are eliminated via Kron reduction [12]. We further denote by p the number of converter units not equipped with primary control—termed *PQ units* hereafter—and by v the number of converter units equipped with primary control—that we call *voltage-controlled units*, with $c = p + v$. To facilitate reference to different units we find it convenient to partition the set of converter nodes (respectively converter edges) into two ordered subsets \mathcal{N}_P and \mathcal{N}_V (respectively \mathcal{E}_P and \mathcal{E}_V) corresponding to *PQ* and voltage-controlled nodes (respectively edges). The incidence matrix associated to the graph is given by:

$$\mathcal{B} = \begin{bmatrix} \mathbb{I}_p & 0 & \mathcal{B}_P \\ 0 & \mathbb{I}_v & \mathcal{B}_V \\ -1_p^\top & -1_v^\top & 0 \end{bmatrix} \in \mathbb{R}^{n \times m}, \quad (\text{II.1})$$

¹A directed graph is an ordered 3-tuple, $\mathcal{G}^\dagger = \{\mathcal{N}, \mathcal{E}, \Pi\}$, consisting of a finite set of nodes \mathcal{N} , a finite set of directed edges \mathcal{E} and a mapping Π from \mathcal{E} to the set of ordered pairs of \mathcal{N} .

where the submatrices $\mathcal{B}_P \in \mathbb{R}^{p \times t}$ and $\mathcal{B}_V \in \mathbb{R}^{v \times t}$ fully capture the topology of the hvdc network with respect to the different units.

B. Converter units

For a characterization of the converter units we consider power converters based on voltage source converter (VSC) technology [13]. Since this paper focuses on primary control, we first provide a description of a single VSC in closed-loop with the corresponding *inner-loop* controller. In hvdc transmission systems, the inner-loop controller is usually achieved via a cascaded control scheme consisting of a current control loop whose setpoints are specified by an outer power loop [14]. Moreover, such a control scheme employs a phase-locked-loop (PLL) circuit, which is a circuit that synchronizes an oscillator with a reference sinusoidal input [15]. The PLL is thus locked to the phase a of the voltage $v_{ac,i}(t)$ and allows, under the assumption of balanced operation of the phases, to express the model in a suitable dq reference frame, upon which the current and power loops are designed, see [16], [17] for more details on this topic. For these layers of control, different strategies can be employed in practice. Amongst these, a technique termed *vector control* that consists of combining feedback linearization and PI control is very popular, see [17]–[19] for an extensive overview on this control strategy. A schematic description of the VSC and of the overall control architecture, which also includes, if any, the primary control layer, is given in Fig. 1. As detailed above, the *inner-loop* control scheme is based on an appropriate dq representation of the ac-side dynamics of the VSC, which for balanced operating conditions is given by the following second order dynamical system [17]:

$$\begin{aligned} L_i \dot{I}_{d,i} &= -R_i I_{d,i} + L_i \omega_i I_{q,i} - d_{d,i} v_{C,i} + V_{d,i} \\ L_i \dot{I}_{q,i} &= -L_i \omega_i I_{d,i} - R_i I_{q,i} - d_{q,i} v_{C,i} + V_{q,i} \end{aligned} \quad (\text{II.2})$$

where $I_{d,i} \in \mathbb{R}$ and $I_{q,i} \in \mathbb{R}$ denote the direct and quadrature currents, $v_{C,i} \in \mathbb{R}_+$ denotes the dc voltage, $d_{d,i} \in \mathbb{R}$ and $d_{q,i} \in \mathbb{R}$ denote the direct and quadrature duty ratios, $V_{d,i} \in \mathbb{R}$ and $V_{q,i} \in \mathbb{R}$ denote the direct and quadrature input voltages, $L_i \in \mathbb{R}_+$ and $R_i \in \mathbb{R}_+$ denote the (balanced) inductance and the resistance respectively. Moreover, the dc voltage dynamics can be described by the following scalar dynamical system:

$$C_i \dot{v}_{C,i} = -G_i v_{C,i} + i_i + i_{C,i}, \quad i_i := d_{d,i} I_{d,i} + d_{q,i} I_{q,i}, \quad (\text{II.3})$$

where $i_{C,i} \in \mathbb{R}$ denotes the current coming from the dc network, i_i denotes the dc current injection via the VSC, $C_i \in \mathbb{R}_+$ and $G_i \in \mathbb{R}_+$ denote the capacitance and the conductance respectively. For a characterization of the power injections we consider the standard definitions of instantaneous active and reactive power associated to the ac-side of the VSC, which are given by [20], [21]:

$$P_i := V_{d,i} I_{d,i} + V_{q,i} I_{q,i}, \quad Q_i := V_{q,i} I_{d,i} - V_{d,i} I_{q,i}, \quad (\text{II.4})$$




Fig. 1: Control architecture of a three-phase voltage source converter that interfaces an ac subsystem—characterized by a three-phase input voltage $v_{ac,i}(t)$ —to an hvdc network—characterized by an ingoing dc current $i_{C,i}(t)$. Bold lines represent electrical connections, while dashed lines represent signal connections [16].

while the dc power associated to the dc-side is given by:

$$P_{DC,i} := v_{C,i} i_i. \quad (\text{II.5})$$

We now make two standard assumptions on the design of the *inner-loop* controllers.

Assumption 2.1: $V_{q,i} = V_{q,i}^* = 0, \quad \forall t \geq 0.$

Assumption 2.2: All *inner-loop* controllers are characterized by stable current control schemes. Moreover, the employed schemes guarantee instantaneous and exact tracking of the desired currents.

Assumption 2.1 can be legitimized by appropriate design of the PLL mechanism, which is demanded to fix the dq transformation angle so that the quadrature voltage is always kept zero after very small transients. Since a PLL usually operates in a range of a few ms , which is smaller than the time scale at which the power loop evolves, these transients can be neglected.

Similarly, Assumption 2.2 can be legitimized by an appropriate design of the current control scheme so that the resulting closed-loop system is internally stable and has a very large bandwidth compared to the dc voltage dynamics and to the outer loops. In fact, tracking of the currents is

usually achieved in $10 - 50 ms$, while dc voltage dynamics and outer loops evolve at a much slower time-scale [1].

Under Assumption 2.1 and Assumption 2.2, from the stationary equations of the currents dynamics expressed by (II.2), i.e. for $\dot{I}_{d,i}^* = 0, \dot{I}_{q,i}^* = 0$, we have that

$$\begin{aligned} d_{d,i}^* &= \frac{1}{v_{C,i}} (-R_i I_{d,i}^* + L_i \omega_i I_{q,i}^* + V_{d,i}^*), \\ d_{q,i}^* &= \frac{1}{v_{C,i}} (-L_i \omega_i I_{d,i}^* - R_i I_{q,i}^*), \end{aligned} \quad (\text{II.6})$$

where $I_{d,i}^*$ and $I_{q,i}^*$ denote the controlled dq currents (the dynamics of which are neglected under Assumption 2.2), while $V_{d,i}^*$ denotes the corresponding direct voltage on the ac-side of the VSC. By substituting (II.6) into (II.3) and recalling the definition of active power provided in (II.4), the controlled dc current can thus be expressed as

$$i_i^* = \frac{V_{d,i}^* I_{d,i}^* - R_i (I_{d,i}^*)^2 - R_i (I_{q,i}^*)^2}{v_{C,i}} = \frac{P_i^* - D_i^*}{v_{C,i}}, \quad (\text{II.7})$$

where

$$P_i^* := V_{d,i}^* I_{d,i}^*, \quad D_i^* := R_i [(I_{d,i}^*)^2 + (I_{q,i}^*)^2] \quad (\text{II.8})$$

denote respectively the controlled active power on the ac-side and the power dissipated internally by the converter. We then make a further assumption.

Assumption 2.3: $D_i^* = 0$.

Assumption 2.3 can be justified by the high efficiency of the converter, *i.e.* by the small values of the balanced three-phase resistance R , which yield $D_i^* \approx 0$. Hence, by replacing (II.7) into (II.3) and using the definitions (II.8), we obtain the following scalar dynamical system [21]:

$$C_i \dot{v}_{C,i} = -G_i v_{C,i} + \frac{V_{d,i}^*}{v_{C,i}} I_{d,i}^* + i_{C,i} \quad (\text{II.9})$$

with $i \sim \mathcal{E}_P \cup \mathcal{E}_V$, which describes the dc-side dynamics of a VSC under assumptions 2.1, 2.2 and 2.3. By taking (II.9) as a point of departure, we next derive the dynamics of the current-controlled VSCs in closed-loop with the outer power control.

If the unit is a *PQ unit*, the current references are simply determined by the outer power loop via (II.4) with constant active power P_j^{ref} and reactive power Q_j^{ref} , which by noting that $V_{q,j}^* = 0$, are given by:

$$I_{d,j}^* = \frac{P_j^{\text{ref}}}{V_{d,j}^*}, \quad I_{q,j}^* = -\frac{Q_j^{\text{ref}}}{V_{d,j}^*}, \quad (\text{II.10})$$

with $j \sim \mathcal{E}_P$, which replaced into (II.9) gives

$$C_j \dot{v}_{C,j} = -G_j v_{C,j} + u_j(v_{C,j}) + i_{C,j}. \quad (\text{II.11})$$

with the new current variable u_j and the dc voltage $v_{C,j}$ verifying the hyperbolic constraint $P_j^{\text{ref}} = v_{C,j} u_j$, $j \sim \mathcal{E}_P$. Hence, a *PQ unit* can be approximated, with respect to its power behavior, by a constant power device of value $P_{P,j}^{\text{ref}} := P_j^{\text{ref}}$, see also Fig. 2a. On the other hand, if the converter unit is a *voltage-controlled unit*, the current references are modified according to the primary control strategy. A common approach in this scenario is to introduce an additional deviation (also called *droop*) in the direct current reference—obtained from the outer power loop—as a function of the dc voltage, while keeping the calculation of the reference of the quadrature current unchanged:

$$I_{d,k}^* = \frac{P_k^{\text{ref}}}{V_{d,k}^*} + \delta_k(v_{C,k}), \quad I_{q,k}^* = -\frac{Q_k^{\text{ref}}}{V_{d,k}^*}, \quad (\text{II.12})$$

with $k \sim \mathcal{E}_V$ and where $\delta_k(v_{C,k})$ represents the state-dependent contribution provided by the primary control. We propose the primary control law:

$$\delta_k(v_{C,k}) = \frac{1}{V_{d,k}^*} (\mu_{P,k} + \mu_{I,k} v_{C,k} + \mu_{Z,k} v_{C,k}^2), \quad (\text{II.13})$$

with $k \sim \mathcal{E}_V$ and where $\mu_{P,k}, \mu_{I,k}, \mu_{Z,k} \in \mathbb{R}$ are free control parameters. By replacing (II.12)-(II.13) into (II.9), we obtain

$$C_k \dot{v}_{C,k} = -(G_k - \mu_{Z,k}) v_{C,k} + \mu_{I,k} + u_k(v_{C,k}) + i_{C,k}, \quad (\text{II.14})$$

with the new current variable u_k and the dc voltage $v_{C,k}$ verifying the hyperbolic constraint $P_k^{\text{ref}} + \mu_{P,k} = v_{C,k} u_k$, $k \sim \mathcal{E}_V$. Moreover, with Assumption 2.3 the injected dc

power is given by:

$$P_{DC,k}(v_{C,k}) = P_{V,k}^{\text{ref}} + \mu_{I,k} v_{C,k} + \mu_{Z,k} v_{C,k}^2, \quad (\text{II.15})$$

with

$$P_{V,k}^{\text{ref}} := P_k^{\text{ref}} + \mu_{P,k},$$

from which follows, with the control law (II.13), that a *voltage-controlled unit* can be approximated, with respect to its power behavior, by a ZIP model, *i.e.* the parallel connection of a constant impedance (Z), a constant current source/sink (I) and a constant power device (P). More precisely—see also Fig. 2b—the parameters $P_{V,k}^{\text{ref}}$, $\mu_{I,k}$ and $\mu_{Z,k}$ represent the constant power, constant current and constant impedance of the ZIP model. Finally, the dynamics of the *PQ units* can be represented by the following scalar systems:

$$\begin{aligned} C_j \dot{v}_{C,j} &= -G_j v_{C,j} + u_j + i_{C,j}, \\ 0 &= P_{P,j}^{\text{ref}} - v_{C,j} u_j, \end{aligned}$$

while for the dynamics of the *voltage-controlled units* we have:

$$\begin{aligned} C_k \dot{v}_{C,k} &= -(G_k - \mu_{Z,k}) v_{C,k} + \mu_{I,k} + u_k + i_{C,k}, \\ 0 &= P_{V,k}^{\text{ref}} - v_{C,k} u_k, \end{aligned}$$

with $j \sim \mathcal{E}_P, k \sim \mathcal{E}_V$ and where $v_{C,j}, v_{C,k} \in \mathbb{R}_+$ denote the voltages across the capacitors, $i_{C,j}, i_{C,k} \in \mathbb{R}$ denote the network currents, $u_j, u_k \in \mathbb{R}$ denote the currents flowing into the constant power devices, $G_j \in \mathbb{R}_+, G_k \in \mathbb{R}_+, C_j \in \mathbb{R}_+, C_k \in \mathbb{R}_+$ denote the conductances and capacitances. The aggregated model is then given by:

$$\begin{aligned} \begin{bmatrix} C_P \dot{v}_P \\ C_V \dot{v}_V \end{bmatrix} &= - \begin{bmatrix} G_P & 0 \\ 0 & G_V + G_Z \end{bmatrix} \begin{bmatrix} v_P \\ v_V \end{bmatrix} + \\ &+ \begin{bmatrix} u_P \\ u_V \end{bmatrix} + \begin{bmatrix} 0 \\ \bar{u}_V \end{bmatrix} + \begin{bmatrix} i_P \\ i_V \end{bmatrix}, \end{aligned} \quad (\text{II.16})$$

together with the algebraic constraints:

$$P_{P,j}^{\text{ref}} = v_{P,j} u_{P,j}, \quad P_{V,k}^{\text{ref}} = v_{V,k} u_{V,k},$$

with $i \sim \mathcal{E}_P, k \sim \mathcal{E}_V$ and the following definitions.

- State vectors

$$v_P := \text{col}(v_{C,j}) \in \mathbb{R}^P, \quad v_V := \text{col}(v_{C,k}) \in \mathbb{R}^V.$$

- Network ingoing currents

$$i_P := \text{col}(i_{C,j}) \in \mathbb{R}^P, \quad i_V := \text{col}(i_{C,k}) \in \mathbb{R}^V.$$

- Units ingoing currents

$$u_P := \text{col}(u_j) \in \mathbb{R}^P, \quad u_V := \text{col}(u_k) \in \mathbb{R}^V.$$


- External sources $\bar{u}_V := \text{col}(\mu_{I,k}) \in \mathbb{R}^V$.

- Matrices

$$\begin{aligned} C_P &:= \text{diag}\{C_j\} \in \mathbb{R}^{P \times P}, \quad C_V := \text{diag}\{C_k\} \in \mathbb{R}^{V \times V}, \\ G_P &:= \text{diag}\{G_j\} \in \mathbb{R}^{P \times P}, \quad G_V := \text{diag}\{G_k\} \in \mathbb{R}^{V \times V}, \\ G_Z &:= \text{diag}\{-\mu_{Z,k}\} \in \mathbb{R}^{V \times V}. \end{aligned}$$

C. Interconnected model

For the model derivation of the hvdc network we assume that the dc transmission lines can be described by standard,



(a) Equivalent circuit scheme for PQ units. (b) Equivalent circuit scheme for *voltage-controlled units*.

Fig. 2: Equivalent circuit schemes of the converter units with constant power devices (CPDs), under Assumption 2.2.

single-cell π -models. However, it should be noted that at each converter node the line capacitors will result in a parallel connection with the output capacitor of the converter [22]. Hence, the capacitors at the dc output of the converter can be replaced by equivalent capacitors and the transmission lines described by simpler RL circuits, for which it is straightforward to obtain the aggregated model [11]:

$$L_T \dot{i}_T = -R_T i_T + v_T, \quad (\text{II.17})$$

with $i_T := \text{col}(i_{T,i}) \in \mathbb{R}^t$, $v_T := \text{col}(v_{T,i}) \in \mathbb{R}^t$ denoting the currents through and the voltages across the lines and $L_T := \text{col}(L_{T,i}) \in \mathbb{R}^{t \times t}$, $R_T := \text{col}(R_{T,i}) \in \mathbb{R}^{t \times t}$ denoting the inductance and resistance matrices. In order to obtain the reduced, interconnected model of the hvdc transmission system under Assumption 2.2, we need to consider the interconnection laws determined by the incidence matrix (II.1). Let us define the node and edge vectors:

$$V_n := \begin{bmatrix} \mathcal{V}_P \\ \mathcal{V}_V \\ 0 \end{bmatrix} \in \mathbb{R}^{c+1}, \quad V_e := \begin{bmatrix} v_P \\ v_V \\ v_T \end{bmatrix} \in \mathbb{R}^m, \quad I_e := \begin{bmatrix} i_P \\ i_V \\ i_T \end{bmatrix} \in \mathbb{R}^m.$$

By using the definition of the incidence matrix (II.1) together with the Kirchhoff's current and voltage laws given by [23], [24]:

$$\mathcal{B} I_e = 0, \quad V_e = \mathcal{B}^\top V_n,$$

we obtain:

$$i_P = -\mathcal{B}_P v_P, \quad i_V = -\mathcal{B}_V v_V, \quad v_T = \mathcal{B}_P^\top v_P + \mathcal{B}_V^\top v_V. \quad (\text{II.18})$$

Replacing i_P and i_V in (II.16) and v_T in (II.17), leads to the interconnected model:

$$\begin{bmatrix} C_P \dot{v}_P \\ C_V \dot{v}_V \\ L_T \dot{i}_T \end{bmatrix} = \begin{bmatrix} -G_P & 0 & -\mathcal{B}_P \\ 0 & -G_V & -\mathcal{B}_V \\ \mathcal{B}_P^\top & \mathcal{B}_V^\top & -G_Z \end{bmatrix} \begin{bmatrix} v_P \\ v_V \\ i_T \end{bmatrix} + \begin{bmatrix} u_P \\ u_V \\ 0 \end{bmatrix} + \begin{bmatrix} 0 \\ \bar{u}_V \\ 0 \end{bmatrix}, \quad (\text{II.19})$$

together with the algebraic constraints:

$$P_{P,j}^{\text{ref}} = v_{P,j} u_{P,j}, \quad P_{V,k}^{\text{ref}} = v_{V,k} u_{V,k}, \quad (\text{II.20})$$

with $i \sim \mathcal{E}_P, k \sim \mathcal{E}_V$.

Remark 2.4: With the choice

$$\mu_{P,k} = 0, \quad \mu_{I,k} = d_k v_C^{\text{nom}}, \quad \mu_{Z,k} = -d_k,$$

the primary control (II.13) reduces to:

$$\delta_k(v_{C,k}) = -\frac{d_k}{V_{d,k}^*} (v_{C,k} - v_C^{\text{nom}}),$$

while the injected current is simply given by

$$i_k^* = \frac{V_{d,k}^*}{v_{C,k}} I_{d,k}^* = \frac{P_k^{\text{ref}}}{v_{C,k}} - d_k (v_C^{\text{nom}} - v_{C,k}),$$

with $k \sim \mathcal{E}_V$. This is exactly the conventional, widely diffused, voltage droop control [2], [6], [25], where d_k is called droop coefficient and v_C^{nom} is the nominal voltage of the hvdc system. The conventional droop control can be interpreted as an appropriate parallel connection of a current source with an impedance, which is put in parallel with a constant power device, thus resulting in a ZIP model. A similar model is encountered in [4] and should be contrasted with the models provided in [3], [7], where the contribution of the constant power device is absent.

Remark 2.5: A peculiarity of hvdc transmission systems with respect to generalized dc grids is the absence of traditional loads. Nevertheless, the aggregated model of the converter units (II.16) can be still employed for the modeling of dc grids with no loss of generality, under the assumption that loads can be represented either by PQ units (constant power loads) or by *voltage-controlled units* with assigned parameters (ZIP loads). This model should be contrasted with the linear models adopted in [3], [7] for dc grids, where loads are modeled as constant current sinks.

III. A REDUCED MODEL FOR GENERAL DC SYSTEMS WITH SHORT LINES CONFIGURATIONS

Since hvdc transmission systems are usually characterized by very long, *i.e.* dominantly inductive, transmission lines, there is no clear time-scale separation between the dynamics of the power converters and the dynamics of the hvdc network. This fact should be contrasted with traditional

power systems—where a time-scale separation typically holds because of the very slow dynamics of generation and loads compared to those of transmission lines [26]—and microgrids—where a time-scale separation is justified by the short length, and consequently fast dynamics, of the lines [27]. Nevertheless, as mentioned in Remark 2.5, the model (II.19)-(II.20) is suitable for the description of a very general class of dc grids. By taking this model as a point of departure, we thus introduce a reduced model that is particularly appropriate for the description of a special class of dc grids, *i.e.* dc grids with short lines configurations. This class includes, among the others, the widely popular case of dc microgrids [28] and the case of hvdc transmission systems with back-to-back configurations [29]. For these configurations, we can then make the following assumption.

Assumption 3.1: The dynamics of the dc transmission lines evolve on a time-scale that is much faster than the time-scale at which the dynamics of the voltage capacitors evolve.

Under Assumption 3.1, (II.17) reduces to:

$$i_T \equiv i_T^* = G_T v_T, \quad (\text{III.1})$$

where i_T^* is the steady-state vector of the line currents and $G_T := R_T^{-1}$ the conductance matrix of the transmission lines. By replacing the expression (III.1) into (II.19) we finally obtain:

$$\begin{aligned} \begin{bmatrix} C_P \dot{v}_P \\ C_V \dot{v}_V \end{bmatrix} &= - \begin{bmatrix} \mathcal{L}_P + G_P & \mathcal{L}_m \\ \mathcal{L}_m^\top & \mathcal{L}_V + G_V + G_Z \end{bmatrix} \begin{bmatrix} v_P \\ v_V \end{bmatrix} + \\ &+ \begin{bmatrix} u_P \\ u_V \end{bmatrix} + \begin{bmatrix} 0 \\ \bar{u}_V \end{bmatrix}, \end{aligned} \quad (\text{III.2})$$

together with the algebraic constraints (II.20) and where we defined

$$\mathcal{L}_P := \mathcal{B}_P G_L \mathcal{B}_P^\top, \quad \mathcal{L}_m := \mathcal{B}_P G_L \mathcal{B}_V^\top, \quad \mathcal{L}_V := \mathcal{B}_V G_L \mathcal{B}_V^\top.$$

Remark 3.2: The matrix:

$$\mathcal{L} := \begin{bmatrix} \mathcal{L}_P & \mathcal{L}_m \\ \mathcal{L}_m^\top & \mathcal{L}_V \end{bmatrix} \in \mathbb{R}^{c \times c}$$

is the Laplacian matrix associated to the weighted undirected graph $\bar{\mathcal{G}}^w$, obtained from the (unweighted directed) graph \mathcal{G}^\dagger that describes the hvdc transmission system by: 1) eliminating the reference node and all edges connected to it; 2) assigning as weights of the edges corresponding to transmission lines the values of their conductances. Similar definitions are also encountered in [3], [7].

IV. CONDITIONS FOR EXISTENCE OF AN EQUILIBRIUM POINT

From an electrical point of view, the reduced system (II.19)-(II.20) is a linear *RLC* circuit, where at each node a constant power device is attached. It has been observed in experiments and simulations that the presence of constant power devices may seriously affect the dynamics of these circuits hindering the achievement of a constant, stable behavior of the state variables—the dc voltages in the present

case [10], [30]–[32]. A first objective is thus to determine conditions on the free control parameters of the system (II.19)-(II.20) for the existence of an equilibrium point. Before presenting the main result of this section, we make an important observation: since the steady-state of the system (II.19)-(II.20) is equivalent to the steady-state of the system (III.2)-(II.20), the analysis of existence of an equilibrium point follows *verbatim*. Based on this consideration, in the present section we will only consider the system (III.2)-(II.20), bearing in mind the the same results hold for the system (II.19)-(II.20). To simplify the notation, we define

$$\begin{aligned} P_P^{\text{ref}} &:= \text{col}(P_{P,j}^{\text{ref}}) \in \mathbb{R}^p, & R_P &:= \mathcal{L}_P + G_P \in \mathbb{R}^{p \times p}, \\ P_V^{\text{ref}} &:= \text{col}(P_{V,k}^{\text{ref}}) \in \mathbb{R}^v, & R_V &:= \mathcal{L}_V + G_V + G_Z \in \mathbb{R}^{v \times v}. \end{aligned} \quad (\text{IV.1})$$

Furthermore, we recall the following lemma, the proof of which can be found in [10].

Lemma 4.1: Consider m quadratic equations of the form $f_i : \mathbb{R}^n \rightarrow \mathbb{R}$,

$$f_i(x) := \frac{1}{2} x^\top \mathcal{A}_i x + x^\top \mathcal{B}_i, \quad i \in [1, m], \quad (\text{IV.2})$$

where $\mathcal{A}_i = \mathcal{A}_i^\top \in \mathbb{R}^{n \times n}$, $\mathcal{B}_i \in \mathbb{R}^n$, $c_i \in \mathbb{R}$ and define:

$$\mathcal{A}(T) := \sum_{i=1}^m t_i \mathcal{A}_i, \quad \mathcal{B}(T) := \sum_{i=1}^m t_i \mathcal{B}_i, \quad \mathcal{C}(T) := \sum_{i=1}^m t_i c_i.$$

If the following LMI

$$\Upsilon(T) := \begin{bmatrix} \mathcal{A}(T) & \mathcal{B}(T) \\ \mathcal{B}^\top(T) & -2\mathcal{C}(T) \end{bmatrix} > 0,$$

is feasible, then the equations

$$f_i(x) = c_i, \quad i \in [1, m], \quad (\text{IV.3})$$

have no solution.

We are now ready to formulate the following proposition, that establishes necessary, control parameter-dependent, conditions for the existence of equilibria of the system (III.2)-(II.20).

Proposition 4.2: Consider the system (III.2)-(II.20), for some given $P_P^{\text{ref}} \in \mathbb{R}^p$, $P_V^{\text{ref}} \in \mathbb{R}^v$. Suppose that there exist two diagonal matrices $T_P \in \mathbb{R}^{p \times p}$ and $T_V \in \mathbb{R}^{v \times v}$ such that:

$$\Upsilon(T_P, T_V) > 0, \quad (\text{IV.4})$$

with

$$\Upsilon := \begin{bmatrix} T_P R_P + R_P T_P & T_P \mathcal{L}_m + \mathcal{L}_m^\top T_V & 0 \\ * & T_V R_V + R_V T_V & -T_V \bar{u}_V \\ * & * & -2(1_p^\top T_P P_P^{\text{ref}} + 1_v^\top T_V P_V^{\text{ref}}) \end{bmatrix},$$

where P_P^* , P_V^* , R_P and R_V are defined in (IV.1). Then the system (III.2)-(II.20) does not admit an equilibrium point.

Proof: First of all, by setting the left-hand of the differential equations in (III.2) to zero and using (IV.1), we have:

$$\begin{aligned} 0 &= -R_P v_P^* - \mathcal{L}_m v_V^* + u_P^*, \\ 0 &= -\mathcal{L}_m^\top v_P^* - R_V v_V^* + u_V^* + \bar{u}_V. \end{aligned}$$

Left-multiplying the first and second set of equations by $v_{P,j}^*$ and $v_{V,k}^*$ respectively, with $j \sim \mathcal{E}_P$, $k \sim \mathcal{E}_V$, we get

$$\begin{aligned} P_{P,j}^{\text{ref}} &= v_{P,j}^* R_{P,j}^\top v_P^* + v_{P,j}^* \mathcal{L}_{m,j}^\top v_V^*, \\ P_{V,k}^{\text{ref}} &= v_{V,k}^* \mathcal{L}_{m,k} v_P^* + v_{V,k}^* R_{V,k}^\top v_V^* - v_{V,k}^* \bar{u}_{V,k}, \end{aligned}$$

which, after some manipulations, gives

$$c_i = \frac{1}{2} (v^*)^\top \mathcal{A}_i v^* + (v^*)^\top \mathcal{B}_i, \quad (\text{IV.5})$$

with $i \sim \mathcal{E}_P \cup \mathcal{E}_V$, $v^* := \text{col}(v_P^*, v_V^*) \in \mathbb{R}^c$ and

$$\begin{aligned} \mathcal{A}_i &:= e_i e_i^\top \begin{bmatrix} R_P & \mathcal{L}_m \\ \mathcal{L}_m^\top & R_V \end{bmatrix} + \begin{bmatrix} R_P & \mathcal{L}_m^\top \\ \mathcal{L}_m & R_V \end{bmatrix} e_i e_i^\top, \\ \mathcal{B}_i &:= e_i e_i^\top \begin{bmatrix} 0 \\ \bar{u}_V \end{bmatrix}, \quad c_i := e_i^\top \begin{bmatrix} P_P^{\text{ref}} \\ P_V^{\text{ref}} \end{bmatrix}. \end{aligned}$$

Let consider the map $f(v^*) : \mathbb{R}^c \rightarrow \mathbb{R}^c$ with components

$$f_i(v^*) = \frac{1}{2} (v^*)^\top \mathcal{A}_i v^*,$$

with $i \sim \mathcal{E}_P \cup \mathcal{E}_V$ and denote by F the image of \mathbb{R}^c under this map. The problem of solvability of such equations can be formulated as in Lemma 4.1, *i.e.* if the LMI (IV.4) holds, then $\text{col}(c_i^*)$ is not in F , thus completing the proof. ■

Remark 4.3: Note that the feasibility of the LMI (IV.4) depends on the system topology reflected in the Laplacian matrix \mathcal{L} and on the system parameters, among which G_Z , \bar{u}_V and P_V^{ref} are free (primary) control parameters. Since the feasibility condition is only necessary for the existence of equilibria for (II.19), it is of interest to determine regions for these parameters that imply non-existence of an equilibrium point.

V. CONDITIONS FOR POWER SHARING

As already discussed, another control objective of primary control is the achievement of *power sharing* among the *voltage-controlled units*. This property consists in guaranteeing an appropriate (proportional) power distribution among these units in steady-state. We next show that is possible to reformulate such a control objective as a set of quadratic constraints on the equilibrium point, assuming that it exists. Since it is a steady-state property, the same observation done in Section IV applies, which means that the results obtained for the system (III.2)-(II.20) also hold for the system (II.19)-(II.20). We introduce the following definition.

Definition 5.1: Let be $v^* := (v_P^*, v_V^*) \in \mathbb{R}^c$ an equilibrium point for the system (III.2)-(II.20), $P_{\text{DC},V}(v^*) := \text{col}(P_{\text{DC},k}(v_{C,k}^*)) \in \mathbb{R}^v$ the collection of injected powers as defined by (II.15) and $\Gamma := \text{diag}\{\gamma_k\} \in \mathbb{R}^{v \times v}$, a positive definite matrix. Then v^* is said to possess the power sharing property with respect to Γ if:

$$\Gamma P_{\text{DC},V}(v^*) = \mathbf{1}_v. \quad (\text{V.1})$$

Then we have the following lemma.

Lemma 5.2: Let $v^* = (v_P^*, v_V^*) \in \mathbb{R}^c$ be an equilibrium point for (III.2)-(II.20) and $\Gamma := \text{diag}\{\gamma_k\} \in \mathbb{R}^{v \times v}$ a positive

definite matrix. Then v^* possesses the power sharing property with respect to Γ if and only if the quadratic equations

$$\frac{1}{2} (v^*)^\top \mathcal{A}_k^{\text{ps}} v^* + (\mathcal{B}_k^{\text{ps}})^\top v^* = p_k^{\text{ps}}, \quad (\text{V.2})$$

with $k \sim \mathcal{E}_V$ and where:

$$\begin{aligned} \mathcal{A}_k^{\text{ps}} &:= 2 \begin{bmatrix} 0 & 0 \\ 0 & \Gamma G_Z \end{bmatrix} e_k e_k^\top, \quad \mathcal{B}_k^{\text{ps}} := \begin{bmatrix} 0 \\ \Gamma \bar{u}_V \end{bmatrix} e_k e_k^\top, \\ p_k^{\text{ps}} &:= e_k^\top \begin{bmatrix} 0 \\ \Gamma P_V^{\text{ref}} \end{bmatrix} \end{aligned}$$

admit a solution.

Proof: From (V.1) we have that by definition:

$$\gamma_k P_{\text{DC},k}^{\text{ref}}(v_{C,k}) = 1,$$

with $k \sim \mathcal{E}_V$, which by recalling (II.15), is equivalent to:

$$\gamma_k (P_{V,k}^{\text{ref}} + \mu_{I,k} v_{C,k} + \mu_{Z,k} v_{C,k}^2) = 1.$$

After some straightforward manipulations, the above equalities can be rewritten as (V.2), completing the proof. ■

An immediate implication of this lemma is given in the following proposition, which establishes necessary conditions for the existence of an equilibrium point that verifies the power sharing property.

Proposition 5.3: Consider the system (III.2)-(II.20), for some given P_P^{ref} , P_V^{ref} and Γ . Suppose that there exist three diagonal matrices $T_P \in \mathbb{R}^{p \times p}$, $T_V \in \mathbb{R}^{v \times v}$, $T_V^{\text{ps}} \in \mathbb{R}^{v \times v}$, such that:

$$\Upsilon(T_P, T_V) + \Upsilon_{\text{ps}}(T_V^{\text{ps}}) > 0, \quad (\text{V.3})$$

with

$$\Upsilon_{\text{ps}} := \begin{bmatrix} 0 & 0 & 0 \\ \star & 2T_V^{\text{ps}} \Gamma G_Z & T_V^{\text{ps}} \Gamma \bar{u}_V \\ \star & \star & -2T_V^{\text{ps}} (\mathbf{1}_v - \Gamma P_V^{\text{ref}}) \end{bmatrix}.$$

Then the system (III.2)-(II.20) does not admit an equilibrium point that verifies the power sharing property.

Proof: The proof is similar to the proof of Proposition 4.2. By using Lemma 5.2 the power sharing constraints can be indeed rewritten as quadratic equations, similarly to (IV.5). Hence, it suffices to apply Lemma 4.1 to the quadratic equations (IV.5), (V.2) to complete the proof. ■

VI. CONDITIONS FOR LOCAL ASYMPTOTIC STABILITY

We now present a result on stability of a given equilibrium point for the system (II.19)-(II.20). The result is obtained by applying Lyapunov's first method.

Proposition 6.1: Consider the system (II.19)-(II.20) and assume that $v^* = (v_P^*, v_V^*, i_T^*) \in \mathbb{R}^m$ is an equilibrium point. Let

$$\begin{aligned} G_P^* &:= \text{diag} \left\{ \frac{P_{P,j}^{\text{ref}}}{(v_{P,j}^*)^2} \right\} \in \mathbb{R}^{p \times p}, \\ G_V^* &:= \text{diag} \left\{ \frac{P_{V,k}^{\text{ref}}}{(v_{V,k}^*)^2} \right\} \in \mathbb{R}^{v \times v}, \end{aligned} \quad (\text{VI.1})$$

and

$$J(v^*) := - \begin{bmatrix} -C_P^{-1}(G_P + G_P^*) & 0 & -C_P^{-1}\mathcal{B}_P \\ 0 & -C_V^{-1}(G_V + G_V^*) & -C_V^{-1}\mathcal{B}_V \\ L_T^{-1}\mathcal{B}_P^\top & L_T^{-1}\mathcal{B}_V^\top & -L_T^{-1}R_T \end{bmatrix}.$$

Then if:

- all eigenvalues λ_i of J are such that

$$\Re\{\lambda_i [J(v^*)]\} < 0,$$

the equilibrium point v^* is locally asymptotically stable;

- there exists at least one eigenvalue λ_i of J such that

$$\Re\{\lambda_i [J(v^*)]\} > 0,$$

the equilibrium point v^* is unstable.

Proof: The first-order approximation of the system (II.19)-(II.20) around v^* is given by:

$$\begin{aligned} \begin{bmatrix} C_P \dot{v}_P \\ C_V \dot{v}_V \\ L_T \dot{i}_T \end{bmatrix} &= \begin{bmatrix} -G_P & 0 & -\mathcal{B}_P \\ 0 & -G_V & -\mathcal{B}_V \\ \mathcal{B}_P^\top & \mathcal{B}_V^\top & -R_T \end{bmatrix} \begin{bmatrix} v_P \\ v_V \\ i_T \end{bmatrix} + \\ &+ \begin{bmatrix} \frac{\partial i_P}{\partial v_P} \Big|_{v^*} & 0 & 0 \\ 0 & \frac{\partial i_V}{\partial v_V} \Big|_{v^*} & 0 \\ 0 & 0 & 0 \end{bmatrix} \begin{bmatrix} v_P \\ v_V \\ i_T \end{bmatrix} \end{aligned} \quad (\text{VI.2})$$

Differentiating (II.20) with respect to v_P, v_V , yields:

$$\begin{aligned} 0_{p \times p} &= \frac{\partial i_P}{\partial v_P} \cdot \text{diag}\{v_{P,j}\} + \text{diag}\{i_{P,j}\}, \\ 0_{v \times v} &= \frac{\partial i_V}{\partial v_V} \cdot \text{diag}\{v_{V,k}\} + \text{diag}\{i_{V,k}\}. \end{aligned}$$

By using (VI.1), it follows that

$$\frac{\partial i_P}{\partial v_P} \Big|_{v^*} = -G_P^*, \quad \frac{\partial i_V}{\partial v_V} \Big|_{v^*} = -G_V^*.$$

The proof is completed by replacing into (VI.2) and invoking Lyapunov's first method. ■

VII. AN ILLUSTRATIVE EXAMPLE

In order to validate the results on existence of equilibria and power sharing for the system (II.19)-(II.20) we next provide an illustrative example. Namely, we consider the four-terminal hvdc transmission system depicted in Fig. 3, the parameters of which are given in Table I.

Since $c = t = 4$, the graph associated to the hvdc system has $n = 4 + 1 = 5$ nodes and $m = 4 + 4 = 8$ edges. We then make the following assumptions.

- Terminal 1 and Terminal 3 are equipped with primary control, from which it follows that there are $p = 2$ PQ units and $v = 2$ voltage-controlled units. More precisely we take

$$\delta_k(v_{C,k}) = -\frac{d_k}{V_{d,k}^*} (v_{C,k} - v_C^{\text{nom}}), \quad k = \{1, 3\}.$$

This is the well-known *voltage droop control*, where d_k is a free control parameter, while v_C^{nom} is the nominal voltage of the hvdc system, see also Remark 2.4.

- The power has to be shared equally among terminal 1 and terminal 3, from which it follows that $\Gamma = \mathbb{I}_2$ in Definition 5.1.




Fig. 3: Four-terminal hvdc transmission system.




Fig. 4: Feasibility regions of the LMI (IV.4) on the plane (d_1, d_3) of droop control parameters. Regions are yellow-coloured if the LMI is feasible and blue-coloured if the LMI is unfeasible.

The next results are obtained by investigating the feasibility of the LMIs (IV.4), (V.3) as a function of the free control parameters d_1 and d_3 . For this purpose, CVX, a package for specifying and solving convex programs, has been used to solve the semidefinite programming feasibility problem [33]. By using a gridding approach, the regions of the (positive) parameters that guarantee feasibility (yellow) and unfeasibility (blue) of the LMI (IV.4) are shown in Fig. 4, while in Fig. 5 the same is done with respect to the LMI (V.3). We deduce that a necessary condition for the existence of an equilibrium point is that the control parameters are chosen inside the blue region of Fig. 4. Similarly, a necessary condition for the existence of an equilibrium point that further possesses the power sharing property is that the control parameters are chosen inside the blue region of Fig. 5.

VIII. CONCLUSIONS AND FUTURE WORKS

In this paper, a new nonlinear model for primary control analysis and design has been derived. Primary control laws

TABLE I: System parameters.

	Value		Value		Value		Value		Value
G_i	$0 \Omega^{-1}$	$P_{V,1}^*$	30 MW	$P_{P,2}^*$	-20 MW	$P_{V,3}^*$	9 MW	$P_{P,4}^*$	-24 MW
C_i	$20 \mu\text{F}$	G_{12}	$0.1 \Omega^{-1}$	G_{14}	$0.15 \Omega^{-1}$	G_{23}	$0.11 \Omega^{-1}$	G_{24}	$0.08 \Omega^{-1}$




Fig. 5: Feasibility regions of the LMI (V.3) on the plane (d_1, d_3) of droop control parameters. Regions are yellow-coloured if the LMI is feasible and blue-coloured if the LMI is unfeasible.

are described by equivalent ZIP models, which include the standard voltage droop control as a special case. A necessary condition for the existence of equilibria in the form of an LMI—which depends on the parameters of the controllers—is established, thus showing that an inappropriate choice of the latter may lead to non-existence of equilibria for the closed-loop system. The same approach is extended to the problem of existence of equilibria that verify a pre-specified power sharing property. The obtained necessary conditions can be helpful to system operators to tune their controllers such that regions where the closed-loop system will definitely not admit a stationary operating point are excluded. In that regard, the present paper is a first, fundamental stepping stone towards the development of a better understanding of how existence of stationary solutions of hvdc systems are affected by the system parameters, in particular the network impedances and controller gains. A final contribution consists in the establishment of conditions of local asymptotic stability of a given equilibrium point. The obtained results are illustrated on a four-terminal example.

Starting from the obtained model, future research will concern various aspects. First of all, a better understanding of how the feasibility of the LMIs are affected by the parameters is necessary. A first consideration is that the established conditions, besides on the controllers parameters, also depends on the network topology and the dissipation via the Laplacian matrix induced by the electrical network. This suggests that the location of the *voltage-controlled units*, as well as the network impedances, play an important role on the existence of equilibria for the system. Similarly, it is of interest to understand in which measure the values of

Z, I and P components of the equivalent ZIP mode affect the LMIs, in order to provide guidelines for the design of primary controllers. Furthermore, the possibility to combine the obtained necessary conditions with related (sufficient) conditions from the literature, *e.g.* in [34], is very interesting and timely. Other possible developments will focus on the establishment of necessary (possibly sufficient) conditions for the existence of equilibria in different scenarios: small deviations from the nominal voltage [4], [9]; power unit outages [4]; linear three-phase, ac circuit, investigating the role played by reactive power [32].

IX. ACKNOWLEDGMENTS

The authors acknowledge the support of: the Future Renewable Electric Energy Distribution Management Center (FREEDM), a National Science Foundation supported Engineering Research Center, under grant NSF EEC-0812121; the Ministry of Education and Science of Russian Federation (Project14.Z50.31.0031); the European Union’s Horizon 2020 research and innovation programme under the Marie Skłodowska-Curie grant agreement No. 734832.

REFERENCES

- [1] A. Egea-Alvarez, J. Beerten, D. V. Hertem, and O. Gomis-Bellmunt, “Hierarchical power control of multiterminal HVDC grids,” *Electric Power Systems Research*, vol. 121, pp. 207 – 215, 2015.
- [2] T. K. Vrana, J. Beerten, R. Belmans, and O. B. Fosso, “A classification of DC node voltage control methods for HVDC grids,” *Electric Power Systems Research*, vol. 103, pp. 137 – 144, 2013.
- [3] M. Andreasson, M. Nazari, D. V. Dimarogonas, H. Sandberg, K. H. Johansson, and M. Ghandhari, “Distributed voltage and current control of multi-terminal high-voltage direct current transmission systems,” *IFAC Proceedings Volumes*, vol. 47, no. 3, pp. 11910–11916, 2014.
- [4] J. Beerten and R. Belmans, “Analysis of power sharing and voltage deviations in droop-controlled DC grids,” *Power Systems, IEEE Transactions on*, vol. 28, no. 4, pp. 4588 – 4597, 2013.
- [5] S. Shah, R. Hassan, and J. Sun, “HVDC transmission system architectures and control - a review,” in *Control and Modeling for Power Electronics, 2013 IEEE 14th Workshop on*, pp. 1–8, June 2013.
- [6] T. Haileselassie, T. Undeland, and K. Uhlen, “Multiterminal HVDC for offshore windfarms – control strategy,” European Power Electronics and Drives Association, 2009.
- [7] J. Zhao and F. Dorfler, “Distributed control and optimization in DC microgrids,” *Automatica*, vol. 61, pp. 18 – 26, 2015.
- [8] N. Monshizadeh, C. D. Persis, A. van der Schaft, and J. M. A. Scherpen, “A networked reduced model for electrical networks with constant power loads,” *CoRR*, vol. abs/1512.08250, 2015.
- [9] J. W. Simpson-Porco, F. Dörfler, and F. Bullo, “On resistive networks of constant-power devices,” *Circuits and Systems II: Express Briefs, IEEE Transactions on*, vol. 62, pp. 811–815, Aug 2015.
- [10] N. Barabanov, R. Ortega, R. Grino, and B. Polyak, “On existence and stability of equilibria of linear time-invariant systems with constant power loads,” *Circuits and Systems I: Regular Papers, IEEE Transactions on*, vol. PP, no. 99, pp. 1–8, 2015.
- [11] D. Zonetti, R. Ortega, and A. Benchaib, “Modeling and control of HVDC transmission systems from theory to practice and back,” *Control Engineering Practice*, vol. 45, pp. 133 – 146, 2015.
- [12] F. Dörfler and F. Bullo, “Kron reduction of graphs with applications to electrical networks,” *IEEE Transactions on Circuits and Systems I: Regular Papers*, vol. 60, no. 1, pp. 150–163, 2013.

- [13] A. Yazdani and R. Iravani, *Voltage-Sourced Controlled Power Converters – Modeling, Control and Applications*. Wiley IEEE, 2010.
- [14] C. Stijn, *Steady-state and dynamic modelling of VSC HVDC systems for power system Simulation*. PhD thesis, PhD dissertation, Katholieke University Leuven, Belgium, 2010.
- [15] R. Best, *Phase-Locked Loops*. Professional Engineering, Mcgraw-hill, 2003.
- [16] D. Zonetti, *Energy-based modelling and control of electric power systems with guaranteed stability properties*. PhD thesis, Université Paris-Saclay, 2016.
- [17] V. Blasko and V. Kaura, “A new mathematical model and control of a three-phase ac-dc voltage source converter,” *IEEE Transactions on Power Electronics*, vol. 12, pp. 116–123, Jan 1997.
- [18] L. Xu, B. Andersen, and P. Cartwright, “Control of vsc transmission systems under unbalanced network conditions,” in *Transmission and Distribution Conference and Exposition, 2003 IEEE PES*, vol. 2, pp. 626–632 vol.2, Sept 2003.
- [19] T. Lee, “Input-output linearization and zero-dynamics control of three-phase AC/DC voltage-source converters,” *IEEE Transactions on Power Electronics*, vol. 18, pp. 11–22, Jan 2003.
- [20] H. Akagi, *Instantaneous Power Theory and Applications to Power Conditioning*. Newark: Wiley, 2007.
- [21] R. Teodorescu, M. Liserre, and P. Rodríguez, *Grid Converters for Photovoltaic and Wind Power Systems*. John Wiley and Sons, Ltd, 2011.
- [22] S. Fiaz, D. Zonetti, R. Ortega, J. Scherpen, and A. van der Schaft, “A port-Hamiltonian approach to power network modeling and analysis,” *European Journal of Control*, vol. 19, no. 6, pp. 477 – 485, 2013.
- [23] A. van der Schaft, “Characterization and partial synthesis of the behavior of resistive circuits at their terminals,” *Systems & Control Letters*, vol. 59, no. 7, pp. 423 – 428, 2010.
- [24] S. Fiaz, D. Zonetti, R. Ortega, J. Scherpen, and A. van der Schaft, “A port-Hamiltonian approach to power network modeling and analysis,” *European Journal of Control*, vol. 19, no. 6, pp. 477 – 485, 2013.
- [25] E. Prieto-Araujo, F. Bianchi, A. Junyent-Ferré, and O. Gomis-Bellmunt, “Methodology for droop control dynamic analysis of multiterminal vsc-hvdc grids for offshore wind farms,” *Power Delivery, IEEE Transactions on*, vol. 26, pp. 2476–2485, Oct 2011.
- [26] P. Sauer, “Time-scale features and their applications in electric power system dynamic modeling and analysis,” in *American Control Conference (ACC), 2011*, pp. 4155–4159, June 2011.
- [27] J. Schiffer, D. Zonetti, R. Ortega, A. M. Stanković, T. Sezi, and J. Raisch, “A survey on modeling of microgrids—from fundamental physics to phasors and voltage sources,” *Automatica*, vol. 74, pp. 135–150, 2016.
- [28] Y. Ito, Y. Zhongqing, and H. Akagi, “DC microgrid based distribution power generation system,” in *Power Electronics and Motion Control Conference, 2004. IPEMC 2004. The 4th International*, vol. 3, pp. 1740–1745, IEEE, 2004.
- [29] M. Bucher, R. Wiget, G. Andersson, and C. Franck, “Multiterminal HVDC Networks – what is the preferred topology?,” *Power Delivery, IEEE Transactions on*, vol. 29, pp. 406–413, Feb 2014.
- [30] M. Belkhat, R. Cooley, and A. Witulski, “Large signal stability criteria for distributed systems with constant power loads,” in *Power Electronics Specialists Conference, 1995. PESC '95 Record., 26th Annual IEEE*, vol. 2, pp. 1333–1338 vol.2, Jun 1995.
- [31] A. Kwasinski and C. N. Onwuchekwa, “Dynamic behavior and stabilization of DC microgrids with instantaneous constant-power loads,” *Power Electronics, IEEE Transactions on*, vol. 26, pp. 822–834, 2011.
- [32] S. Sanchez, R. Ortega, R. Grino, G. Bergna, and M. Molinas, “Conditions for existence of equilibria of systems with constant power loads,” *Circuits and Systems I: Regular Papers, IEEE Transactions on*, vol. 61, no. 7, pp. 2204–2211, 2014.
- [33] M. Grant and S. Boyd, “CVX: Matlab software for disciplined convex programming, version 2.1.”
- [34] S. Bolognani and S. Zampieri, “On the existence and linear approximation of the power flow solution in power distribution networks,” *IEEE Transactions on Power Systems*, vol. 31, pp. 163–172, Jan 2016.