



HAL
open science

Proposed design for simultaneous measurement of wall and near-wall temperatures in gas microflows

Varun Yeachana, Vikash Kumar, Lucien Baldas, Marcos Rojas-Cárdenas, Christine Barrot, Ryan Enright, Stéphane Colin

► **To cite this version:**

Varun Yeachana, Vikash Kumar, Lucien Baldas, Marcos Rojas-Cárdenas, Christine Barrot, et al.. Proposed design for simultaneous measurement of wall and near-wall temperatures in gas microflows. 3rd MIGRATE International Workshop, Jun 2018, Bastia, France. pp.211489. hal-02148822

HAL Id: hal-02148822

<https://hal.science/hal-02148822>

Submitted on 5 Jun 2019

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.



MIGRATE 2018: 211489

PROPOSED DESIGN FOR SIMULTANEOUS MEASUREMENT OF WALL AND NEAR-WALL TEMPERATURES IN GAS MICROFLOWS

**Varun Yeachana¹, Vikash Kumar², Lucien Baldas¹, Marcos Rojas-Cardenas¹,
Christine Barrot¹, Ryan Enright², Stéphane Colin^{1*}**

1. Institut Clément Ader (ICA), Université de Toulouse, CNRS, INSA, ISAE-SUPAERO, Mines-Albi,
UPS, Toulouse France

2. Thermal Management Research Group, Efficient Energy Transfer (η ET) Dept., Bell Labs Ireland,
stephane.colin@insa-toulouse.fr

KEY WORDS

Molecular tagging thermometry, gas microflows, phosphorescence, ITO-coated sapphire sensor, temperature jump

ABSTRACT

Gas behavior in systems at microscale has been receiving significant attention from researchers in the last two decades [1-4]. Today, there is an enhanced emphasis on developing new experimental techniques to capture the local temperature profiles in gases at rarefied conditions. The main underlying reason behind this focus is the interesting physics exhibited by gases at these rarefied conditions, especially in the transition regime. There is the onset of local thermodynamic disequilibrium, which manifests as velocity slip and temperature jump [1-4] at the wall. However, there is limited experimental evidence on understanding these aforementioned phenomena. With the advances in experimental facilities, it is today possible, at least in principle, to map the local temperature profiles in gases at rarefied conditions. Molecular tagging approach is one such technique which has shown the potential to map the temperature profile in low pressure conditions [5].

In molecular tagging approach, a very small percentage of tracer molecules are introduced into the gas of interest, referred as carrier gas. In gas flow studies, the typical tracers employed are acetone and biacetyl. These tracer molecules, assumed to be in equilibrium with the carrier gas, are excited with a source of energy at a specific wavelength, typically a laser. The excited molecules are unstable and tend to de-excite in a radiative and non-radiative manner, which is manifested as fluorescence and phosphorescence. Following the deformation with time of a tagged line permits to obtain the flow velocity. In addition, the dependence of the phosphorescence and fluorescence intensity to the gas temperature could also allow to use this technique for local temperature measurements.

The objective of this study is to develop an experimental setup capable of simultaneously mapping the wall and fluid near-wall temperatures with the final goal to measure temperature jump at the wall when rarefied conditions are reached. The originality of this setup shown in Figure 1 is to couple surface temperature measurements using an infrared camera with Molecular Tagging Thermometry (MTT) for gas temperature measurements. The bottom wall of the channel will be made of Sapphire substrate of 650 μ m thickness coated with a thin film of Indium Tin Oxide (ITO). The average roughness of this ITO layer is about 3 nm. The top wall of the channel will be made of SU8 and bonded with the bottom wall with a layer of PDMS. The channel will be filled in with acetone vapor,

or with a carrier gas seeded with acetone molecules. The channel height h and the pressure of acetone will be chosen in order to achieve a Knudsen number of the order of 0.1 corresponding to the slip or early transition regimes. The ITO layer will be uniformly heated in order to generate within the gas a temperature gradient perpendicular to the surface, that will result in rarefied conditions in a temperature jump i.e. a difference of temperature between the wall and the gas molecules.




Figure 1: Schematic of the proposed experimental setup

Surface temperature measurement of the sapphire wall will be measured with the ITO layer emitting an IR signal recorded by a thermal camera. This is a non-intrusive technique to measure the wall temperature, which has been developed at Nokia Bell Labs in Dublin [6]. For measuring the temperature of the molecules close to the wall, evanescent ultraviolet (UV) waves will be used to illuminate a thin layer of fluid near the wall and to excite the acetone tracer molecules present in this layer, as shown in the zoomed view of Figure 1. A pulsed laser sheet of wavelength 310 nm will be subjected to total internal reflection (TIR) at the top end of the bottom wall (in our case a sapphire substrate with refractive index 1.75). A sapphire prism helps in bending of the light beam at the appropriate angle. To satisfy the condition of continuity of electric and magnetic fields at the boundary of reflection, waves of light are transmitted into the medium of lower refractive index (here acetone vapor with a refractive index 1.35) [9]. These waves are referred to as evanescent waves, and they exhibit an exponential decay in intensity with distance. Their presence is felt within an order 100 nm in the material of lower refractive index [7-9]. Therefore, these evanescent waves can be employed to probe the regions closer to the wall.

Evanescent wave-based studies have been previously employed by researchers, especially in multilayer Nano-PIV studies to study the near-wall behavior of liquid flows [7-9]. Also, some researchers have adopted this technique to map the temperature in liquids in regions which are few hundred nanometers from the wall [9]. In general, these techniques employ fluorescent particles. The challenge of this study will be to obtain near-wall gas temperature measurement based on phosphorescence of molecules instead of particles. The phosphorescence is captured by an Intensified relay optics (IRO) attached to the CCD camera. The IRO not only intensifies the signal of



photoluminescence, but also provides with an adjustment for the gate i.e. the duration for which the signal is captured (the CCD camera is always open, but the signal is captured based on the gate value). The intensity dependence of acetone phosphorescence with temperature has been experimentally demonstrated in our previous work on MTT [5]. Capturing the phosphorescence of the acetone molecules close to the wall will give us an information of the near-wall temperature of acetone vapor.

In our previous study [5], phosphorescence emission of acetone vapor has been studied at the excitation wavelength of 310 nm, at various conditions of pressure ($p = 15,000$ Pa, 10,000 Pa, 7500 Pa, 5000 Pa, 2500 Pa and 1000 Pa) and conditions of temperatures (20 °C, 34 °C, and 50 °C). Therefore, these conditions of temperature and pressure will be targeted in the future experiments on the proposed experimental setup. The initial aim of the study will be to carry out experiments without flow in the system. Subsequently, experiments with flow in the system will be conducted to study temperature jump. Based on the difference in temperature values obtained by analyzing both the ITO generated IR signal and the visible phosphorescent signal of acetone molecules within the Knudsen layer at the wall, it should be possible to get information on the temperature jump at the wall.

Acknowledgements

This project has received funding from the European Union's Framework Programme for Research and Innovation Horizon 2020 (2014-2020) under the Marie Skłodowska-Curie Grant Agreement No. 643095, and from the Fédération de Recherche FERMAT (FR 3089).

References and Citations

- [1] Kandlikar, S., Garimella, S., Li, D., Colin, S., & King, M. R. (2005). *Heat transfer and fluid flow in minichannels and microchannels*. Elsevier.
- [2] Colin, S. (2005). Rarefaction and compressibility effects on steady and transient gas flows in microchannels. *Microfluidics and Nanofluidics*, 1(3), 268-279.
- [3] Agrawal, A. (2011). A comprehensive review on gas flow in microchannels. *International Journal of Micro-Nano Scale Transport*, 2(1), 1-40.
- [4] Colin, S. (2012). Gas microflows in the slip flow regime: a critical review on convective heat transfer. *Journal of Heat Transfer*, 134(2), 020908.
- [5] Yeachana, V., Fratantonio, D., Rojas-Cárdenas, M., Barrot, C., and Colin, S. (2017). Preliminary investigations on temperature dependency of acetone vapor luminescence for molecular tagging thermometry. Proceedings of 2nd International MIGRATE Workshop, Sofia, Bulgaria p.MIGRATE-153514.
- [6] Kumar, V., Jeffers, N., and Enright, R. (2017) Characterization of thin Indium Tin Oxide (ITO) coated sapphire sensor for applications in simultaneous optical imaging and non-intrusive surface temperature measurement of gas microflows. Proceedings of 2nd International MIGRATE Workshop, Sofia, Bulgaria p.MIGRATE-152927.
- [7] Li, H. F., & Yoda, M. (2008). Multilayer nano-particle image velocimetry (MnPIV) in microscale Poiseuille flows. *Measurement Science and Technology*, 19(7), 075402.
- [8] Bouzigues, C. I., Tabeling, P., & Bocquet, L. (2008). Nanofluidics in the debye layer at hydrophilic and hydrophobic surfaces. *Physical Review Letters*, 101(11), 114503.
- [9] Yoda, M., & Kim, M. (2013). Studying interfacial transport with evanescent wave-based particle velocimetry and thermometry. *Heat Transfer Engineering*, 34(2-3), 101-112.