Keywords: Large Eddy Simulation, yaw and wake interaction.

Wake interaction of yawed wind turbine by Large-Eddy Simulation

F. Houtin-Mongrolle^a, P. Benard^a, G. Lartigue^a, V. Moureau^a, L. Bricteux^b and J. Reveillon^a

According to the current energetic and environmental challenges, maximizing the electric power generated in windfarms is a societal concern. New strategies such as involving wind turbine yaw angle seem relevant to reduce wake interaction and associated power losses¹. Therefore, yawed turbine aerodynamics is modified and remains a challenging investigation topic.

Since experimental data on actual windfarm scales are not affordable and given the constant growth of computational resources, high order numerical simulations tend to be a promising approach². The goal of this study is to evaluate a highly resolved numerical model under yaw condition in a wind tunnel before applying it to actual windfarm. The blade modeling is performed using an Actuator Line Method³ (ALM), coupled to the low Mach-number massively-parallel finite-volume Large-Eddy Simulation (LES) flow solver on unstructured meshes, called YALES2^{4,5}.

The Blind Test 5 experimental configuration led at NTNU⁶, gathering numerous experimental data, is reproduced in this study. Two cases will be investigated: (A) a single yawed turbine and (B) a yawed turbine wake interaction with downstream turbine. The computational domain of these two cases will be NTNU wind tunnel, involving a turbulence grid aiming to create a fully turbulent sheared inflow⁶. The grid will be modeled using multiple Actuator Lines (to mimic the turbine blades) with dedicated polars^{7,8.} Each computational case is performed on a coarse and a fine mesh with around 20.10⁶ and 170.10⁶ tetrahedra, respectively.

At first, a comparison of global quantities with experimental data will be led, such as averaged power and thrust coefficient, or yaw moment. This will be followed by local characteristics analysis including velocity and turbulence intensity profiles as well as wake scan downstream of the turbine(s). This first validation step will allow to go into a deeper analysis using advanced post processing such as mean phases temporal statistics wake deflection by Proper Orthogonal Decomposition (POD)⁹, or frequential modes analysis.



Figure 1: Instantaneous streamwise velocity field of wake interaction between two turbines of case B with fine mesh.

[a] CORIA, CNRS UMR6614, Normandie Université, INSA and University of Rouen, 76801 Saint-Etienne-du-Rouvray, France [b] Université de Mons (UMONS), Polytechnic Faculty, Belgium

- [1] P. M. O. Gebraad et al., *Wind Energ.*; **19**, 95 (2016)
- [2] S-P Breton et al., *Phil.Trans.R.Soc.A* **375** (2017)
- [3] J. Sørensen t al., J. Fluids Eng **124**(2), 393 (2002)
- [4] P. Benard et al., *Comput. Fluids* **173**, 133 (2018).–
- [5] V. Moureau et al., *C.R. Mec.* **339**(2/3), 141, (2011).
- [6] F. Mühle et al., *Wind Energ. Sci.* **3**, 883, (2018).
- [7] M. Mahbub Alam et al., *J. Fluid Mech.*, **669**, 432 (2011)
- [8] R.J. Martinuzzi et al., *Exp. Fluids*, **34**, 585 (2013).
- [9] J.L. Lumley, Stochastic tools in turbulences, DTIC document, 12 (1970)