



**HAL**  
open science

## Accurate reactivity effects of pwr control rods using apollo3 advanced solvers

Jm. Palau, V. Jouault, G. Rimpault

► **To cite this version:**

Jm. Palau, V. Jouault, G. Rimpault. Accurate reactivity effects of pwr control rods using apollo3 advanced solvers. PHYSOR 2018, Apr 2018, Cancun, Mexico. hal-02415315

**HAL Id: hal-02415315**

**<https://hal.science/hal-02415315>**

Submitted on 17 Dec 2019

**HAL** is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

## **ACCURATE REACTIVITY EFFECTS OF PWR CONTROL RODS USING APOLLO3<sup>®</sup> ADVANCED SOLVERS**

**Jean-Marc Palau<sup>1</sup>, Valentin Jouault<sup>1</sup> and Gérald Rimpault<sup>1</sup>**

<sup>1</sup>CEA, DEN, DER/SPRC/LEPh, Cadarache, F-13108, Saint-Paul-lez-Durance, France  
Contact: jean-marc.palau@cea.fr

[jean-marc.palau@cea.fr](mailto:jean-marc.palau@cea.fr), [valentin.jouault@cea.fr](mailto:valentin.jouault@cea.fr), [gerald.rimpault@cea.fr](mailto:gerald.rimpault@cea.fr)

### **ABSTRACT**

In this paper, the most advanced features of the APOLLO3<sup>®</sup> new deterministic neutron transport code are being used to calculate accurately control rod reactivity effects. In order to illustrate the advantage of the proposed scheme, two models are being used: a model in which the control rod assembly is surrounded by standard assemblies, calculated using 2D TDT-MOC solver and fine structure self-shielding method with 281 groups at the lattice calculation level; and a semi-heterogeneous model (3x3 zones) of the control rod assembly at the core calculation level. Compared to the traditional single assembly and homogeneous core calculation usually associated with an equivalence method such as SPH, these new models take advantage of the possibility of subdividing an assembly with the MINARET transport core solver through unstructured conforming triangular spatial mesh (Discontinuous Galerkin Finite Elements), to represent explicitly the control rod shadowing effects within the control rod assembly. Tests to demonstrate the ability of such an approach have been carried out on a standard UOX fuel PWR reactor. The new APOLLO3<sup>®</sup> scheme has been checked against TRIPOLI-4<sup>®</sup> Monte-Carlo calculation and has been found extremely accurate without requiring any equivalence method. This calculation scheme lays down the foundations for a new upgrading approach for deterministic calculations to study PWR cores.

KEYWORDS: APOLLO3<sup>®</sup>, V&V, PWR, Control Rod

### **1. INTRODUCTION**

In order to meet new industrial's expectations in terms of neutronic calculation accuracy and versatility, CEA launched the APOLLO3<sup>®</sup> project [1]. The project's main purpose is to develop the deterministic multi-spectral neutron transport code APOLLO3<sup>®</sup>. This is being done at CEA with the support of EDF and AREVA, with the aim of having a better modeling of physical phenomena of existing reactor cores (until 3rd generation) but also of future reactor concepts (4th generation). APOLLO3<sup>®</sup> is aiming at replacing the previous 2nd generation of deterministic codes like APOLLO2, CRONOS2 and ECCO/ERANOS.


The APOLLO3<sup>®</sup>-PWR package built with APOLLO3<sup>®</sup> solvers defines reference calculation schemes associated with several multigroup nuclear data library to calculate all neutron parameters together with certified biases and uncertainties derived from the VV&UQ (Verification/Validation and Uncertainty Quantification) process. This VV&UQ process incorporates numerical verification and validation as well

as experimental validation leading to uncertainty quantification. The purpose of this paper is to present the recent developments in the PWR calculation scheme of APOLLO3<sup>®</sup>, mostly focusing on the effect of control rod assemblies representation on reactivity. After presenting the standard two-steps APOLLO3<sup>®</sup> reference calculation scheme the new control rod assemblies' representation will be introduced and its benefits will be shown on a 900 MWe PWR core.

## 2. APOLLO3<sup>®</sup> CALCULATION SCHEME

### 2.1. Two-steps Calculation Scheme

The use of a scientific calculation code to run a simulation requires, from the user, many choices among the calculation models and options of the code. Those choices should match design specification of different nature (grid, solver type ...), accounting the main physics phenomena to reach the target accuracies. The typical calculation scheme for APOLLO3<sup>®</sup> is presented in Figure 1. It is based on the separation of the cell/lattice calculation (orange) from the core calculation (green).



**Figure 1.** : APOLLO3<sup>®</sup> calculation scheme.

First, the code sets the nuclear data multi-group libraries, associated with probability tables, following the energy grid chosen by the user (1). Then self-shielding calculations (2) are performed to generate self-shielded cross sections of the most relevant resonant isotopes in different regions. These cross sections are used in the assembly flux calculation (3), and this process can be repeated (4 and 4') with eventually updating of fission and slowing-down sources (needed for FBR applications). By using ad-hoc leakage and homogenization/condensation models we get self-shielded, condensed and homogenized (5) cross sections which are stored in a Multi-Parametric Output library (MPO). Finally, we use the different MPOs (processed for each kind of assembly) to perform the core calculation with appropriate flux solver (6).


### 2.2. Current PWR Calculation Scheme

The Table 1 summarizes the current APOLLO3<sup>®</sup> reference calculation scheme used for PWR.

**Table I. :** APOLLO3<sup>®</sup>-PWR Calculation Scheme.

Calculation Step	Functionality	Value
<b>Lattice Calculation (2D)</b>	Scattering Anisotropy (1)	$P_3$
	Energy Grid (1)	281 Groups
	Self-shielding (2)	Fine-structure method for the core group method for the reflector
	Self-shielding solver (2)	Multicell
	Flux Solver (3)	TDT-MOC
<b>Core Calculation (3D)</b>	Energy Grid (5)	20 Groups
	Flux Solver (6)	MINARET ( $S_N$ )

The 2D lattice calculation scheme is based on the SHEM-MOC [2] reference calculation scheme of APOLLO2. The energy mesh is the optimized SHEM-281 groups, and the self-shielding calculation is performed with a fine-structure (Livolant-Jeanpierre) equivalence method, using a  $P_{ij}$  multicell model and subgroup method for the steel reflector, while 2D flux calculations is based on the long-characteristics method solver TDT-MOC [3]. In this validation study, no leakage model is used for lattice calculations (to make the TRIPOLI-4<sup>®</sup> comparison easier). The only difference between APOLLO3<sup>®</sup> and APOLLO2 calculation schemes lies in the spatial meshing of cells (cf. Figure 2). The reference scattering anisotropy is chosen as  $P_3$  Legendre polynomial expansion of scattering cross-sections which is requested to treat accurately absorber assemblies, as shown in [4].




**Figure 1 :** APOLLO2 (a) and APOLLO3<sup>®</sup> (b) spatial meshes for PWR fuel cells

Fissile and control rod assemblies are treated directly with this calculation scheme, in an infinite lattice representation. For steel/water reflectors, a different representation is needed, since there are no fissile isotopes in these media.

To calculate axial reflectors self-shielded cross sections, we first perform a calculation of a fissile assembly and generate its homogenized (but not collapsed) cross sections. Then, we perform an axial 1D calculation with TDT-MOC on a half-assembly (for the upper and lower part of the reflector) with the previously generated cross sections. We thus homogenize and collapse to broad energy mesh the resulting self-shielded cross sections of the reflector.

To calculate the radial reflector self-shielded cross sections, we defined a pattern including fissile assemblies and an exact geometric description of the radial reflector (an example is provided in Figure 3). The self-shielding calculations are carried out for the fissile assembly and the reflector separately, the reflector self-shielded cross-sections being processed by using a 1D description at this step (following recommendations from SHEM-MOC calculation scheme). Then, a 2D TDT-MOC calculation is performed on the pattern (considered as an infinite lattice), and the self-shielded, homogenized and condensed cross sections for the radial reflector are generated.



**Figure 3.** : Representation of the radial reflector for the studied PWR core.

All the core calculations are done with MINARET  $S_n$  transport flux solver [5] which solves the time-independent first-order form of the Boltzmann equation using the DGFEM method (Discontinuous Galerkin Finite Element Method) for the spatial discretization. This solver enables us to deal with spatial triangular and unstructured – but conform – spatial mesh in 2D and semi-unstructured in 3D (cylindrical) geometries. It should be noted that no equivalence method is used in this calculation scheme since the homogenization involves only one single assembly zone.

### 3. NEW CONTROL ROD REPRESENTATION

The treatment of critical heterogeneous assemblies is an important challenges for deterministic codes. Existing neutrons mostly come from the fissile zones are transported through absorbers assemblies. Since a straightforward one-step 3D core transport calculation is not possible yet (see paper [9] this conference), we need to define intermediate calculations with a reduce impact of approximations and well suited spectral representations in order to produce representative self-shielded cross sections for critical media. More specifically, this may require the description of part of the core (several assemblies called clusters as we shall see further), in order to have an energy spectrum similar to the one established in the core. This kind of representation has been used for axial and radial reflectors and we will investigate in the following section the performance of this model for control rod assemblies.

#### 3.1. Lattice Representation


In the current PWR reference calculation scheme, the calculation of the control rod assembly is performed using the same model as fissile assemblies, i.e. the infinite lattice model, based on the fundamental mode assumption (Isolated representation). However, this representation is not realistic when we consider the whole core heterogeneous geometry (in terms of different assembly types). It can be assessed that a new representation is necessary to describe more precisely physical phenomena occurring at whole core level.

In classical PWR reactor cores, control rods assemblies are surrounded by a lattice of fissile assemblies. This configuration permits to avoid power peaks by smoothing the power radial distribution.

In order to reproduce this configuration, we propose a new representation of control rods for the lattice step of the calculation (cf. Figure 4). The calculation is performed on a 3x3 cluster, with one control rod assembly surrounded by 8 fissile assemblies. We use a refined spatial mesh on the central (rodded)

assembly, to have an accurate description of the local spatial phenomena in this assembly, but we don't refine the surrounding fissile assemblies, since we don't need to have a so high accuracy on the incoming spectrum (this would require large time and memory consumptions for a poor accuracy gain at the end).

The calculation is performed according to the reference calculation scheme (SHEM-MOC) recommendations in terms of fine structure self-shielding and TDT-MOC flux solver options [2]. The two kinds of assemblies are self-shielded separately, with fine structure method and the multicell model with reflective boundary conditions. Then, the TDT-MOC calculation is performed on the cluster, with the same boundary conditions. Finally, the control rod is homogenized and we generate the homogenized condensed self-shielded cross sections for the central zone.



**Figure 4. :** Cluster-type representation for PWR control rod calculation (a). The central part corresponds to the control rod assembly with a refine spatial mesh (b), and peripheral zones are fissile assemblies.


### 3.2. Core Representation

In the current APOLLO3<sup>®</sup>-PWR calculation scheme, at the core calculation step, all assemblies are homogenized radially without requiring equivalence, and only axial heterogeneities are considered (depending on control-rod insertion). In the nominal configuration, this representation is acceptable since the fissile assemblies' local effects have an insignificant impact on the core reactivity. However, in the rod inserted assembly configurations, this is not necessarily the case, especially with thermal/epithermal strong absorbers (B4C/AIC/Gd) control rod assemblies.

In the classical PWR control rod assemblies, there are around twenty control rods. In Figure 4b for example, those control rods are distributed regularly all over the assembly. With this distribution, we can distinguish two regions: a central zone, delimited by the eight central control rods, and a peripheral one. Because of this division control rod shadowing (or screening) effects varying from the periphery to the central part occur.

When a neutron enters a control rod assembly, it has a great chance of being absorbed by the peripheral control rods. Only few neutrons pass through the peripheral zone and are absorbed by central control rods. Hence, central control rods "see" a different neutron spectrum than peripheral ones, in other words, central control rods are shadowed by peripheral ones.

When control rod assemblies are homogenized, these phenomena aren't taken into account in the core calculations. To fix this problem, we propose a partial homogenization of the control rod assemblies, which will consist on dividing them into nine regions, including the central zone as shown in Fig. 5.




**Figure 5. :** Partial Homogenization of a control rod assembly (control rods are in orange).

#### 4. PWR CORE CALCULATIONS WITH APOLLO3®

##### 4.1. Presentation of the PWR Core

The studied reactor core is a typical 900 MWe PWR as represented in Fig. 6a.



**Figure 6.a :** PWR reactor core, modelled with TRIPOLI-4® (a) or APOLLO3® (b)

In the reactor core there are seven types of Uranium oxides fissile assemblies, differing by their enrichments, the number of Pyrex rods and the type of control rod (black or gray ). In total, there are three types of control rod assemblies, named U1B, U1G and U3B. U1B and U1G are the same assemblies, but U1G contains gray control rods, whereas U1B has black control rods.

The two steps lattice (2D)/core (3D) calculations are performed as follows: first, the self-shielded homogenized and collapsed cross sections are produced for each assembly, with control rod inserted or withdrawn. Then, the core calculation is launched using the MINARET flux solver. It is performed with a radial mesh of 7 cm and an axial mesh of 5 cm, and lasts 725h (30h on 24 processors ), for a memory cost of 7 Go (21 Go on 24 processors). The radial reflector is represented as a cartesian lattice of homogenized assemblies (cf. Fig. 6b) consistent with the cluster model used in the lattice calculation (cf. Fig. 3).

The reference Monte-Carlo calculation is performed on the full heterogeneous core (cf. Fig. 6a) with TRIPOLI-4<sup>®</sup>, following 1 billion neutrons histories and reaching a precision better than 4 pcm (1 $\sigma$ ) on  $k_{\infty}$ . The calculation lasts 328h (14h on 24 processors).

**Table II.** : APOLLO3-PWR calculation scheme results (keff and control rod efficiency).

	Nominal	Rod inserted	Efficiency $\Delta\rho$
TRIPOLI-4 <sup>®</sup>	1.06740	0.90549	-16752 pcm
APOLLO3 <sup>®</sup>	1.06848	0.89759	-17819 pcm
$\Delta\rho$ (pcm) or $\delta(\Delta\rho)$ (%)	+ 95pcm	- 973pcm	6.4 %

In the nominal configuration, the APOLLO3<sup>®</sup> reference calculation scheme is accurate against TRIPOLI-4<sup>®</sup>, even if there is still room for improvement. For example, we could advantageously replace the fine structure self-shielding method by the subgroup method with 361 energy groups or use the MOC-3D o generate axial reflector cross sections as shown in papers [6][7] .

In the rod inserted configuration, the bias is not satisfying and the reactivity is significantly (clearly) underestimated by APOLLO3<sup>®</sup>. In order to seek the origin of this bias, we will use the bias decomposition.

#### 4.2. The bias decomposition method

The bias decomposition method consists of dividing the global bias (resulting of the comparison of APOLLO3<sup>®</sup> and TRIPOLI-4<sup>®</sup>) into separate biases, all of which represent an approximation. This method requires the use of multi-group TRIPOLI-4<sup>®</sup> calculations using homogenized self-shielded cross-sections coming from APOLLO3<sup>®</sup> lattice calculations (details of this decomposition/breakdown of model biases can be found in paper [8]). This type of calculation will be noted *T4 XS AP3*.

In this part, we will consider two kinds of approximation for the core calculation: the flux solver and the impact of lattice approximations on core results. To evaluate the impact of flux solver, a comparison of calculations with identical self-shielded cross sections is required. Thus, the flux solver bias is determined by measuring the discrepancy between the APOLLO3<sup>®</sup> calculation and *T4 XS AP3*. On the other hand, to evaluate the impact of lattice approximations, a comparison with identical transport method is required. This bias is calculated by comparing the TRIPOLI-4<sup>®</sup> calculation with *T4 XS AP3*.

**Table III.** : Bias decomposition of the studied PWR core for nominal and rod inserted configurations.

	Nominal	Rod inserted
Global bias (pcm)	+ 95	- 973
MINARET (pcm)	+ 2	- 75
Lattice Approximations (pcm)	+ 93	- 898

Lattice approximations are the major contributors of the global bias (90 %). To determine which assemblies are responsible of this discrepancy, we can separate the lattice approximations into assembly biases, corresponding to the contribution of each assembly.

To do so, in the *T4 XS AP3* calculation, we replace a homogenized assembly (with AP3 cross sections) by a heterogeneous one, with its original material compositions. We then compare the result of this calculation with the original *T4 XS AP3*. The measured bias is then the lattice approximation bias induced by the replaced assembly.



**Table IV. :** Impact of each assembly on global bias for the studied PWR core in the rod inserted configuration. Location for each assembly can be found in Fig. 6b.

assembly	Impact (pcm)
<b>U1B</b>	<b>- 875</b>
<b>U1G</b>	<b>- 92</b>
<b>U3B</b>	<b>- 201</b>
<b>Others</b>	+ 37
<b>Axial Reflectors</b>	<b>+ 165</b>
<b>Radial Reflector</b>	+ 15

Table 4 shows that control rod assemblies are responsible of the main discrepancy in reactivity between APOLLO3<sup>®</sup> and TRIPOLI-4<sup>®</sup> in the rod inserted configuration. We also notice that the axial reflector bias is non negligible due to the two-step calculation process (radial then axial calculation). The use of MOC-3D [7] shall reduce this bias, permitting us to perform a direct calculation of both axial reflectors.

#### 4.3. Validation of the new control rod assembly representation at lattice level

In order to validate the new representation, we need to assess its accuracy by comparing its results to reference Monte-Carlo ones. To do so, we compare the infinite multiplication coefficient resulting from an APOLLO3<sup>®</sup> assembly calculation for both representations defined consistently in Monte-Carlo calculation. The reference Monte-Carlo calculation is performed with TRIPOLI-4<sup>®</sup> and 1 billion neutron histories leading to a precision better than 4 pcm (1 sigma) on k infinity. The results are given in Table 5 for the three control rod assemblies with the new cluster type representation.

**Table VI. :** Reactivity discrepancies for control rod assembly calculations with the cluster-type representation

	<b>U1B</b>	<b>U1G</b>	<b>U3B</b>
<b>TRIPOLI-4<sup>®</sup></b>	1.05498	1.06990	1.21936
<b>APOLLO3<sup>®</sup></b>	1.05235	1.06852	1.21692
<b><math>\Delta\rho</math> (pcm)</b>	<b>- 236</b>	<b>- 121</b>	<b>- 165</b>

The previous isolated representation gave poor results regarding reactivity discrepancies, especially with black control rods. With the new cluster-type representation, reactivity biases are more acceptable. However, the calculation cost increases significantly: the calculation time goes from 25 min to 4.5h, and the memory cost goes from 2.1 Go to 25 Go.

To measure the benefits of this new modeling regarding core calculations, we compare neutron flux spectrum in the control rods. The reference flux spectrum results from a TRIPOLI-4<sup>®</sup> core calculation, and is compared to the averaged flux spectrum measured in a U1B assembly (cf. Fig. 7).

The new cluster-type modeling is more representative of the core situation; especially in the thermal bump (discrepancy to TRIPOLI-4<sup>®</sup> goes from -25 % to -10 % at 0.1 eV). Moreover, the global behavior in the fast zone of the spectrum is improved. However, there are still some remaining biases in the resonance domain, especially for <sup>238</sup>U resonance, at 6.63 eV and 20.8 eV.

#### 4.4. Impact of control rod assembly representation on Core calculations

The final goal of this new representation is to improve APOLLO3<sup>®</sup> core calculation accuracy against TRIPOLI-4<sup>®</sup> reference calculations, when control rods are fully inserted. Indeed, the control rod

representation has no effect in the nominal configuration where control rods are fully removed (bias of + 95 pcm with the reference calculation scheme).

In Table 7, we present the discrepancies between TRIPOLI-4<sup>®</sup> and APOLLO3<sup>®</sup> core calculations of the studied PWR, with control rods fully inserted:

- Calculation 2: we use the Cluster-type representation for lattice calculation, with a complete homogenization of control rod assemblies for core calculation;
- Calculation 4: we use the Cluster-type representation for lattice calculation, and the semi-heterogeneous (3x3 zones) modeling of control rod assemblies for calculation.




Figure 7. : 281 groups control rod assembly spectra comparison

Table VII. : Impact of control rod assemblies representation in APOLLO3<sup>®</sup> for the studied PWR core calculation (TRIPOLI-4<sup>®</sup> reference:  $k_{eff} = 0.90549$ )

Calculation Number	Assembly Representation	Core Representation	APOLLO3 <sup>®</sup>	$\Delta\rho$ (pcm)	$\delta(\Delta\rho)$ (%)
2	Cluster-Type	Homo.	0.90233	- 387	2.9
4	Cluster-Type	Semi-Het.	0.90533	- 20	0.7

Compared to the standard APOLLO3<sup>®</sup>-PWR reference calculation scheme (Table II), we see here a clear improvement in the reactivity and reactivity effects predictions using cluster-type models. Thanks to the semi-heterogeneous (3x3 zones) modeling, the accounting of the shadowing effects leads to a 700 pcm reactivity gain and *less than 1% remaining bias concerning the control rod efficiency*.

In Figure 9a, we plot the macroscopic fission rate's radial profile (see X-axis in Figure 8) in a control rod assembly for core calculations 2 and 4 (calculations 1 and 3 correspond to isolated control rod assembly representations leading to results quoted in Table II and IV). We compare those profiles with TRIPOLI-4<sup>®</sup> macroscopic fission rates radial profile in a control rod assembly placed in the center of the core.




Figure 8. : 2 Axes for fission rate plotting (cf. Fig. 9)




Figure 9. : X-axis fission rates profiles (a) and comparison between X-axis and diagonal profiles (b).

Plot (a) shows that the macroscopic fission rate profile shape for the lattice calculation is consistent with the TRIPOLI-4<sup>®</sup> one. The values are different since the incoming flux is different for the two calculations. Concerning the core calculations, we see that the macroscopic fission rate profile for Calculation 2 does not fit with the TRIPOLI-4<sup>®</sup> profile, since the depression behind peripheral control rods (CR1) is not observed. The semi-heterogeneous modeling fixes this issue. However, the increase of the fission rate in the central zone is not described, since this part is homogenized (a representation cell by cell should be useful to avoid this problem but leads to more demanding computer resources for the core calculations).


Plot (b) stresses the interest of dividing the assembly into 9 zones, rather than in 2 zones (a central one and a peripheral one). The fission rate is higher in the corners than in the sides, since there is less absorption in the corners. Moreover, the corners are surrounded by three fissile assemblies, whereas the sides are only next to one fissile assembly. Finally, the fission rate profile in the central zone is the same for every direction.

As shown in Table 8, the combination of the two representations (Calculation 4) offers the best accuracy on  $k_{\text{eff}}$  (and control rod reactivity effects), with a very low bias against TRIPOLI-4<sup>®</sup> (- 20 pcm). Furthermore error compensations between lattice and core calculations are non-significant for this calculation.

**Table VIII.** : Bias decomposition for Calculations 2 and 4.

	Calculation 2	Calculation 4
<b>Global bias (pcm)</b>	- 387	- 20
<b>MINARET (pcm)</b>	- 75	- 67
<b>Lattice Approximations (pcm)</b>	<b>- 312</b>	<b>+ 46</b>

Concerning the whole fission rate map in the core (figure 9) the discrepancy between calculation 4 and TRIPOLI-4<sup>®</sup> does not reach 5% (quoted in red in the colored map) except in control rods location. These results were obtained without any equivalency methods. Indeed, previous studies [10] showed that equivalency procedures could improve a calculation scheme's accuracy on reactivity, but worsen reaction rate distribution.



**Figure 9.** : Fission discrepancy between APOLLO3<sup>®</sup> and TRIPOLI-4<sup>®</sup> (max 5% in red, min -5% in blue)

We should also mention that we also perform cell by cell core calculation using SPh equivalence. In this heterogeneous case SPh method improved the fission rate results (max error of 3%) but reactivity was still discrepant compared to TRIPOLI-4<sup>®</sup> rising up to 200 pcm.

## 5. CONCLUSIONS

In this work, we have shown that using the most advanced features of the APOLLO3<sup>®</sup> new deterministic neutron transport code associated to a new representation of control rod assemblies, enables us to calculate accurately control rod reactivity effects.

The first part of this work was to improve the quality of the self-shielded cross sections generated at the lattice calculation level. The new model consists of taking into account the eight fuel assemblies neighboring each controlled assembly in the lattice calculation step. This cluster-type representation permits us to be more representative of the core situation, since the neutron flux spectrum in the assembly is closer to the one encountered in the core. Concerning reactivity effect, we have a 600 pcm gain in

reactivity bias against TRIPOLI-4<sup>®</sup> compared to the standard reference calculation scheme but a remaining bias of – 387 pcm due to the global homogenization.

The other part of this work was to improve the representation of control rod assemblies at the core level. Usually, assemblies are fully homogenized radially, but this model does not take into account the absorber rod shadowing effects. In order to better represent these phenomena, we propose a partial homogenization of control rod assemblies, which consists in dividing them into (3x3) zones. This model allows us to represent the fission rate profile after the peripheral control rods, and respect the difference of fission rate between corners and sides zones. At the end, we have a 700 pcm reactivity gain against TRIPOLI-4<sup>®</sup> thanks to this representation. Finally, the refined computational scheme leads to a small -20 pcm reactivity bias against TRIPOLI-4<sup>®</sup> in rod inserted configuration, without using any equivalence method. This work lays the foundations for an advanced APOLLO3<sup>®</sup>-PWR reference calculation scheme, ongoing works being devoted to the replacement of the fine structure self-shielding equivalence method by the subgroup method .

### ACKNOWLEDGMENTS

APOLLO3<sup>®</sup> and TRIPOLI-4<sup>®</sup> are registered trademark of CEA. We gratefully acknowledge CEA, AREVA and EDF for their long term partnership and their support. We would like to thank also the APOLLO3<sup>®</sup> development team for their efforts in implementing the models described here.

### REFERENCES

1. D. Schneider, F. Dolci, F. Gabriel, J. Palau, M. Guillo and B. Pothet, “APOLLO3<sup>®</sup>: CEA/DEN Deterministic Multi-purpose code for Reactor Physics Analysis” *Proceedings of PHYSOR 2016 conference* proceeding, Sun Valley, USA, May 1-5, 2016.
2. A. Santamarina and al., “APOLLO2.8 : A Validated Code Package for PWR Neutronics Calculations” in *Advances in Nuclear Fuel Management IV (ANFM 2009)*, Hilton Head Island, South Carolina, USA, April 12-15, 2009.
3. R. Sanchez and A. Chetaine, “Synthetic acceleration for a 2D characteristic method in non regular meshes” in *M&C 1999*, Madrid, Espagne, September 27-30, 1999.
4. A. Calloo, Développement d'une nouvelle modélisation de la loi de choc dans les codes de transport déterministe, PhD thesis, Université de Grenoble, 2012.
5. J.-Y. Moller, J.-J. Lautard and D. Schneider, “MINARET, a deterministic neutron transport solver for nuclear core calculations” in *M&C 2011*, Rio de Janeiro, Brésil, May 8-12, 2011.
6. A. Canbakan, A. Hebert, J.F. Vidal, “Validation of a subgroup method for pressurized water reactor fuel assembly models” in *M&C 2015*, Nashville, Tennessee, April 19–23, 2015.
7. P. Archier, J.-M. Palau and J.-F. Vidal, “Validation of the newly implemented 3D TDT-MOC Solver of APOLLO3<sup>®</sup> code on a whole 3D SFR Heterogeneous Assembly”, in *PHYSOR 2016*, Sun Valley, Idaho, USA, May 1-5, 2016.
8. V. Jouault, J.-M. Palau, G. Rimpault, J.F. Vidal, “A New Breakdown Methodology to Estimate Neutronic Model Biases Applied to APOLLO3<sup>®</sup> SFR Core Calculations”, in *M&C 2015*, Jeju, Korea, April 16-20, 2017
9. J.-M. Palau, E. Masiello, J.-F. Vidal, P. Archier and B. Faure, D. “Recent Progress in the V&V of the French APOLLO3<sup>®</sup> code : 3D full core analysis of the UH1.2 integral experiment using IDT method of characteristics”, this conference.
10. J.-F. Vidal and al., “New Modeling of LWR Assemblies using the APOLLO2 code package,” in *M&C + SNA 2007*, Monterey, California, USA, April 15-19, 2007.