

Decontamination of metallic surfaces by nanosecond laser ablation

L. Carvalho, W. Pacquentin, M. Tabarant, M. Dal, H. Maskrot, . Semerok A

► To cite this version:

L. Carvalho, W. Pacquentin, M. Tabarant, M. Dal, H. Maskrot, et al.. Decontamination of metallic surfaces by nanosecond laser ablation. International Conference On Laser Ablation 2017, Sep 2017, Marseille, France. International Conference On Laser Ablation 2017, 2017. hal-02417751

HAL Id: hal-02417751 https://hal.science/hal-02417751

Submitted on 18 Dec 2019

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers. L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés. RECHERCHE À L'INDUSTRIE

C22den

DECONTAMINATION OF METALLIC SURFACES BY NANOSECOND LASER ABLATION

L. Carvalho^a, W. Pacquentin^a, M. Tabarant^a, M. Dal^b, H. Maskrot^a, A. Semerok^a

(a) Den - Service d'Etudes Analytiques et de Réactivité des Surfaces (SEARS), CEA, Université Paris-Saclay, F-91191, Gif sur Yvette, France (b) Laboratoire Procédés et Ingénierie en Mécanique et Matériaux (PIMM), ENSAM, 151 Boulevard de l'Hôpital, Paris

Context & Aim of the study

The need of cleaning of equipment employed in the nuclear industry is growing and will be a major issue in the coming decades. To deal with such situation, the decontamination of metallic equipment by laser ablation is an advantageous technique that can provide the reduction of nuclear waste while minimizing the worker exposure. The efficiency of this process has already been proved but the previous studies showed the presence of a residual contamination. The goal of this study is therefore to determine the limiting factors of the technique by the comprehension of the physical phenomena involved.

- \rightarrow Study of the factors responsible for residual contamination
- \rightarrow Comprehension of ablation mechanisms induced by nanosecond regime using modelization
- \rightarrow Optimization of laser decontamination

Experimental protocol

Material

LASER set up

Experimental strategy

Stainless steel AISI 304L

	Fe	Cr	Ni	Mn	Si	Со	Мо	С
%								
weight	Bal.	18.57	9.23	1.44	0.36	0.22	0.22	0.02

Sample preparation with tracing element incorporation

(1) Contamination by nebulization of $Eu(NO_3)_3$

2 Fixation of Eu by laser melting

(3) Oxidation by thermal treatment in furnace

- Layer composition: $Fe_2O_3 + Fe_3O_4/FeCr_2O_4$
- Contamination in Eu in the whole volume
- Oxide layer thickness : from 100 nm to 2 µm

	Aspiration nozzle					
<image/> <section-header><section-header></section-header></section-header>	nometric scan					
Yb fiber laser IPG YLP-1/120/20 Wavelenght: 1064 nm Gaussian beam (M ² = 2.1) Beam radius (1/e ²) : 62 µm Pulse duration: 110 ns Repetition rate : 20 kHz Mean power : 20 W	Scanning of the surface by consecutive laser pulses Collection of ablated matter Fast kinetics					

Characterization of the ablated matter and the surface after cleaning



Beam laser CCD image	Schema of the scanning regime



Optimization of laser cleaning parameters

Parameter	Min	Max
Laser pulse fluence	5 J/cm ²	12 J/cm ²
Laser spot overlapping	60 %	90 %
Number of scan	1	10



Cleaning of oxidized metallic surface

Characterisation of the ablated matter

Collection of the aerosol on 0.45 µm nanopore filters



Observation of collected matter :

- Fragments of oxide $(10 20 \mu m)$
- Aerosols (1 5 µm)

Modelling of laser ablation

- Modelling of a single laser impact with COMSOL Multiphysics[®] :
 - Heat transfer and fluid flow

3D+t model



Hypothesis of limiting factors

 \rightarrow Identification of ablation mechanisms

Decontamination efficiency



Penetration of Eu in the

Glow Discharge Mass Spectrometry profiles before and after decontamination (1 scan, 97.3 J/cm² accumulated fluence)

ELEMENT GD+ - THERMO Scientific

collected aerosol



- ✓ Determination of a cleaning power threshold $(\mathbf{P} = \mathbf{6W})$
- ✓ Decontamination lower than 100 % after 1 scan \rightarrow Residual contamination to be treated

- Stainless steel AISI 304L
- Mechanisms of matter ejection :



Temperature arise and phase transition during the laser pulse (110 ns) Ejection of a melt pool (laminar flow)

Formation of a ring at the solidification

Comparison with experimental results



Perspectives of modelization

Temperature distribution (K) & velocity (white arrows) at 1 µs







