



HAL
open science

Real-time energy scheduling for microgrids based on the Contract Collaboration Problem

Mario Levorato, Rosa Figueiredo, Yuri Y. Frota, Antoine Jouglet, David Savourey

► **To cite this version:**

Mario Levorato, Rosa Figueiredo, Yuri Y. Frota, Antoine Jouglet, David Savourey. Real-time energy scheduling for microgrids based on the Contract Collaboration Problem. 21e congrès annuel de la Société Française de Recherche Opérationnelle et d'Aide à la Décision (ROADEF 2020), Feb 2020, Montpellier, France. hal-02528081

HAL Id: hal-02528081

<https://hal.science/hal-02528081v1>

Submitted on 1 Apr 2020

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.



Real-time energy scheduling for microgrids based on the Contract Collaboration Problem [183]

Mario Levorato, Rosa Figueiredo, Yuri Frota, Antoine Jouglet
and David Savourey

EasyChair preprints are intended for rapid
dissemination of research results and are
integrated with the rest of EasyChair.

February 6, 2020

Real-time energy scheduling for microgrids based on the Contract Collaboration Problem

Mario Levorato^{1,2}, Rosa Figueiredo¹, Yuri Frota², Antoine Jouglet³, David Savourey³

¹ Avignon Université, Avignon, France

mario.costa-levorato-junior@alumni.univ-avignon.fr, rosa.figueiredo@univ-avignon.fr

² Universidade Federal Fluminense, Niterói, Brésil

{mlevorato,yuri}@ic.uff.br

³ Université de Technologie de Compiègne, Compiègne, France

{antoine.jouglet,david.savourey}@utc.fr

Mots-clés : *optimisation robuste, micro-réseaux, engagements flexibles, planification énergétique.*

1 Introduction

Along with the advent of smart grids, we have witnessed several technological advances, including renewable energy sources and flexible loads, such as smart appliances and electric vehicles. Moreover, new electricity market rules and regulation mechanisms have been proposed [2]. Thanks to instant communication, control devices have become important elements, essential for managing the energy balancing of the grid. Based on a specific strategy, they execute real-time energy scheduling according to fluctuations in production (e.g. solar panels in cloudy weather) and consumption in different periods of time. Interesting examples involve the use of energy generators during a period of higher demand and, analogously, employing a set of batteries to store energy during off-peak times so as to ease high demand in peak periods.

In this work, we study real-time energy scheduling strategies to be used by smart control devices within a contract collaboration framework, established between two systems, both producers and consumers of the same kind of energy resource. One system is called the *client* (e.g. campus, hospital, hotel) and the other one the *partner* (i.e. energy company).

2 The Contract Collaboration Problem

Connected via the main energy grid, the *client* and *partner* systems have to collaborate in order to balance their consumption and production over a given time horizon. Such time horizon is divided into a set $\mathcal{I} = \{I_0, \dots, I_{\bar{t}-1}\}$ of \bar{t} time periods where $I_t = [T_t, T_{t+1})$, for each $t \in \{0, 1, 2, \dots, \bar{t} - 1\}$.

Client-partner collaboration is established by the use of a set of contracts of consumption or production, both offered by the *partner*, each one having its own functional constraints and gain/cost functions. On each time period, the *client* is free to enter into a commitment with the *partner* through any subset of contracts. However, such commitments must be honored. The *client* also has the option to buy energy out of any engaged contract, but at a higher cost which can vary with the time period.

The *client's* microgrid is composed by subsystems that produce/consume the energy resource, each one with its own functional constraints and a cost/gain of consuming/producing over the time periods. In particular, the consumption/production can be *driven* for a subset of these systems (*drivable systems*) while the consumption/production is already planned for the *non-drivable systems*. Drivable systems are devices that allow being turned on/off or that must be loaded/unloaded from time to time (e.g. batteries, electric car, fuel-powered generators), whereas non-drivable systems (e.g. always-on appliances like refrigerators) must be permanently turned on. Additionally, some of the drivable systems can store the energy resource under a

capacity constraint and provide it when needed, thus being called *storage systems* (e.g. batteries). The uncertainty considered in the problem lies in a subset of the *non-drivable systems*, for which only uncertain provisions of the consumption/production are known. The so-called *uncertain non-drivable systems* include, for example, renewable generation and variable energy consumption.

The Contract Collaboration Problem (CCP) consists in determining a cost-optimal contract subscription from the client to the partner which not only satisfies any client-side consumer demands over the time horizon (even in the worst case scenario), but also in such a way that each commitment taken by the client with the partner is honored. Additionally, the list of engaged contracts, for the whole time horizon, has to be determined beforehand and it cannot be altered.

3 Real-time energy scheduling

In order to properly manage the client's microgrid, as a complement to the contract subscription, energy scheduling decisions have to be made in order to balance demand and supply. From a real-time point of view, inside each time period $I_t \in \mathcal{I}$, the instantaneous production/consumption of each system is measured every Δ time units. It is also at this time scale that drivable systems are driven, i.e, every Δ time units a scheduling decision has to be taken, according to the state of the client's microgrid, such as :

- turning on/off a producer/consumer drivable system ;
- determining if a storage system will absorb or refund energy ;
- buying/selling a quantity of energy under an engaged contract ;
- buying an amount of energy out of engaged contracts.

4 Solution method

The novelty in our work is the incorporation of a bilateral flexible multi-contract subscription framework, which allows the trading of energy at different prices and in flexible amounts. The problem solution is established at two levels. First, a time-decomposition-based CCP model provides the list of contracts the client will engage in each period. Two versions of the model were developed for this purpose : deterministic and robust. For the deterministic version, uncertain devices consumption/production fluctuation is ignored, and their average power values are assumed. The robust version aims to minimize the energy cost against the worst-case scenario of production/consumption of electricity. In a second level, in order to balance demand and supply, different real-time energy scheduling strategies are proposed.

Experimental data were collected from a microgrid located at Université de Technologie de Compiègne (UTC) [1], with the following elements : 2 drivable systems (one electric car and a group of diesel engine-generators), 1 non-drivable system representing the invariable building consumption, and 2 uncertain non-drivable systems (one photo-voltaic production system and the uncertain consumption of the same building). We will present preliminary results based on simulations, comparing the performance of the proposed real-time energy scheduling strategies, when using either the deterministic or robust model solution as input.

Acknowledgement

Research conducted during a visiting period at Avignon Université by means of a Doctoral Exchange Program sponsored by CAPES, Ministry of Education, Brazil (Process No. : 88881.187708/2018-01).

Références

- [1] Atelier projet : Smart-house et micro-réseaux. Technical report, Université de Technologie de Compiègne, June 2015.
- [2] Pierluigi Siano. Demand response and smart grids – a survey. *Renewable and sustainable energy reviews*, 30 :461–478, 2014.