



HAL
open science

Experimental characterization of a novel soft polymer heat exchanger for wastewater heat recovery

Sixiang Lyu, Cheng Wang, Chuanyu Zhang, Laurent Royon, Xiaofeng Guo

► **To cite this version:**

Sixiang Lyu, Cheng Wang, Chuanyu Zhang, Laurent Royon, Xiaofeng Guo. Experimental characterization of a novel soft polymer heat exchanger for wastewater heat recovery. *International Journal of Heat and Mass Transfer*, 2020, 161, pp.120256. 10.1016/j.ijheatmasstransfer.2020.120256 . hal-02919621

HAL Id: hal-02919621

<https://hal.science/hal-02919621>

Submitted on 22 Aug 2022

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.



Distributed under a Creative Commons Attribution - NonCommercial 4.0 International License

Experimental characterization of a novel soft polymer heat exchanger for wastewater heat recovery

Sixiang Lyu¹, Cheng Wang², Chuanyu Zhang³, Laurent Royon³, Xiaofeng Guo^{3,4}

1. Department of Energy Technology, KTH Royal Institute of Technology, Stockholm, Sweden

2. Jiangsu Provincial Key Laboratory of Oil & Gas Storage and Transportation Technology, Changzhou University, Changzhou, Jiangsu, PR China

3. Université de Paris, LIED, UMR 8236, CNRS, Paris, France

4. Université Gustave Eiffel, ESIEE Paris, Noisy le Grand, France

Authors for correspondence: xiaofeng.guo@esiee.fr (X. Guo) and wangcheng3756@163.com (C. Wang)

ABSTRACT

Wastewater released from showers, sinks, and washers contains a considerable amount of waste heat that can be recovered by using a heat exchanger. Conventional metal heat exchangers for wastewater heat recovery have common problems of corrosion, fouling and clogging, which makes it necessary to develop a new type of heat exchanger for such low-grade thermal energy recovery applications. This study deals with a novel patented polymer heat exchanger (WO2020049233A1) made of soft polyurethane tubes that are capable of oscillation once subjected to external forces. Laboratory tests coupled with theoretical analyses show a stable global heat transfer coefficient of 100-110 W/m²·K, achieving 67-92% of the performance of titanium-, aluminum-, and copper-made heat exchangers with the same configuration. It further reveals that the performance of the soft heat exchanger can be enhanced by 30% when it is under oscillation. In addition, the external convective thermal resistance appears to be the dominant one instead of heat conduction through the wall material. The special operating condition of heat recovery from a sewer pipeline makes the polymer heat exchanger particularly adapted with its equivalent thermal performance but advantages of high flexibility, modularity, and low cost.

KEY WORDS

Polymer heat exchanger, wastewater, heat recovery, heat transfer enhancement, oscillation, serpentine-like

NOMENCLATURE

A	[m ²]	Heat transfer area of the pipe	<i>Subscripts</i>	
A_c	[m ²]	Cross-sectional area of the pipe		
c_p	[J/kg·K]	Specific heat capacity of water	Al	Aluminum
D	[m]	Diameter of the pipe	c	Central pipe
f	[-]	Friction factor	Cu	Copper
h	[W/m ² ·K]	Convective heat transfer coefficient	D	Diameter
k	[W/m·K]	Thermal conductivity of the fluid	h	Hydraulic
L	[m]	Length of a unit pipe	HTF	Heat transfer fluid
$LMTD$	[K]	Logarithmic mean temperature difference	i	Pipe inside
\dot{m}	[kg/s]	Mass flow rate	in	Inlet
N	[-]	Number of peripheric pipes	m	Middle
Nu	[-]	Nusselt number	o	Pipe outside
P	[m]	Wetted perimeter of the pipe	out	Outlet
Pr	[-]	Prandtl number	p	Peripheric pipe
\dot{Q}	[W]	Heat transfer rate	s	Surface
R	[K/W]	Thermal resistance	tot	Total
Re	[-]	Reynolds number	Ti	Titanium
T	[°C]	Temperature	w	Water in LMTD calculation / Wall in thermal resistance
u	[m/s]	Fluid velocity		
U	[W/m ² ·K]	Overall heat transfer coefficient		
UA	[W/K]	Heat conductance		

Greek symbols

λ	[W/m·K]	Thermal conductivity of polymer material
μ	[Pa·s]	Fluid dynamic viscosity
ρ	[m ³ /kg]	Fluid density

27

28

29 INTRODUCTION

30 The growing world urbanization and climate change bring imminent challenges for the sustainable development of the
31 society. A recent study by U.S. Energy Information Administration [1] predicted an increase in world energy consumption by
32 nearly 50% between 2018-2050, of which almost all the increase comes from non-OECD countries having strong economic
33 growth and rapid urbanization pace. Cities appear to dominate energy consumption and CO₂ emissions. In 2013, the world's
34 urban areas accounted for about 64% of global primary energy use and produced 70% of the total CO₂ emissions [2]. More
35 recently, the Covid-19 crisis inevitably urge the society to strengthen efforts made to the energy-climate transition.

36 Accessible, low-cost and stable alternative solutions are key to replace fossil-based energy. One way is to expand the share
37 of renewable energies, such as solar photovoltaic (PV), wind, and bioenergy. However, this usually requires a considerable
38 amount of financial support and their implementation is severely dependent on policy implementation, including the building of
39 new energy infrastructures. Moreover, PV might be in conflict with agriculture when it comes to land occupation, while
40 bioenergy can be in competition with food. The mismatch between demand and renewable production can also be problematic
41 [3]. An alternative solution is to increase energy efficiency by reusing or converting waste energy (mostly in the form of heat)
42 to other forms of energy from existing systems.

43 In recent years, wastewater in urban sewer networks has attracted extensive interest for thermal energy recovery because of
44 its easy accessibility and high abundance. Wastewater released from showers, sinks, and drains contains significant quantities of
45 thermal energy, much higher than organic energy [4]. An amount of 1.16 kWh thermal energy can be gained, if 1 m³ of water is
46 cooled down by 1 °C. According to Mazhar et al. [5], approximately 3.5 kWh of thermal energy per person per day could be
47 harvested and used directly to meet thermal demands. Moreover, reusing heat from wastewater also helps to reduce greenhouse
48 gas emissions. Takashi et al. [6] conducted a feasibility study in wastewater heat recovery and concluded that 2.5 tons of CO₂
49 can be avoided per 10 000 m³ of wastewater. Guo and Hendel [7] performed a case study in Paris to evaluate the field
50 performance of a district-scale wastewater heat recovery system with an effluent flow rate of 115 m³/h, and reported that up to
51 75% CO₂ could be reduced annually with a primary energy savings of 32%. Cold recovery case studies have also been carried
52 out in Amsterdam drinking water network by van der Hoek et al. [8].

53 Conventionally, there are two techniques to extract heat from wastewater in urban sewer channels by means of heat
54 exchangers. There are already some existing systems or demonstrating projects using both technologies worldwide [9–12]. The
55 first technique (integrated system) is to install a metal-made tubular heat exchanger at the bottom of the sewer pipeline [7,13].
56 Several tubular exchangers with long length are often connected in series to achieve the desired heat capacity, due to their
57 relative small heat exchanger surface and low heat transfer coefficient [7]. Apart from weight and cost, metal heat exchangers
58 also have issues of corrosion and fouling that often cause low efficiency or even failures [14,15]. Moreover, in sewer pipes, the
59 efficiency of the heat exchanger will be largely reduced if its surface is surrounded by sediments or biofilms or is not
60 completely submerged [13].

61 The second technique (external system) is to pump the wastewater to a heat exchanger installed outside of the sewer. Spiral
62 heat exchangers with advantages of compact design, large exchange surface, and high heat transfer coefficient are usually used
63 in this technique [16]. Besides, the high-speed flow through spiral heat exchangers can reduce the effect of fouling. However, it

64 requires a dedicated by-pass piping network and high installation and pumping costs [13]. Also, regular maintenance is
65 necessary to avoid clogging by solid matters in wastewater.

66 Hence, facing this new application, it is desirable to find a solution to overcome those problems associated with metal heat
67 exchangers. One promising solution is to use polymer materials instead of metals for manufacturing heat exchangers. Many
68 different polymer materials have been studied for their physicochemical properties, such as polypropylene (PP), polyethylene
69 (PE), polycarbonate (PC), polytetrafluoroethylene (PTFE), etc. [15,17]. These materials have advantages of greater corrosion
70 and fouling resistance, higher geometric flexibility, and they are easier to manufacture with reduced energy of formation and
71 fabrication [15,17]. The use of polymer heat exchangers also helps to reduce transportation and installation costs, which
72 eventually lowers the total investment [14].

73 Nevertheless, polymer materials have significant low thermal conductivities of typically less than 0.5 W/m·K compared to
74 most metals which range from 10 W/m·K to 400 W/m·K [15]. Therefore, extensive research has been carried out to improve the
75 thermal performance of polymer heat exchangers. The commonly used technique is to dope the polymer thermal conductivity
76 by adding metal, ceramic, or carbon-based particles into the polymer matrix [15]. Breuer and Sundararaj [18] reported that the
77 thermal conductivity of PP could be increased by 120% with 1 wt.% loading of single-walled carbon nanotubes (SWCNTs).
78 Mamuya et al. [19] studied the thermal conductivity of polyvinyl chloride (PVC) filled with copper powders at different filler
79 volume contents and reported 3-4 times thermal conductivity improvements with a filler volume content of 30%. Compared
80 with the thermal performance of metal heat exchangers, Chen et al. [14] have shown that a modified PP heat exchanger with
81 thermal conductivity of 15 W/m·K can achieve 95% of the titanium heat exchanger performance and 84% of the aluminum or
82 copper heat exchanger performance with the same dimensions.

83 In addition to conductivity enhancement of polymers, the operating condition, in particular vibration or other movements,
84 also have potentially high impacts on heat exchanger performance. Recently, vibration effects on heat transfer enhancement
85 have been confirmed numerically or experimentally. Shi et al. [20] numerically studied heat transfer enhancement by Vortex-
86 Induced Vibration (VIV) generated by a cylindrical obstacle in a channel. Their results indicate that VIV can significantly
87 increase the average Nusselt number up to 90.1% over that of a smooth channel. Liu et al. [21] used an experimental approach
88 to study the effects of mechanical vibration on heat transfer characteristics of laminar flow in a circular heated tube. An
89 increased Nusselt number and a maximum heat transfer enhancement of 14.94% was found owing to the vibration. A more
90 sophisticated technique is to use ultrasonic vibration to enhance heat transfer. Chen et al. [22] investigated the heat transfer
91 enhancement under ultrasonic vibration using a stainless steel circular heater rod, and found a maximum heat transfer increment
92 of 1 557 W/m²·K with an increment ratio of 3.01. In terms of energy input, however, their ultrasonic transducer requires a total
93 power of 150 W with a frequency of 40 Hz. Undesirable local heating could be problematic for the use of ultrasounds [23,24].
94 To our knowledge, the use of unmodified polymer heat exchanger in sewer wastewater heat recovery has yet not appeared in
95 the literature.

96 In this paper, we report a newly patented polymer heat exchanger (WO2020049233A1) designed for wastewater heat
97 recovery from sewers [25]. Laboratory experiments are carried out to determine its heat transfer characteristics, including heat
98 transfer rate, heat transfer coefficient, and thermal resistance. As a unique advantage, oscillational movement of the soft heat
99 exchanger is also studied to explore the heat transfer enhancement potential compared with standstill position (which is true to
100 all classical rigid heat exchangers). In the absence of established correlation for serpentine-shape cylinder heat convection,
101 theoretical results obtained from ideal models of parallel flow and crossflow heat exchanger with the same dimension and
102 working conditions are used to define the upper and lower performance limits of the studied heat exchanger. Based on the
103 model, the sensibility of heat exchanger performance on material thermal conductivity allows the comparison with metal heat
104 exchangers. The data and results from this paper may offer some reference for the design and use of polymer heat exchanger in
105 wastewater heat recovery or similar applications.

106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121

POLYMER HEAT EXCHANGER

Design and dimensions

Figure 1 shows schematically the structure of the novel heat exchanger and the dimension of the tested prototype. The heat exchanger is made of polymer polyurethane (PU), consisting of ten peripheric pipes and one central pipe [25]. The pipes are connected at one end by a cap for fluid return and this end is freely immersed in the source-side fluid (wastewater). The peripheric pipes (Port 1) and central pipe (Port 2) at the other end allow the feeding and return of the heat transfer fluid (HTF).

Manufactured by extrusion, this soft polymer heat exchanger holds important advantages of high modularity and flexibility. Namely, it can be prefabricated then cut into any length according to the capacity requirement or installation environment. The heat exchanger can be operated at four different modes depending on the direction of HTF flow and relative temperatures between the HTF and source-side fluid, as shown in **Table 1**. Heat recovery refers to the situations when HTF temperature is lower than that of the source-side, while cold recovery refers to the cases when HTF temperature is higher than the source-side fluid.




Figure 1 Basic structure of the soft polymer heat exchanger (left) and dimension of the pipes (right).

122
123

Table 1: Different operating modes of the polymer heat exchanger.

Cases	Port 1	Port 2	Relative temperature	Type of recovery
Case 1	HTF in	HTF out	$T_{HTF} < T_{source}$	Heat recovery
Case 2	HTF out	HTF in	$T_{HTF} < T_{source}$	Heat recovery
Case 3	HTF in	HTF out	$T_{HTF} > T_{source}$	Cold recovery
Case 4	HTF out	HTF in	$T_{HTF} > T_{source}$	Cold recovery

124

Flow patterns

The soft nature of the material, together with the one end in free movement, makes the heat exchanger be easily deformed during operation due to external forces (turbulent flow, natural convection, thermocline, vortices, etc.). The deformation of the heat exchanger changes not only the shape but also the flow pattern between the HTF and source-side fluid. **Figure 2** illustrates positions of the heat exchanger (only one peripheric pipe is shown instead of ten) in both straight and serpentine positions and their corresponding flow patterns. In the straight position, parallel flow dominates heat transfer between the HTF and source-

130

131 side fluid, with peripheric pipes being co-current and the central pipe in counter-current configuration. However, a crossflow is
 132 created when the heat exchanger is in the serpentine position, which could enhance the external convection. Moreover, previous
 133 studies [26,27] have shown that Dean vortices can be formed when a fluid flows in a curved channel, resulting in an enhanced
 134 internal convective heat transfer. In sum, the facility of deformation of the novel heat exchanger makes it potentially more
 135 performant compared to a rigid heat exchanger under equal material and operating conditions.
 136




Figure 2 Schematic view of the heat exchanger in different positions and their corresponding fluid flow patterns (left: straight position with parallel flow; right: serpentine position with mixed parallel-cross flow).

137

138 THEORETICAL MODEL

139 Overall heat transfer coefficient

140 The overall heat exchange coefficient (U) depends on those of peripheric (U_p) and central pipes (U_c). Each of them depends
 141 on internal and external convection and conduction through walls. The thermal resistances for internal convective (R_i), external
 142 convective (R_o), and conductive heat transfer through walls (R_w) can be calculated using the Eqs. (1)-(3) [27], hence the total
 143 thermal resistance is the sum of them by Eq. (4):

$$R_i = \frac{1}{\pi h_i D_i N L} \quad (1)$$

$$R_o = \frac{1}{\pi h_o D_o N L} \quad (2)$$

$$R_w = \frac{\ln\left(\frac{D_o}{D_i}\right)}{2\pi\lambda N L} \quad (3)$$

$$R_{tot} = R_i + R_o + R_w \quad (4)$$

144 The overall heat transfer coefficient of the peripheric pipes or central pipe may be determined as follows [27]:

$$U_p = \frac{1}{A_p \cdot R_{tot,p}} \quad (5)$$

$$U_c = \frac{1}{A_c \cdot R_{tot,c}} \quad (6)$$

145

146 The global heat transfer coefficient of the entire heat exchanger is finally calculated by the sum of the overall heat transfer
147 coefficient of each pipe to the ratio of heat transfer area as shown in Eq. (7):

$$U = U_p \cdot \frac{A_p}{A_p + A_c} + U_c \cdot \frac{A_c}{A_p + A_c} \quad (7)$$

148 Substituting Eq. (5) and (6) in (7), the Eq. (7) becomes:

$$U = \frac{1}{A \cdot R_{tot,p}} + \frac{1}{A \cdot R_{tot,c}} \quad (8)$$

149

150 Internal convective heat transfer coefficient

151 To determine the internal convective heat transfer coefficient (h_i), the Reynolds number of internal tube flow is calculated
152 to determine the flow regime:

$$Re_D = \frac{u\rho D_i}{\mu} \quad (9)$$

153 For internal pipe flow, the flow can be considered as laminar flow if $Re_D < 2300$, and turbulent if $Re_D > 2900$ [27]. It worth
154 noting that for N peripheric pipes, the mean velocity u is calculated by the \dot{m}_p being divided by N (N=10).

155 In the case of fully developed laminar flow with constant surface temperature, and without considering the entrance
156 development zone, the Nusselt number can be considered as constant:

$$Nu_D = 3.66 \text{ if } T_s = \text{constant} \quad (10)$$

157 For turbulent flow, the correlation provided by Gnielinski [27] is used to determine the Nusselt number:

$$Nu_D = \frac{(f/8)(Re_D - 1000)Pr}{1 + 12.7(f/8)^{1/2}(Pr^{2/3} - 1)} \quad (11)$$

158 This correlation is valid for $0.5 \leq Pr \leq 2000$ and $3000 \leq Re_D \leq 5 \cdot 10^6$, and it can be applied for both constant heat flux and
159 temperature conditions. In the equation, the Darcy friction factor f can be obtained from the Churchill equation (1977) [28] that
160 is valid for all flow regimes:

$$f = 8 \cdot \left[\left(\frac{8}{Re} \right)^{12} + \left(\left\{ 2.457 \cdot \ln \left(\frac{1}{\left(\frac{\epsilon}{D_i} \right)^{0.9} + 0.27 \frac{\epsilon}{D_i}} \right) \right\}^{16} + \left(\frac{37530}{Re} \right)^{16} \right)^{-1.5} \right]^{\frac{1}{12}} \quad (12)$$

161 where ϵ and D_i are the surface roughness (0.0015 mm for PU) and the inner diameter of the pipe.

162 Once Nu_D is obtained, the internal convective heat transfer coefficient of the peripheric or central pipe is determined by Eq.
163 (13):

$$h_i = \frac{Nu_D k}{D_i} \quad (13)$$

164

165

166

167 External heat transfer coefficient

168 The external convection coefficient (h_o) depends on the relative flow pattern between the HTF and source-side fluid. As the
 169 soft heat exchanger is in a serpentine position, the complex flow pattern involves both parallel and crossflow, the latter being
 170 more favorable to convective heat transfer. Thus, the external convection coefficient around a serpentine-cylinder should be
 171 limited by values obtained by parallel and crossflow correlations.

172 In parallel flow, the external convective heat transfer coefficient is calculated by considering the peripheric and central pipe
 173 to be a single united pipe. This united pipe together with the external water pipeline acts as a concentric tube annulus. The
 174 hydraulic diameter of the concentric tube annulus is calculated using Eq. (14):

$$D_h = \frac{4A_c}{P} = \frac{D_{ti}^2 - 10D_{po}^2 - D_{co}^2}{D_{ti} + 10D_{po} + D_{co}} \quad (14)$$

175 Then, Eq. (9) allows determining Reynolds number with D_h in place of D_i . The flow regime is laminar with calculated $Re = 745$
 176 (source-side fluid flow rate 60 g/s) and for the case of fully developed laminar flow in an annulus, with one surface insulated
 177 and another surface at a constant temperature, Nu_o entirely depends on the geometry of the concentric tube. Rohsenow et al.
 178 suggest $Nu_o = 4.17$ [29].

179 The external convective heat transfer coefficient is then determined using:

$$h_o = \frac{Nu_o k}{D_h} \quad (15)$$

180

181 In the case of crossflow, the flow structure can no longer be considered as an annulus, Eq. (14) for calculating hydraulic
 182 diameter is adjusted to Eq. (16) as follows [27]:

$$D_h = \frac{D_{co}^2 + 10D_{po}^2}{D_{co} + 10D_{po}} \quad (16)$$

183 To determine the Nusselt number on the external surface with calculated Re of about 52, the correlation for $Re < 500$
 184 presented by Hsu (1963) is used [30], as shown in Eq. (17). Although Churchill and Bernstein (1977) correlation [27] covers a
 185 larger range of Re through a single equation, the current study uses fixed source-side flow rate having constant Re , which
 186 makes Eq. (17) sufficient.

$$Nu = 0.43 + 0.48Re^{\frac{1}{2}} \quad (17)$$

187 The formula for the external convective heat transfer coefficient in crossflow remains the same as described in Eq. (15).

188

189 Heat transfer rates

190 The heat transfer rate of the heat exchanger is calculated with the outlet temperatures determined by using the Logarithmic
 191 Mean Temperature Difference (LMTD) method. For the peripheric pipe and central pipe, the LMTD is expressed in Eqs. (18)-
 192 (19) [27]:

$$LMTD_p = \frac{(T_{w,out} - T_{HTF,m}) - (T_{w,in} - T_{HTF,in})}{\ln\left(\frac{T_{w,out} - T_{HTF,m}}{T_{w,in} - T_{HTF,in}}\right)} \quad (18)$$

$$LMTD_c = \frac{(T_{w,out} - T_{HTF,m}) - (T_{w,in} - T_{HTF,out})}{\ln\left(\frac{T_{w,out} - T_{HTF,m}}{T_{w,in} - T_{HTF,out}}\right)} \quad (19)$$

193 It is worth noting the expression of LMTD is based on co-current flow pattern for peripheric pipes and counter-current flow for
194 the central one. This is furtherly illustrated in **Figure 4**.

195 Similarly, the heat conductance (UA) can be obtained for the peripheric and central pipe from Eqs. (5) and (6) as follows:

$$(UA)_p = \frac{1}{R_{tot,p}} \quad (20)$$

$$(UA)_c = \frac{1}{R_{tot,c}} \quad (21)$$

196 The outlet temperatures, including the middle and outlet temperature of the HTF fluid ($T_{HTF,m}$, $T_{HTF,out}$) and the outlet
197 temperature of the source-side fluid ($T_{w,out}$), can be derived by solving a system of three equations (22)-(24) with known
198 information of inlet temperatures, flow rates, and heat conductance.

$$(UA)_p LMTD_p = \dot{m}_{HTF} c_{p,HTF} (T_{HTF,m} - T_{HTF,in}) \quad (22)$$

$$(UA)_c LMTD_c = \dot{m}_{HTF} c_{p,HTF} (T_{HTF,out} - T_{HTF,m}) \quad (23)$$

$$\dot{m}_w c_{p,w} (T_{w,out} - T_{w,in}) = \dot{m}_{HTF} c_{p,HTF} (T_{HTF,in} - T_{HTF,out}) \quad (24)$$

199 With the solved outlet temperatures, the heat transfer rate is obtained respectively for the peripheric pipe and central pipe
200 using the heat transfer equations (25)-(26). The global heat transfer rate is the sum of two components in series (Eq. (27)).

$$\dot{Q}_p = \dot{m}_p c_{p,HTF} (T_{HTF,in} - T_{HTF,m}) \quad (25)$$

$$\dot{Q}_c = \dot{m}_c c_{p,HTF} (T_{HTF,m} - T_{HTF,out}) \quad (26)$$

$$\dot{Q} = \dot{Q}_p + \dot{Q}_c \quad (27)$$

201

202 **EXPERIMENTAL PROCEDURE AND DATA ANALYSIS**

203 **Experimental procedure**

204 The polymer heat exchanger is tested in a temperature-regulated water pipeline (with an internal diameter of 90 mm) for
205 source-side fluid under operating mode Case 1 (Table 1), as shown in **Figure 3**. The heat exchanger is designed to have a length
206 of 1.65 m, slightly shorter than the water pipeline. Both HTF and source-side fluid use water, and the inlet temperature of the
207 source-side and HTF is maintained at 30 °C and 20 °C respectively by two thermostats. HTF is fed into the heat exchanger from
208 the peripheric pipes and returned to the thermostat from the central pipe. At the heat exchanger inlet, outlet, and middle point,
209 as well as the inlet and outlet of the water pipeline, fluid temperatures are measured by K-type thermocouples. The HTF-side
210 pressure loss is measured by an AST5100 wet-wet differential pressure transmitter, with corresponding flow rates measured by

211 Coriolis mass flowmeters (mini CORI-FLOW, Bronkhorst). The heat exchanger model and its corresponding temperature
 212 profile in this working mode (Case 1) are illustrated in **Figure 4**.

213 During the experimental runs, the flow rate of the source-side fluid is kept at a constant value of 60 g/s. It is 4 to 15 times
 214 higher than the HTF flow rate (4.27-15.7 g/s) and allows a reasonable hypothesis of fixed temperature wall condition during
 215 heat convection coefficient estimation. The experiment is kept running continuously with varying HTF flow rates to determine
 216 its effects on the thermal performance of the heat exchanger. At each level of the HTF flow rates, four representative data points
 217 are chosen for further calculation and analysis. As a preliminary study, the influence of oscillation on heat exchanger
 218 performance is also tested. The oscillation is created manually by shaking the heat exchanger around its longitudinal axis. With
 219 the other end of the soft heat exchanger in free movement, a transient serpentine form is created with an amplitude of ± 35 mm
 220 and under a frequency of 1-2 Hz. Approximately 2-3 sinusoidal cycles constitute the total length of the heat exchanger (1.65
 221 m).

222 The reading of thermocouples and flowmeters are automatically recorded by a computer. The main measurement
 223 uncertainties are from the thermocouples and flowmeters and are within ± 0.5 °C and ± 0.1 g/s, respectively.

224




Figure 3 Schematic of the experimental setup.

225




Figure 4 The heat exchanger model (left) and the expected temperature profile (right) in heat recovery operating mode.

226

227

228 **Experimental data analysis**

229 The experimental heat transfer rate between the HTF and source-side fluid can be calculated respectively for the peripheric
230 pipes and central pipe using Eqs. (25)-(26), and the global heat transfer rate is the sum of the two components in series by Eq.
231 (27). The experimental LMTD is estimated using the same Eqs. (18)-(19) for the peripheric pipe and central pipe, respectively.

232 The heat conductance (UA) is determined as follows using the previously calculated LMTD:

$$(UA)_p = \frac{\dot{Q}_p}{LMTD_p} \quad (28)$$

$$(UA)_c = \frac{\dot{Q}_c}{LMTD_c} \quad (29)$$

233 The overall heat transfer coefficient (U) can be calculated individually for peripheric and central pipe:

$$U_p = \frac{(UA)_p}{A_p} \quad (30)$$

$$U_c = \frac{(UA)_c}{A_c} \quad (31)$$

234 Finally, the global heat transfer coefficient of the entire heat exchanger is obtained using the Eq. (7).

235

236 **RESULTS AND DISCUSSION**

237 **Temperature profiles**

238 The outlet temperatures ($T_{w,out}$, $T_{HTF,out}$ and $T_{HTF,m}$) of the polymer heat exchanger obtained from the experiment (EXP),
239 parallel flow (PF), and crossflow (CF) theoretical models by the LMTD method are compared at various HTF flow rates, as
240 shown in **Figure 5**. Constant inlet temperatures $T_{w,in}$ and $T_{HTF,in}$ are averaged at measured values of 30.14 °C and 20.75 °C,
241 respectively. As already illustrated in **Figure 4**, the HTF temperature lift can be divided into two parts: the temperature lifted in
242 the peripheric pipes ($T_{HTF,m} - T_{HTF,in}$) and the temperature lifted in the central pipe ($T_{HTF,out} - T_{HTF,m}$). Results reveal that,
243 with about three-fold heat transfer area, the temperature lift in the peripheric pipes is substantially higher compared to the
244 central pipe regardless of flow patterns. For example, for the HTF flow rate at 8.71 g/s, the experimental results show HTF
245 temperature is increased from 20.75 °C to 24.26 °C after the peripheric pipes and then to 24.62 °C at the outlet of the central
246 pipe. Moreover, since the flow rate of the source-side fluid (60 g/s) is about 4 to 15 times higher than the HTF flow rate, the
247 temperature change in the source-side fluid is significantly smaller than that of HTF. According to experimental results, the
248 maximum temperature difference in the source-side fluid is as low as 0.7 °C while the value is 6.09 °C in HTF. In addition,
249 compared with inlet temperatures, the experimental outlet temperatures in both HTF and source-side fluid (water) are between
250 those estimated by parallel flow and crossflow models, with crossflow giving the highest temperature differences. This confirms
251 the particular parallel-cross mixed flow pattern between the serpentine-shape soft heat exchanger and source-side fluid.




Figure 5: Comparison of outlet temperatures derived from experiment and theoretical models.

252

253 **Experimental heat transfer rate**

254 Heat transfer rate has been commonly used to evaluate the heat transfer performance of heat exchangers. With Eqs. (25)-
 255 (26), the experimental heat transfer rate of the polymer heat exchanger is calculated, and the results are shown in **Figure 6**. For
 256 both peripheric and central pipes, the heat transfer rate increases with higher HTF flow rates. For the highest flow rate of 15.70
 257 g/s, the total heat transfer rate under the test condition (hot and cold inlets being respectively 30.14 °C and 20.75 °C) can
 258 achieve 168 W, leading to a linear value of 102 W/lm (watt per linear meter). Moreover, the peripheric pipes dominate the
 259 performance of the heat exchanger, accounting for 87%-95% of the global heat transfer rate in the tested flow range (22 W for
 260 the central pipe and 146 W for peripheric ones in the case of 168 W). This is mainly due to the relatively larger heat transfer
 261 surface of the peripheric pipe (0.145 m²) than that of the central one (0.052 m²).

262 It worth noting the pressure loss of the HTF side is also measured for all flow rates and results show a maximal pressure
 263 drop of 24 588 Pa for the total length of 1.65 m. Details are given in **Appendix A1**.

264




Figure 6 Experimental heat transfer rates for peripheric and central pipes at different HTF flow rates. (Error bars represent the standard deviation for a set of 4 repetitive test results)

266 **Comparison with theoretical models**

267 The characteristics of heat exchanger in crossflow and parallel flow are studied with the theoretical LMTD model, which is
 268 validated by NTU- ϵ method (details in **Appendix A2**). The results are compared with the experimental ones, as illustrated in
 269 **Figure 7** and **Figure 8**. It worth noting that the aim of theoretical models is to provide upper and lower limits of the
 270 experimental performance, instead of validating experimental results.

271 **Figure 7** shows the global heat transfer rate obtained from the experiment, parallel flow and crossflow theoretical models. It
 272 shows that the experimental result is in between the data provided by parallel flow and crossflow correlations. Comparing with
 273 the experimental results, the crossflow theoretical model gives 34%-64% higher global heat transfer rate in the studied range of
 274 HTF flow rate, of which 64% occurs at the highest HTF flow rate of 15.70 g/s; while the values are 50%-62% lower in the
 275 parallel flow. Therefore, it can be concluded that the actual flow in the heat exchanger during experimental runs is neither pure
 276 parallel flow nor crossflow, but a combination of the two.

277 **Figure 8** shows similar trends in terms of the global heat transfer coefficient. Compared with the experimental results,
 278 which range from 100 to 110 W/m²·K, the theoretical overall heat transfer coefficient in crossflow could double the
 279 experimental performance, whereas the coefficient in parallel flow could be reduced to 1/3. In other words, the theoretical
 280 model in crossflow and parallel flow prescribe an upper and a lower limit of thermal performance to the actual flow in the heat
 281 exchanger. Moreover, as the HTF flow rates increase and the corresponding internal flow regime turns from laminar to
 282 turbulent flow, the global heat transfer coefficient keeps stable for all three data series. This implies that the global heat transfer
 283 coefficient might be mainly limited by the external convection or the heat conduction through walls, instead of the internal
 284 convection.

285




Figure 7 Comparison between experimental and theoretical global heat transfer rate.

Experiments are conducted with serpentine-shape heat exchanger in a straight water pipeline, which is a combination of crossflow and parallel flow. The theoretical results from crossflow and parallel flow convection correlation provide upper and lower limits of the heat exchanger performance.

286

287




Figure 8 Experimental global heat transfer coefficient and its upper and lower limits provided by theoretical cross-flow (CF) and parallel-flow (PF) models.

288

289

290 Thermal resistances

291

As over 87% of the global heat transfer rate is exchanged through the peripheric pipes, only the thermal resistances of the peripheric part is studied in this section. **Figure 9** illustrates the influence of HTF flow rates and flow patterns (parallel flow and crossflow) on the three thermal resistances of peripheric pipes (R_{pi} , R_{pw} , and R_{po}). Clearly, the total thermal resistance is considerably lower in crossflow than parallel flow, by a factor of about 7. Since the internal Dean flow for the case of crossflow pattern is considered negligible in this study, the only difference between parallel and crossflow lies in the external convection. It shows that external convective thermal resistance is the principal resistance in both flow patterns, accounting for more than 90% of the total thermal resistance in parallel flow and about 50% in crossflow. This is due to the influence of a considerably lower external convective heat transfer coefficient caused by a larger hydraulic diameter on the external surface in comparison with the internal one. Therefore, the increase of HTF flow rates, which enhances the internal convection only, has little influence on the global thermal resistances in all flow rates and for both flow patterns. More importantly, comparing the three thermal resistances, the wall resistance in peripheric pipes (R_{pw}) is the lowest. The use of low-conductivity polymer can be potentially competitive to metal-made heat exchangers. Since the situation is slightly different in the central pipe, global heat exchange coefficient should be used to investigate the influence of thermal conductivity.

304

305




Figure 9 Thermal resistances of peripheric pipes in the cases of parallel flow and crossflow.

306

307 Comparison with metal heat exchangers

308 With the theoretical model, the material thermal conductivity is studied to determine its effects on the thermal performance
 309 of the heat exchanger in both cases of parallel flow and crossflow. The results obtained with PU ($\lambda = 0.29$ W/m·K) are
 310 compared with three selected metal heat exchangers, titanium, aluminum, and copper, whose thermal conductivity are 22
 311 W/m·K, 236 W/m·K, and 398 W/m·K, respectively. The global heat transfer coefficient is used as bases for comparison under
 312 the same working conditions: $\dot{m}_{HTF} = 10.86$ g/s, $T_{HTF,in} = 20.7$ °C, $T_{w,in} = 30.1$ °C, $\dot{m}_w = 60$ g/s. Three fictive PU with their
 313 thermal conductivities multiplied by a factor of 2, 4, and 6 are also analysed.

314 **Figure 10** shows the theoretical results of the global heat transfer coefficient as a function of thermal conductivity in the
 315 case of crossflow and parallel flow. The detailed comparison results, as well as their relative performance ratios to each metal
 316 heat exchanger, are listed in **Table 2** and **Table 3**. The polymer heat exchanger shows promising performance compared with
 317 conventional metal ones with the same dimension and working conditions. For crossflow in **Figure 10**, the polymer heat
 318 exchanger is expected to have a U-value of 209.44 W/m²·K, while the best metal performance (Copper) gives 312.18 W/m²·K.
 319 For parallel flow, the values are respectively 36.18 W/m²·K and 39.37 W/m²·K. From the comparison results in **Table 2** and
 320 **Table 3**, it is clear that the thermal performance of the heat exchanger made of PU can achieve about 67% and 92% of the
 321 titanium, aluminum, or copper heat exchanger in crossflow and parallel flow, respectively. If the thermal conductivity is doped
 322 by a factor of 6, reaching 1.74 W/m·K, the heat exchanger performance can achieve about 90% and 99% of the three selected
 323 metal materials, respectively in crossflow and parallel flow. As previously discussed, the experimental performance of PU-
 324 made heat exchanger is limited by the parallel flow and crossflow models, it is reasonable to conclude that the heat exchanger
 325 can achieve a performance of 67%-92% of titanium, aluminum, or copper heat exchangers.

326 **Figure 10** also provides a design guide for polymer heat exchangers in terms of material choice. In the case of crossflow,
 327 there is a critical value (about 5.0 W/m·K) of material thermal conductivity that divides the performance curve into two parts.
 328 Below this value, the curve is very sharp, which means that improving thermal conductivity will considerably boost the heat
 329 exchanger thermal performance. However, over this value, the curve tends to be flat at 312 W/m·K and thus improving thermal
 330 conductivity contributes very little to the heat performance enhancement. In the case of parallel flow, the important critical
 331 value is about 1 W/m·K. Above this value, increasing thermal conductivity has little effect on the curve since U-value tends to
 332 stay at a constant global heat transfer coefficient of approximately 40 W/m²·K. From the heat exchange performance point of

333 view, improving thermal conductivity is worthless after the critical value since the main thermal resistance comes from the
 334 convective heat transfer, in particular the external one, rather than the pipe heat conduction (see **Figure 9**). As the real
 335 serpentine shape heat exchanger should be in between parallel and crossflow, the critical heat conductivity should be between 1
 336 and 5 W/m·K.
 337




Figure 10 Theoretical relation between global heat transfer coefficient and material thermal conductivity in the case of crossflow (left) and parallel flow (right) (working conditions: $\dot{m}_{HTF} = 10.86$ g/s, $T_{HTF,in} = 20.7$ °C, $T_{w,in} = 30.1$ °C, $\dot{m}_w = 60$ g/s).

338

339 **Table 2** Performance comparison between heat exchanger made of different materials in crossflow.

Heat exchanger material	λ [W/m·K]	U [W/m ² ·K]	U/U_{Ti}	U/U_{Al}	U/U_{Cu}
Polyurethane (PU)	0.29	209.44	0.678	0.671	0.671
2·PU	0.58	242.10	0.783	0.776	0.776
4·PU	1.16	267.74	0.866	0.858	0.858
6·PU	1.74	279.36	0.904	0.895	0.895
Titanium (Ti)	22	309.03	1	0.990	0.990
Aluminum (Al)	236	312.05	1.010	1	1.000
Copper (Cu)	398	312.18	1.010	1.000	1

340

341 **Table 3** Performance comparison between heat exchanger made of different materials in parallel flow.

Heat exchanger material	λ [W/m·k]	U [W/m ² ·K]	U/U_{Ti}	U/U_{Al}	U/U_{Cu}
Polyurethane (PU)	0.29	36.18	0.920	0.919	0.919
2·PU	0.58	37.62	0.957	0.956	0.956
4·PU	1.16	38.45	0.978	0.977	0.977
6·PU	1.74	38.75	0.985	0.984	0.984
Titanium (Ti)	22	39.32	1	0.999	0.999
Aluminum (Al)	236	39.37	1.001	1	1.000
Copper (Cu)	398	39.37	1.001	1.000	1

342

343

344

346 **Performance enhancement by oscillation – preliminary results**

347 As one of the advantages of using soft material, oscillation and its influence on thermal performance is studied
 348 experimentally. Manually agitation of the heat exchanger around its longitudinal axis creates serpentine-like movement with
 349 transient deformation. As described earlier, the heat exchanger deforms as an external force is applied, either from mechanical
 350 shaking or from the natural flow of the source side fluid. **Figure 11** shows some preliminary experimental results of the heat
 351 transfer rate for a continuous experimental run at four different HTF flow rates. It is found that oscillation significantly
 352 improves thermal performance by more than 30% regardless of the HTF flow rates. This is presumably due to the disturbance
 353 of the flow characteristics by movement, which perturbs the thermal boundary layer and thus improves the external heat
 354 convection. As previously discussed, results from the theoretical model indicate that principal thermal resistance lies in the
 355 external convection between the pipe and source-side fluid. Disturbance from manual shaking allows a continuous reduction of
 356 the thermal boundary layer since the flow pattern alternates between parallel flow and crossflow. As a result, the crossflow
 357 pattern would be more pronounced than in a stationary situation.

358 The thermal performance improvement by movement can be better illustrated by comparing the experimental results (with
 359 and without oscillation) with the theoretical performance limits (parallel flow and crossflow) under the same working
 360 conditions, as shown in **Figure 12** (left). Compared with the stationary case, a clear increase of 30% in heat transfer rate is
 361 observed for the heat exchanger under oscillation, which suggests an enhanced thermal performance closer to that of crossflow
 362 (+60%). However, the performance is still within the theoretical performance range limited by parallel flow and crossflow
 363 correlations. It offers evidence that more crossflow pattern is presenting in the heat exchanger subjected to oscillational
 364 movement. The major heat transfer enhancement under oscillation may be explained by plotting the global heat transfer
 365 coefficient against Re in peripheric pipes, as shown in **Figure 12** (right). In peripheric pipes, Re ranges from 379 to 873 with
 366 corresponding HTF flow rates from 6.35 to 15.59 g/s. A significant rise in the global heat transfer coefficient by about 50% can
 367 be observed for the heat exchanger under movement.

368




Figure 11 Heat transfer rates comparison between fixed and oscillation positions at different HTF flow rates.

369




Figure 12 Heat transfer improvement by oscillation of the heat exchanger in the source-side fluid: (left) experimental results and theoretical limits and (right) experimental global heat transfer coefficients with respect to Re .

370

371

372

CONCLUSIONS AND PERSPECTIVES

373

In this paper, a patented soft polymer heat exchanger for wastewater heat recovery is studied to explore its heat transfer characteristics, including heat transfer rate, heat transfer coefficient, and thermal resistance. The effect of material thermal conductivity and oscillation on the thermal performance justifies the interests of the novel heat exchanger. Both experiments and theoretical calculations are carried out.

377

Experimental results show a global heat transfer coefficient between 100-110 W/m²·K for an HTF flow rate of 4.27-15.70 g/s and 60 g/s at the source side. It is further found that with a heat transfer area three times larger than the central pipe, the peripheric pipes are largely dominating (over 87%) the performance of the heat exchanger in terms of heat transfer rate. In addition, when subjected to a manually assisted serpentine-like movement, the heat exchanger shows a significantly better performance, with an increase of about 30% compared with a stationary situation.

382

The theoretical models demonstrate that the performance of the polymer heat exchanger is in between the parallel and crossflow heat exchangers with the same configuration. More specifically, the experimental global heat transfer rate is up to 64% lower than the theoretical value in crossflow while up to 62% higher than those estimated by the parallel flow model. Hence, it reveals that the actual flow pattern in the experiment is a combination of parallel flow and crossflow. In terms of thermal resistance, theoretical results confirm that the external convective thermal resistance is the dominant one, and the low thermal conductivity of polymer does not significantly deteriorate the global heat transfer coefficient.

388

With the theoretical models, a sensitivity study on the material thermal conductivity on heat exchanger performance is investigated. The results show that there is a critical value that divides the performance curve of the heat exchanger into two parts. Below this value, improving thermal conductivity will considerably boost the heat exchanger performance while over this value improving thermal conductivity contributes very little to the heat performance enhancement. This critical value is about 5.0 W/m·K in the crossflow heat exchanger and 1.0 W/m·K in the parallel flow heat exchanger. For the specific polymer heat exchanger made of polyurethane in this paper, it can reach 67% and 92% of the titanium, aluminum, and copper heat exchanger

393

394 performance in crossflow and parallel flow, respectively. It can be concluded that using polymer materials to make heat
395 exchangers can be thermally competitive to the conventional metal-based heat exchangers.

396 The polymer heat exchanger presented in this paper shows high potentiality to be used in the wastewater heat recovery
397 application, not only because of the merits of using polymer materials but also its unique adaption to the installation
398 environment. Firstly, it is flexible and can be changed to any shape as required. Secondly, due to the low weight, it always
399 floats on the upper part of the wastewater where the water temperature is usually higher than the bottom part. In this way, the
400 heat transfer between wastewater and HTF can be maximized. As mentioned previously, the heat exchanger performance
401 potentially can be further improved in a crossflow environment or under movement. Future works will be focused on the study
402 of heat transfer enhancement by vibration with different frequencies and amplitudes preferably induced by source-side fluid.
403 Other perspectives include the implementation of the polymer heat exchanger in a real case with specific environments.
404

405 ACKNOWLEDGEMENTS

406 The authors would like to acknowledge research supports provided by Erganeo (France), I-SITE FUTURE (France),
407 ERASMUS program (European Union) as well as China Scholarship Council (P.R. China).
408

409 REFERENCES

- 410
- 411 [1] Energy Information Administration (EIA), International Energy Outlook 2019, (2019). <https://www.eia.gov/outlooks/ieo/pdf/ieo2019.pdf> (accessed
412 April 8, 2020).
 - 413 [2] International Energy Agency (IEA), Cities are at the frontline of the energy transition, (2016). [https://www.iea.org/news/cities-are-at-the-frontline-of-](https://www.iea.org/news/cities-are-at-the-frontline-of-the-energy-transition)
414 [the-energy-transition](https://www.iea.org/news/cities-are-at-the-frontline-of-the-energy-transition) (accessed April 8, 2020).
 - 415 [3] X. Guo, A.P. Goumba, C. Wang, Comparison of direct and indirect active thermal energy storage strategies for large-scale solar heating systems,
416 *Energies*. 12 (2019). <https://doi.org/10.3390/en12101948>.
 - 417 [4] X. Hao, J. Li, M.C.M. Van Loosdrecht, H. Jiang, R. Liu, Energy recovery from wastewater: Heat over organics, (2019).
418 <https://doi.org/10.1016/j.watres.2019.05.106>.
 - 419 [5] A. Mazhar, S. Liu, A. Shukla, A Key Review of Non-Industrial Greywater Heat Harnessing, *Energies*. 11 (2018) 386.
420 <https://doi.org/10.3390/en11020386>.
 - 421 [6] I. Takashi, A. Toshiya, H. Keisuke, Life cycle inventory analyses for CO2 emission and cost of district heating and cooling systems using wastewater
422 heat (in Japanese), *J. JSCE (Japan Soc. Civ. Eng. Div. D Environ. Syst. Eng.* 64 (2008) 107–122.
 - 423 [7] X. Guo, M. Hendel, Urban water networks as an alternative source for district heating and emergency heat-wave cooling, *Energy*. 145 (2018) 79–87.
424 <https://doi.org/10.1016/j.energy.2017.12.108>.
 - 425 [8] J.P. van der Hoek, S. Mol, S. Giorgi, J.I. Ahmad, G. Liu, G. Medema, Energy recovery from the water cycle: Thermal energy from drinking water,
426 *Energy*. 162 (2018) 977–987. <https://doi.org/10.1016/j.energy.2018.08.097>.
 - 427 [9] CELSIUS, Waste heat recovery from sewage water in Cologne, Germany, (2020). [https://celsiuscity.eu/waste-heat-recovery-from-sewage-water-in-](https://celsiuscity.eu/waste-heat-recovery-from-sewage-water-in-cologne-germany/)
428 [cologne-germany/](https://celsiuscity.eu/waste-heat-recovery-from-sewage-water-in-cologne-germany/) (accessed May 4, 2020).
 - 429 [10] CELSIUS, Excess heat from sewage in Hamburg and Singen, Germany, (2020). [https://celsiuscity.eu/excess-heat-from-sewage-in-hamburg-and-](https://celsiuscity.eu/excess-heat-from-sewage-in-hamburg-and-singen-germany/)
430 [singen-germany/](https://celsiuscity.eu/excess-heat-from-sewage-in-hamburg-and-singen-germany/) (accessed May 4, 2020).
 - 431 [11] ReUseHeat, Nice, (n.d.). <https://www.reuseheat.eu/nice/> (accessed May 4, 2020).
 - 432 [12] Veolia, Opening of a new Energido unit in Aix-les-Bains: Veolia transforms into wastewater to produce energy, (2015).
433 <https://www.veolia.com/en/veolia-group/media/news/opening-new-energido-unit-aix-les-bains-veolia-recycles-wastewater-produce-energy> (accessed
434 May 4, 2020).
 - 435 [13] D.J. Dürrenmatt, O. Wanner, A mathematical model to predict the effect of heat recovery on the wastewater temperature in sewers, *Water Res.* 48
436 (2014) 548–558. <https://doi.org/10.1016/j.watres.2013.10.017>.
 - 437 [14] L. Chen, Z. Li, Z.Y. Guo, Experimental investigation of plastic finned-tube heat exchangers, with emphasis on material thermal conductivity, *Exp.*
438 *Therm. Fluid Sci.* 33 (2009) 922–928. <https://doi.org/10.1016/j.exptthermflusci.2009.04.001>.
 - 439 [15] H. Bart, S. Scholl, eds., *Innovative Heat Exchangers*, Springer International Publishing AG, Cham, Switzerland, 2018.
440 <https://doi.org/https://doi.org/10.1007/978-3-319-71641-1>.

- 441 [16] A. Laval, Alfa Laval brochure-spiral heat exchangers, n.d. [http://www.heat-transfer-solutions.com/documents/alfa-laval-spiral-heat-exchanger---](http://www.heat-transfer-solutions.com/documents/alfa-laval-spiral-heat-exchanger---brochure.pdf)
442 [brochure.pdf](http://www.heat-transfer-solutions.com/documents/alfa-laval-spiral-heat-exchanger---brochure.pdf) (accessed May 4, 2020).
- 443 [17] X. Chen, Y. Su, D. Reay, S. Riffat, Recent research developments in polymer heat exchangers - A review, *Renew. Sustain. Energy Rev.* 60 (2016)
444 1367–1386. <https://doi.org/10.1016/j.rser.2016.03.024>.
- 445 [18] O. Breuer, U. Sundararaj, Big returns from small fibers: a review of polymer/carbon nanotube composites, *Polym. Compos.* 25 (2004) 630–645.
- 446 [19] Y.P. Mamunya, V. V Davydenko, P. Pissis, E. V Lebedev, Electrical and thermal conductivity of polymere filled with metal powders, *Eur. Polym. J.*
447 38 (2002) 1887–1897.
- 448 [20] J. Shi, J. Hu, S.R. Schafer, C.L. Chen, Numerical study of heat transfer enhancement of channel via vortex-induced vibration, *Appl. Therm. Eng.* 70
449 (2014) 838–845. <https://doi.org/10.1016/j.applthermaleng.2014.05.096>.
- 450 [21] W. Liu, Z. Yang, B. Zhang, P. Lv, Experimental study on the effects of mechanical vibration on the heat transfer characteristics of tubular laminar
451 flow, *Int. J. Heat Mass Transf.* (2017). <https://doi.org/10.1016/j.ijheatmasstransfer.2017.07.025>.
- 452 [22] S.W. Chen, F.C. Liu, H.J. Lin, P.S. Ruan, Y.T. Su, Y.C. Weng, J.R. Wang, J. Der Lee, W.K. Lin, Experimental test and empirical correlation
453 development for heat transfer enhancement under ultrasonic vibration, *Appl. Therm. Eng.* 143 (2018) 639–649.
454 <https://doi.org/10.1016/j.applthermaleng.2018.07.133>.
- 455 [23] M. Legay, B. Simony, P. Boldo, N. Gondrexon, S. Le Person, A. Bontemps, Improvement of heat transfer by means of ultrasound: Application to a
456 double-tube heat exchanger, *Ultrason. Sonochem.* 19 (2012) 1194–1200. <https://doi.org/10.1016/J.ULTSONCH.2012.04.001>.
- 457 [24] M. Legay, O. Bulliard-Sauret, S. Ferrouillat, P. Boldo, N. Gondrexon, Methods to Evaluate Heat Transfer Enhancement in an Ultrasonic Heat
458 Exchanger, *Heat Transf. Eng.* (2019) 1–16. <https://doi.org/10.1080/01457632.2019.1649917>.
- 459 [25] X. Guo, Flexible heat exchanger intended to be positioned in a moving exterior fluid, comprising a collection of flexible temperature probes,
460 WO2020049233A1, 2020.
- 461 [26] H. Wang, L. Balasubramaniam, S.D. Marshall, X. Jin, R. Arayanarakool, P.S. Lee, P.C.Y. Chen, Numerical Study of Heat Transfer Enhancement of
462 Roll-to-Roll Microchannel Heat Exchangers, *J. Heat Transfer.* 140 (2018) 1–8. <https://doi.org/10.1115/1.4038910>.
- 463 [27] T.L. Bergman, A.S. Lavine, F.P. Incropera, D.P. Dewitt, *Fundamental of Heat and Mass Transfer*, Seventh Ed, John Wiley & Sons, 2011.
- 464 [28] S.W. Churchill, Friction-factor equation spans all fluid-Flow regimes, *Chem. Eng. (New York)*. 84 (1977) 91–92.
- 465 [29] W.M. Rohsenow, J.P. Hartnett, Y.I. Cho, *Handbook of heat transfer*, Third Edit, McGraw-Hill, New York, 1998. [https://doi.org/10.5860/choice.36-](https://doi.org/10.5860/choice.36-3347)
466 [3347](https://doi.org/10.5860/choice.36-3347).
- 467 [30] R. Karwa, *Heat and Mass Transfer*, Springer, Singapore, 2017. <https://doi.org/10.1007/978-981-10-1557-1>.
- 468

469 **APPENDICES**

470 **A1: Pressure loss**

471 The pressure drop through the HTF side is measured by an AST5100 wet-wet differential pressure transmitter. HTF flowrate
 472 ranges from 4.3 to 15.7 g/s, and it the same with the thermal performance part. The pressure loss follows a logarithmic trend
 473 with respect to the mass flowrate, and its maximal and minimum values are respectively 7 132 Pa and 24 588 Pa for the total
 474 length of 1.65 m.

475




Figure A1 HTF side pressure loss at the full range of flow rates.

476

477 **A2: Validation of LMTD with NUT- ϵ method**

478 In order to validate theoretical results calculated from the LMTD method, NTU- ϵ method is used. The heat transfer rate is
 479 calculated separately for the peripheric pipe and central pipe. As the calculation procedures are the same, here taking the
 480 peripheric pipe as an example. The heat capacity rates (C) for the two fluids are determined as shown in Eqs. (32)-(33). The
 481 heat capacity ratio (C_r) is then the minimum value to the maximum value of the two heat capacity rates (C_{HTF} , C_w).

$$C_{HTF} = \dot{m}_{HTF} c_{p,HTF} \quad (32)$$

$$C_w = \dot{m}_w c_{p,w} \quad (33)$$

$$C_r = \frac{\min(C_{HTF}, C_w)}{\max(C_{HTF}, C_w)} \quad (34)$$

482 The Number of Transfer Units (NTU) is defined as:

$$NTU = \frac{(UA)_p}{\min(C_{HTF}, C_w)} \quad (35)$$

483 The effectiveness (ϵ) is then estimated from Eqs. (36)-(37) depending on the flow patterns in the pipe [27]:

$$\varepsilon_p = \frac{1 - \exp[-NTU(1 + C_r)]}{1 + C_r} \quad (\text{in parallel flow, peripheric pipe}) \quad (36)$$

$$\varepsilon_c = \frac{1 - \exp[-NTU(1 - C_r)]}{1 - C_r \exp[-NTU(1 - C_r)]} \quad (\text{in crossflow, } C_r < 1, \text{ central pipe}) \quad (37)$$

484 Finally, the heat transfer rate can be evaluated according to Eqs. (38)-(39) from the above calculated results. The global heat
485 transfer rate is calculated using Eq. (27).

$$\dot{Q}_p = \varepsilon_p \cdot \min(C_{HTF}, C_w)(T_{w,in} - T_{HTF,in}) \quad (38)$$

$$\dot{Q}_c = \varepsilon_c \cdot \min(C_{HTF}, C_w)(T_{w,in} - T_{HTF,m}) \quad (39)$$

486 With the heat transfer rates, the outlet temperatures can be determined as follows:

$$T_{HTF,m} = T_{HTF,in} + \frac{\dot{Q}_p}{C_{HTF}} \quad (40)$$

$$T_{HTF,out} = T_{HTF,m} + \frac{\dot{Q}_c}{C_{HTF}} \quad (41)$$

$$T_{w,out} = T_{w,in} - \frac{\dot{Q}}{C_w} \quad (42)$$

487

488 The comparison results of the HTF outlet temperature in crossflow derived from LMTD and NTU- ε methods are illustrated in
489 **Figure A2**. The results obtained from LMTD method are numerically in line with that from NTU- ε method. The temperature
490 differences between two methods are only 0.1 °C and 0.05 °C respectively at the HTF middle and outlet locations, which
491 indicates that the LMTD method is highly accurate.




Figure A2 A comparison between the HTF outlet temperatures in crossflow as calculated from LMTD and NTU- ε methods.

492

493