



# Open-Switch Fault-Tolerant Operation of a Two-Stage Buck/Buck–Boost Converter With Redundant Synchronous Switch for PV Systems

Saima Siouane, Slavisa Jovanovic, Philippe Poure

## ► To cite this version:

Saima Siouane, Slavisa Jovanovic, Philippe Poure. Open-Switch Fault-Tolerant Operation of a Two-Stage Buck/Buck–Boost Converter With Redundant Synchronous Switch for PV Systems. IEEE Transactions on Industrial Electronics, 2019, 66 (5), pp.3938-3947. 10.1109/TIE.2018.2847653 . hal-02987916

**HAL Id: hal-02987916**

**<https://hal.science/hal-02987916>**

Submitted on 8 Feb 2022

**HAL** is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

# Open-switch Fault Tolerant Operation of a Two-Stage Buck/Buck-Boost Converter with redundant synchronous switch for PV systems

Saima Siouane, *Student Member, IEEE*, Slaviša Jovanović, *Member, IEEE*,  
Philippe Poure, *Member, IEEE*

**Abstract**—In PV systems, DC-DC converters have been identified as one of the most critical and challenging subsystem in terms of failure rate. Thus, this paper proposes fault tolerant operation of a two-stage Buck/Buck-Boost converter under open-circuit switch failure. Remedial actions are efficient in any failure of one of the two switches of the converter. Here, a new unified approach is considered, for the overall fault tolerant operation of the two stages of the converter. The fault tolerant circuit we propose lies on performing redundancy by implementing the equivalent synchronous switch for the two main switches of the two stages, in offline mode. The fault tolerant circuit results from the basic two-stage Buck/Buck-Boost converter and its equivalent circuit with a synchronous switch, merged together to form the new DC-DC fault tolerant circuit. Therefore, post-fault operation at full power can also be performed. By using a switch fault management unit with reduced complexity, inserted between the control block and the switches, we have designed a unified, efficient and optimized fault tolerant control, suitable in both healthy and post-fault operations. Some selected experimental tests, which all confirm the good performances of the proposed fault tolerant approach, are presented and discussed.

**Index Terms**—Switch failure, fault tolerant operation, open-circuit failure, two-stage converter, Buck, Buck-Boost, synchronous redundant switch.

## I. INTRODUCTION

In the past decades, many research works have targeted the use of renewable energy sources such as Photovoltaic (PV). A failure may occur in any part of the system such as PV panel or DC-DC conversion. To ensure service continuity, an approach based on fault tolerant operation is mandatory. Research works in PV reliability studies are focused on storage devices and power electronic converters that are identified as the most critical and challenging utility interface in terms of failure rate, lifetime, and maintenance cost [1]. The converter failures, caused by semi-conductors, account for 21% of the total failures in power converters, thus challenging the reliability of the system [2]. According to a survey [2], semiconductor and soldering joints failures in power devices take up 34% of

power electronic system failures. Therefore, fault tolerant operation for converters used in PV systems should be proposed.

Service continuity under switch failure in PV systems is the general goal of this paper. It can be performed with the integration of fault tolerance and requires two main steps: first, fault detection and identification, also known as “fault diagnosis”; and second, “remedial actions” [1], also called “Fault tolerant operation” [2], [3]. The first step identifies the location and nature of the failure: open or short circuit failures can be considered. The “remedial actions” are the process to first electrically isolate the faulty component, if needed, and then, reconfigure the converter by using a suitable fault tolerant control. Physical fault isolation is always required in the case of a short-circuit switch failure to cut the current path, before reconfiguring the converter. In this case, the damaged switch can be electrically isolated by a fuse or by controllable components (relay, triac or switch). These additional components can be inserted in series with the faulty switch or in a shoot-through loop across the DC bus. Whatever solution is implemented, the short-circuit switch failure becomes an open-circuit switch failure, after isolation. For this reason, only open-circuit switch failure will be addressed in our contribution. More, one can also notice that system performances could be degraded in post-fault operation [2].

In this paper, the “fault diagnosis” step is not considered. Switch fault diagnosis in DC-DC converters has been the subject of intensive research for more than several decades and fruitful results have been reported [3]–[13]. One of these algorithms and methods can be indifferently used for open circuit switch fault diagnosis for the studied two-stage converter. Our contribution focuses on “remedial actions” for service continuity in two-stage converters under open-circuit failure of one of the two switches. It proposes the design of a redundant circuit associated with an optimized control strategy, which employs an added switch  $S$  to replace functionally both of the two original switches  $S_1$  and  $S_2$  of the two-stage converter in faulty mode. In doing so, the proposed method is better than the conventional redundancy approaches in terms of switch number.

In the following section, a general overview of fault tolerant approaches for DC-DC converters is presented. Then, the “remedial actions” proposed in this paper in the case of a Buck/Buck-Boost converter are introduced and their originality is highlighted, compared with the state of the art.

In Section III, the proposed Buck/Buck-Boost fault tolerant circuit is introduced and studied in detail. It is efficient in any open-circuit failure of one of the two switches in the circuit; more, it guarantees service continuity at full power. Then, in Section IV, a suitable and optimized fault tolerant control is also proposed. A unified control is applied in both healthy and faulty conditions; only a fault management interface is placed between the unified control outputs and the drivers of the switches. It applies the suited switching pattern by adapting the switching control orders in open circuit switch failure. For verification, experimental tests are realized. The fault-tolerant Buck/Buck-Boost converter was built in our laboratory; the control is implemented on a dSPACE target and tested experimentally. Some selected experimental results are provided in Section V. It is shown that the fault-tolerant converter continues to supply the load at full power, even with an open circuit failure in one of the semiconductor switches.

## II. REMEDIAL ACTIONS FOR FAULT TOLERANT DC-DC CONVERTERS

### A. Introduction

When considering fault tolerant operation, the word “redundancy” comes to mind. Let’s first define what is covered by this common concept of redundancy; “redundancy” means that some components are duplicated or added in the basic converter structure, as a precaution against switch failure and to perform service continuity. This means that the principle of parallel operation of similar subsystems, converters or components, widely used in industrial applications and commonly called “N+k redundant configuration”, is not the only one concerned and only some components can be added (switch, relay, semi-conductor-controlled rectifier, thyristor, ...) for fault tolerant purpose. In general, k is equal to 1, for cost considerations. In any case, it is commonly accepted that fault tolerant operation is always based on hardware redundancy design with a corresponding fault tolerant control [2].

Numerous remedial actions and approaches for fault tolerant DC-DC converters are separately reported in the recent literature. In the case of semiconductor failures, a general classification about fault tolerant techniques for power electronics converters was recently proposed by W. Zhang *et al.* [2]. In this survey, three-phase and multilevel converters are the most concerned; therefore, the particular case of DC-DC converters is not considered. In the spirit of this survey and based on the various cases presented in the literature, this section aims to present a comprehensive synthesis of the remedial actions in non-isolated DC-DC converters case, illustrated by some selected publications. The innovative approach we propose will be finally discussed, comparatively.

Based on the scientific literature, remedial actions for non-isolated DC-DC converters are based on redundant switches. Various scenarios are proposed in the literature; they can be categorized in two cases, depending if the redundant switch is connected in parallel with the main switch, or separated from it. Let’s first consider the case of DC-DC circuits where the redundant switch is connected in parallel with the main switch. In this case, the redundant switch is not

separated from the main switch. It is not used during normal operation and is activated during the reconfiguration process of the circuit, to replace the corresponding faulty switch. This approach has been proposed in [4] where fault diagnosis and remedial actions for single switch DC-DC converters are studied. Nevertheless, in such an offline scheme, extra switches do not operate in healthy conditions; consequently, for cost considerations, they can be shared in a system to replace multiple main switches of similar DC-DC converters, potentially faulty. In this case, additional linking components, such as selecting relays or thyristors, are often associated with the shared redundant switch. In [5], this approach has been validated in multiple parallel step-up DC-DC converters connected to a common DC bus, where a single redundant switch is shared with all the converters. Notice that when the redundant switch is shared, it becomes separated from the main switches by the linking components.

Dylan Lu *et al.* proposed a step-down dual-switch DC-DC converter with open-switch fault-tolerant capability, where the redundant switch is not connected in parallel to the main switch [14] but is separated from it. This new converter is derived from the two classical Buck and Buck-Boost step-down topologies, merged together to form the new DC-DC circuit. Consequently, when one of the two switches fails, the other one can be activated to continue step-down operation. Nevertheless, the duty cycles being different in Buck and Buck-Boost operation modes, the post-fault control must be modified accordingly, to guarantee the same regulation.

### B. Proposed reconfiguration based on synchronous redundant switch

Open-circuit switch fault tolerance of two-stage DC-DC converters, by implementing a global reconfiguration (for the two stages) and based on synchronous redundant switch, is a novel approach, first proposed in this paper. It is first introduced in this sub-section and will be detailed and applied in Section III, in the case of a two-stage Buck/Buck-Boost converter. As mentioned before, fault tolerant approach is always based on hardware redundancy, associated to a suitable control strategy; this is also the case of the approach we propose. Furthermore, all the hardware fault tolerant approaches published in the literature concern single-stage DC-DC converters or modular converters based on identical DC-DC conversion modules; so, an unified approach for the overall fault tolerant operation of two-stage converters has never been considered.

Nevertheless, two-stage converters are commonly used in PV systems; conventionally, the front stage tracks the Maximum Power Point while the second one regulates the output voltage. Here, we consider a Buck/Buck-Boost two-stage structure, thus including two active switches. Commonly, these two switches are separately and asynchronously controlled. Based on the state of the art, the first idea that comes to mind to perform fault tolerant operation is to apply in offline mode the “redundant switches” approach, by connecting one redundant switch in parallel with each of the two main switches. Furthermore, for the considered converter, it is not possible to share a common redundant switch with linking components because




Fig. 1. PV system with two-stage DC-DC conversion and energy storage.

the main switches have not the same current directions, as it will be demonstrated in the following section. Finally, considering the classical approaches, using two redundant parallel switches is mandatory. The new approach we propose lies on performing redundancy by implementing in the fault tolerant converter the equivalent synchronous switch for the two main switches, in offline scheme. The proposed fault tolerant two-stage converter circuit results from the basic two-stage circuit and its equivalent circuit with synchronous switch, merged together to form the new DC-DC fault tolerant converter. Excepted the two switches from the basic circuit and the synchronous switch, all other parts of the fault tolerant circuit are shared in healthy conditions and post-fault operation. In this case, the redundant switch is the synchronous switch, used in offline mode. As a synchronous switch includes a single switch and two diodes [15], the redundant switch (and driver) number is reduced to one. More, post-fault operation at full power can also be performed without degrading the overall system performances. Nevertheless, a suitable synchronous control must be applied in post-fault operation, instead of the asynchronous control applied in healthy conditions; the way of reducing the complexity of the associated fault tolerant control in a unified approach will be detailed later, based on a fault management unit. Here, in the case of an open-circuit failure of one of the two main switches, both switches are opened by the fault management unit and functionally replaced by the redundant equivalent synchronous switch.

### III. BUCK/BUCK-BOOST FAULT TOLERANT CIRCUIT

The studied PV system with two DC-DC conversion stages separated with a battery for energy storage is shown in Fig. 1. Given that the PV output voltage is often higher than the battery's one, the first stage is a step-down Buck converter, whereas the second stage allowing to supply a load with different voltage levels (higher or lower than the battery voltage) is a Buck-Boost converter. This PV system is controlled with two control signals applied to the switches  $S_1$  and  $S_2$ . To ensure continuity of service of the proposed PV system and minimize the number of redundant components (i.e. switches), one solution may be to share a single redundant switch between  $S_1$  and  $S_2$ , as discussed in Section II.B and published in [5]. In order to find a common node between  $S_1$  and  $S_2$  and mutualize a single redundant switch, these two switches (see Fig. 1) are moved towards each other while maintaining the same electrical behavior of the converter, as shown in Fig. 2a. The opposite current directions in the switches  $S_1$  and  $S_2$  (see Fig. 2a), however, do not allow




Fig. 2. PV system: (a) initial two-stage DC-DC conversion system, (b) electrically equivalent circuit to (a) when synchronous control is applied to  $S_1$  and  $S_2$ , (c) proposed fault tolerant DC-DC conversion circuit based on circuits (a) and (b).

the sharing of a single additional switch between these two switches. On the other hand, the drain of the switch  $S_1$  shares a common node with the source of the switch  $S_2$ . Thus, if a synchronous control is applied to these two switches  $S_1$  and  $S_2$  having a common drain-source node, they can be replaced with a synchronous switch based on a single switch  $S$  associated to two diodes  $D_3$  and  $D_4$  [15], as shown in Fig. 3. Consequently, the DC-DC conversion circuits presented in Fig. 2a and b are electrically equivalent. Note that these two circuits have the same electrical behavior only if a synchronous control is applied to the switches  $S_1$  and  $S_2$ .

To ensure the continuity of service of the proposed PV system, we propose a new and original fault tolerant conversion circuit presented in Fig. 2c. It results from a combination of the initial two-stage two-switches DC-DC conversion circuit presented in Fig. 2a with the single switch DC-DC conversion topology from Fig. 2b. The fault tolerant circuit in Fig. 2c has been first introduced and validated by simulation in a conference paper [16]. In [16], the same synchronous control is applied to the fault tolerant circuit under both modes (healthy conditions and post fault operation), to perform fault




Fig. 3. Synchronous switch equivalent circuits.

tolerant operation whereas, in this paper, a new optimized fault tolerant control is proposed in Section IV. It is based on an asynchronous control applied in healthy conditions and a synchronous control, applied in post fault operation. The fault-tolerant topology proposed in Fig. 2c guarantees the continuity of service of the PV system at full power in the case of an open-circuit fault (OCF) either on  $S_1$  of the Buck converter or on  $S_2$  of the Buck-Boost converter. The conventional redundancy approach where each switch has its own redundant counterpart has been avoided in this topology. On the contrary, it employs a reduced number of redundant switch allowing to replace functionally both switches ( $S_1$  and/or  $S_2$ ) in faulty mode (whenever an OCF is detected on  $S_1$  and/or  $S_2$ ) and ensures normal operation of the PV system. The overall fault-tolerant PV system is driven either by the switches  $S_1$  and  $S_2$  ( $S$  is OFF) or by the switch  $S$  ( $S_1$  and  $S_2$  are OFF). In healthy conditions, the asynchronous control signals applied to  $S_1$  and  $S_2$  ensure the normal operation of the system whereas in faulty mode, after the diagnosis of an OCF on either  $S_1$  or  $S_2$ , the control signal applied to  $S$  ensures the continuation of the normal operation of the system. In both modes, the same system operation at full power is carried out without degrading the performances of the overall system. In healthy conditions, the available control variables are the duty ratios ( $D_1$  and  $D_2$ ) and frequencies ( $f_1$  and  $f_2$ ) of both control signals ( $\delta_1$  and  $\delta_2$ ) applied to the switches  $S_1$  and  $S_2$  (see Fig. 2c). On the other hand, in faulty conditions, the number of available control variables is smaller than in the healthy ones and is equal to two: the duty ratio  $D$  and the frequency  $f$  of the control signal  $\delta$  applied to the switch  $S$  are used to drive the overall fault tolerant PV system (see Fig. 2c).

#### IV. FAULT-TOLERANT CONTROL

In the previous section, where the fault-tolerant two-stage circuit for PV systems has been presented, driving the switches  $S_1$ ,  $S_2$  and  $S$  depends on the operational conditions: in the healthy conditions the asynchronous control is used to drive the switches  $S_1$  and  $S_2$  ( $S$  is OFF), whereas in the faulty conditions the synchronous control is applied to the switch  $S$  ( $S_1$  and  $S_2$  are OFF). In this section, the main goal is to propose and design a fault-tolerant controller which is as simple as possible for both operational modes (healthy and faulty) and which allows to switch rapidly from one operational mode to another without degrading the overall performances of the PV system.

##### A. Efficient control strategy with fast post-fault management

If we observe the control variables identified in the previous section, we can note that four control variables are available to drive the proposed fault-tolerant circuit from Fig. 2c in the healthy conditions (equivalent to Fig. 2a) : the duty ratios  $D_1$  and  $D_2$ , and the frequencies  $f_1$  and  $f_2$  of the signals  $\delta_1$  and  $\delta_2$  respectively (see Fig. 2c). On the contrary, only two control variables, the duty ratio  $D$  and the frequency  $f$  of the signal  $\delta$ , are available for the synchronous control used to drive the post-fault circuit from Fig. 2c (equivalent to Fig. 2b). These




Fig. 4. Principle of the PV control strategy proposed in this paper: the first scenario (cyan) where the synchronous control signal  $\delta$  driving the post-fault circuit has the same frequency as the signal  $\delta_1$  ( $f = f_1$ ) and the same duty ratio as the signal  $\delta_2$  ( $D = D_2$ ); the second scenario (light blue) where the control variables  $D$  and  $f$  of the synchronous signal  $\delta$  are  $D = D_1$  and  $f = f_2$  respectively.

control variables, no matter the operational mode (healthy or faulty conditions), allow simultaneously the tracking of the Maximum Power Point at the output of the PV panel and the regulation of the output voltage  $v_O$  supplied to the load (see Fig. 2c). To design a fault tolerant controller allowing to switch smoothly and rapidly from the asynchronous to synchronous mode (healthy to faulty mode), the equivalent circuits shown in Fig. 2a and b must have the same operating point before and after the occurrence of an OCF on  $S_1$  and/or  $S_2$ . Having the same operating point in both modes implies that the control variables from two sets,  $\{f_1, f_2, D_1, D_2\}$  and  $\{f, D\}$  for the asynchronous and synchronous control respectively, have the same values before and after an OCF:  $f = f_1$  or  $f_2$  and  $D = D_1$  or  $D_2$ . Therefore, there are two possible scenarios allowing to perform independently and simultaneously the functionalities, the MPPT and output voltage regulation: the first one where  $f = f_1$  and  $D = D_2$ ; or, the second scenario where  $f = f_2$  and  $D = D_1$ . These two scenarios are summarized in Fig. 4. The other scenarios ( $f = f_1$  and  $D = D_1$ ;  $f = f_2$  and  $D = D_2$ ) would not allow to keep the same operating point after the occurrence of an OCF and would perform at a time only one of the two mentioned functionalities. Consequently, by choosing one of the two presented scenarios, the PV controller will be able to generate the control signals driving all three switches ( $S_1$ ,  $S_2$  and  $S$ ) of the proposed circuit for both asynchronous and synchronous modes in advance, and therefore only the speed of multiplexing of the right control signals will define the overall speed of reconfiguration from healthy to post-fault operation.

The proposed control strategy based on the same operating point before and after an OCF (one of the two presented scenarios, see Fig. 4) implies that MPPT and voltage output regulation in both modes are performed simultaneously with

two control variables of different nature:  $D = D_1$  or  $D_2$  and  $f = f_1$  or  $f_2$ . Consequently, the conduction modes of the energy transfer inductors  $L_1$  and  $L_2$  of the proposed fault-tolerant circuit (see Fig. 2c) must be different: if both operate either in continuous conduction mode (CCM) or in discontinuous conduction mode (DCM), it is not possible (see Eqs. 1 and 2) to control their conduction modes and thus the previously mentioned functionalities (MPPT and  $V_O$  regulation) independently. The only solution would therefore be to have the inductors  $L_1$  and  $L_2$  operating in different conduction modes.

In the following, we chose the inductors  $L_1$  and  $L_2$  to be operating in DCM and CCM, respectively. This choice is justified by the fact that the output load must be permanently supplied with power and thus the inductor  $L_2$  should operate in CCM while  $L_1$  in DCM. Moreover, the first scenario of sharing control signals presented in Fig. 4 is also adopted in this work, where  $f = f_1$  and  $D = D_2$ .

### B. Asynchronous control in healthy conditions

In healthy conditions, each DC-DC conversion stage is controlled independently in the asynchronous mode, where the switches  $S_1$  and  $S_2$  are driven by two different control signals  $\delta_1$  and  $\delta_2$  respectively (Fig. 5). The Buck converter driven with the control signal  $\delta_1$  tracks the Maximum Power Point (MPP) using a Maximum Power Point Tracking (MPPT) algorithm [17]. On the other hand, the Buck-Boost converter which is driven with the control signal  $\delta_2$  is used to regulate the output voltage across the load. As previously explained, in order to control independently these two conversion stages in the faulty mode, they must operate in different conduction modes. Therefore, DCM has been chosen for the Buck converter, whereas CCM is the conduction mode of the Buck-Boost converter.




Fig. 5. Asynchronous and synchronous control: in the absence of OCF on  $S_1$  and/or  $S_2$  ( $OCF=0$ , in red), the asynchronous signals  $\delta_1$  and  $\delta_2$  drive the fault tolerant circuit; otherwise ( $OCF=1$ , in blue), only the synchronous signal  $\delta$  drives the fault-tolerant circuit and ensures the continuity of service.




Fig. 6. The proposed fault-tolerant circuit with associated control in both healthy and faulty conditions.

The Buck converter transfer function in DCM is given by:

$$M_{Buck,DCM} = \frac{2}{1 + \sqrt{1 + \frac{8 \cdot L_1 \cdot f_1}{D_1^2 \cdot R_L}}} \quad (1)$$

where either the duty ratio  $D_1$ , the frequency  $f_1$  or both can be used to track the MPP at the output of the PV panel. In this work, we chose to keep the duty ratio  $D_1$  constant and track the MPP only by regulating the frequency  $f_1$  of the signal  $\delta_1$  as presented in Fig. 6.

The Buck-Boost converter transfer function in CCM is given by:

$$M_{Buck-Boost,CCM} = \frac{V_O}{V_B} = \frac{D_2}{1 - D_2} \quad (2)$$

where  $D_2$  is the duty cycle of the control signal  $\delta_2$  (see Fig. 6) driving the Buck-Boost converter. By analyzing this transfer function, the choice of control variable ( $D_2$  or  $f_2$ ) of the Buck-Boost converter is easily made: the regulation of the output voltage  $V_O$  is performed by acting on the duty ratio  $D_2$  of the signal  $\delta_2$ , while its frequency  $f_2$  is kept constant (see Fig. 6).

### C. Synchronous control: an OCF on $S_1$ and/or $S_2$

When an OCF occurs and is detected on  $S_1$  and/or  $S_2$ , both control signals  $\delta_1$  and  $\delta_2$  used to asynchronously control the switches  $S_1$  and  $S_2$  in the healthy mode are disabled (see Fig. 5). Therefore,  $S_1$  and  $S_2$  are always open and no longer used in this synchronous mode. This is why the precise location of the OCF occurrence ( $S_1$  or  $S_2$ ) is not necessary. Moreover, by disabling the control signals  $\delta_1$  and  $\delta_2$  and opening the switches  $S_1$  and  $S_2$ , the switch  $S$  and the diodes  $D_3$  and  $D_4$  can conduct and thus take over the control of the fault tolerant circuit. The control signal  $\delta$  of the switch  $S$  ensures that the proposed fault tolerant circuit has the same functionalities in the faulty operational mode (synchronous control) as in the healthy conditions (asynchronous control), without degrading the performances of the PV system. Indeed, the frequency  $f$  of the synchronous control signal  $\delta$  is equal to the frequency  $f_1$  of the asynchronous control signal  $\delta_1$  used to control the



Buck converter in the healthy mode and allows to track the MPP in the same way as in the healthy mode according to Eq. 1. On the other hand, the duty cycle of the synchronous control signal  $\delta$  is equal to  $D_2$  of the asynchronous control signal  $\delta_2$  and allows to regulate the output voltage  $V_O$  according to Eq. 2, in the same way as in the healthy conditions.

Fig. 6 summarizes the control of the proposed fault tolerant circuit: the asynchronous control in healthy and synchronous control in faulty conditions. The advantage of using the asynchronous control in the healthy mode to control the proposed fault tolerant circuit is the possibility to choose different frequencies  $f_1$  and  $f_2$  of the control signals  $\delta_1$  and  $\delta_2$  respectively. The frequency  $f_1$  is used to track the MPP of the first conversion stage, while the frequency  $f_2$  is not used as a control variable of the second conversion stage to regulate the output voltage  $V_O$ , due to the CCM operational mode. By choosing different values for  $f_1$  and  $f_2$ , the switching losses of the second conversion stage (Buck-Boost converter) driven with the asynchronous control signal  $\delta_2$  whose frequency is  $f_2$  can be reduced.

## V. EXPERIMENTAL RESULTS

TABLE I  
PARAMETERS OF THE PV SYSTEM.

Elements	Value	Elements	Value
$L_1$	$15\mu H$	$C_2$	$22\mu F$
$L_2$	$470\mu H$	$V_B$	$12V$
$C_1$	$100\mu F$	$R_L$	$25\Omega$

The proposed two-stage fault tolerant circuit for PV systems with optimized fault tolerant control is validated experimentally. The experimental parameters are presented in Table I. The choice of inductance values  $L_1$  and  $L_2$  is based on the chosen conduction modes (DCM and CCM) for both conversion stages. Given the focus of this paper on remedial actions in open-circuit switch failure, the PV source is replaced with a voltage source for a fixed operating point. Thus, for the PV panel at the input of the proposed fault tolerant circuit, one fixed operating point corresponding to the full power of 20W of two 10W PV panels connected in parallel has been chosen ( $V_{PV} = 17.5V$  and  $I_{PV} = 1.14A$ ). The experimental setup used for this validation is presented in Fig. 7. It comprises the fault tolerant two-stage Buck/Buck-Boost converter presented in the previous sections, a DC voltage source and a resistive load  $R_L$ . A dSPACE DS1104 control card and CPL1104 dSPACE interface device are used to generate the control signals  $\delta_1$ ,  $\delta_2$  and  $\delta$ , which represent respectively the control signals of the switches  $S_1$ ,  $S_2$  and  $S$  for both asynchronous healthy and synchronous faulty modes, and interface them to the fault tolerant circuit. The switches  $S_1$ ,  $S_2$  and  $S$  are all MOSFET components IRFP4110 from Infineon/International Rectifier. Schottky barrier diodes MBR10100 from ON Semiconductor are used for all diodes. The current measurements are carried out with 5MHz bandwidth current probes, I-prober 520 by Aim & Thurlby Thandar Instruments. The sampling period used in the dSPACE control system is 50μs.




Fig. 7. Fully experimental setup.

All signals were recorded with a Lecroy oscilloscope WaveSurfer 4000 with the following parameters for all presented waveforms: the vertical sensitivity of 2V/div for the control signals of all switches, 10V/div for the fault detection signal and output voltage  $V_O$ , 2A/div for the currents  $i_{L1}$ ,  $i_{D1}$  and  $i_{D3}$ , and 1A/div for the currents  $i_{L2}$ ,  $i_{D2}$  and  $i_{D4}$ .

The experimental results showing the asynchronous control applied in healthy conditions in steady state are shown in Figs. 8, 9 and 10, and also on the left-hand side of the presented waves in Figs. 13, 14 and 15 in transient state in the case of an OCF on  $S_1$  (Figs. 13 and 14) or  $S_2$  (Fig. 15). On the other hand, the experimental results showing the synchronous control of operation in post-fault conditions in steady state are shown in Figs. 11 and 12, and also on the right-hand side of the presented waves in Figs. 13, 14 and 15. For the asynchronous control in healthy conditions, the frequency  $f_1$  of the control signal  $\delta_1$  driving the Buck converter is set to 25kHz, while the frequency  $f_2$  of the control signal  $\delta_2$  of the Buck-Boost converter is set to 10kHz (see Fig. 8). In addition, the shapes of currents  $i_{L1}$  and  $i_{L2}$  show that the inductor  $L_1$  operates in discontinuous conduction mode, while the inductor  $L_2$  is in continuous conduction mode. Moreover, the currents of free wheeling diodes  $D_1$  and  $D_2$  of the first Buck and the second Buck-Boost converter are shown in Figs. 9 and 10 respectively. On the other hand, in post-fault mode, the fault tolerant circuit is driven synchronously only with the signal  $\delta$  at the switching frequency of 25kHz (see Fig. 11). In steady state, the currents of all diodes, the free wheeling ones ( $D_1$  and  $D_2$ ) and those used in conjunction with the synchronous switch ( $D_3$  and  $D_4$ ), are also given for post-fault mode in Fig. 12. By comparing the currents of free wheeling diodes  $D_1$  and  $D_2$  in healthy and post-fault mode (see Figs. 9, 10 and 12), it can be noticed that these currents have the same shapes. As explained in Section IV, the proposed fault tolerant circuit guarantees the same functionality before and after an OCF occurrence, which can justify these same shapes of currents  $i_{D1}$  and  $i_{D2}$  in both modes.

It should also be noted that the current  $i_{L1}$  during the asynchronous control used to drive the fault tolerant circuit in healthy conditions (see Fig. 8) does not have exactly the same shape as in steady state after the fault occurrence and




Fig. 8. Steady state of the proposed fault tolerant topology in healthy conditions.




Fig. 9. Steady state of the fault tolerant topology in healthy conditions: the relevant currents of the first Buck stage ( $i_{S_1}$ ,  $i_{D_1}$  and  $i_{L_1}$ ).




Fig. 10. Steady state of the fault tolerant topology in healthy conditions: the relevant currents of the second Buck-Boost stage ( $i_{S_2}$ ,  $i_{D_2}$  and  $i_{L_2}$ ).

transition to the synchronous mode of operation (see Fig. 11). This is explained by the fact that the current paths in the proposed fault tolerant PV system are not the same in healthy (before OCF occurrence) and in faulty conditions (after OCF occurrence). In the healthy conditions, where the asynchronous control is used to drive the switches  $S_1$  and  $S_2$ , the positive growth of the current  $i_{L_1}$  is only ensured by the ON state of the switch  $S_1$  and the current path goes only through this active component. On the other hand, after the detection of an OCF and the transition to the synchronous control mode, the control signal  $\delta$  is only applied to the switch  $S$  and consequently the current paths (and energy exchanges) in the fault tolerant circuit during the ON state change. The positive growth of the current  $i_{L_1}$  during the ON phase of the switch  $S$  goes through two modes: in the first phase it is simultaneously ensured by the switch  $S$  and the diode  $D_3$  (see Fig. 12, red part), while in the second phase it passes through the switch  $S$  and the diode  $D_4$  (see Fig. 12, blue part). The transition from the first (red) state to the second (blue) one is dictated by the condition  $i_{L_1} < i_{L_2}$ . These different current paths cause some additional voltage drops on these current paths thus modifying the slope (and the shape) of the current  $i_{L_1}$  in the synchronous mode of operation.

To realize experimental results of the transition from healthy to faulty conditions, the following scenario is carried out: an OCF on the switch  $S_x$  ( $x \in \{1, 2\}$ ) is generated at a random time by forcing the reset of the control signal supplied to the switch. This can be seen on the top waveform (yellow) of Fig. 13 in the case of an OCF on  $S_1$ . The occurred OCF is




Fig. 11. Steady state of the fault tolerant topology in post-fault operation.

detected by the fault tolerant detection signal active on the falling edge. In the phase 1 (denoted by ① in Fig. 13), the two switches  $S_1$  and  $S_2$  are controlled with the asynchronous control signals  $\delta_1$  and  $\delta_2$ , while the control signal applied to the switch  $S$  is equal to zero. After the OCF occurrence denoted with the falling edge of the signal “Fault detection” ( $F_D$ ), the system response is not immediate (see Fig. 13, the phase 2). The main reason for this delay is the dSPACE system sampling time which limits the update of all measured and computed values to the timing interval of  $50\mu s$ . That is why after the falling edge of the signal  $F_D$ , an additional period of the control signal  $\delta_1$  is still generated. The second phase (denoted by ② in Fig. 13) starts with a first step consisting in the reconfiguration of the proposed fault tolerant circuit: the control signals  $\delta_1$  and  $\delta_2$  are not generated anymore while the control signal  $\delta$  starts to be generated. Consequently, the continuity of service of the proposed fault tolerant PV system is ensured. After the reconfiguration and the transition from the healthy (asynchronous) to faulty (synchronous) mode (denoted by ③ in Fig. 13), the currents  $i_{L_1}$  and  $i_{L_2}$  still respect their conduction modes of operation. In addition, the current  $i_{L_2}$  in the reconfigured faulty mode has a slightly different shape (smaller period) because the switch  $S$  is now driven at a frequency of  $25kHz$  (period of  $40\mu s$ ) instead of  $10kHz$  (period of  $100\mu s$ ) in the healthy mode (see Fig. 11).

Figs. 14 and 15 show the influence of the transition from healthy to faulty mode of operation on the output voltage  $v_O$ , depending on the fault location:  $S_1$  (Fig. 14) and  $S_2$  (Fig. 15). After the occurrence and detection of an OCF (top yellow signal on both figures), there are still some parasite asynchronous signals  $\delta_1$  and  $\delta_2$  for the same reasons explained above. Nevertheless, in the experimental results shown in Fig. 14, it can be seen that the OCF occurrence on  $S_1$  does not influence the average value of the output voltage  $v_O$ , which keeps its same value from healthy conditions, mainly due to the efficiency of the optimized fault-tolerant control. The only difference is the frequency of ripples which is higher in faulty mode due to the use of higher frequency to control the circuit with the synchronous signal  $\delta$ . On the other hand, in the case of an OCF occurred on  $S_2$ , the experimental results are shown in Fig. 15. Consequently, the output voltage  $v_O$  starts to drop and needs some time before achieving the same average value as in the healthy conditions.

## VI. DISCUSSION

In the previous sections, we have presented a general approach allowing to guarantee the service continuity at full






Fig. 12. Steady state of the fault tolerant topology in post-fault operation: the currents in all diodes ( $i_{D1}$ ,  $i_{D2}$ ,  $i_{D3}$  and  $i_{D4}$ ), inductors ( $i_{L1}$  and  $i_{L2}$ ) and single switch  $i_s$ .

power of a two-stage DC-DC circuit, under both OCF and/or SCF as well, bearing in mind that in all cases, an SCF after the cut of the short circuit path will be considered as an OCF. Indeed, a short-circuit must be first isolated and the current path cut before applying remedial actions. In healthy conditions, the two-stage converter behaves as a usual structure where both stages are single switch non-isolated DC-DC converters with an asynchronous control. In the considered application case, the first stage is a Buck converter whereas a second one is a Buck-Boost converter.

The effectiveness of the service continuity of the studied Buck/Buck-Boost circuit has been validated through experiments. Because of the applied synchronous control in the post fault mode, only two control parameters are available: duty cycle  $D$  and frequency  $f$ , requiring different conduction modes for the two DC-DC converters. It does mean that one converter must operate in DCM whereas the other one in CCM. In our application case, we have chosen to control the first stage Buck converter in DCM and the second stage Buck-Boost converter in CCM, mainly for output voltage regulation and continuous load feeding purposes. It is clear that the use of a first stage Buck converter introduces some additional PV current ripples, worsened with the DCM mode. Nevertheless, in the same spirit of the presented approach, another first stage non-isolated DC-DC converter (Boost or Buck-Boost) can be chosen to reduce these drawbacks, if allowed by the application requirements. Similarly, as for the first stage, the choice of the second stage non-isolated DC-DC converter can be reconsidered. However, the main goal of our contribution was to present a new fault tolerant design approach applied on two cascaded DC-DC converters and based on single switch redundancy, illustrated in the case of a Buck/Buck-Boost

converter, but not exclusively limited to this combination.

## VII. CONCLUSION

This paper proposes the open-circuit switch fault tolerant operation of a two-stage Buck/Buck-Boost circuit for PV systems. Remedial actions are based on an original unified approach where the overall fault tolerant operation of both stages at full power is considered. The fault tolerant circuit and the optimized fault-tolerant control we proposed lies on performing redundancy by implementing the equivalent synchronous switch for the two main switches of both stages, in offline mode. The equivalent synchronous switch includes a single switch and two diodes, thus reducing as low as possible the number of redundant switches. Excepted the switches, all other parts of the fault tolerant circuit are shared in healthy and post-fault operations. Therefore, post-fault operation at full power can also be performed if a suitable synchronous control is applied, instead of the asynchronous one used in healthy conditions. The proposed efficient control allows switching very quickly from healthy to faulty conditions, without the necessity to be reconfigured. Some selected experimental results are given to verify the validity of the theoretical approach. Thus, the service continuity is validated in any open-circuit switch fault of one of the two switches of the Buck/Buck-Boost circuit.

The new remedial actions we have proposed, based on redundant synchronous switch approach, is an efficient, fast and original solution to guarantee the service continuity of two-stage converters, if a suitable and unified fault tolerant control is also designed.

## REFERENCES

- [1] H. Wang, M. Liserre, F. Blaabjerg, P. de Place Rimmen, J. B. Jacobsen, T. Kvisgaard, and J. Landkildehus, "Transitioning to physics-of-failure as a reliability driver in power electronics," *IEEE Journal of Emerging and Selected Topics in Power Electronics*, vol. 2, pp. 97–114, March 2014.
- [2] W. Zhang, D. Xu, P. N. Enjeti, H. Li, J. T. Hawke, and H. S. Krishnamoorthy, "Survey on fault-tolerant techniques for power electronic converters," *IEEE Transactions on Power Electronics*, vol. 29, pp. 6319–6331, Dec 2014.
- [3] E. Pazouki, Y. Sozer, and J. A. D. Abreu-Garcia, "Fault diagnosis and fault-tolerant control operation of nonisolated dc-dc converters," *IEEE Transactions on Industry Applications*, vol. 54, pp. 310–320, Jan 2018.
- [4] E. Jamshidpour, P. Poure, E. Gholipour, and S. Saadate, "Single-switch dc-dc converter with fault-tolerant capability under open- and short-circuit switch failures," *IEEE Transactions on Power Electronics*, vol. 30, pp. 2703–2712, May 2015.
- [5] E. Jamshidpour, P. Poure, and S. Saadate, "Photovoltaic systems reliability improvement by real-time fpga-based switch failure diagnosis and fault-tolerant dc-dc converter," *IEEE Transactions on Industrial Electronics*, vol. 62, pp. 7247–7255, Nov 2015.
- [6] S. Nie, X. Pei, Y. Chen, and Y. Kang, "Fault diagnosis of pwm dc-dc converters based on magnetic component voltages equation," *IEEE Transactions on Power Electronics*, vol. 29, pp. 4978–4988, Sept 2014.
- [7] E. Ribeiro, A. J. M. Cardoso, and C. Boccaletti, "Fault-tolerant strategy for a photovoltaic dc-dc converter," *IEEE Transactions on Power Electronics*, vol. 28, pp. 3008–3018, June 2013.
- [8] H. Givi, E. Farjah, and T. Ghanbari, "Switch and diode fault diagnosis in nonisolated dc-dc converters using diode voltage signature," *IEEE Transactions on Industrial Electronics*, vol. 65, pp. 1606–1615, Feb 2018.
- [9] E. Farjah, H. Givi, and T. Ghanbari, "Application of an efficient rogowski coil sensor for switch fault diagnosis and capacitor esr monitoring in nonisolated single-switch dc-dc converters," *IEEE Transactions on Power Electronics*, vol. 32, pp. 1442–1456, Feb 2017.




Fig. 13. Control of the proposed fault tolerant topology in both healthy and faulty conditions: transition from asynchronous to synchronous control in the case of an OCF on  $S_1$ .




Fig. 14. Influence of the transition from healthy to post-fault mode of operation on the output voltage  $v_O$ : case of an OCF on  $S_1$ .

[10] T. Li and L. Parsa, "Design, control, and analysis of a fault-tolerant soft-switching dc-dc converter for high-power high-voltage applications," *IEEE Transactions on Power Electronics*, vol. 33, pp. 1094–1104, Feb 2018.

[11] J. Poon, P. Jain, I. C. Konstantakopoulos, C. Spanos, S. K. Panda, and S. R. Sanders, "Model-based fault detection and identification for switching power converters," *IEEE Transactions on Power Electronics*, vol. 32, pp. 1419–1430, Feb 2017.




Fig. 15. Influence of the transition from healthy to post-fault mode of operation on the output voltage  $v_O$ : case of an OCF on  $S_2$ .


- [12] L. F. Costa, G. Buticchi, and M. Liserre, "A family of series-resonant dc-dc converter with fault-tolerance capability," *IEEE Transactions on Industry Applications*, vol. 54, pp. 335–344, Jan 2018.
- [13] J. Poon, P. Jain, C. Spanos, S. K. Panda, and S. R. Sanders, "Fault prognosis for power electronics systems using adaptive parameter identification," *IEEE Transactions on Industry Applications*, vol. 53, pp. 2862–2870, May 2017.
- [14] D. D. C. Lu, J. L. Soon, and D. Verstraete, "Derivation of dual-switch step-down dc/dc converters with fault-tolerant capability," *IEEE Transactions on Power Electronics*, vol. 31, pp. 6064–6068, Sept 2016.
- [15] T.-F. Wu and T.-H. Yu, "Unified approach to developing single-stage power converters," *IEEE Transactions on Aerospace and Electronic Systems*, vol. 34, no. 1, pp. 211–223, 1998.
- [16] S. Siouane, S. Jovanović, and P. Poure, "Service continuity of pv synchronous buck/buck-boost converter with energy storage," in *2017 IEEE International Conference on Environment and Electrical Engineering and 2017 IEEE Industrial and Commercial Power Systems Europe (EEEIC / I CPS Europe)*, pp. 1–6, June 2017.
- [17] M. Rakhshan, N. Vafamand, M. H. Khooban, and F. Blaabjerg, "Maximum power point tracking control of photovoltaic systems: A poly-

nomial fuzzy model-based approach," *IEEE Journal of Emerging and Selected Topics in Power Electronics*, vol. 6, pp. 292–299, March 2018.



**Slaviša Jovanović** (M'08) received the B.S. in electrical engineering from the University of Belgrade, Serbia, in 2004, M.S. and Ph.D degrees in electrical engineering from the University of Lorraine, France, in 2006 and 2009, respectively.

From 2009 to 2012, he was with the Diagnosis and Interventional Adaptive Imaging laboratory (IADI), Nancy, France, as a research engineer working on MRI-compatible sensing embedded systems. Then, he joined the Faculty of Sciences and Technologies and the Jean Lamour Institute (UMR 7198), University of Lorraine, Nancy, where he is currently an Associate Professor. His main research interests include energy harvesting circuits, neuromorphic architectures, reconfigurable Network-on-Chips and algorithm-architecture matching for real-time signal processing. He is the author and co-author of more than 50 papers in conference proceedings and international peer-reviewed journals, and he holds one patent.



**Saima Siouane** was born in 1990. She received the Engineer degree in Electronics from National Polytechnic School, Algiers, Algeria in 2013, the M.S. degree from National School of Engineering of Poitiers, France, in 2014, and Ph.D degree in Electronic Systems from the University of Lorraine, France, in 2017. She is currently a Temporary Lecturer and Research Assistant, at University of Lorraine - Institute Jean Lamour, Nancy, France. Her main research interests include renewable energy, thermoelectric generator, photovoltaic system, DC-DC converter and fault tolerant power systems.

ator, photovoltaic system, DC-DC converter and fault tolerant power systems.



**Philippe Poure** was born in 1968. He received the Engineer Degree and Ph.D. Degree in Electrical Engineering from INPL-ENSEM-GREEN, France, in 1991 and 1995 respectively.

From 1995 to 2004, he was an Associate Professor and worked at the University Louis Pasteur of Strasbourg, France, in the field of mixed-signal System-On-Chip for control and measurement in Electrical Engineering. Since September 2004, he joined the Université de Lorraine, Nancy - France and works on fault diagnosis and fault tolerant operation of high-reliability electronic converters, applied to energy harvesting systems and power systems.