



**HAL**  
open science

## Experimental study of a centrifugal compressor with two successive and counter-rotating impellers

Van-Thang Nguyen, Amélie Danlos, Richard Paridaens, Florent Ravelet,  
Michael Deligant, Sofiane Khelladi, Farid Bakir

### ► To cite this version:

Van-Thang Nguyen, Amélie Danlos, Richard Paridaens, Florent Ravelet, Michael Deligant, et al.. Experimental study of a centrifugal compressor with two successive and counter-rotating impellers. 18th International Symposium on Transport Phenomena and Dynamics of Rotating Machinery (IS-ROMAC18), Nov 2020, Honolulu, United States. 10.1088/1742-6596/1909/1/012023 . hal-03260477

**HAL Id: hal-03260477**

**<https://hal.science/hal-03260477>**

Submitted on 15 Jun 2021

**HAL** is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.



Distributed under a Creative Commons Attribution 4.0 International License

PAPER • OPEN ACCESS

## Experimental study of a centrifugal compressor with two successive and counter-rotating impellers

To cite this article: Van-Thang Nguyen *et al* 2021 *J. Phys.: Conf. Ser.* **1909** 012023

View the [article online](#) for updates and enhancements.




**The Electrochemical Society**  
Advancing solid state & electrochemical science & technology

The ECS is seeking candidates to serve as the  
**Founding Editor-in-Chief (EIC) of ECS Sensors Plus,**  
a journal in the process of being launched in 2021

The goal of ECS Sensors Plus, as a one-stop shop journal for sensors, is to advance the fundamental science and understanding of sensors and detection technologies for efficient monitoring and control of industrial processes and the environment, and improving quality of life and human health.

*Nomination submission begins: May 18, 2021*



# Experimental study of a centrifugal compressor with two successive and counter-rotating impellers

Van-Thang NGUYEN<sup>1,2</sup>, Amelie DANLOS<sup>1</sup>, Richard PARIDAENS<sup>1</sup>, Florent RAVELET<sup>1</sup>, Michael DELIGANT<sup>1</sup>, Sofiane KHELLADI<sup>1</sup>, Farid BAKIR<sup>1</sup>

<sup>1</sup>Arts et Metiers Institute of Technology, CNAM, LIFSE, HESAM University, 75013 Paris, France

<sup>2</sup>Faculty of Vehicle and Energy Engineering, Le Quy Don Technical University, Hanoi, Vietnam

E-mail: [amelie.danlos@lecnam.net](mailto:amelie.danlos@lecnam.net)

**Abstract.** In many industries, reducing the size of the compression system represents a significant goal for designers. In fact, increasing the power density of the compressor actually means lowering production costs. The chief purpose of this study is to compare, in terms of aerodynamic performances, a centrifugal compressor consisting of an impeller and a volute, to an innovative concept based on the principle of two successive impellers and designed to work in counter-rotation. To simplify the experimental research in this study, the volute of the conventional compressor is maintained for the new design. The conventional impeller has been replaced by two successive impellers having the same meridian profile, and whose diameter of the rear impeller is identical to that of the conventional impeller. The impellers design of the counter-rotation stage was carried out granting to an approach proposed here. The numerical results underline the advantage of the innovative compressor, in terms of power density, compared to the conventional design. The numerical forecasts also agree significantly with the results of experimental tests got on a test bench exclusively designed for compressors. Experimental optimization of the rotational speed ratio of the two counter-rotating impellers has demonstrated the possibility of increasing the compression ratio and efficiency over a wide range of flow.

## 1. Introduction

Since the 20th century, counter-rotating turbomachines are used to improve performances with reducing the size and the weight. A counter-rotating turbomachinery consists of two impellers rotating in two opposite directions, with two different rotation speeds  $N_1$  and  $N_2$ . This type of systems has been tested for axial-flow fans [1, 2, 3, 4, 5] and shows that it is possible to obtain a higher pressure rise, to improve the efficiency and to extend the operating range of mass flow rate. The speed ratio  $\theta_i = \frac{N_1}{N_2}$  was studied in the case of counter-rotating axial compressor stage [6, 7, 8] and has shown that if the second rotor is 50% faster than the first one, the stall free range can be improved and, on the other hand, if the first rotor rotates 50% faster than the second one, the load on the first rotor is increased and the stall appears earlier in the second rotor. Counter-rotating pumps have also been investigated [9, 10] by combining a rotor-stator and a front-rear rotor and lead to a more compact system with a lower rotation speed of rotors. Counter-rotating centrifugal compressors have not been experimentally studied yet. But numerical simulations



have shown encouraging results [11]. This paper presents experimental results of the performance comparison between a Counter-Rotating Centrifugal Compressor (CRCC) and a Single Impeller Centrifugal Compressor (SICC) to show the advantages of this innovative design.

## 2. Design of a counter-rotating centrifugal compressor


SICC was constructed for a suction application and was chosen as a reference compressor in this study. The innovative CRCC made of two impellers rotating in opposite directions is designed based on SICC with the same point design in order to analyze the benefits of a novel compressor.

### 2.1. Introduction of SICC

An impeller of SICC has an external diameter  $D_2$  equal to 286 mm. The gap between the impeller and the casing is 1.5 mm which represents 5% of the blade width  $b_2 = 29.7\text{mm}$ . The impeller presents 7 blades and 7 splitters with a small vanless diffuser in respect for the geometry shown obtained with the Turbo3D software developed in our laboratory (figure 1). The point design of the compressor is determined by a mass flow rate  $\dot{m} = 0.73\text{kg/s}$ , a pressure ratio equal to 1.31, and the impeller speed  $N=16000\text{rpm}$ . More details of SICC geometric parameter are summarized in the table 1.


**Table 1.** Geometric parameters of the SICC impeller

Parameter	Value	Parameter	Value
Hub diameter $D_{1h}$	59.5 mm	Inlet blade angle at hub $\beta_{1h}$	45.3°
Shroud diameter $D_{1s}$	161 mm	Inlet blade angle at Shroud $\beta_{1sh}$	69.8°
Outer diameter $D_2$	286 mm	Outlet blade angle $\beta_2$	64°
Blade width $b_2$	29.7 mm	Mass flow rate $\dot{m}$	0.73kg/s
Rotational speed $N$	16000 rpm	Pressure ratio	1.36
Number of blades $Z$	7+7	Power consumption	28kW
Pressure ratio $\Pi$	1.31		



**Figure 1.** Impeller of SICC designed by Turbo3D software. Diagram of (a) meridional view and (b) front view

The global performance of SICC obtained in previous experiment is shown in figure 2. It presents the variation of pressure ratio and polytropic efficiency according to the change of the corrected mass flow rate in various rotation speeds.



**Figure 2.** The experimental performance map of SICC

### 2.2. Design of two innovative rotors

Two impellers of CRCC were designed with the same size and the meridional profile as the SICC's impeller (reference impeller). Two compressors use the same volute for easy evaluation. The reference impeller is then replaced by two impellers rotating in the opposite directions. The first impeller of CRCC rotates with angular velocity  $\omega_1$  and the second one rotates with angular velocity  $\omega_2$  in the inverse direction. At the designed point, both impellers rotate with the same speed ( $\omega_1 = \omega_2$ ).


The outer diameter of the first impeller, placed in front of the second impeller, is determined with the length ratio defined by equation 1:

$$LR = \frac{L_{1st}}{L_m} \quad (1)$$

Where  $L_{1st}$  is the length of the first impeller at the hub/shroud contour and  $L_m$  the total length of the reference impeller in meridional surface as shown in figure 3b. A previous work [11] presented a numerical investigation of different CRCC configurations with various LR values. The selected configuration here optimizes the efficiency and is obtained for LR=0.3. This value imposes the outer diameter of the first impeller. The velocity triangle presented in figure 3a gives the outlet blade angle of the first impeller. The inlet blade angle of the second impeller is then calculated to adapt the flow in the outlet of the first impeller according to the theorem of aerodynamic. All characteristics of these impeller are shown in table 2 and 3.

### 3. CRCC test bench


The test bench uses to study the performances of the CRCC is designed in a suction application at LIFSE laboratory as shown in figure 3. Working fluid is the air at room temperature. The



**Figure 3.** Diagram of (a) the velocity triangle and (b) a meridional contour of CRCC. Points 1 and 2 represent respectively the inlet and outlet of the first impeller and points 3 and 4 respectively stand for the inlet and outlet of the second impeller. Points 5 represents the volute outlet


**Table 2.** First impeller geometric parameters

Parameter	Value	Parameter	Value
$D_{1h}$	51.5mm	$\beta_{1h}$	45.3°
$D_{1sh}$	161mm	$\beta_{1sh}$	69.8°
$D_{2h}$	118mm	$\beta_{2h}$	53.6°
$D_{2sh}$	176mm	$\beta_{2sh}$	68.4°
$N_1$	-16000rpm	$Z_1$	7



**Table 3.** Second impeller geometric parameters

Parameter	Value	Parameter	Value
$D_{3h}$	128.5mm	$\beta_{3h}$	72.7°
$D_{3sh}$	183mm	$\beta_{3sh}$	77°
$D_4$	286mm	$\beta_4$	64°
$N_2$	16000rpm	$Z_2$	9



outlet pressure of the compressor is the atmospheric pressure at the time of measurement. The test bench includes the compressor (CRCC) connects to an upstream tank and a downstream muffler to reduce the noise. The tank on which a flat plate pierced 120 holes with a diameter of 8 mm allows controlling the inlet flow rate. A long pipe with a diameter of  $D=158,5\text{mm}$  connects the tank to the compressor. A honeycomb is placed upstream of the pipe to obtain a flow with minimum distortion for measuring mass flow rate and reducing the effect on the performance.

This pipe is equipped with a flow-meter, a thermocouple, and four pressure taps to measure the inlet parameters of the compressor. The flow-meter places at an upstream distance  $12D$  is used to measure the inlet flow rate. It includes a Pitot tube connected to an FC66 manometer with an accuracy  $\leq \pm 1\%$  of reading. Four pressure taps placed upstream on the circumferential inlet pipe at a distance  $3D$ , is connected to an FC322 manometer with an accuracy  $0.5\%$  to measure the differential pressure between the inlet and the atmospheric pressure. One thermocouple Pt100 is placed upstream at a distance  $20D$  to measure the inlet temperature. Three other ones are installed downstream on the circumferential outlet pipe at a distance  $4D$  to measure the outlet temperature of the compressor. These thermocouples have a range of uncertainty of  $0.02^\circ C \div 0.04^\circ C$  in the range of temperature considered in this experimental study. In the case of measurements, the CRCC is driven by two independent electric motors. The speed of the second impeller is kept constant at 9000rpm. Besides, the rotation speed of the first impeller will be adjusted to investigate the influence on the performance.




Figure 4. The test bench of CRCC

#### 4. Experimental results

The pressure ratio is calculated by the ratio of the atmospheric pressure to the inlet pressure measured by FC322 manometer.

$$\Pi = \frac{P_{atm}}{P_{in}} \quad (2)$$


The polytropic efficiency is described by the equation 3:

$$\eta_p = \frac{\gamma - 1}{\gamma} \ln \frac{P_{out}}{P_{in}} \frac{T_{in}}{T_{out}} \quad (3)$$


Where  $T_{out}$  and  $T_{in}$  are respectively the outlet and the inlet temperature of the compressor and  $\gamma$  the specific heat ratio.

#### 4.1. Global performances of the innovative CRCC at the speed of 9000rpm

The innovative counter-rotating system is designed with two impellers rotate with the same speed. In this section, the experimental results is presented in case of the speed of the first impeller  $N_1 = -9000rpm$  and the second impeller  $N_2 = 9000rpm$ . Figures 5 and 6 show the comparison between the pressure ratio ( $\Pi_s$ ), polytropic efficiency ( $\eta_p$ ), and power consumption of CRCC and those of SICC. The solid black line represents CRCC, while the dashed blue line describes the SICC. The red and green lines show the electric power of respectively the first and second impeller of CRCC. It is easy to see in figure 5 that the pressure ratio of CRCC is always



**Figure 5.** Comparison between CRCC's global performance (the solid black line: CR- $\theta_4$ ) and SICC's one at the speed of 9000rpm



**Figure 6.** Comparison between CRCC's power consumption ( $CR(P_{total})$ ): the first rotor consumption ( $CR(P_1)$ ), the second rotor consumption ( $CR(P_2)$ ) and SICC's one

higher than that of SICC. At the operating point, the pressure ratio of CRCC gets  $1.128 \pm 0.002$  while that of the SICC is only  $1.1 \pm 0.002$ . the CRCC configuration gives higher performance than the SICC. It can be said that the CRCC pressure ratio, in this case, has increased by about 2.5% in comparison to SICC's one. In addition, the efficiency curves illustrate that the CRCC's efficiency is always better than the SICC's one. The best efficiency of CRCC has been improved by about 8% compared to the efficiency of SICC. Concerning the power consumption, figure 6 shows that the total power consumption of CRCC (the solid black line) is always higher than that of SICC (the dashed blue line). At the operating point, the power consumption of the first and second impellers is 1.51kW and 5kW, respectively, while the power consumption of the SICC is 5.15kW. It can be noted that the consumption of the second impeller (the solid green line) is approximately equal to that of the SICC. Besides, the consumption of the first impeller (the solid red line) is quite small and increases slightly as the flow decreases. It looks like the characteristic of an axial turbomachine. This shows that the fluid is compressed mainly in the second impeller because it has a large variable diameter from the inlet to the outlet. Consequently, the CRCC configuration requires more energy due to higher pressure rise and overcome the additional mechanical losses of the drive system as well as the aerodynamic losses in the interactive region between two impellers.



#### 4.2. Influence of the speed ratio

By replacing the impeller of SICC compressor with the innovative counter-rotating system, it is possible to control independently the rotation speed of each impeller. The impeller speed ratio is then defined as  $\theta_i = \frac{N_1}{N_2}$ . Different values of the impeller speed ratio are proposed as it can be shown in table 4. The minus sign represents two impellers rotate in the opposite direction.

**Table 4.** Impeller speed ratio


Speed ratio ( $\theta$ )	Value	The first impeller speed ( $N_1$ )	The second impeller speed ( $N_2$ )
$\theta_1$	-0.7	-6300	9000
$\theta_2$	-0.8	-7200	9000
$\theta_3$	-0.9	-8100	9000
$\theta_4$	-1	-9000	9000
$\theta_5$	-1.1	-9900	9000
$\theta_6$	-1.2	-10800	9000
$\theta_7$	-1.3	-11700	9000

For all studied impeller speed ratios, the rotation speed of the second impeller is fixed at 9000rpm. The advantages of an innovative generation compressor have been made by comparing the performance of the two machines under nearly identical operating conditions and the same peripheral velocity. Figure 7 shows the effect of the impeller speed ratio on the performance of CRCC. It is clear that the pressure ratio increase gradually with the increase of the first impeller speed. The pressure ratio has been increased from  $\Pi_s = 1.107 \pm 0.002$  at  $\theta_1 = -0.7$  to  $\Pi_s = 1.145 \pm 0.002$  at  $\theta_7 = -1.3$ . It is worth noting that the pressure ratio curve of the CRCC with  $\theta_7 = -1.3$  approaches that of the SICC at 11000rpm. That shows that the CRCC can achieve almost the same performance of SICC but at a lower speed of about 2000rpm. An interesting fact is that the performance of the compressor does not seem to be affected by the speed ratio. The best efficiency point is always  $72\% \pm 2\%$  comparing to  $64\% \pm 2\%$  of SICC. These points are achieved at different mass flow rates corresponding to different speed ratios. Set of the best efficiency points generates an effective operating zone of CRCC in case of change the speed of impellers. We can conclude that the impeller speed ratio in the range selected for this work greatly affects the pressure ratio, effective operating zone, and surge margin while remaining the polytropic efficiency stable of CRCC.

Nevertheless, the surge margin seems to be appeared soon in CRCC configuration. Higher speed ratio leads to the surge phenomena occurs earlier because of higher pressure ratio and higher incidence angle at the impeller inlet.

## 5. Conclusion

In this study, a counter-rotating centrifugal compressor (CRCC) has been experimentally studied to measure the effect of the innovative system on global performances. Results of the comparison with a single impeller centrifugal compressor (SICC) highlight the increase of the pressure rise and the polytropic efficiency. CRCC can improve by about 8% in polytropic efficiency and 2.5% in pressure ratio when the speed of two impellers is the same. Besides, the effect of the speed ratio of CRCC is conducted to find out its effect on the performance. The results show that the speed ratio has no effect on the maximum efficiency (it remains  $72\% \pm 2\%$ ) but it increases significantly the pressure ratio (it increases by about 4% at  $\theta_7 = -1.3$ ). In addition, changing



**Figure 7.** Effect of speed ratio  $\theta_i$  on the global performances of CRCC with the second impeller rotation speed fixed at 9,000 rpm. The solid lines represent the CRCC configuration and the dash lines display the SICC.

the speed ratio can make a wider effective operating zone in comparison with the single point of SICC. However, the surge margin occurs early in CRCC configuration because of higher pressure rise and higher incidence angle at the inlet of impellers. In future work, this inconvenience of CRCC will be resolved by finding a couple of speeds of CRCC's impeller to extend the operating range and in particular to push back the surge limit to a smaller flow rate.

## References

- [1] Nouri H, Danlos A, Ravelet F, Bakir F and Sarraf C 2013 Experimental study of the instationary flow between two ducted counter-rotating impellers *J. Eng. For Gas Turbines and Power* **135**
- [2] Govardhan, M., Vijayraj, K. (2015). Aerodynamics of contra-rotating fans with swept blades. In Proceedings of the ASME 2015 Gas Turbine India Conference (pp. 111).
- [3] F. Ravelet, F. Bakir, C. Sarraf, J. Wang, Experimental investigation on the effect of load distribution on the performances of a counter-rotating axial-flow fan, *Experimental Thermal and Fluid Science*(2018), doi: <https://doi.org/10.1016/j.exptthermfluidsci.2018.03.004>
- [4] Ai Z, Qin G, Lin J, Chen X, He W. Variable-speed method for improving the performance of a mine counter-rotating fan. *Energy Sci Eng.* 2020;8:24122425. <https://doi.org/10.1002/ese3.676>
- [5] Ghenaïet, A., Beldjilali, I. (2020). Influence of Staggering and Interdistance on Performance of a Low-Speed Counterrotating Axial Fan. *Journal of Aerospace Engineering*, 33(1), 122. [https://doi.org/10.1061/\(ASCE\)AS.1943-5525.0001081](https://doi.org/10.1061/(ASCE)AS.1943-5525.0001081)
- [6] Sharma P B, Shigemitsu T and Watanabe S 1985 Stalling behavior of a contra-rotating axial compressor stage. *Inter. Sympos. On Air Breathing Engines*
- [7] Sharma P B and Adekoya A 1996 A review of recent research on conter-rotating axial flow compressor stage *ASME Int. Gas Turbine and Aero Engine Congress Exhibition*
- [8] Chen, Y. Y., Liu, B., Xuan, Y., Xiang, X. R. (2008). A study of speed ratio affecting the performance of a contra-rotating axial compressor. Proceedings of the Institution of Mechanical Engineers, Part G: Journal of Aerospace Engineering, 222(7), 985991. <https://doi.org/10.1243/09544100JAERO364>
- [9] Furukawa A, Shigemitsu T and Yasunobu T 2007 Performance test and flow measurement of contra-rotating axial flow pump. *J. Th. Sci.*
- [10] Tosin S, Dreiss A and Friedrichs J 2015 Experimental and numerical investigation of a counter-rotating mixed-flow single stage pump *ASME Expo* **111**.
- [11] Nguyen V T, Danlos A, Paridaens R, and Bakir F 2019 Study of the effect of the contra-rotating component on the performance of the centrifugal compressor *International Journal of Mechanical, Industrial and Aerospace Sciences* **13** 392. <https://doi.org/10.5281/zenodo.3298874>