



HAL
open science

Experimental Study on the Use of Enhanced Coconut Oil and Paraffin Wax Phase Change Material in Active Heating Using Advanced Modular Prototype

Khaireldin Faraj, Mahmoud Khaled, Jalal Faraj, Farouk Hachem, Cathy Castelain

► To cite this version:

Khaireldin Faraj, Mahmoud Khaled, Jalal Faraj, Farouk Hachem, Cathy Castelain. Experimental Study on the Use of Enhanced Coconut Oil and Paraffin Wax Phase Change Material in Active Heating Using Advanced Modular Prototype. *Journal of Energy Storage*, 2021, 41, pp.102815. 10.1016/j.est.2021.102815 . hal-03291107

HAL Id: hal-03291107

<https://hal.science/hal-03291107>

Submitted on 20 Jul 2021

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

Experimental Study on the Use of Enhanced Coconut Oil and Paraffin Wax Phase Change Material in Active Heating Using Advanced Modular Prototype

Khaireldin Faraj^{1,2}, Mahmoud Khaled^{3,4*}, Jalal Faraj^{3,5}, Farouk Hachem², Cathy Castelain¹

¹Laboratory of Thermal Energy of Nantes, LTEN, Polytech' Nantes, University of Nantes, Nantes-France.

²Energy and Thermo-Fluid Group, Lebanese International University, LIU, PO Box 146404 Bekaa, Lebanon.

³Energy and Thermo-Fluid Group, The International University of Beirut BIU, PO Box 146404 Beirut, Lebanon.

⁴University Paris Diderot, Sorbonne Paris Cite, Interdisciplinary Energy Research Institute (PIERI), Paris, France.

⁵Lebanese university, Faculty of Technology, Saida, Lebanon

*In correspondence to: Mahmoud Khaled, International University of Beirut, PO Box 146404, Beirut, Lebanon

E-mail : mahmoud.khaled@liu.edu.lb; Phone : 009611706881/2/3/4 ; Fax : 009611306044

Abstract

The use of phase change materials in buildings as a thermal energy storage system gained the attention of researchers all over the world. In the current study, coconut oil bio-based PCM is macro-encapsulated with enhanced thermal conductivity containers and coupled with hydronic radiant floor heating system. The study follows experimental aspect utilizing two identical small scale modular test prototypes. Investigations are directed toward studying the effect of the active CO-PCM system under different weather conditions, effect of combining active and passive systems, effect of PCM choice/type and effect of PCM location within the active floor, on the thermal and energy storage performances. Results revealed that coupling CO-PCM to active floor, passive wall and passive roof is capable of achieving load shifting and energy savings; and is affected by the control method, weather conditions, electricity tariff policy and PCM position and type. Further discussions, conclusions and perspective recommendations are summarized within the article.

Highlights

- Identical experimental advanced modular prototypes are designed and implemented.
- Macro-encapsulation technique using enhanced thermal conductivity containers.
- Thermal comfort and temperature fluctuations reduction using CO and PW PCMs.
- Load shifting by combined CO-PCM applications leads to possible annual cost saving.
- Positioning CO-PCM plates below heating layer ensued energy saving of 393.5 kWh.

Keywords: Phase Change Materials; Modular Prototype; Coconut-oil; Paraffin wax; Radiant Heating System; Thermal Energy Storage.

1. Introduction

Within the past few decades, the world has encountered a massive increase in energy consumption accompanied by an increase in CO₂ emissions that lead to arising environmental risks. This enormous increase was a consequence to the growth in world's population that stimulated the evolution of economy and energy demand [1]. Buildings proved to be accumulating for the largest energy consumption quantity world-widely, with a percentage ranging between 30-40%¹ [2–5], that is expected to rise up by 2050 reaching 50% [6]. The majority of energy consumed within the building sector is directed toward heating and cooling systems. For instance,

¹ The percentages differs in regions and countries: 40% in Europe [73][74], 33% in China [75], 40% in U.S. [76] and 28% in Tunisia [77].

Abbreviations

PCM	<i>Phase change material</i>	SAH	<i>Solar air heater</i>
TES	<i>Thermal energy storage</i>	RC	<i>Radiative cooling</i>
LHS	<i>Latent heat storage</i>	RHS	<i>Radiant heating system</i>
SHS	<i>Sensible heat storage</i>	EPS	<i>Expanded polystyrene Foam</i>
NZEB	<i>Net zero energy building</i>	XPS	<i>Extruded polystyrene Foam</i>
TW	<i>Trombe wall</i>	SWHS	<i>Solar water heating system</i>
TABS	<i>Thermally activated building structure</i>	HVAC	<i>Heating, ventilating and air conditioning</i>
HAR	<i>Heat accumulator</i>	PCMW	<i>PCM wallboard</i>
EG	<i>Expanded Graphite</i>	EP	<i>Expanded Perlite</i>
SAT-FA	<i>Sodium acetate trihydrate-formamide</i>	ERFHS	<i>Electric radiant floor heating system</i>
		HRFHS	<i>Hydronic radiant floor heating system</i>

Units and symbols

Temperature	T ($^{\circ}\text{C}$)	Conductivity	k ($\text{W}/\text{m}\cdot\text{K}$)
Enthalpy	h (kJ/kg)	Specific Heat	C_p ($\text{kJ}/\text{kg}\cdot\text{K}$)
Volume	V (m^3)	Area	A (m^2)

47 according to U.S. Energy Information Administration space heating and air conditioning accounts for 48% of
48 overall energy consumption in residential site [7]; and according to ministry of electricity and water in Kuwait,
49 cooling systems in buildings account for 70% of electricity produced in power plants [8]. For that, it is essential
50 to develop new materials and adapt buildings and their heating/cooling systems to align with the requirements
51 needed for energy conservation enhancement and sustainability in constructions [9].

52
53 Thermal energy storage (TES) in buildings, with its three distinctive forms: latent, sensible and thermochemical,
54 became a key element in the process of building adaptation toward Sustainability and Green Buildings. Phase
55 change material latent heat thermal energy storage (PCM-LHTES) proved to be a promising technique in storing
56 energy, filling the gap between supply and demand, due to its high latent heat over narrow temperature ranges
57 [10,11]. With their favorable properties, PCMs are capable of increasing the buildings thermal mass, performing
58 load shifting, enhancing occupants thermal comfort and increasing overall building energy efficiency.
59 Furthermore, proper use of PCM applications in buildings contributes to the international trend toward
60 implementing Net Zero Energy Buildings (NZEB) building policies (which is to be implemented by 2030 in U.S.
61 [12]). Also, motivating people towards contributing in PCM energy storage systems utilization requires social
62 awareness [13]. Researches focused on the use of PCM in buildings contained several applications that are
63 categorized as Passive PCM applications or Active PCM applications. PCMs are used passively in building
64 envelopes as: walls [14–16], Trombe walls [17], solar façades [18,19], roofs [8], floors, suspended ceilings [20],
65 windows [21], decorative elements, furniture and textiles [22–24], and passive heat exchanger components; or
66 actively being coupled to: radiant heating systems (RHS) [25–27], solar water heating systems (SWHS) [28],
67 radiative cooling (RC) [29], thermally activated building structures (TABS), solar air heater (SAH) [30–32],
68 heating, ventilating and air conditioning (HVAC), geo-cooling [2], activated TWs and activated solar façades.
69 Any combination of the aforementioned PCM-LHTES system applications yields a particular important study as
70 mentioned in previous works [33,34].

71
72 Between all heating applications, radiant underfloor heating/cooling coupled with PCM has promising
73 performance. Radiant heating systems can be either hydronic heating systems utilizing a working fluid and can
74 be coupled to SWHS, or an electrical radiant mat system which rely on the advantage of load shifting enabled by
75 PCMs. Recent studies related to the use of PCM coupled to radiant heating system in buildings (forming an active
76 application) and the adapted systems as well as hybrid studies are reviewed thoroughly.

77
78
79 Several research articles were conducted and targeted towards investigating the performance of underfloor
80 radiant systems coupled with PCM. Lin et al. [35] investigated the effect of integrating paraffin-based SSPCM

81 with electric radiant heating system in Tsinghua, Beijing, China. A large-scale test room was constructed ($3 \times$
82 $2 \times 2 \text{ m}^3$) with the floor containing electric heater above which lies the PCM. Results showed that more than
83 50% of electric load required for sustaining thermal comfort was shifted to off-peak periods which allows
84 economic savings due to different electricity Tariffs between day and night [36]. Huang et al. [37] focused on
85 testing a retrofit integrated with a SWHS coupled to floor capillary tubes under which lies Macro-packs filled
86 with Capric acid PCM and compared by a conventional room in the cold climate of Shenyang, Liaoning, China.
87 Results revealed that PCM is able to supply the room with energy equivalent to 47.7% of energy supplied by the
88 solar system for 16 hrs. Cheng et al. [38] tested the effectiveness of thermal conductivities of SSPCM integrated
89 with ERFHS as retrofitting in a conventional room ($4 \times 3 \times 3 \text{ m}^3$) located at Yangtze, Anhui, China. Results were
90 promising reflecting that the enhancement in thermal conductivity of PCM promotes the heating system energy
91 efficiency as the thermal conductivity is below 1 W/m.K. Zhou and He [39] performed a comparative
92 experimental study on the performance of HFRHS coupled with storage materials (PCM-LHTES and Sand-SHS)
93 utilizing different pipe types (regular PE coils and capillary mat). Results proved that the use of capillary mat is
94 more beneficial compared to PE coils during the charging phase; And, PCM is favorable over sand during
95 discharging process (pumping-off period) with longer duration by 2 times of heat release. A numerical study by
96 Zhou et al. [40] covered the integration of shape-stabilized PCM boards with active heating/cooling pipes for
97 side-wall cooling and underfloor heating. Based on their results, it was depicted that an annual heating energy
98 consumption reduction of 16.2% is achieved. Devaux and Farid [27] compared the thermal performance of two
99 different PCM types incorporated in walls, ceilings and in-combination with underfloor heating system. Results
100 showed that the use of PCM enhances thermal comfort and permits successive load shifting and energy
101 consumption reduction contributing an energy and cost savings of 32% and 42%, respectively.
102

103 Lu et al. [41] introduced a solar water heating system and coupled it to PCM floor. The PCM was macro-
104 encapsulated at the circumference of the heating pipes passing the floor. The authors performed experimental
105 analysis via two identical large-scale prototypes, and numerical analysis using TRNSYS software and results were
106 promising. Experimental results revealed that the fluctuations in indoor temperature were reduced in the PCM
107 room compared to control room, with a 5.87% reduction in energy consumption if the room is to be maintained
108 at 20 °C. Garg et al. [42] designed and implemented a PCM-based heat exchanger placed in the roof of a small-
109 scale test chamber for heat gain reduction in summer conditions of Mumbai, India. Results showed that a reduction
110 of 50% in heat gain from the roof, and more than 6 °C in the mean air temperature were obtained by the PCM
111 heat exchanger. The concept of capillary tubes embedded in PCM as an active system was studied by Jobli et al.
112 [43]. 140 m long plastic capillaries were embedded in PCM of the ceiling of a test chamber ($1.2 \times 1.3 \times 2 \text{ m}^3$).
113 A numerical model was validated with the obtained experimental results to show that the robustness of the model
114 is fulfilled when the volumetric flow rate of the working fluid (water) exceeds 800 ml/min while correction factors
115 are addressed in the reverse case.
116

117 The choice of PCM is essential in any application. Fang et al. [44] prepared a novel shape-stabilized PCM
118 composed of sodium acetate trihydrate-formamide (SAT-FA) and expanded graphite (EG) as supporting material,
119 for the use with electric radiant floor heating systems (ERFHS). The prepared PCM plates were used in an
120 insulated small-scale simulation test facility ($1.15 \times 1.15 \times 1.3 \text{ m}^3$) equipped with ERFHS. Results showed that
121 the thermal performance of the system with PCM was enhanced where thermal comfort was increased as the
122 temperature fluctuations in vertical indoor environment decreased. In a comparative study directed toward
123 investigating the effect of combining active and passive PCM applications, Kong et al. [5] managed to introduce
124 a novel system composed of PCM wallboards (passive) prepared from paraffin and EP, and a heat accumulator
125 (HAR) filled with PCM coupled to a solar heating system used as a radiating wall. Two identical test cubicles of
126 1 m edge size comprising a window were prepared and tested under different stages. Results revealed that PCM
127 enhanced the thermal inertia of the test cubicle and that the functioning duration of the solar heating system was
128 increased by means of HAR filled with Paraffin PCM; And the combination of both systems enhanced the thermal
129 comfort and building thermal efficiency for the cubicle.
130

131 Combination of different PCM applications in buildings yields significant enhancement in building thermal
132 performance. Several studies focused on testing the effect of integrating two different PCM applications. Lu et
133 al. [45] studied the effect of combining hydronic radiant floor heating system (HRFHS) as active application with
134 a Trombe wall passive system. It was depicted that a positive difference of 7.5°C in the average indoor temperature

135 between PCM room and reference room was achieved. Also, it was found that an average energy-saving rate of
136 54.27% was achieved by the PCM room compared to the reference room. Zhu and Yang [46] validated a numerical
137 model through an experimental study focusing on the thermal performance of a PCM building envelope embedded
138 with radiant cooling pipes. The simulation covered the effect of pipe spacing and PCM thickness as well as
139 orientation of the embedded wall. It was proved that pipe embedded PCM envelope is effective in terms of thermal
140 comfort enhancement and energy saving during the heating season.

141
142 A numerical study executed by Plytaria et al. [47] focused on the simulation of solar cooling radiant walls
143 coupled with PCM using TRNSYS software for a 100 m² area building. Results revealed that the optimum location
144 of PCM is in the south wall with a reduction of auxiliary energy of 30%. In another numerical study with the same
145 building dimensions, Plytaria et al. [48] managed to investigate and optimize the performance of underfloor solar
146 assisted heating system integrated with PCM. Using TRNSYS simulation tool authors proved that the use of
147 BioPCM Q29 as Macro-encapsulated PCM placed under the floor heating tubes reduces the auxiliary energy load
148 by 65%, and the rise of indoor temperature reached 0.8 °C.

149 Sun et al. [49] prepared three identical laboratory small-scale test facilities to test the thermal performance of
150 HRFHS coupled with double-layer PCM utilizing different inorganic PCMs namely: Na₂HPO₄·12H₂O
151 (T_m=31.3°C) and CaCl₂·6H₂O (T_m=20.2°C). Three identical test facilities (0.44 × 0.44 × 0.57 m³) were
152 constructed and equipped as follows: reference cell containing pebbles (8-12 mm diameter), PCM cell 1 having
153 TM/EG composite PCM at the bottom while DHPD-SSP/EG PCM above, and PCM cell 2 containing PCMs in
154 reverse order. The cells were placed in an artificial climate chamber simulating summer and winter conditions.
155 Results showed that for winter and summer climates, thermal comfort duration offered by the PCM was 2.2 and
156 1.7 times that in the reference room, respectively, taking into account reversing the positions of the double layered
157 PCMs (test cell 3). Lee et al. [12] performed an experimental study on the performance of high-tech HRFHS with
158 PCM. The study involved two main aspects: thermal behavior and stress analysis. Four different systems are
159 tested based on the amount of SSPCM coupled with the HFRHS as follows: 1000g, 2000g, 4000g and 8000g of
160 SSPCM per unit area referred as A_10, A_20, A_40 and A_80. Results showed that HFRHS coupled with PCM
161 could store more heat as the amount of SSPCM increases however, the compressive strength that the floor can
162 withstand decreases.

163
164 A tabulated summary for the aforementioned studies reviewed in the literature, for direct comparison, is
165 presented in **Table 1**. Also, the used PCMs in respective studies and their thermo-physical properties are presented
166 and summarized in **Table 2**.

167
168
169 The above mentioned literature studies, presented in *section 1.1*, show that most previous research focused on
170 studying the effect of using one type of PCM incorporated with a single active radiant PCM application. Few are
171 the studies focusing on combining active and passive systems. Also, it is found that PCM incorporation methods
172 are directed toward enhancing the thermal conductivity that PCM lack. Parametric analysis is done numerically
173 with validation against reduced-scale prototypes. Also, it is found that plenty of studies utilized a single test
174 facility instead of two thus lacking simultaneous experimental investigation. Some prototypes are far from
175 simulating real case where the sizes and features are inconvenient. Besides, plenty of experiments were done in
176 artificial controlled environments and few are the tests that covers variable real weather conditions. Therefore,
177 the aim of this study is to perform parametric analysis to investigate the effect of integrating PCM as LHTES with
178 HRFHS (active application) and building envelope (passive application) using sustainable enhanced macro-
179 encapsulated PCM plates containing coconut oil and paraffin wax. Two advanced modular prototypes are used in
180 the study with conventional enhanced insulation and features. The study is terminated with relevant conclusions
181 and future recommendations.

182
183
184

Table 1 Summary of literature studies for active PCM radiant heating applications in buildings.

Author	Year	Test methodology	Prototype/software	Climate	Used PCM	PCM-LHTES technique/system	Key results
Kong et al. [5]	2017	Experimental	Two identical small-scale test cubes ($1 \times 1 \times 1 \text{ m}^3$)	Tianjin, China	Paraffin-based PCM	Combination of passive PCMW and active solar water heater coupled to HAR filled with PCM	- PCMW enhanced the thermal inertia of the envelope. - Enhancement in thermal performance, indoor thermal comfort, and building energy efficiency by combining active HAR with PCM and passive PCMW.
Lu et al. [41]	2017	Experimental and Numerical	Two identical large-scale test rooms / TRNSYS	Ninghe, Tianjin, China	CA-HA (<i>capric acid with hexadecyl alcohol</i>) HS24	PCM floor coupled with solar water heating system	- Indoor temperature fluctuations decreased in PCM room compared to reference. - Energy consumption saving of 5.87% was achieved in PCM room if indoor temperature was maintained at 20°C.
Garg et al. [42]	2018	Experimental and Numerical	Small-scale test chamber	Mumbai, India	(In-organic chemical compound)	Radiant heat exchanger with PCM in the roof	- PCM based heat exchanger decreases heat gain to test chamber by 50% and indoor temperature by more than 6 °C.
Lu et al. [45]	2018	Experimental	Two identical large-scale test rooms ($2 \times 2 \times 2.5 \text{ m}^3$)	Tianjin, China	Paraffin-based PCM	Combination of passive Trombe wall and active HRFHS with PCM	- average indoor temperature is higher in the PCM room by 7.15°C is passive stage. - 54.27% average energy-saving rate achieved by PCM room compared to reference room.
Fang et al. [44]	2019	Experimental	small-scale test room ($1.15 \times 1.15 \times 1.3 \text{ m}^3$)	-	Salt-hydrate-based Eutectic PCM	Underfloor electrical heating with PCM	- Vertical temperature fluctuations decreased with the presence of PCM, with an increase in thermal comfort time.
Jobli et al. [43]	2019	Experimental and Numerical	Laboratory reduced-scale prototype	<i>Laboratory environment</i>	Paraffin-based PCM	Hybrid capillary tube PCM wall and ceiling	- Experimental and numerical results agree when the flow rate in the capillary tubes exceeds 800 ml/min. Otherwise, correction factors are introduced.
Faraj et al. [26]	2019	Experimental	small-scale test house ($1.18 \times 1.18 \times 1.21 \text{ m}^3$)	<i>Agricultural Refrigerator (0°C to 5°C)</i>	Bio-based PCM (Coconut oil)	Macro-encapsulated PCM plates coupled with underfloor electric heating	- CO-PCM permitted successful load shifting. - Cost saving of \$98 per year was achieved by integrating CO-PCM.
Plytaria et al. [48]	2019	Numerical	TRANSYS 17 ($10 \times 10 \times 3 \text{ m}^3$)	Athens, Greece	BioPCM Q29M91	PCM integrated in solar assisted HFRHS	- Reduction of 65% in auxiliary load is achieved for PCM layer under the underfloor heating pipes. - Increase of 0.8 °C in the indoor temperature.
Sun et al. [49]	2020	Experimental	Three identical test cells ($0.44 \times 0.44 \times 0.57 \text{ m}^3$)	<i>Artificial climate chamber</i>	<i>Double-layer of hydrate salt-based PCMs</i>	PCM coupled to floor radiant system	- In winter climate, PCM-1 ensures thermal comfort duration 2.2 times that in reference cell. - In summer climate, PCM-2 ensures thermal comfort duration 1.7 times that in reference cell.
Lee et al. [12]	2020	Experimental	Thermal room ($0.5 \times 0.5 \times 1.8 \text{ m}^3$)	<i>Laboratory controlled temperature</i>	n-Octadecane with xGnP	PCM coupled to HFRHS	- Amount of PCM added in the manufacturing process of SSPCM is important regarding thermal performance and stress analysis.

Table 2 Thermo-physical properties of key PCMs used in studied literature and coupled (*or designed for the usage*) with radiant heating applications for buildings

PCM used	Type	Synthetic/ commercial	Application	Incorporation method	Melting temperature	Latent heat	Thermal conductivity	Specific heat	Ref.
Paraffin 75 wt% + Polyethylene 25 wt%	Paraffin-based PCM	Synthetic	Underfloor radiant heating system with PCM	Shape-stabilization	52 °C	150 kJ/kg	0.15 W/m.K	2 kJ/kg.K	[35]
Paraffin (Energain wallboards)	Paraffin-based PCM	Commercial	Combining PCM- ERFHS with PCMW in walls and ceiling Combined passive PCMW with active solar heated HAR filled with PCM	Micro- encapsulation	28 °C	120 kJ/kg	0.2 W/m.K	2 kJ/kg.K	[27]
Paraffin 60 wt% + EP 40 wt%	Paraffin-based PCM	Synthetic	Underfloor electrical heating with PCM	Shape-stabilization	25 °C	106.2 kJ/kg	-	-	[5]
92% SAT-FA + 8% EG	Salt-hydrate- based Eutectic PCM mixture	Synthetic	Underfloor radiant heating system with PCM	Shape-stabilization	38.54 °C	187.6 kJ/kg	3.11 W/m.K	-	[44]
Paraffin	Paraffin-based PCM	Commercial	Combined passive TW with active HRFHS with PCM	Macro- encapsulation	35-40 °C	73.3-79.6 kJ/kg	-	-	[45]
RT18HC	Paraffin-based PCM	Commercial	Pipe-embedded PCM cooling wall	Macro- encapsulated	17-19 °C	260 kJ/kg	0.2 W/m.K	2 kJ/kg.K	[46]
BioPCM Q29M91	Bio-based PCM	Commercial	Solar assisted HRFHS with PCM	Macro- encapsulated	29 °C	210-250 kJ/kg	0.15-2.5 W/m.K	2.2-4.5 kJ/kg.K	[48,50]
70% SAT-urea + 30% fumed silica SiO ₂	Non-eutectic PCM mixture	Synthetic	Underfloor radiant heating system with PCM	Shape-stabilization	35.75 °C	151.6 kJ/kg	-	-	[51]
Na ₂ HPO ₄ ·12H ₂ O + 25% EG	Salt-hydrate- based PCM	Synthetic	HRFHS with PCM	Shape-stabilization	31.3 °C	169.4 kJ/kg	-	-	[49]
n-Octadecane + xGnP	Paraffin-based PCM	Synthetic	HRFHS with PCM	Shape-stabilization	28 °C	256.5 kJ/kg	0.23 W/m.K	92 kJ/kg.K	[12]
HS24 (SAVE®)	Inorganic mixture	Commercial	Roof Radiant cooling heat exchanger with PCM	Macro- encapsulated	23-32 °C	199 kJ/kg	1.05 W/m.K	2.07 kJ/kg.K (solid) 2.42 kJ/kg.K (liquid)	[42]
62.5% Capric acid (CA) + 37.5% hexadecyl alcohol (HA)	Organic-based mixture	Synthetic	PCM floor coupled with solar water heating system	Macro- encapsulation	19-25 °C	266-288 kJ/kg	0.116 W/m.K (solid) 0.148 W/m.K (liquid)	1.975 kJ/kg.K (solid) 2.21 kJ/kg.K (liquid)	[41]
A23 Plus-ice	Paraffin-based	Commercial	Hybrid capillary tube PCM wall and ceiling	Micro-encapsulated	21 °C	210 kJ/kg	0.18 W/m.K	2.22 kJ/kg.K	[43]

188

189

190 2. Methodology

191

192 The study follows one aspect which is experimental investigation using an advanced modular small-scale
193 prototype. Two identical modular prototypes are designed and implemented where the detailed description is
194 presented in *section 2.1*. PCM used is macro-encapsulated using enhanced plates and hydronic radiant floor
195 heating is used as the active heating system for the current study. *Section 2.2* deals with the measurement tools,
196 reliability tests and uncertainty analysis as well as the control system used for heat load management.

197

198

199

200 2.1 Experimental Set-up

201

202 2.1.3 Experimental Prototype

203

204 Two small-scale advanced modular test prototypes are designed and implemented such that they follow
205 specified criteria. Firstly, the prototypes are designed to allow several configurations and combinations to be
206 modeled; These are: active, passive, heating, cooling or any combination of these applications. The prototypes
207 are also designed to allow variable PCM types, position and amount, as well as variable envelope partitions
208 thicknesses. Suitable scale, utilization of real features and standardized construction materials are also permitted
209 by the design.

210

211 For each prototype, since they are meant to be identical, the following detailed implementation process is
212 followed. Firstly, a skeletal structure made from aluminum squared-hollow beams ($A_c = 100 \text{ cm}^2$) is assembled
213 as shown in [Figure 1](#). L-shape aluminum channels are embedded at the internal edges of the prototypes
214 forming a seat for the envelope side, floor and roof layers. The prototypes are small-scale with the dimensions of
215 1.6 m (*width*) \times 1.6 m (*length*) \times 1.4 m (*height*) which are nearly 1:8 scaled to a typical Lebanese building
216 room in Bekaa Valley. The internal volume of each prototype is 2.352 m^3 . Different conventional building
217 material layers are installed in the different sides as illustrated in [Figure 2](#). The composition of the walls
218 from internal to external surface is respectively made of: (1) 8 mm inner wood layer, (2) 30 mm first XPS
219 insulation layer, (3) 15 mm Fiber glass insulation layer, (4) 30 mm second XPS insulation layer, (5) 12 mm outer
220 wood layer and (6) 4 mm ALUCOBOND® composite finishing layer. [Table 3](#) summarizes the different
221 dimensions and thermo-physical properties of the different materials for the sides roof and floor composition.

222



223

224

Figure 1 Skeletal structure of the modular prototypes.

225

226 Floor layers are installed first, then wall layers and finally the roof. All layers are fastened by relevant screws
227 except the layers of the floor and the west wall. Complete thermal contact for floor layers is dependent on weight,

228 while the west wall comprises hold down toggle clamps (shown in [Figure 3](#)) to facilitate the assembling
 229 and reassembling of the prototype layers for parametric studies. The test prototypes and complete experimental set-
 230 up are located at the second floor of a conventional 3-story building in Al-Rafid, Bekaa, Lebanon (33°57 N, 35°82
 231 E). The test facilities are subjected to real weather conditions where the second floor is with no walls (open at all
 232 directions). A single-glazing glass door (0.45 m × 0.70 m) with aluminum frames is installed at the south wall
 233 of the prototype, while a double-glazing window (0.60 m × 0.42 m) with aluminum frames, and air as the filler,
 234 is installed at the east wall. Each prototype is mounted on 4 heavy-duty wheels to allow free transportation, with
 235 two of the wheels comprising breaks for stability upon testing.

236 **Table 3** Characteristics of possible wall layers used in the initial assembly of the prototype.

c	Characteristics					
	Thickness, t	Density, ρ	Specific Heat, C_p	Conductivity, λ	Flammability	Ref.
	mm	Kg/m ³	kJ/kg.K	W/m.K	-	
Aluminum L-channel	2	2698	0.921	205	Fire resistant	[52,53]
XPS insulation	30	20.8 – 43.1	-	0.029	Fire resistant	[54]
Glass Wool insulation	15	16-40	-	0.035-0.05	Fire resistant	[55]
Wood base layer and wood cover layer	8-12	-	1.3-2.4	0.41-0.19	Flammable	[52,56,57]
Aluminum composite (<i>Alucobond</i> [®])	4	0.222	-	($U = 5.54$ $W/m^2.K$)	Fire resistant	[58]




Figure 2 Wall composition showing different layers.



241

242 **Figure 3** Hold down toggle clamps implemented in the west walls of the prototypes for facilitating assembling and
 243 reassembling.

244 The final design of the modular prototype, named “ThermoGreen”, and an exploded view of the modeled
 245 prototype using SolidWorks software is presented in [Figure 4](#). The complete set-up of the two
 246 implemented prototypes are illustrated in [Figure 5](#).



247

248 **Figure 4** Exploded view and logo of the complete assembly of the modular prototype.

249

250 **2.1.2 PCM and Enhanced Encapsulation Plates**

251

252 The proper selection of PCM is a critical issue within any study incorporating PCM. The used PCMs in the
 253 current study are: Coconut oil (CO) having a melting temperature of 25 °C, and Paraffin wax having a melting
 254 temperature of 58-60 °C. The selection was based on using a PCM that has its melting temperature range
 255 compatible with the standard of “Thermal Environmental Conditions for Human Occupancy” (ANSI/ASHRAE
 256 standard 55-2013). The standard states that the marginal limits for indoor operative temperature are 20 °C and 27

257 °C and the marginal limits for floor surface temperature are 19 °C and 29 °C [44,59]. The compatibility for CO-
 258 PCM is based on having its melting temperature within the range offered by the aforementioned standard.
 259 However, PW-PCM with high melting temperature was selected to check its effectiveness in keeping the heating
 260 source at high temperature. Therefore, the location of PCM in the system defines the proper choice of melting
 261 range.

262
 263 The choice of PCM then relies on having maximal heat storage capacity and thermal stability. Environmental
 264 concerns are also quite important. CO and PW have high latent heat (~103 kJ/kg and 189 kJ/kg [60], respectively)
 265 and are not flammable, but have poor thermal conductivity. Thermo-physical properties of CO-PCM were tested
 266 in TQP² laboratories. The melting temperature of CO-PCM was confirmed to be around 25°C and the latent heat
 267 was tested using the method of mixtures by applying energy balance as follows:

$$268 \quad Q_{loss} = Q_{gain} \quad (1)$$

269 Which yields:

$$270 \quad m_w C_w (T_{i,w} - T_{f,w}) = m_{CO} L_{CO} + m_{CO} C_{CO} (T_{i,CO} - T_{f,CO}) \quad (2)$$

271
 272 Where: m is the mass of water/CO (kg), C is the specific heat at constant pressure (kJ/kg.K), T_i and T_f are the
 273 initial and final temperatures for water/CO (°C) and L is the latent heat of fusion to be determined (kJ/kg). The
 274 method is done by placing a test tube of known mass of solid-state PCM inside a well-insulated water bath of
 275 high temperature, where the heat released from the water are gained by the PCM allowing it to melt. Results of
 276 the tests are summarized in [Table 4](#) and compared to reference data from previous researches.

277 **Table 4** Thermo-physical properties measured in TQP laboratories.

CO-PCM	T _m (°C)	C _p (kJ/kg.K)	L _H (kJ/kg)	S.G.	K (W/m.K)	Fire retardation
Experimental (TQP)	25	2.174	102.97	0.919	-	Not flammable
Reference	22-24 [61], 25 [62], 26.78 [63]	2.1 [64]	103.25 [61], 70-100 [62], 110.4 [63]	0.916 [65]	0.321 [63], 0.5 [66]	

278

² TQP or Trust for the Quality of Products is a leading firm in material testing that is certified to ISO-9001 and is located in Beirut, Lebanon.



279
280
281

Figure 5 The two identical prototypes (ThermoGreen®) used in the experimental investigation of the current study.



282
283


Figure 6 Enhanced PCM macro-containers showing the steel buffers and copper wires.

284 The incorporation method followed for packing studied PCMs is macro-encapsulation. Galvanized steel is used
 285 to fabricate macro-containers that are designed to be 1400 mm long, 465 mm wide, and 28 mm thick. The
 286 thickness of the steel boards is 2 mm, which means that 25 mm thickness for PCM is allowed within the containers.
 287 Since thermal conductivity is a critical issue that affects the thermal performance of PCM in buildings, several
 288 studies were directed toward enhancing the thermal conductivity.

289 For the current study, steel buffers ($\lambda_{st} = 50.2 \text{ W/m.K}$ [52]) are welded inside the containers at a distance of 100
 290 mm between each two consecutive buffers. The length of each buffer is 350 mm. Also, 3 mm high-conductivity
 291 copper wires ($\lambda_{Cu} = 385 \text{ W/m.K}$ [52]) are inserted at the mid plane through the aforementioned buffers after being
 292 drilled at 50 mm intervals, forming a net matrix that centralizes PCM and thus enhancing the thermal conductivity
 293 of the plate. **Figure 6** demonstrates the PCM plates showing the formed conductive matrix and the final
 294 outcome. The plates are equipped with two drain openings that are capped with screws, and placed at the top edge
 295 of the plate to allow filling and draining of liquid PCM.

296 It is recommended to use other synthesized bio-PCMs that have favorable thermos-physical properties. Nano-
 297 encapsulation of Beeswax through Composite Nanotubes [67,68] and Nano-encapsulation of Palmitic Acid PCM
 298 [69,70], are two examples of enhanced PCMs having high melting temperature close to paraffin wax (around
 299 60°C) used in the study but with higher thermal conductivities reaching 2.8 W/m.K and latent heats reaching
 300 115.5 kJ/kg for beeswax nanocomposite, and 180~188 kJ/kg for Palmitic acid nanocomposite.

301



302

303

Figure 7 Cross-section of the prototype showing the envelope's material composition.

304 2.1.3 Active Hydronic Radiant Floor Heating System

305

306 The used system for fulfilling the heating load is active hydronic floor heating system (HRFHS) using PEX-
 307 AL-PEX composite pipes of 16 mm diameter (*will be called PEX throughout the context for simplification*). These
 308 pipes are coextruded crosslinked polyethylene composite pressure tubes that are reinforced by a welded aluminum
 309 tube in-between inner and outer layers [71]. The composition of the floor, starting from the outer covering layer
 310 at the base, inwardly, is: 12 mm wood layer, 30 mm XPS insulation layer, 4 mm EPS layer with circular pins (16
 311 mm height) by which the piping net is fixed, 28 mm CO-PCM enhanced macro-containers and finally an 8 mm
 312 floor covering surface layer of wood. ~~Figure 7~~ ~~Figure 7~~ illustrates a cross-sectional view for the assembled
 313 prototype showing the composition of walls and floor. The layout of the pipe is spiral as shown in ~~Figure 8~~ ~~Figure~~
 314 ~~8~~ upon implementation phase and the distance between two adjacent pipes is 10 cm.

315

316 The heating tubes are connected to an electrical water heater with a capacity of 50 L (heater element rated
 317 power: 1.5 kW, at 50-60 Hz). ~~Figure 9~~ ~~Figure 9~~ shows a schematic representation for the heating system equipment
 318 and connections with measurement, power and control system, for the two prototypes. Heated water is delivered
 319 to each prototype via circulating water pump running at a flow rate of 0.15 to 0.17 kg/s. Technical data for each
 320 pump are summarized in ~~Table 5~~ ~~Table 5~~. At the inlet and exit of each water pump, one-way valve is connected
 321 for preventing counter flow and protecting the equipment. After being circulated in the prototypes, water is
 322 returned to the heater cold water inlet to be reheated, and thus a closed loop/cycle is formed. The electrical heater
 323 has a vent at its top for safety against over pressurization, and contains a thermostat and temperature gauge for
 324 temperature regulation at a set point chosen by the operator. The two prototypes are positioned next to each other
 325 such that all the faces are subjected to same weather conditions and no face is shaded by another face.

326



Figure 8 Hydronic pipes configuration at the prototype's floor.

Table 5 Technical data for circulating water pumps used in the study.

Name	Automatic Boosting Pump BPS-100	
Manufacturer	Saad Tahan Co.	
Specification	Value	Unit
Power consumption	100	W
Power supply	220/50	V/Hz
Max. capacity	16	L/min
Max. head	12	m
Max. suction	4	m
Pipe diameter	0.5	inches
Rotational speed	2850	rpm
Protection	<i>Thermally protected</i>	
Notes	<i>Certified to ISO9001</i>	


327

328

329

330

331



332

333 **Figure 9** Hydronic radiant heating system implemented in the prototypes and the respective connected measurement and
 334 control systems.

335 **2.2 Measurement Instrumentation and System Control**

336
 337 **2.2.1 Sensors Used and Reliability Tests**

338
 339 Measurements are done to test the thermal behavior of the rooms in the presence of PCM. The parameters tested
 340 are: (1) temperature T in $^{\circ}\text{C}$, (2) humidity Φ as percentage %, (3) solar radiation G_s in W/m^2 and (4) wind speed
 341 V_w in m/s . Temperature is the most influencing and critical parameter in the study. For that, 12 *K-type*
 342 *thermocouples* are used to measure temperatures at different positions within the prototypes with an accuracy of
 343 $\pm 1.5^{\circ}\text{C}$ and a resolution of 0.25°C . Humidity is measured using a *humidity sensor*; Wind speed is measured using
 344 an *air-flow anemometer AR816+* (manufactured by SMART SENSOR®) with an accuracy of $\pm 5\%$ and a
 345 resolution of $0.1 \text{ m}/\text{s}$; And solar radiation is measured by a *solar power meter* with $\pm 5\%$ accuracy and $0.1 \text{ W}/\text{m}^2$
 346 resolution, TES1333 (manufactured by TES Electrical Electronic Corp., Taipei, Taiwan), and is certified to ISO-
 347 9002. Temperature data are recorded at 1-minute time interval using PA Hilton data acquisition system (data
 348 logger) and its respective HDL software. A desktop computer is equipped with the measurement tools to save
 349 data acquired by the data logger and transform them into excel tables.

350
 351 Repeatability tests were done and the uncertainty analysis is performed following two methods: (1) standard
 352 uncertainties for parameters measured by instruments with known precision are calculated following the
 353 rectangular distribution (since no confidence level is given and expectations for extreme values are likely)
 354 (*equation 9*); (2) Combined uncertainty for Thermocouples is calculated using *equation 10* considering the effect
 355 of precision error of temperature measurement related to thermocouple fixation (calculated as standard
 356 uncertainty) and the repeatability standard deviation; both equations in reference to EURACHEM / CITAC Guide
 357 CG 4 [72] and are written as follows:

358
$$u(x) = a/\sqrt{3} \quad (3)$$

359
$$u_c(x) = \sqrt{u(x)^2 + S_x^2} \quad (4)$$


360 Where: x represents the parameter under measurement (temperature, solar radiation, wind speed, or humidity),
 361 $u(x)$ represents the standard uncertainty using rectangular distribution, 'a' represents the certified precision of
 362 the measuring tool specified by the manufacturer, $\sqrt{3}$ which is the coverage factor, $u_c(x)$ represents the combined
 363 uncertainty and S_x is the repeatability standard deviation (or repeatability uncertainty) obtained from repeatability
 364 tests that are graphed in [Figure 10](#) (3 examples are given). S_x is calculated using equation 11 [49].
 365 Repeatability test is done by cooling hot water in a container 2 times under identical test conditions for a specified
 366 time interval.

367
$$S_x = \sqrt{\frac{1}{N(N-1)} \sum_{i=1}^N (x_i - \bar{x})^2} \quad (5)$$

368 Where: N is the number of repeated tests (trials), \bar{x} is the average reading and x_i is the current actual trial reading.
 369 [Table 6](#) summarizes the results of uncertainty tests done for the instruments used in the study and states
 370 the confidence level as well.


371 **Table 6** Detailed information of measurement equipment.

Measured Parameter	Measuring Equipment	Type	Manufacturer	Precision	Resolution	Standard uncertainty	Combined uncertainty	Confidence
T	Thermocouple	K-type	-	±1.5°C	0.25°C	1.583	1.8	98.2%
G _s	Solar power meter	TES1333	TES Electrical Electronic Corp.	±10 W/m ²	0.1 W/m ²	5.77	-	94.23%
V _w	Anemometer	AR816	Smart Sensor®	±5%	0.1 m/s	2.88	-	97.12%
Φ	Humidity sensor	-	-	±5%	0.1%	2.88	-	97.12%
Data logger	Data acquisition system	HDL	PA Hilton Ltd.	-	-	-	-	-



374 **Figure 10** Repeatability tests for 3 typical thermocouples T5, T8 and T11.

375 The repeatability test yielded the following graphs ([Figure 10](#) and [Figure 11](#)) that shows
 376 reliable results obtained by the thermocouples with the standard deviation S_x being below 2 for the range of
 377 operation related to the experiments. Higher standard deviations are accumulated at high temperatures which are
 378 far from comfort level zone. The number of trials for the repeatability tests is 5.




379

380 **Figure 11** Standard deviation repeatability uncertainty as function of time for selective thermocouples during calibration.

381 2.2.2 Control System

382

383 The control system used, for each prototype, comprises an ST1000 (220V AC) all-purpose digital temperature
 384 controller thermostat module with an NTC thermistor temperature sensor probe. The accuracy given by the
 385 manufacturer is $\pm 1^\circ\text{C}$ and the resolution is 0.1°C with a sensor error delay of 1 minute. This gives a standard
 386 uncertainty of 0.577% (refer to equation 3). A relay module for protecting the circuit from high currents is
 387 connected prior to the pump as shown in [Figure 12](#).
 388



389

390 **Figure 12** Control system configuration showing all connections, and a real photo of the instruments.

391 The procedure of testing accompanied by the control system states that: The NTC sensor is placed inside the
 392 room at a height of 0.5 m; When the temperature of the room falls below 18°C , switch 'a' in the microcontroller
 393 closes and the AC current is allowed to pass into the AC electrical relay; The three switches in the relay will then
 394 close allowing the passage of the current into the pump that will suck hot water from the 50 L electrical heater
 395 that is already functioning; the floor will possess radiant heat until the temperature of the room reaches the set
 396 point which is in this case 25°C at which switch 'a' in the microcontroller will be opened and the pump will be
 397 switched off. The procedure of control is illustrated in [Figure 13](#), where T_{set} and ΔT are the set point
 398 temperature and the the temperature difference set by the user while T_{in} is the indoor temperature of the room
 399 under test and is read by the NTC temperature sensor.

400

401

402

403




Figure 13 Flowchart for control methodology for heating and cooling systems.

404
405

406

407 3. Results and Analysis

408

409 The experiments were done during the terminating months of the cold winter season of 2020, namely between
 410 March 1st, 2020 and May 3rd, 2020; and the second phase of the tests took place during the middle of December
 411 2020. Four main configurations were implemented and analyzed covering the effect of weather conditions,
 412 combining active and passive systems, effect of PCM type on thermal performance of HFRHS and effect of PCM
 413 position in regards of the floor heating system. [Table 7](#) below summarizes the different experimental tests
 414 and their respective details of different configurations. The locations of thermocouples for tests 1 and 5 are
 415 illustrated in [Figure 14](#).

416

417

Table 7 Prototypes configurations for different experimental tests.

#	Date & Time		Experimental Objective	ThermoGreen® Specifications		Heating system	Notes
	Date	Time		Prototype -A-	Prototype -B-		
1	Monday 10/2/2020 till Thursday 13/2/2020	80 hr start 6:00	Effect of PCM integration with active underfloor radiant heating system at different weather* conditions and different PCM substitution layer	Underfloor active radiant with CO-PCM above Heating Pipes	Reference	Hydronic	No PCM in ref.
2	Wednesday 26/2/2020	24 h start 6:00	Effect of active underfloor radiant heating – combined with passive PCM wall and roof	CO-PCM in all floor, roof and west wall	Reference	Hydronic	No PCM in ref.
3	Wed. 19/2/2020	24 h start 6:00	Effect of PCM type in active underfloor radiant application	Underfloor active radiant with CO-PCM in floor	Underfloor active radiant with PW-PCM in floor	Hydronic	
4	Saturday 19/12/2020	10 h start 20:00	Effect of PCM position in the floor (below PCM plates)	Underfloor active radiant with CO-PCM below Heating Pipes	Reference	Hydronic	No PCM in ref.




Figure 14 Location of K-type thermocouples for temperature measurement in tests 1, 2, and 3.

419
420

3.1 Active radiant heating with PCM under different weather conditions

421
422

The preliminary tests investigated the effect of CO-PCM placed in the floor, above the hydronic radiant pipes and compared with a control room with no PCM. Figure 15 shows the temperature variations recorded by the floor and room sensors for prototypes A (containing CO-PCM plates) and B (deprived from PCM and considered as control) during three consecutive days encountering variable weather conditions (refer to Figure 16). It is shown that for the first cold rainy day with 78% relative humidity and a wind speed varying between 0.4 and 1.2 m/s, the first heating phase lasted 18.567 hr. for the Active CO-PCM room. Then, the cooling phase remains for 5.33 hr. as the ambient temperature fluctuates between 5.7 and 11.7 °C. However, for the control room 4 heating-cooling cycles are observed with the first cycle having heating and cooling durations of 8.5 hr. and 1.033 hr., respectively. This indicates that the PCM is storing thermal energy in the form of latent heat after which the penetration of heat continues to the floor surface in a slow manner. Then, the heating unit is powered off so the PCM releases its heat slowly maintain the room temperature with its thermal comfort range for more time. The room temperatures are illustrated in Figure 17. It is observed that the fluctuations in the control room (within the comfort zone by means of the control system, i.e. between 18 and 24 °C) are eliminated by means of PCM in Active CO-PCM room. Where the number of heating-cooling cycles is reduced from 12 to 5 compared to the control room. The observed water heating tubes temperature fluctuations (between 50 and 65 °C) is due to the thermostatic effect of the boiler.

423
424
425
426
427
428
429
430
431
432
433
434
435
436
437
438
439


As the ambient temperature decreased in the second day of the experiment, the heating duration for the control room lasted for 11.45 hr. followed by a temperature decay lasting 1.733 hr. bearing in mind that the weather was cloudy with a relative humidity of 68% and a wind speed varying between 0.4 and 1.6 m/s. As the weather starts to get warmer (sunny day but with no solar radiation reaching the prototypes) and the humidity decreases to the upper comfort bound of 60%, the heating-cooling cycles increased from 1 to 2 and from 2 to 4 in rooms A and B, respectively.

440
441
442
443
444
445
446


The floor surface temperature during the three days was varying between 19.7 and 28.6°C, as the upper surface of PCM macro-containers varied between 21.3 and 39.8°C. However, for the control room, the floor surface reached a temperature of 37.7°C which is beyond thermal comfort. The results revealed within the graphs depict that CO-PCM is suitable for load shifting and indoor temperature fluctuations reduction thus maintaining residents thermal comfort.

447
448
449
450
451

452



453




454

455 **Figure 15** Temperature variations recorded by the floor and room sensors for prototypes A (containing the PCM) and B
456 (deprived from PCM - control) during test 1 for different weather conditions.


457

458 The power curves showing the pump power consumption as function of time for the two test prototypes are
459 shown in [Figure 18](#). It is clear from the curves that there is a reduction in energy demand fluctuation thus
460 a decrease of start-up and shut-down processes of the electrical boiler and pump, thus maintenance requirements
461 are reduced.




462

463 **Figure 16** Maximum and minimum wind speeds, weather conditions and average humidity during experiment 1.



464

465 **Figure 17** Variation of room temperatures for experiment 1 as function of time within three testing days.



466
467 **Figure 18** Pump power consumption for rooms A and B during test 1.

468 **3.2 Combining active and passive applications**


469
470 The second experiment was focused on combining the active CO-PCM floor system with passive PCM layers
471 at the west wall and roof. In this case, two plates filled with CO-PCM were installed in the west wall of prototype
472 A with the remaining vacancy³ being occupied with XPS insulation. The roof also contained two PCM plates with
473 XPS at the remaining edges to comply with the west wall design. A clear presentation is given in [Figure 2](#)
474 [Figure 2](#) for the roof.

475
476 The plots of the temperatures recorded for the different layers of the floor, indoor and outdoor are illustrated in
477 [Figure 19](#)
478 It is shown that during 18 hours of continuous data acquisition, the PCM in the tested room
479 was capable of shifting the load by 4.184 hrs. The heating durations for the 1st cycle were 4.983 hr. and 1.65 hr.
480 in rooms A and B respectively. However, room, floor, PCM plate upper surface, and PEX temperatures decreased
481 from their peak values to lower values during 4.184 hr. and 4.15 hr. in rooms A and B, respectively. The decay
482 in temperatures during cooling had a lower slope value in comparison with the decay in the control room. Three
483 heating-cooling cycles were observed for the control room while two heating-cooling cycles were observed for
484 the PCM room. A plot for the power consumption is illustrated in [Figure 20](#)
485 showing the intervals of high and low peak loads based on the Tariff policy of electricity within the site of experiment, Lebanon. The
486 shaded parts of the plot represent the time of low-peak load and the unshaded parts represent high-peak load
487 interval (discussed in details in *section 5*). It is obvious that the presence of PCM in floor, wall and roof caused
488 the complete shifting from high to low peak loads. For instance, the operation of the heating system in the control
489 room occurred for 0.667 hr. within low-peak load and for 3.933 hr. within high-peak load; However, the presence
490 of PCM altered the thermal behavior of the room and shifted the load so that 0.983 hrs. were within high-peak
491 load, and 4 hr. were within the low-peak load. This variation resulted in cost savings that are discussed further
492 more (*section 5*).


493 It is depicted in the figures of temperature profiles that the heating duration when PCM is present above the
494 PEX tubes is relatively high, and causes a delay in reaching the thermal comfort. This is favorable to a certain

³ The remaining vacancy is a result of having the plates each with a width of 46.6 cm and the total height available within the side walls is 120 cm, thus 26.6 cm remains and are occupied by XPS.

495 limit where temperature fluctuations decrease. On the other hand, such long time increases the residents'
 496 dissatisfaction. As for the temperature of the room that have reached 24 °C, the CO-PCM in the room did not melt
 497 and thus the performance of PCM in the roof was similar to the XPS insulation where sensible heat loss penetrated
 498 through the PCM whereas the presence of PCM in wall encountered partial melting. For that, it is recommended
 499 to choose the PCM in the roof and wall within the margins of 18-20 °C as for benefiting from the complete latent
 500 energy of the PCM. For higher temperature set value (i.e. 30°C for example) wall and roof PCM could be
 501 functioning with their complete effectiveness, however, room temperature will be exceeded. Also, one important
 502 consideration is the use of auxiliary electric mats placed below the PCMs present in the wall and the roof so that
 503 upon heating the room, complete melting for CO-PCM occurs all over the envelope.
 504



505



506

507 **Figure 19** Temperature variations recorded by the floor and room sensors for prototypes A (containing PCM in floor, west
 508 wall and roof) and B (deprived from PCM - control) during test 2.




Figure 20 Pump power consumption for rooms A and B during test 2.

3.3 Comparison between CO-PCM and PW-PCM

The third experimental test is directed toward comparative investigation of the thermal performance of the two prototypes having different PCM types (different thermo-physical properties especially: melting temperatures and latent heat). The preliminary results are shown in Figure 21, where it combines readings from the two prototypes. Room A contained CO-PCM above the heating tubes and is considered as the control; and room B contained paraffin wax (PW-PCM), also above the heating tubes, and is considered the variable test (refer to Figure 14-A to check the layers' order). Table 8 shows the thermo-physical properties of CO and PW PCMs.

The start of the heating cycles had the same trend in both rooms, from time 0 till 9.683 hr. at which PW-room B reached 24 °C where the pump is powered off and a gradual decay in temperature starts accounted by release of stored energy in PW plates. However, the heating in room B continued for an extra 6.95 hr. to reach the desired room temperature, before its gradual decrease accompanied by the heat release from melted CO. After that, PW-room starts a new heating cycle where as CO-room remains decaying within thermal comfort. It is observed that at the time heating stops in cycle 1 of room B, the room temperature remains increasing to 27.6 °C which is caused by the relatively high temperature of the PCM plates (where the melting point of PW is 58°C, thus replacing the role of the PEX tubes at this stage).

A plot of the power consumption shown in Figure 22 indicates that although there is load-shifting accompanied by CO-PCM, the large margin of heating time (caused probably of the relatively low thermal conductivity of CO-PCM compared to PW-PCM, or due to experimental sources of error: incomplete thermal contact between layers of PCM and PEX for example) over continuous tariff shifts of 4 hr. each, is not favorable. PW in this case shows better thermal response, with less time of operation within high-peak and low-peak load margins.


Summing up the aforementioned and analyzed tests, Figure 23 compares the number of heating-cooling cycles for control and test prototypes for each test. It is shown that lower number of cycles is always a property

541 of the tested rooms containing the PCM. This ensures the two major advantages of using PCM in active floor
 542 system, and passive walls and roof: (1) Enhancement of thermal comfort by decreasing indoor temperature
 543 fluctuations, and (2) Load shifting resulting in cost savings for regions of variable electricity tariff policy shifts.


544 **Table 8** Thermo-physical properties measured in TQP laboratories.

PCM	T _m (°C)	C _p (kJ/kg.K)	L _H (kJ/kg)	K (W/m.K)
Coconut oil (CO)	25	2.174	102.97	0.321 [63], 0.5 [66]
Paraffin wax (PW)	58-60 [60]	-	189 [60]	0.21 [60]

545
546




547
548 **Figure 21** Temperature variations recorded by the floor and room sensors for prototypes A (containing CO-PCM in floor)
 549 and B (containing PW-PCM in floor) during test 3.



550
551 **Figure 22** Pump power consumption for rooms A and B during test 3.

552



553

554

Figure 23 Comparison for the number of heating and cooling cycles in rooms A and B at various tests.

555

556

3.4 Effect of PCM position within the floor (CO-PCM Below HRFHS)

557

558

559

560

561

562

563

The last test in this study investigates the effect of CO-PCM position in reference to test 1. CO-PCM plates were placed below the PEX tubes as shown in [Figure 24](#). The EPS layer that holds the hydronic tubes is eliminated and the tubes are connected to the wood layer by means of 18 mm diameter clips, to maintain the spiral layout. During this test, the prototypes were rotated such that the doors are at the west direction. The test was performed among two stages: (1) 10 hrs. of variable weather conditions taking into account solar radiation effect, and (2) 24 hrs. of stable weather with no solar radiation effect (shadings are used and the focus was on ambient temperature).

564

565

566

567

568

569

570

571

572

573

574

575

Stage 1 – The results are plotted on the same graph illustrated in [Figure 25](#). It is shown that the temperature of the hydronic pipes increased and remained above 55 °C upon heating when the pumps were switched on, leading to an increase in PCM and floor surface temperatures. During the first 2 hrs. of the test, the control test room (B) was subjected to solar radiation ranging between 628 and 819 W/m², wind speed of 0.2 – 0.8 m/s and humidity ranging between 60.9 and 62.6%. The solar radiation was facing the south wall of room B and penetrating through the window. This caused the slightly higher slope of room temperature compared to room A, where the room temperature was increased from 18 to 27 °C by means of the PEX and solar radiation – this is reflected by the increase of floor surface temperature reaching 39 °C at the end of the cycle which is less than the floor surface temperature reached in room A before reaching the room desired temperature. As time continues increasing to reach 2.83 hr., the floor surface temperature in room A continues its gradual increase to reach 42 °C, while the room temperature reaches 26.5 °C. It is shown that the PCM till this point did not melt, and its temperature is increasing sensibly from 12.4 to 25 °C at which it starts melting.

576

577

578

579

580

581


582

583

584

The delay of 1 hr. to reach the comfort set point in room A compared to B was mainly due to the advantage of having solar radiation in room B. Then, all temperatures decrease during 2 hrs. at which both rooms are heated again, with solar radiation being eliminated from room B. It is observed that the temperature of PCM remained increasing till 28 °C and remained at this temperature although the PEX tubes are heated again; this indicates the phase change phenomena (melting) of the PCM. The floor surface temperature and thus the room temperature in room A reaches the set points before room B, and the decay in temperatures had a lower slope in room B after the pump is switched off indicating the functioning of PCM in releasing its stored heat. Two similar cycles occurred where the durations of heating and cooling in room A were 0.65 and 2.53 hrs.; and in room B were 0.88 and 2.27 hrs., ensuring a difference of 0.26 hr. in cycle 2 (0.37 hr. in cycle 3).


585



586

587

Figure 24 Location of K-type thermocouples for temperature measurement for test 4.



588


589 Figure 25 Temperature variations recorded by the floor and room sensors for prototypes A (containing CO-PCM in floor
590 below PEX tubes) and B (control) during test 4 - stage 1.

591 Stage 2 – The test in stage 2 was conducted for a complete day with shadings used to eliminate the effect of
592 solar radiation. Two graphs showing the results of the temperature distribution of the floor and room for
593 prototypes A and B are illustrated in Figure 26. Three heating-cooling cycles are observed in both rooms.
594 To have a closer view of the detailed outcomes, floor surface and room temperatures with ambient outdoor
595 temperature are plotted against time in Figure 27. As depicted in the graph, for a relatively cold weather
596 of an outdoor ambient temperature fluctuating between 7.6 and 13.6 °C, a total heating duration of 4.784 hrs. in
597 the control room B is reduced to 3.418 hrs. in room A by means of CO-PCM. This indicates the capability of the
598 PCM in saving energy. The concept behind this observation is that the hydronic PEX tubes are radiating and
599 conducting heat on all directions of their circumferences. Heat that is directed toward indoor is the useful heat,
600 whereas heat that is being transmitted downward in the floor is being lost. The presence of PCM below the PEX
601 tubes, captures this heat and releases it when the pump is switched off, thus forming a source of heat energy again
602 to the room.


603 Room temperatures increase from 18 to 24°C in a higher slope within room A compared to room B however
604 the phenomenon is opposed while discharging (the slope of room temperature decay is smaller for room A). This

605 leads to smaller heating times and larger cooling times in the presence of PCM. Also, it is observed that after the
 606 last heating cycle, the decay in temperatures of room and floor surface for A and B encountered some differences.
 607 The slopes of temperature decay for A were smaller than that for B indicating the PCM functioning; And at the
 608 end of the test a difference of 2.5 °C in room and 1 °C in floor surface temperatures between A and B, respectively,
 609 were obtained.

610 Finally, a plot of the power input for rooms A and B consumed by pumps delivering hot water for heating is
 611 illustrated in [Figure 28](#)Figure 28. It is shown clearly that the duration of heating in room B is larger than that in
 612 room A, and that, as aforementioned before, there is a delay in powering on the pump in room A as an effect of
 613 PCM. The energy stored by the PCM is reused for maintaining thermal comfort within the room. Therefore,
 614 placing PCM below the heating system results in energy savings that are translated into cost saving furthermore,
 615 even with a defined electricity cost with stable rate (no differentiation for electricity cost into high-peak and low-
 616 peak shifts).




617




618

619 **Figure 26** Temperature variations recorded by the floor and room sensors for prototypes A (containing CO-PCM in floor
 620 below PEX tubes) and B (control) during test 4 - stage 2.



621

622 **Figure 27** Variation of room temperature and floor surface temperatures for prototypes A and B of experiment 4 – stage 2.



623
624 *Figure 28 Pump power consumption for rooms A and B during test 3*

625
626
627 **4. Conclusions and Recommendations**

628
629 The current research was focused on studying the thermal performance of underfloor hydronic radiant heating
630 system coupled with enhanced coconut oil PCM plates. Experimental aspect was followed, where four different
631 experimental tests were done to: (1) investigate the effect of active CO-PCM coupled with variable weather
632 conditions; (2) effect of combining active PCM system with passive PCM system; (3) effect of PCM type
633 comparing CO-PCM with PW-PCM; and (4) the effect of PCM position, namely placing the PCM below HRFHS.
634 The investigation utilized two identical small scale modular prototypes (ThermoGreen®) with automated control
635 systems for sustaining thermal comfort temperature range as for bounding heating and cooling phases within each
636 test in each room. The study included thermal and economic analyses directed toward investigating the effects of
637 PCM systems on achieving thermal comfort and reducing energy consumption and yearly operational costs. The
638 major arising conclusions are:

- 639
- 640 1. The proposed modular design of the used prototype proved its capability to accommodate various
641 parameters and their effect on thermal performance of the room.
 - 642 2. Using CO-PCM filling enhanced thermal conductivity macro-containers within the layers of the tested
643 prototypes is beneficial in terms of thermal comfort enhancement and annual cost savings.
 - 644 3. Using CO-PCM as active application coupled to HRFHS, and when combined with passive wall and roof
645 permit load shifting from high-peak to low-peak periods resulting in daily and annual cost savings.
 - 646 4. Weather conditions alters the time zone (period) of heating operation which might lead to negative
647 feedbacks regarding cost saving (experiment 1), where the operational cost of the control room is slightly
648 less than that of PCM room.
 - 649 5. The choice of PCM in the roof was not beneficial as the temperature of the roof did not reach the working
650 temperature range of the PCM while maintain the room at 24 °C.
 - 651 6. PW-PCM proved to be more efficient than coconut oil in the case of using PCM as Active TES coupled
652 to HRFHS although load shifting was attained by CO-PCM.
 - 653 7. The position of PCM is very critical. Placing CO-PCM below HRFHS is more beneficial than placement
654 above the heating system. This was obvious where experiment 4 proved the capability of PCM in
655 achieving energy savings even if there were no electricity tariff shifts, unlike placing PCM above the
656 PEX tubes that results in load shifting and requires differences in electricity costs at specific changeable
time zones.

- 657 8. Temperature fluctuation reductions leading to achieving residents' thermal comfort was attained by all
658 cases utilizing PCM.
659 9. Using PCM is a key method toward environmental sustainability and reduction of greenhouse gases
660 caused by heating and cooling conventional systems in residential buildings. It is a keyway toward
661 changing renovations and new erections into NZEB.
662

663 As for future work, the following recommendations are suggested:

- 664 1. The study was focused on heating season and the effect of PCM on reducing heating annual operational
665 costs, however using the system with additional features such as solar façade and nocturnal sky radiation
666 coupled to the hydronic floor system is to be studied.
- 667 2. Economic and Environmental aspects are to be studied to surround the topic in more detail.
- 668 3. Combing PCM applications is favorable and requires that the choice of PCM for each system must
669 comply with the other system. In the case of the current study PCM selection should follow the
670 conventional uniform temperature distribution from the floor reaching the roof.
- 671 4. The skeletal frame of the prototype is recommended to be insulated from the envelope layers especially
672 the underfloor heating layer as it represents a thermal bridge between envelope layers and indoor with
673 outdoor, thus increasing losses.
- 674 5. The combination of triple systems: active HRFHS with passive envelope combined to active Trombe wall
675 system is to be studied further on.
- 676 6. Thermally activated building structure utilizing CO-PCM in its envelope using capillary tubes and electric
677 mats might be of favorable efficiency.
- 678 7. A simulation model using COMSOL Multiphysics can be beneficial in supporting optimization studies
679 with ThermoGreen®.

680
681

682 **References**

683

- 684 [1] F.S. Javadi, H.S.C. Metselaar, P. Ganesan, Performance improvement of solar thermal systems
685 integrated with phase change materials (PCM), a review, *Solar Energy*. 206 (2020) 330–352.
686 <https://doi.org/10.1016/j.solener.2020.05.106>.
- 687 [2] P. McKenna, W.J.N. Turner, D.P. Finn, Geocooling with integrated PCM thermal energy storage in a
688 commercial building, *Energy*. 144 (2018) 865–876. <https://doi.org/10.1016/j.energy.2017.12.029>.
- 689 [3] M.T. Plytaria, C. Tzivanidis, E. Bellos, K.A. Antonopoulos, Energetic investigation of solar assisted heat
690 pump under floor heating systems with and without phase change materials, *Energy Conversion and
691 Management*. 173 (2018) 626–639. <https://doi.org/10.1016/j.enconman.2018.08.010>.
- 692 [4] A. Maccarini, G. Hultmark, N.C. Bergsøe, A. Afshari, Free cooling potential of a PCM-based heat
693 exchanger coupled with a novel HVAC system for simultaneous heating and cooling of buildings,
694 *Sustainable Cities and Society*. 42 (2018) 384–395. <https://doi.org/10.1016/j.scs.2018.06.016>.
- 695 [5] X. Kong, P. Jie, C. Yao, Y. Liu, Experimental study on thermal performance of phase change material
696 passive and active combined using for building application in winter, *Applied Energy*. 206 (2017) 293–
697 302. <https://doi.org/10.1016/j.apenergy.2017.08.176>.
- 698 [6] J. Lizana, R. Chacartegui, A. Barrios-padura, C. Ortiz, Advanced low-carbon energy measures based on
699 thermal energy storage in buildings: A review, *Renewable and Sustainable Energy Reviews*. 82 (2018)
700 3705–3749. <https://doi.org/10.1016/j.rser.2017.10.093>.
- 701 [7] K. Biswas, J. Lu, P. Soroushian, S. Shrestha, Combined experimental and numerical evaluation of a
702 prototype nano-PCM enhanced wallboard q, *Applied Energy*. 131 (2014) 517–529.
703 <https://doi.org/10.1016/j.apenergy.2014.02.047>.
- 704 [8] H.J. Alqallaf, E.M. Alawadhi, Concrete roof with cylindrical holes containing PCM to reduce the heat
705 gain, *Energy and Buildings*. 61 (2013) 73–80. <https://doi.org/10.1016/j.enbuild.2013.01.041>.
- 706 [9] L. Karim, F. Barbeon, P. Gegout, A. Bontemps, L. Royon, New phase-change material components for
707 thermal management of the light weight envelope of buildings, *Energy and Buildings*. 68 (2014) 703–
708 706. <https://doi.org/10.1016/j.enbuild.2013.08.056>.

- 709 [10] A. Kasaeian, L. bahrami, F. Pourfayaz, E. Khodabandeh, W.M. Yan, Experimental studies on the
710 applications of PCMs and nano-PCMs in buildings: A critical review, *Energy and Buildings*. 154 (2017)
711 96–112. <https://doi.org/10.1016/j.enbuild.2017.08.037>.
- 712 [11] K. Du, J. Calautit, Z. Wang, Y. Wu, H. Liu, A review of the applications of phase change materials in
713 cooling, heating and power generation in different temperature ranges, *Applied Energy*. 220 (2018) 242–
714 273. <https://doi.org/10.1016/j.apenergy.2018.03.005>.
- 715 [12] J. Lee, S. Wi, S. Yang, S. Kim, Experimental study and assessment of high-tech thermal energy storing
716 radiant floor heating system with latent heat storage materials, *International Journal of Thermal
717 Sciences*. 155 (2020). <https://doi.org/10.1016/j.ijthermalsci.2020.106410>.
- 718 [13] M. Mofijur, T. Meurah, I. Mahlia, A.S. Silitonga, H.C. Ong, M. Silakhori, M.H. Hasan, N. Putra, S.M.A.
719 Rahman, Phase Change Materials (PCM) for Solar Energy Usages and Storage: An Overview, *Energies*.
720 12 (2019) 1–20. <https://doi.org/10.3390/en12163167>.
- 721 [14] N. Zhu, N. Hu, P. Hu, F. Lei, S. Li, Experiment study on thermal performance of building integrated
722 with double layers shape-stabilized phase change material wallboard, *Energy*. (2018).
723 <https://doi.org/10.1016/j.energy.2018.11.042>.
- 724 [15] N. Zhu, M. Wu, P. Hu, L. Xu, F. Lei, S. Li, Performance study on different location of double layers
725 SSPCM wallboard in office building, *Energy & Buildings*. 158 (2018) 23–31.
726 <https://doi.org/10.1016/j.enbuild.2017.09.075>.
- 727 [16] R.J. Khan, Z.H. Bhuiyan, D.H. Ahmed, Investigation of heat transfer of a building wall in the presence
728 of phase change material (PCM), *Energy and Built Environment*. 1 (2020) 199–206.
729 <https://doi.org/https://doi.org/10.1016/j.enbenv.2020.01.002>.
- 730 [17] A.A. Abed, O.K. Ahmed, M.M. Weis, K.I. Hamada, Performance augmentation of a PV/Trombe wall
731 using Al₂O₃/Water nano-fluid: An experimental investigation, *Renewable Energy*. 157 (2020) 515–529.
732 <https://doi.org/10.1016/j.renene.2020.05.052>.
- 733 [18] A. De Gracia, L. Navarro, A. Castell, Á. Ruiz-pardo, Solar absorption in a ventilated facade with PCM .
734 Experimental results, 30 (2012) 986–994. <https://doi.org/10.1016/j.egypro.2012.11.111>.
- 735 [19] A. de Gracia, L. Navarro, A. Castell, L.F. Cabeza, Energy performance of a ventilated double skin
736 facade with PCM under different climates, *Energy and Buildings*. 91 (2015) 37–42.
737 <https://doi.org/10.1016/j.enbuild.2015.01.011>.
- 738 [20] T.A. Vik, H.B. Madessa, P. Aslaksrud, E. Folkedal, O.S. Øvrevik, Thermal Performance of an Office
739 Cubicle Integrated with a Bio-based PCM: Experimental Analyses, *Energy Procedia*. 111 (2017) 609–
740 618. <https://doi.org/10.1016/j.egypro.2017.03.223>.
- 741 [21] D. Li, Y. Wu, C. Liu, G. Zhang, M. Arıcı, Numerical investigation of thermal and optical performance of
742 window units filled with nanoparticle enhanced PCM, *International Journal of Heat and Mass Transfer*.
743 125 (2018) 1321–1332. <https://doi.org/10.1016/j.ijheatmasstransfer.2018.04.152>.
- 744 [22] N. Sarier, E. Onder, Organic phase change materials and their textile applications: An overview,
745 *Thermochimica Acta*. 540 (2012) 7–60. <https://doi.org/10.1016/j.tca.2012.04.013>.
- 746 [23] H. Johra, P. Heiselberg, Influence of internal thermal mass on the indoor thermal dynamics and
747 integration of phase change materials in furniture for building energy storage: A review, *Renewable and
748 Sustainable Energy Reviews*. 69 (2017) 19–32. <https://doi.org/10.1016/j.rser.2016.11.145>.
- 749 [24] B.Y. Yun, J.H. Park, S. Yang, S. Wi, S. Kim, Integrated analysis of the energy and economic efficiency
750 of PCM as an indoor decoration element: Application to an apartment building, *Solar Energy*. 196
751 (2020) 437–447. <https://doi.org/10.1016/j.solener.2019.12.006>.
- 752 [25] R. Barzin, J.J.J. Chen, B.R. Young, M.M. Farid, Application of PCM underfloor heating in combination
753 with PCM wallboards for space heating using price based control system, *Applied Energy*. 148 (2015)
754 39–48. <https://doi.org/10.1016/j.apenergy.2015.03.027>.
- 755 [26] K. Faraj, J. Faraj, F. Hachem, H. Bazzi, M. Khaled, C. Castelain, Analysis of underfloor electrical
756 heating system integrated with coconut oil-PCM plates, *Applied Thermal Engineering*. 158 (2019).
757 <https://doi.org/10.1016/j.applthermaleng.2019.113778>.
- 758 [27] P. Devaux, M.M. Farid, Benefits of PCM underfloor heating with PCM wallboards for space heating in
759 winter, *Applied Energy*. 191 (2017) 593–602. <https://doi.org/10.1016/j.apenergy.2017.01.060>.
- 760 [28] T. Bouhal, T.E. Rhafiki, T. Kousksou, A. Jamil, Y. Zeraoui, PCM addition inside solar water heaters :
761 Numerical comparative approach, *Journal of Energy Storage*. 19 (2018) 232–246.
762 <https://doi.org/10.1016/j.est.2018.08.005>.

- 763 [29] W. He, C. Yu, J. Yang, B. Yu, Z. Hu, D. Shen, X. Liu, M. Qin, H. Chen, Experimental study on the
764 performance of a novel RC-PCM-wall, *Energy and Buildings*. 199 (2019) 297–310.
765 <https://doi.org/10.1016/j.enbuild.2019.07.001>.
- 766 [30] M. Abuşka, S. Şevik, A. Kayapınar, A comparative investigation of the effect of honeycomb core on the
767 latent heat storage with PCM in solar air heater, *Applied Thermal Engineering*. (2018).
768 <https://doi.org/10.1016/j.applthermaleng.2018.11.056>.
- 769 [31] A. Wadhawan, A.S. Dhoble, V.B. Gawande, Analysis of the effects of use of thermal energy storage
770 device (TESD) in solar air heater, *Alexandria Engineering Journal*. (2017).
771 <https://doi.org/10.1016/j.aej.2017.03.016>.
- 772 [32] C.Q. Chen, Y.H. Diao, Y.H. Zhao, Z.Y. Wang, L. Liang, T.Y. Wang, T.T. Zhu, C. Ma, Thermal
773 performance of a closed collector-storage solar air heating system with latent thermal storage: An
774 experimental study, *Energy*. 202 (2020). <https://doi.org/10.1016/j.energy.2020.117764>.
- 775 [33] K. Faraj, M. Khaled, J. Faraj, F. Hachem, C. Castelain, A review on phase change materials for thermal
776 energy storage in buildings: Heating and hybrid applications, *Journal of Energy Storage*. (2020).
777 <https://doi.org/10.1016/j.est.2020.101913>.
- 778 [34] K. Faraj, M. Khaled, J. Faraj, F. Hachem, C. Castelain, Phase change material thermal energy storage
779 systems for cooling applications in buildings: A review, *Renewable and Sustainable Energy Reviews*.
780 (2019). <https://doi.org/10.1016/j.rser.2019.109579>.
- 781 [35] K. Lin, Y. Zhang, X. Xu, H. Di, Experimental study of under-floor electric heating system with shape-
782 stabilized PCM plates, *Energy and Buildings*. 37 (2005) 215–220.
783 <https://doi.org/10.1016/j.enbuild.2004.06.017>.
- 784 [36] K. Lin, Y. Zhang, X. Xu, H. Di, R. Yang, P. Qin, Modeling and simulation of under-oor electric heating
785 system with shape-stabilized PCM plates, 39 (2004) 1427–1434.
786 <https://doi.org/10.1016/j.buildenv.2004.04.005>.
- 787 [37] K. Huang, G. Feng, J. Zhang, Experimental and numerical study on phase change material floor in solar
788 water heating system with a new design, *Solar Energy*. 105 (2014) 126–138.
789 <https://doi.org/10.1016/j.solener.2014.03.009>.
- 790 [38] W. Cheng, B. Xie, R. Zhang, Z. Xu, Y. Xia, Effect of thermal conductivities of shape stabilized PCM on
791 under-floor heating system, *APPLIED ENERGY*. 144 (2015) 10–18.
792 <https://doi.org/10.1016/j.apenergy.2015.01.055>.
- 793 [39] G. Zhou, J. He, Thermal performance of a radiant floor heating system with different heat storage
794 materials and heating pipes, *Applied Energy*. 138 (2015) 648–660.
795 <https://doi.org/10.1016/j.apenergy.2014.10.058>.
- 796 [40] Y. Zhou, S. Zheng, H. Chen, G. Zhang, Indoor and Built Thermal performance and optimized thickness
797 of active shape-stabilized PCM boards for side-wall cooling and under-floor heating system, *Indoor and
798 Built Environment*. 25 (2016) 1279–1295. <https://doi.org/10.1177/1420326X16671983>.
- 799 [41] S. Lu, Y. Zhao, K. Fang, Y. Li, P. Sun, Establishment and experimental verification of TRNSYS model
800 for PCM floor coupled with solar water heating system, *Energy & Buildings*. 140 (2017) 245–260.
801 <https://doi.org/10.1016/j.enbuild.2017.02.018>.
- 802 [42] H. Garg, B. Pandey, S.K. Saha, S. Singh, R. Banerjee, Design and analysis of PCM based radiant heat
803 exchanger for thermal management of buildings, *Energy and Buildings*. 169 (2018) 84–96.
804 <https://doi.org/10.1016/j.enbuild.2018.03.058>.
- 805 [43] M. Jobli, R. Yao, Z. Luo, M. Shahrestani, N. Li, L. Hong, Numerical and experimental studies of a
806 Capillary-Tube embedded PCM component for improving indoor thermal environment, *Applied
807 Thermal Engineering*. 148 (2019) 466–477. <https://doi.org/10.1016/j.applthermaleng.2018.10.041>.
- 808 [44] Y. Fang, Y. Ding, Y. Tang, X. Liang, C. Jin, S. Wang, X. Gao, Thermal properties enhancement and
809 application of a novel sodium acetate trihydrate-formamide/expanded graphite shape-stabilized
810 composite phase change material for electric radiant floor heating, *Applied Thermal Engineering*. 150
811 (2019) 1177–1185. <https://doi.org/10.1016/j.applthermaleng.2019.01.069>.
- 812 [45] S. Lu, H. Tong, B. Pang, Study on the coupling heating system of floor radiation and sunspace based on
813 energy storage technology, *Energy and Buildings*. 159 (2018) 441–453.
814 <https://doi.org/10.1016/j.enbuild.2017.11.027>.
- 815 [46] L. Zhu, Y. Yang, Numerical study on the thermal performance of pipe-embedded PCM building
816 envelope in the heating season, *Energy Procedia*. 158 (2019) 2663–2670.

- 817 <https://doi.org/10.1016/j.egypro.2019.02.019>.
- 818 [47] M.T. Plytaria, E. Bellos, C. Tzivanidis, K.A. Antonopoulos, Numerical simulation of a solar cooling
819 system with and without phase change materials in radiant walls of a building, *Energy Conversion and*
820 *Management*. 188 (2019) 40–53. <https://doi.org/10.1016/j.enconman.2019.03.042>.
- 821 [48] M.T. Plytaria, C. Tzivanidis, E. Bellos, K.A. Antonopoulos, Parametric analysis and optimization of an
822 under floor solar assisted heating system with phase change materials, *Thermal Science and Engineering*
823 *Progress*. 10 (2019) 59–72. <https://doi.org/10.1016/j.tsep.2019.01.010>.
- 824 [49] W. Sun, Y. Zhang, Z. Ling, X. Fang, Z. Zhang, Experimental investigation on the thermal performance
825 of double-layer PCM radiant floor system containing two types of inorganic composite PCMs, *Energy*
826 *and Buildings*. 211 (2020). <https://doi.org/10.1016/j.enbuild.2020.109806>.
- 827 [50] PhaseChange, Technical Data - Q29, BioPCM Q29. (n.d.). [https://phasechange.com/wp-](https://phasechange.com/wp-content/uploads/2018/02/BioPCM-Data-Sheet-Q29.pdf)
828 [content/uploads/2018/02/BioPCM-Data-Sheet-Q29.pdf](https://phasechange.com/wp-content/uploads/2018/02/BioPCM-Data-Sheet-Q29.pdf).
- 829 [51] W. Fu, T. Zou, X. Liang, S. Wang, X. Gao, Z. Zhang, Preparation and properties of phase change
830 temperature-tuned composite phase change material based on sodium acetate trihydrate–urea/fumed
831 silica for radiant floor heating system, *Applied Thermal Engineering*. 162 (2019).
832 <https://doi.org/10.1016/j.applthermaleng.2019.114253>.
- 833 [52] H.D. Young, Values for diamond and silica aerogel from CRC Handbook of Chemistry and Physics,
834 *University Physics*. (n.d.). <http://hyperphysics.phy-astr.gsu.edu/hbase/Tables/thrcn.html>.
- 835 [53] Thermtest, COMMON MATERIAL THERMAL PROPERTIES, (2019).
836 <https://thermtest.com/materials-database>.
- 837 [54] Owens-corning, Foamular Extruded Polystyrene (XPS) Insulation: SI and IP units for selected properties,
838 (2011). [https://dcpd6wotaa0mb.cloudfront.net/mdms/dms/EIS/10015703/10015703-FOAMULAR-SI-](https://dcpd6wotaa0mb.cloudfront.net/mdms/dms/EIS/10015703/10015703-FOAMULAR-SI-and-I-P-Units-for-Selected-Properties-Tech.-Bulletin.pdf)
839 [and-I-P-Units-for-Selected-Properties-Tech.-Bulletin.pdf](https://dcpd6wotaa0mb.cloudfront.net/mdms/dms/EIS/10015703/10015703-FOAMULAR-SI-and-I-P-Units-for-Selected-Properties-Tech.-Bulletin.pdf).
- 840 [55] G. Hammond, C. Jones, *Inventory of Carbon and Energy*, 2nd ed., Elsevier, 2011.
841 <https://www.sciencedirect.com/topics/engineering/insulation-material>.
- 842 [56] Engineering Toolbox, Specific Heat of some common Substances, (2003).
843 https://www.engineeringtoolbox.com/specific-heat-capacity-d_391.html (accessed September 30, 2020).
- 844 [57] J.D. Maclean, W. Madison, *Thermal Conductivity of Wood, Heating, Piping and Air Conditioning*. 13
845 (1941) 380–391. <https://www.fpl.fs.fed.us/documnts/pdf1941/macle41a.pdf>.
- 846 [58] 3A Composites, ALUCOBOND technical data, (2020).
847 <https://alucobond.com.sg/products/alucobond/technical-data/>.
- 848 [59] F. McQuiston, J. Parker, J. Spitler, *Heating, Ventilating and Air Conditioning Analysis and Design*, 6th
849 editio, John Wiley & Sons, Inc., 2005.
- 850 [60] N. Ukrainczyk, S. Kurajica, J. Sipusic, Thermophysical Comparison of Five Commercial Paraffin Waxes
851 as Latent Heat Storage Materials, *Chemical and Biochemical Engineering Quarterly*. 24 (2010) 129–137.
852 <https://doi.org/10.15255/CABEQ.2014.240>.
- 853 [61] E.S. Mettawee, A.I. Ead, Energy Saving in Building with Latent Heat Storage, *International Journal of*
854 *Thermal and Environmental Engineering*. 5 (2013) 21–30. <https://doi.org/10.5383/ijtee.05.01.003>.
- 855 [62] S. Wonorahardjo, I.M. Sutjahja, D. Kurnia, Z. Fahmi, W.A. Putri, Potential of Thermal Energy Storage
856 Using Coconut Oil for Air Temperature Control, *Buildings*. 2 (2018).
857 <https://doi.org/10.3390/buildings8080095>.
- 858 [63] H. Lee, S. Jeong, S.J. Chang, Y. Kang, S. Wi, S. Kim, Thermal Performance Evaluation of Fatty Acid
859 Ester and Paraffin Based Mixed SSPCMs Using Exfoliated Graphite Nanoplatelets (xGnP), *Applied*
860 *Sciences*. 6 (2016) 106. <https://doi.org/10.3390/app6040106>.
- 861 [64] W.A. Putri, Z. Fahmi, I.M. Sutjahja, D. Kurnia, S. Wonorahardjo, Thermophysical parameters of
862 coconut oil and its potential application as the thermal energy storage system in Indonesia, *Journal of*
863 *Physics: Conference Series*. 739 (2016). <https://doi.org/10.1088/1742-6596/739/1/012065>.
- 864 [65] M. Irsyad, Harmen, Heat transfer characteristics of coconut oil as phase change material to room cooling
865 application, in: *1st International Symposium on Green Technology for Value Chains 2016*, IOP
866 *Conference Series: Earth and Environmental Science* 60, 2017. <https://doi.org/10.1088/1755-1315/>.
- 867 [66] P.V. Krishna, R.R. Srikant, D.N. Rao, Experimental investigation on the performance of nanoboric acid
868 suspensions in SAE-40 and coconut oil during turning of AISI 1040 steel, *International Journal of*
869 *Machine Tools and Manufacture*. 50 (2010) 911–916. <https://doi.org/10.1016/j.ijmachtools.2010.06.001>.
- 870 [67] N. Putra, S. Rawi, M. Amin, E. Kusriani, E.A. Kosasih, T.M.I. Mahlia, Preparation of beeswax/multi-

- 871 walled carbon nanotubes as novel shape-stable nanocomposite phase change material for thermal energy
872 storage, *Journal of Energy Storage*. 21 (2019) 32–39. <https://doi.org/10.1016/j.est.2018.11.007>.
- 873 [68] M. Amin, N. Putra, E.A. Kosasih, E. Prawiro, R.A. Luanto, T.M.I. Mahlia, Thermal properties of
874 beeswax/graphene phase change material as energy storage for building applications, *Applied Thermal*
875 *Engineering*. 112 (2016) 273–280. <https://doi.org/10.1016/j.applthermaleng.2016.10.085>.
- 876 [69] M. Mehrali, S. Tahan, M. Mehrali, T. Meurah, I. Mahlia, H. Simon, C. Metselaar, M. Sajad, E.
877 Sadeghinezhad, A. Reza, Preparation and characterization of palmitic acid/graphene nanoplatelets
878 composite with remarkable thermal conductivity as a novel shape-stabilized phase change material,
879 *Applied Thermal Engineering*. 61 (2013) 633–640.
880 <https://doi.org/10.1016/j.applthermaleng.2013.08.035>.
- 881 [70] S.T. Latibari, M. Mehrali, M. Mehrali, T.M.I. Mahlia, H.S.C. Metselaar, Synthesis, characterization and
882 thermal properties of nanoencapsulated phase change materials via sol-gel method, *Energy*. 61 (2013)
883 664–672. <https://doi.org/10.1016/j.energy.2013.09.012>.
- 884 [71] Plastics Pipe Institute, PEX-ALUMINUM-PEX COMPOSITE (PEX-AL-PEX), (2020).
885 <https://plasticpipe.org/building-construction/bcd-pex-al-pex.html> (accessed May 23, 2021).
- 886 [72] Eurachem, CITAC, Quantifying Uncertainty in Analytical Measurement, Third, Eurachem / CITAC
887 Guide CG 4, 2012.
- 888 [73] D. Shen, C. Yu, W. Wang, Investigation on the thermal performance of the novel phase change materials
889 wall with radiative cooling, *Applied Thermal Engineering*. 176 (2020).
890 <https://doi.org/10.1016/j.applthermaleng.2020.115479>.
- 891 [74] B.P. Jelle, S.E. Kalnæs, Phase Change Materials for Application in Energy-Efficient Buildings, Elsevier
892 Ltd, 2017. <https://doi.org/10.1016/B978-0-08-101128-7.00003-4>.
- 893 [75] Y. Li, J. Zhou, E. Long, X. Meng, Experimental study on thermal performance improvement of building
894 envelopes by integrating with phase change material in an intermittently heated room, *Sustainable Cities*
895 *and Society*. (2018). <https://doi.org/10.1016/j.scs.2018.01.040>.
- 896 [76] S. Wijesuriya, M. Brandt, P.C. Tabares-velasco, Parametric analysis of a residential building with phase
897 change material (PCM) -enhanced drywall , precooling , and variable electric rates in a hot and dry
898 climate Time of Use, *Applied Energy*. 222 (2018) 497–514.
899 <https://doi.org/10.1016/j.apenergy.2018.03.119>.
- 900 [77] F. Mehdaoui, M. Hazami, A. Messaouda, H. Taghouti, A. Guizani, Thermal testing and numerical
901 simulation of PCM wall integrated inside a test cell on a small scale and subjected to the thermal
902 stresses, *Renewable Energy*. (2018). <https://doi.org/10.1016/j.renene.2018.12.029>.
- 903