

Co-simulation domain decomposition algorithm for hybrid EMT-Dynamic Phasor modeling

Hélèna Shourick, Damien Tromeur-Dervout, Laurent Chédot

► To cite this version:

Hélèna Shourick, Damien Tromeur-Dervout, Laurent Chédot. Co-simulation domain decomposition algorithm for hybrid EMT-Dynamic Phasor modeling. 2022. hal-03625830

HAL Id: hal-03625830 https://hal.science/hal-03625830v1

Preprint submitted on 31 Mar 2022

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers. L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.



Distributed under a Creative Commons Attribution - NonCommercial - NoDerivatives 4.0 International License

Co-simulation domain decomposition algorithm for hybrid EMT-Dynamic Phasor modeling

Hélèna Shourick · Damien Tromeur-Dervout · Laurent Chédot

Abstract An iterative coupling algorithm based on a restricted additive Schwarz domain decomposition is investigated to co-simulate electrical circuits with hybrid electromagnetic (EMT) and transient stability (TS) modeled using dynamic phasors. This co-simulation algorithm does not introduce any delay between the data exchanged at the cosimulation step. The pure linear convergence property of the iterative method allows it to be accelerated towards the true solution by a non-intrusive Aitken's acceleration of the convergence post-processing, even if the domain decomposition interface conditions make the iterative method divergent. This provides a method less sensitive to the splitting. This algorithm can then be implemented in a distributed master-slaves architecture. An example on a linear RLC circuit combining EMT and TS modeling, and a partitionning with overlap is given.

1 Introduction

The introduction of renewable energies into the power grid leads to the use of more components based on power electronics. These components imply faster dynamics. Power system safety simulations, which cannot be handled by traditional Transient Simulations (TS) conducted with dynamic

H. Shourick L.Chédot SuperGrid Institute, 23 rue Cyprian, 69100 Villeurbanne, France e-mail: helena.shourick@supergrid-institute.com, laurent.chedot@supergrid-institute.com D. Tromeur-Dervout ICJ, Université de Lyon, UMR5208 CNRS-U.Lyon1, 15 Bd Latarjet, 69622 Villeurbanne, France e-mail: damien.tromeur-dervout@univ-lyon1.fr phasors (DP), require Electro-Magnetic Transient (EMT) simulations. Nevertheless, the advantage of TS programs is their computational speed which makes them suitable for handling large-scale networks, however, their modeling is not sufficiently detailed and can only catch slow dynamics. On the other hand, EMT simulators can capture fast dynamics, but are limited in computational speed; therefore, they are used to simulate only small portions of the network. For large power grids, it can be expected that the need for highlevel detail requiring Electro-Magnetic Transient (EMT) modeling will be localized near disturbances, and other parts of the network will use TS modeling.

Based on this assumption, the co-simulation approach is an attractive candidate to handle these hybrid power system simulations. Nevertheless, the EMT-TS co-simulation has to face several locks as already underlined in [6] among which we can mention:

- the data exchange between TS and EMT simulators, including choice of the interface variables (i.e. the partitioning of the network), the data conversion between waveform and dynamic phasors or phasors;
- the interaction protocol between TS and EMT simulators, including the time step size difference between EMT and TS, the coupling algorithm (i.e. iterative or non iterative, the signal rebuilding Zero order hold or high order hold), the convergence of the resulting coupling algorithm.

Advances in these areas have been proposed in recent years. Among these is the partitioning based on traveling wave patterns of the transmission line which introduce natural decoupling into the nodal equations of an EMT simulator due to transmission line latency. Note that this latency limits the flexibility of choosing DP time steps [9]. Le-Huy & al [7] developed a simple hybrid line model that accounts for wave propagation in both electromagnetic and TS simulations i.e both ends exchange historical current and the delay is considered as a phase shift for the TS part. Another cosimulation that splits the transmission line is the one of Rupasinghe & al [12] in which a Base-Frequency Phasor Adaptive Simulation Transient solver is developed, which allows to derive frequency-dependant equivalent of network components using base-frequency dynamic phasors at the discrete level. Then the offset frequency parameter can switch from EMT to DP at the fundamental frequency. Plumier & al [10]has proposed a co-simulation algorithm coupling EMT and phasor which dynamically updates by an iterative procedure the equivalent impedance of Norton and Thevenin equivalent models representing the boundary conditions between each subsystem. Some acceleration of the coupling algorithm is achieved by a prediction scheme which is similar to a Richardson extrapolation of temporal quantities.

Shu & al [14] proposed a two-level Schur complement through which the Thevenin equivalent obtained for each EMT subsystem could fully consider the coupling among different EMT subsystems and the TS central system. Abhyankar and Flueck [1] proposed an implicitly coupled TSEMT algorithm where the set of TS and EMT equations are solved by a Newton's method at each TS time step. An important issue in this approach is the computation of the instantaneous Thevenin equivalent voltage for EMT time steps that are not on the temporal boundary. Their experiment has shown that it is peferable to use the TS solution at the end TS time step rather than a linear interpolation between the two TS interval steps, probably due to the Newton's algorithm. Rimorov & al [11] focused on the problems of cosimulation stability and precision in the presence of delays and proposed a generalized interface framework related to the search for a power-conjugate interface that combines current and voltage through an "impedence" parameter resulting from non-physical related boundary conditions.

In co-simulation algorithms such as non-iterative Jacobi, zero-order hold iterative co-simulation and non-iterative algorithm improving variables smoothing, the delay of one cosimulation step (i.e. TS time step delay) between the given inputs and the retrieved outputs of the TS and EMT systems can lead to instabilities. Some iterative techniques such as the fixed point method [4] or the Newton-like method [10, 1] can, even with a high order smoothing constraints, solve the so-called "constraint function" corresponding to the interface of the systems [5].

In this paper, we consider a fixed point coupling algorithm based on the Schwarz domain decomposition technique which can be related to the dynamic iteration method (DI) (i.e waveform relaxation of [8]) in which we used a restricted additive Schwarz (RAS) splitting [13]. These DI methods can be convergent or divergent depending on the domain partitioning and boundary conditions. Nevertheless, we used the good property of purely linear convergence or divergence (i.e. the error operator of the method does not depend on the iteration number) to accelerate the iterative method towards the true solution with the Aitken's acceleration technique even with a divergent method [15]. The advantages of our approach are:

- the fundamental concept of the method is to post-process the sequence of interfaces solutions generated by the domain decomposition solver. It can use different boundary conditions for the acceleration as long as they are linear in the variables (i.e Dirichlet, Neumann, Robin, those of [11],...);
- as it is a post-process the method can be used nonintrusively in the local solver;
- it is not necessary for domain partitioning to be cut on the transmission lines;
- it can also support an overlap of TS and EMT parts.
 We then have some components with the two representations.

The outline of the paper is as follows: Section 2 describes the EMT and TS (modeled with dynamic phasors), as well as the translation techniques needed to exchange data from one model to the other. The co-simulation domain decomposition algorithm and its Aitken convergence acceleration technique are given in Sect. 3. Section 4 gives the concept that we are developing in the co-simulation platform based on co-simulation algorithm. Section 5 presents results obtained on a linear RLC circuit before concluding in Sect. 6.

2 EMT and Dynamic Phasor modelling

EMT modeling uses the Modified Augmented Nodal Analysis [16] to build the system of differential algebraic equations (DAE) (1) relating the current and voltage unknowns of the electrical network.

$$F(t, x(t), \dot{x}(t), y(t)) = 0$$
, with Initial Conditions. (1)

where *x* (respectively *y*) are the differential (respectively algebraical) unknowns.

The linearized backward differential formula (BDF) time discretization of (1) (here Backward Euler) leads to solving the linear system (2) in order to integrate the state space representation of the DAE from time step t^n to time step $t^{n+1} = t^n + \Delta t_{emt}$ (the operator I represents the difference between two potentials or the identity for intensity variables, *G* represents the voltage/current sources) :

$$\underbrace{\begin{pmatrix} \mathbb{I} - \Delta t_{emt}A & B \\ C & D \end{pmatrix}}_{\mathbf{H}_{Atomit}} \begin{pmatrix} x^{n+1} \\ y^{n+1} \end{pmatrix} = \begin{pmatrix} \mathbb{I} & 0 \\ 0 & 0 \end{pmatrix} \begin{pmatrix} x^n \\ y^n \end{pmatrix} + G^{n+1}.$$
 (2)

We use Dynamic Phasors for **TS modeling**. Consider a T_0 -periodic signal with its pulse $\omega_0 = \frac{2\pi}{T_0}$, by applying the

Fourier transform, the signal can be written on the interval $\tau \in [t - T_0, t]$ as $x(\tau) = \sum_{h=-\infty}^{+\infty} X_h e^{jh\omega_0\tau}$, where the Fourier coefficients are: $X_h = \frac{1}{T_0} \int_{T_0} x(\tau) e^{-jh\omega_0\tau} d\tau$.

Now consider a waveform that is not strictly periodic. (in an almost periodic state) so that the Fourier coefficients would vary over time:

$$X_h(t) = \frac{1}{T_0} \int_{t-T_0}^t x(\tau) e^{-jh\omega_0 \tau} d\tau = \langle x \rangle_h.$$
(3)

This time-varying coefficient is conventionally called the h-dynamic phasor. Only relevant harmonics (a subset $I = \{\dots, -1, 0, 1, \dots\}$) are computed and the signal is given by

$$x(t) = \sum_{h \in I} X_h(t) e^{jh\omega_0 t}.$$
(4)

The introduction of (4) in (1) leads, by using the orthogonality of the functions $e^{ih\omega_0 t}$, to a DAE system with smoother dynamics allowing the use of a bigger time step Δt_{TS} . The number of TS variables is then multiplied by the chosen number of harmonics. The structure of the matrix H_{TS} of the BDF scheme, by choosing two harmonics h = aand h = c and by solving the imaginary and real part separately and with **S** the matrix holding account of the differential property of dynamic phasor modeling is written (with $H_{\Delta t_{TS}}$ defined by (2)):



Suppose $\Delta t_{TS} = m\Delta t_{emt}$ with $(m \in \mathbb{N}^*)$. The TS and EMT parts of the network have to exchange interface solutions at each TS time step. These values must be transformed to be understandable from one part to another.

Translation from EMT to Dynamic Phasor: to translate the EMT values to dynamic phasor ones, a Fast Fourier Transform is applied on a history of the duration of T_0 containing the values taken by the part computed by the EMT at the intermediate m EMT time steps. The history must be the size of a period T_0 . We can therefore take a Δt_{TS} the size of T_0 and fill the History with the m intermediate time steps, but it is better to be able to take a smaller TS time step. Let's take a Δt_{TS} shorter than a period, to perform the FFT a history of the size of T_0 is still necessary, a "sliding" history will be performed by deleting the m oldest values from the beginning of the history and adding the m new values to the end of the history. This operation is repeated at each moment of passage of information, i.e. after each time step TS (and therefore after m EMT time steps). The observation window will no longer be $[t - T_0, t]$ but $[t - T_0 + \alpha \Delta t_{TS}, t + \alpha \Delta t_{TS}]$

with $\alpha \in [0, T_0/\Delta t_{TS}]$, by applying the suitable change of variable in (2), an offset of $e^{jh\omega_0\alpha\Delta t_{TS}}$ appears, it will then be compensated by applying a shift of $e^{-jh\omega_0\alpha\Delta t_{TS}}$ on the FFT. This translation from EMT to DP is defined at the discrete level by the linear operator E_{TS}^{emt} .

Translation from Dynamic Phasor to EMT: to rebuild an EMT signal from dynamic phasor coefficients, it suffices to apply (4) with the chosen harmonics at each EMT time step. This translation from DP to EMT is defined at the discrete level by the linear operator E_{ent}^{TS} .

3 Co-simulation domain decomposition algorithm

The BDF scheme leads at each time step to solve a linear system Hx = b. We use the Restrictive Additive Schwarz domain decomposition as follows:

3.1 Restrictive Additve Schwarz (RAS)

By adapting the notations of [3], we consider a non-singular matrix $H \in \mathbb{R}^{n \times n}$ having a non-zero pattern and the associated directed graph G = (W, F), where the set of vertices $\Omega = \{1, n\}$ represents the *n* unknowns and the set of edges $F = \{(i, j) | a_{i,j} \neq 0\}$ represents the pairs of vertices that are coupled by a non-zero element in H. Next, we assume that a graph partitioning was applied and resulted in N non-overlapping subsets Ω_i^0 whose union is Ω . Let Ω_i^p be the *p*-overlap partition of Ω , obtained by including all the vertices imme-diately neighboring the vertices of Ω_i^{p-1} . Let $R_i^p \in \mathbb{R}^{n_i \times n}$ be the operator which restricts $x \in \mathbb{R}^n$ to the components of x belonging to Ω_i^p . Let $\tilde{R}_i^0 \in \mathbb{R}^{n \times n}$ be the operator which restricts $x \in \mathbb{R}^n$ to the components of x belonging to Ω_i^0 and 0 otherwise. Let $\Omega_{i,e}^p = \Omega_i^{p+1} \setminus \Omega_i^p$ and $R_{i,e}^p \in \mathbb{R}^{n_{i,e} \times n}$ the restriction operator which restricts $x \in \mathbb{R}^n$ to the components of x belonging to $\Omega_{i,e}^p$. By defining $H_i = R_i^p H R_i^{pT}$, $F_i = R_i^p H(R_{i,e}^p)^T$, $x_i = R_i^p x$ and $b_i = R_i^p b$, $x_{i,e} = R_{i,e}^p x$, then the Restrictive Additive Schwarz (RAS) iteration k + 1 to solve $Hx^{\infty} = b \in \mathbb{R}^n$ is written locally for the Ω_i^p partition:

$$x_i^{k+1} = H_i^{-1}(b_i - F_i x_{i,e}^k).$$
(5)

By defining $M_{RAS}^{-1} \stackrel{def}{=} \sum_{i=0}^{N-1} \tilde{R}_i^{0T} H_i^{-1} R_i^p$ and adding the contribution of each partition Ω_i^p , RAS can be viewed as a Richardson's process (using $R_i^p A = R_i^p A (R_i^{pT} R_i^p + R_{ie}^{pT} R_{ie}^p)$):

$$\sum_{i=0}^{N-1} \tilde{R}_{i}^{0T} R_{i}^{p} x^{k+1} = \sum_{i=0}^{N-1} \tilde{R}_{i}^{0T} H_{i}^{-1} R_{i}^{p} b - \sum_{i=0}^{N-1} \tilde{R}_{i}^{0T} H_{i}^{-1} R_{i}^{p} H R_{i,e}^{pT} \mathbf{A}_{i}^{b} \mathbf{A}_{i$$

It can be reduced to a problem with the unknowns on the interface $\Gamma = \left\{ \Omega_{0,e}^p, \dots, \Omega_{N-1,e}^p \right\}$ of size $n_{\Gamma} = \sum_{i=0}^{N-1} n_{i,e}$, by

defining $R_{\Gamma} = (R_{0,e}^{p}, \dots, R_{N-1,e}^{p})^{T} \in \mathbb{R}^{n_{\Gamma} \times n}$ and by using the property $R_{i,e}^{pT} R_{i,e}^{p} R_{\Gamma}^{T} R_{\Gamma} = R_{i,e}^{pT} R_{i,e}^{p}$:

$$\underbrace{R_{\Gamma}x^{k+1}}_{z^{k+1}} = \underbrace{R_{\Gamma}\left(I - M_{RAS}^{-1}A\right)R_{\Gamma}^{T}}_{P}\underbrace{R_{\Gamma}x^{k}}_{z^{k}} + \underbrace{R_{\Gamma}M_{RAS}^{-1}b}_{c}.$$
(8)

The pure linear convergence of the RAS at the interface given by : $z^k - z^{\infty} = P(z^{k-1} - z^{\infty})$ (the error operator *P* does not depend on the iteration *k*) allows to apply the Aitken's convergence acceleration technique, i n order to obtain the true solution z^{∞} on the interface Γ : $z^{\infty} = (I - P)^{-1}(z^k - Pz^{k-1})$, and so after another local solve, the true solution x^{∞} . Let us note that one can accelerate the convergence towards the solution for a convergent or a divergent iterative method. The only requirement is that 1 is not one of the eigenvalues of *P*. Considering $e^k = z^k - z^{k-1}$, $k = 1, \ldots$, the operator $P \in \mathbb{R}^{n_{\Gamma} \times n_{\Gamma}}$ can be computed algebraically after $n_{\Gamma} + 1$ iterations as $P = [e^{n_{\Gamma}+1}, \ldots, e^2][e^{n_{\Gamma}}, \ldots, e^1]^{-1}$.

3.2 RAS for EMT-TS

Let us now adapt the RAS method to the hybrid TS-EMT modeling of a linear electrical network. The $x_{i,e}^k$ term of Eq. (5) for TS (respectively EMT) part comes from the EMT (respectively TS) part. Let x_{TS}^{N+1} and y_{TS}^{N+1} (respectively x_{emt}^{n+1} and y_{emt}^{n+1}) be the differential and algebraic unknowns of TS (respectively EMT). The time discretisation of the DAE for TS to integrate from T^N to T^{N+1} , assuming that $\Delta t_{TS} = m\Delta t_{emt}$ can be witten as:

$$\underbrace{\begin{pmatrix} \mathbb{I} - \Delta t_{TS}A_{TS} & B_{TS} \\ C_{TS} & D_{TS} \end{pmatrix}}_{H_{TS}} \underbrace{\begin{pmatrix} x_{TS}^{N+1} \\ y_{TS}^{N+1} \end{pmatrix}}_{w_{TS}^{N+1}} = \underbrace{\begin{pmatrix} \mathbb{I} & 0 \\ 0 & 0 \end{pmatrix}}_{\Theta_{TS}} \begin{pmatrix} x_{TS}^{N} \\ y_{TS}^{N} \end{pmatrix} + \underbrace{\begin{pmatrix} E_{TS}^{A} & E_{TS}^{B} \\ E_{TS}^{C} & E_{TS}^{D} \end{pmatrix}}_{E_{TS}^{emt}} \underbrace{\begin{pmatrix} x_{emt}^{m} \\ y_{emt}^{m} \end{pmatrix}}_{E_{TS}^{emt}} + G_{TS}^{N+1}.$$
(9)

Similarly one time step for the EMT side to integrate from t^n to $t^{n+1} = t^n + \Delta t_{ent}$ is written:

$$\underbrace{\begin{pmatrix} \mathbb{I} - \Delta t_{emt} A_{emt} & B_{emt} \\ C_{emt} & D_{emt} \end{pmatrix}}_{H_{emt}} \underbrace{\begin{pmatrix} x_{emt}^{n+1} \\ y_{emt}^{n+1} \end{pmatrix}}_{w^{n+1}} = \underbrace{\begin{pmatrix} \mathbb{I} & 0 \\ 0 & 0 \end{pmatrix}}_{\Theta_{emt}} \begin{pmatrix} x_{emt}^{n} \\ y_{emt}^{n} \end{pmatrix} + \underbrace{\begin{pmatrix} E_{emt}^{A} & E_{emt}^{B} \\ E_{emt}^{C} & E_{emt}^{D} \end{pmatrix}}_{E_{emt}^{TS}} \underbrace{\begin{pmatrix} x_{TS}^{N+1}(t^{n+1}) \\ y_{TS}^{N+1}(t^{n+1}) \end{pmatrix}}_{W^{N+1}(t^{n+1})} + G_{emt}^{n+1}.$$
(10)

The *m* time steps can be gathered in one larger system considering $t^n = T^N$:



These systems need the values of the TS (respectively EMT) solution at the instant $T^{N+1} = T^N + m\Delta t_{emt}$ to be connected to the EMT (respectively TS) part. We need the RAS iterative algorithm to obtain the exact values at time T^{N+1} . Iteration p + 1 is then iterated by taking the connected values, at the iteration p, of the other subdomain. We can use the multiplicative form or the additive form as follows:

$$\begin{cases} H_{TS} w_{TS}^{N+1,\mathbf{k}+1} = \Theta_{TS} w_{TS}^{N} + E_{TS}^{emt} w_{emt}^{m,\mathbf{k}} + G_{TS}^{N+1}, \\ \mathbb{H}_{emt} \mathbb{W}_{emt}^{N+1,\mathbf{k}+1} = \mathbb{E}_{emt}^{TS} \mathbb{W}_{TS}^{N+1,\mathbf{k}} + \mathbb{G}_{emt}^{N+1}. \end{cases}$$
(12)

Note that \mathbb{W}_{TS}^{N+1} in Eq. (11) may present a jump between



Fig. 1 TS-EMT hybrid simulation of the test of section 5 with a jump in the voltage source at t = 0.2s that last less than Δt_{TS} : without (top) and with (bottom) linear interpolation of \mathbb{W}_{TS}^{N+1}

 $(x^n, y^n)^t$ and $W^{N+1}(t^{n+1})$ which may produce some spurious oscillations in the solution (see Fig. 1(top) v_3 , i_{12}). That is why we use a linear interpolation on q time points between

 $(x^n, y^n)^t$ and $W^{N+q}(t^{n+1})$ (contrary to the experiment of [1], see Fig. 1(bottom) v_3 , i_{12})).

4 Co-simulation platform

The platform under development at SuperGrid-Institute is based on the co-simulation algorithm. It is designed in a master-slaves approach (see Fig. 2) where the co-simulation algorithm is the master in charge of doing the orchestration to call the slaves EMT and TS models. Slaves and Master are launched as Message Passing Interface (MPI) processes.

The slaves can be either Funtional Mock-up Units [2] (in order to be able to develop models with dedicated tools such as Modelica electrical libraries) or C++ code implementing the DAE function.

To obtain more parallelism, the local resolutions are carried out on the slaves side via an instance of the FMUobject architecture. Each slave contains an instance of a FMUobject C++ class that embeds a local DAE solver such as IDA of Sundials and is also in charge of instantiating the FMU when it applies.

The master manages the co-simulation algorithm by sending commands, using the MPI point to point communication routines, to FMUobject which then manages the FMU with FMI commands. Then the master receives the interface values from the slave and applies the Aitken's acceleration before sending the true solution interface values back to the slaves.



Fig. 2 Co-simulation platform architecture with MPI Master-Slaves communications and using local solver in the FMI standard or C++ DAE functions.

5 Results

In order to illustrate our co-simulation algorithm, we consider the RLC circuit of Fig 3. The small linear system associated with the RLC circuit is partitioned into two subdomains using graph partitioning without overlap (Figure 4 top) and with an overlap of 1 (Figure 4 bottom). Each subdomain needs two values from the other to solve its equa-



Fig. 3 Linear RLC circuit and its associated EMT modeling DAE system with $L_1 = L_2 = 0.7$, $C_1 = C_2 = 1.10^{-6}$, $R_1 = R_2 = 77$, $Z_s = 1.10^{-6}$, $\omega = 2\pi 50$, E = 5.

tions (i.e i_{34} and v_3 for Ω_2 , i_{67} and v_6 for Ω_1 in the non-overlapping subdomains case).



Fig. 4 Graph partitioning of the RLC circuit in two subdomains and the associated matrix partioning without overlap (top) and with overlap of 1 (bottom).

Figure 5 gives the log_{10} of the error between two consecutive RAS iterations at t = 0.02. It shows a linear convergence behavior and can therefore be accelerated by the Aitken's convergence acceleration technique after the 9 iterations needed to numerically construct the error operator *P* of Eq. 8.

Figure 6 shows the solutions v_4 EMT (left) and i_{71} TS (right) of heterogeneous DDM EMT ($\Delta t = 2.10^{-4}$) -TS ($\Delta T = 2.10^{-2}$) with comparison with the DAE solution on monodomain. We proceed to an amplitude jump at t = 0.04 for the voltage source.



Fig. 5 Heterogeneous EMT ($\Delta t = 2.10^{-4}$)-TS($\Delta T = 2.10^{-2}$) RAS convergence error for each subdomain at t = 0.02 and its Aitken's acceleration with *P* computed numerically from 9 iterations ($n_{\Gamma} = 8$).



Fig. 6 Heterogeneous EMT ($\Delta t = 2.10^{-4}$)-TS($\Delta T = 2.10^{-2}$) DDM results comparison with DAE monodomain.

6 Conclusion

An iterative co-simulation algorithm based on a restricted additive Schwarz heterogeneous DDM was used to co-simulate an RLC electrical circuit where part of the domain is modeled with EMT modeling and the other part with TS modeling. It integrates a non-intrusive aitken technique to accelerate convergence, possible thanks to the pure linear convergence or divergence property of the RAS of the heterogeneous DDM TS-EMT, with or without overlap. This co-simulation algorithm is the orchestrator of a Master-Slaves co-simulation platform under development.

References

- S. Abhyankar and A. J. Flueck. An Implicitly-Coupled Solution Approach for Combined Electromechanical and Electromagnetic Transients Simulation. In 2012 IEEE POWER AND ENERGY SO-CIETY GENERAL MEETING, IEEE Power and Energy Society General Meeting PESGM, 2012.
- T. Blochwitz, M. Otter, J. Åkesson, M. Arnold, Ch. Clauss, H. Elmqvist, M. Friedrich, A. Junghanns, J. Mauss, D. Neumerkel, H. Olsson, and A. Viel. Functional mockup interface 2.0: The standard for tool independent exchange of simulation models. In

Proceedings of the 9th International Modelica Conference, pages 173–184. The Modelica Association, 2012.

- X. Cai and M. Sarkis. A restricted additive schwarz preconditioner for general sparse linear systems. *SIAM J. Sci. Comput.*, 21:792– 797, 1999.
- 4. Y. Éguillon, B. Lacabanne, and D. Tromeur-Dervout. IFOS-MONDI: A Generic Co-simulation Approach Combining Iterative Methods for Coupling Constraints and Polynomial Interpolation for Interfaces Smoothness. In SCITEPRESS Science and Technology Publications, editors, *Proceedings of the 9th International Conference on Simulation and Modeling Methodologies, Technologies and Applications*, pages 176–186, 2019.
- Y. Éguillon, B. Lacabanne, and D. Tromeur-Dervout. IFOS-MONDI Co-simulation Algorithm with Jacobian-Free Methods in PETSc. to appear in Engineering with computers, arXiv:2101.04485v1, 2021.
- V. Jalili-Marandi, V. Dinavahi, K. Strunz, J. A. Martinez, and A. Ramirez. Interfacing techniques for transient stability and electromagnetic transient programs. *IEEE TRANSACTIONS ON POWER DELIVERY*, 24(4):2385–2395, OCT 2009.
- Ph. Le-Huy, G. Sybille, P. Giroux, L. Loud, J. Huang, and I. Kamwa. -time electromagnetic transient and transient stability co-simulation based on hybrid line modelling. *IET Gener. Transm. Distrib.*, 11(12, SI):2983–2990, AUG 24 2017.
- E. Lelarasmee, A. Ruehli, and A. Vincentelli. The Waveform Relaxation Method for Time-Domain Analysis of Large Scale Integrated Circuits. *Computer-Aided Design of Integrated Circuits and Systems, IEEE Transactions on*, 1:131 – 145, 08 1982.
- K. Mudunkotuwa and S. Filizadeh. Co-simulation of electrical networks by interfacing emt and dynamic-phasor simulators. *Electric Power Systems Research*, 163:423–429, 2018.
- F. Plumier, P. Aristidou, C. Geuzaine, and T. Van Cutsem. Cosimulation of electromagnetic transients and phasor models: A relaxation approach. *IEEE TRANSACTIONS ON POWER DELIV-ERY*, 31(5):2360–2369, OCT 2016.
- D. Rimorov, J. Huang, C. F. Mugombozi, Th. Roudier, and I. Kamwa. Power Coupling for Transient Stability and Electromagnetic Transient Collaborative Simulation of Power Grids. *IEEE TRANSACTIONS ON POWER SYSTEMS*, 36(6):5175– 5184, NOV 2021.
- J. Rupasinghe, S. Filizadeh, A. M. Gole, and K. Strunz. Multirate co-simulation of power system transients using dynamic phasor and EMT solvers. *JOURNAL OF ENGINEERING-JOE*, 2020(10):854–862, OCT 2020.
- H. Shourick, D. Tromeur-Dervout, and L. Chedot. Accelerating the convergence of Dynamic Iteration method with Restricted Additive Schwarz splitting for the solution of RLC circuits. *ArXiv*, abs/2202.07602, 2022.
- D. Shu, X. Xie, Q. Jiang, Q. Huang, and C. Zhang. A novel interfacing technique for distributed hybrid simulations combining emt and transient stability models. *IEEE Transactions on Power Delivery*, 33(1):130–140, Feb 2018.
- D. Tromeur-Dervout. Approximating the trace of iterative solutions at the interfaces with nonuniform Fourier transform and singular value decomposition for cost-effectively accelerating the convergence of Schwarz domain decomposition. *ESAIM: Proc.*, 42:34–60, 2013.
- L. Wedepohl and L. Jackson. Modified nodal analysis: an essential addition to electrical circuit theory and analysis. *Engineering Science and Education Journal*, 11(3):84–92, 2002.