



**HAL**  
open science

# Robust microgrid energy trading and scheduling under budgeted uncertainty

Mario Levorato, Rosa Figueiredo, Yuri Frota

► **To cite this version:**

Mario Levorato, Rosa Figueiredo, Yuri Frota. Robust microgrid energy trading and scheduling under budgeted uncertainty. *Expert Systems with Applications*, 2022, 203, pp.117471. 10.1016/j.eswa.2022.117471 . hal-03671957

**HAL Id: hal-03671957**

**<https://hal.science/hal-03671957>**

Submitted on 19 May 2022

**HAL** is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

# Robust microgrid energy trading and scheduling under budgeted uncertainty

Mario Levorato<sup>a,b,c</sup> (mlevorato@ic.uff.br), Rosa Figueiredo<sup>b</sup>  
(rosa.figueiredo@univ-avignon.fr), Yuri Frota<sup>a</sup> (yuri@ic.uff.br)

<sup>a</sup> IC-UFF, Universidade Federal Fluminense, Av. Gal. Milton Tavares de Souza, s/n.  
Boa Viagem - Niterói, RJ, Brazil, 24210-310

<sup>b</sup> LIA-CERI, Avignon Université, 339 Chemin des Meinajeries, Avignon, France 84911

<sup>c</sup> Operations Research and Data Science Division, Petrobras, Rio de Janeiro, Brazil

## Corresponding Author:

Mario Levorato

IC-UFF, Universidade Federal Fluminense, Av. Gal. Milton Tavares de Souza, s/n.

Boa Viagem - Niterói, RJ, Brazil, 24210-310

Tel: +55 21 4042-7135

Email: mlevorato@ic.uff.br

# Robust microgrid energy trading and scheduling under budgeted uncertainty

M. Levorato<sup>a,b,c,\*</sup>, R. Figueiredo<sup>b</sup>, Y. Frota<sup>a</sup>

<sup>a</sup>*IC-UFF, Universidade Federal Fluminense, Av. Gal. Milton Tavares de Souza, s/n. Boa Viagem - Niterói, RJ, Brazil, 24210-310*

<sup>b</sup>*LIA-CERI, Avignon Université, 339 Chemin des Meinageries, Avignon, France 84911*

<sup>c</sup>*Operations Research and Data Science Division, Petrobras, Rio de Janeiro, Brazil*

---

## Abstract

The advent of smart grids came with several technological developments including new electricity market rules and regulation mechanisms. Microgrids can trade energy with the main grid to either sell its production surplus (from renewable energy sources) or buy an additional amount to support local consumers' demand, which includes flexible loads, such as smart appliances and electric vehicles. In this scenario, smart control devices are important elements, executing real-time energy scheduling according to fluctuations in production and consumption. As we might expect, the main grid's power generation and supply becomes more unscheduled and risky as energy trading quantities oscillate over time. This work studies a flexible energy contract subscription framework, coupled with a real-time command strategy, suited for energy scheduling of microgrids with uncertainty in both production and consumption. Our main contributions are a Robust Optimization model under budgeted uncertainty for contract subscription and a set of heuristic control strategies for the real-time energy scheduling. The robust model is capable of providing solutions for multi-period-ahead trading of energy, while minimizing the worst-case cost. We run an extensive computational case study on a real microgrid instance to confirm the efficacy of our solution approach.

---

\*Corresponding author

*Email addresses:* [mlevatorato@ic.uff.br](mailto:mlevatorato@ic.uff.br) (M. Levorato),  
[rosa.figueiredo@univ-avignon.fr](mailto:rosa.figueiredo@univ-avignon.fr) (R. Figueiredo), [yuri@ic.uff.br](mailto:yuri@ic.uff.br) (Y. Frota)

*Keywords:* OR in energy, Robust Optimization, Real-time energy scheduling, Microgrid, Flexible commitments

---

## 1. Introduction

A microgrid consists of a small-scale integrated energy system that can manage its own generation and storage resources to dynamically supply local consumers' electricity demands (Lasseter & Paigi, 1998). Since a microgrid can integrate various sources of distributed generation, especially Renewable Energy Sources (RES), an increasing participation of microgrids can help relieve the supply tension of conventional generators in the main grid. However, the high fluctuation of RES production makes energy management more complex and uncertain. Consider, for example, a microgrid powered by a photo-voltaic system. Even if energy consumption follows a regular pattern, its renewable generation is subject to sudden weather changes, difficult to predict with accuracy. Consequently, the microgrid will present a volatile production profile and sometimes its energy storage capacity may not be able to cope with the instant demand for energy. The subsequent decision, how much electricity to buy, will therefore inherit a considerable level of uncertainty, which is also undesirable for the main grid, since it introduces risk and higher operational costs.

Other relevant issues concerning microgrids have arisen with the introduction of free energy markets. Consumers became able to produce energy (thus being called prosumers) and, in parallel, contract types, market models and pricing schemes have evolved (Mitter et al., 2010; Joe-Wong et al., 2012; Morstyn et al., 2019; Aussel et al., 2020). In liberalized markets, large-scale generators, suppliers, industrial consumers and other financial intermediaries trade energy in wholesale markets, including day-ahead auctions, where agents submit their bids and offers for delivery of electricity for each hour of the following day, before market closing time. Small-scale prosumers, on the other hand, are currently serviced by large suppliers in the retail market. Nonetheless, the introduction of forward energy trading is expected to happen at the local level, with microgrids

and actively managed distribution networks becoming more widespread (Cazalot et al., 2016). As new challenges related to local purchasing fluctuations of prosumers arise, it is imperative for the main grid to regulate and stabilize the microgrids' energy purchasing behaviors. One way to accomplish this objective is through the introduction of flexible commitments contracts (Tal et al., 2003).

This work addresses a new framework for microgrid energy trading, with the novel introduction of flexible commitments in a multiple contract setting. The impacts of this contract-based framework are also investigated, from the viewpoint of microgrid energy management. Consider a time horizon, divided into discrete time periods. For each period, one or more contracts are offered, each one defining either selling or purchasing commitments, and providing the flexibility to trade energy between minimum and maximum amounts. Bearing in mind the uncertain nature of the renewable resources, the prosumer must choose the contracts for the whole time horizon, with the objective of minimizing the worst-case cost, at the same time guaranteeing that each commitment will be honored. In a second level of decision, in each time period, following the list of engaged contracts and minimum/maximum commitment constraints, a real-time scheduler coordinates the microgrid's systems, making energy trading and transfer operations, according to current storage units' status and instantaneous information regarding local electricity production and demand.

Although microgrid energy dispatch has been well studied in the literature, existing methods do not investigate the subscription to multiple and flexible electricity contracts, or even committing to future amounts of energy usage, according to forward markets. The same holds true for works focused on dynamic electricity pricing (Mitter et al., 2010; Joe-Wong et al., 2012). The closest work is the one by Duan & Zhang (2013), which, based on Stochastic Optimization, proposed a dynamic contract mechanism to smooth out fluctuations of microgrids' purchasing from the main grid, with time-specific commitments. Their research, however, assumes a single dynamic contract for the whole time horizon, in which the microgrid buys electricity from the energy company.

Among the benefits of flexible contracts, it enables small customers to engage

in a set of short-term contracts and spread energy purchasing decisions over a period of time. Besides avoiding the risk of relying on a single energy contract, the client also has the option to sell the contracted energy back to the grid and start over, which could be used to hedge against risk.

Flexible contract engagement may have drawbacks as well. Intelligent energy scheduling strategies are needed, a smart meter is essential to make accurate readings, and purchasing decisions are often more complex, with the client more exposed to risk, as market prices can go up or down. Moreover, if the client needs to buy out of any engaged contract, the energy price will be higher than existing contract prices. For these reasons, the choice of energy contracts should be robust enough to protect the consumer even in the worst-case scenario, given its operational constraints. Traditional modeling approaches for handling uncertainty include Robust Optimization (RO) and Stochastic Optimization (SO). In this work, RO was chosen for two main reasons. First, for recently-installed microgrid energy systems, probability distributions for energy production/consumption are generally unknown. Second, SO methods typically rely on scenario trees for modeling uncertainty, which makes them computationally expensive (Narayan & Ponnambalam, 2017). By applying a RO approach, the obtained models have improved tractability with less computational effort.

In a conference work (Levorato et al., 2019), we introduced a first robust microgrid energy management model based on an electricity contract subscription framework with flexible commitments. In that previous work, we assumed a conservative box-shaped uncertainty set and obtained preliminary computational results on a single realistic case-study instance. In the present work, we extend both model and real-time command strategies: a budgeted uncertainty robust counterpart, which controls the level of solution conservatism, is described (Bertsimas & Sim, 2004) and used in a look-ahead strategy for the real-time energy scheduling. We also present extensive computational experiments on a set of multiyear and seasonal case-studies based on data from a Japanese research center microgrid recently described by Vink et al. (2019).

The main features of this paper are summarized as follows. Section 2 intro-

duces the Contract Collaboration Problem and the underlying framework. Once the problem has been formally defined, Section 3 presents the state of the art on microgrid energy trading and management as well as on related works on Robust Optimization. In the context of the forward electricity market for microgrids, we describe in Section 4 a mathematical model for multi-contract energy trading with flexible commitments. A robust version of this model is then presented in Section 5, providing protection by minimizing the costs against the worst-case realization of local production and consumption of electricity, under budgeted uncertainty. Then, in Section 6, we describe real-time command strategies for energy scheduling within the microgrid, taking into account the contracts previously selected by our model. Finally, we present a case study, based on a real microgrid, detailing the results of these scheduling strategies, when coupled with the robust model solution (list of engaged contracts), in contrast with a deterministic approach to solve the problem.

## 2. The Contract Collaboration Framework




Figure 1: The Contract Collaboration framework

Considering the context of demand response and smart grids (Siano, 2014), we propose a Contract Collaboration framework, established in two phases (Figure 1). It consists of an approach to handle energy management in microgrids, along with purchase/sell contracts based on flexible commitments.

The first level of decision concerns the list of contracts the client can subscribe, at each time period, given the microgrid's energy demands and opera-

tional constraints (*Contract* table in Figure 1). The solution to the so-called Contract Collaboration Problem (CCP), formally described in Section 2.1, provides the client with a commitment planning for the time horizon (i.e. which contracts to engage at each time period). Once this decision has been made, the list of engaged contracts, for the whole time horizon, cannot be changed.

In a second level of decision, inside each time period, a Real-time Command Strategy (RTCS) is responsible for performing on-line energy scheduling (item 2 in Figure 1). As explained in Section 2.2, the RTCS follows a predefined strategy to balance energy demand and supply at each instant of time, considering renewable energy sources, storage devices, drivable systems and deciding how much energy will be traded via each engaged contract.

### 2.1. The Contract Collaboration Problem (CCP)

The contract collaboration is established between two entities, both producers and consumers of a same kind of energy resource. One entity is called the *client* (individuals, households or businesses) and the other one the *partner* (energy supplier). These two entities have to collaborate in order to balance their consumption and production over a given time horizon. We consider a set  $\{T_0, T_1, \dots, T_{\bar{t}}\}$  of time points dividing the given time horizon into a set  $\mathcal{I} = \{I_0, \dots, I_{\bar{t}-1}\}$  of  $\bar{t}$  time periods where  $I_t = [T_t, T_{t+1})$ , for each  $t \in \{0, 1, 2, \dots, \bar{t} - 1\}$ .

The collaboration between the entities is established by the use of a set  $C$  of contracts of consumption or production, both offered by the partner. Let  $C_t \subseteq C$  be the subset of contracts offered by the partner at time period  $I_t$ . Each contract  $c \in C_t$  has its own functional constraints and its own gain/cost functions. The partner determines the set  $C_t$  and sets a price to engage each contract  $c \in C_t$ . On each time period  $I_t \in \mathcal{I}$ , the client is free to enter into a commitment with the partner through any subset of  $C_t$ . However, these commitments have to be taken by the client at the beginning of the time horizon and must be honored. At any time period, the *client* also has the option to buy energy out of any engaged contract, but at a higher cost which can vary with the time period.



The client’s microgrid is composed by a set of systems  $S$  that produce/consume energy, each one with its own functional constraints and a cost/gain of consuming/producing over the time periods. In particular, the consumption/production can be driven for a subset of these systems (*drivable systems*) while the consumption/production is already planned for the other ones (*non-drivable systems*). Drivable systems are devices that allow being turned on/off or that must be loaded/unloaded from time to time (e.g., batteries, electric car), whereas non-drivable systems must be permanently turned on. Additionally, some of the drivable systems can store the energy resource under a capacity constraint and provide it when it is needed, thus being called *storage systems*. The uncertainty considered in the problem lies in a subset of the *non-drivable systems*, for which only uncertain previsions of the consumption/production are known. The so-called *uncertain non-drivable systems* include, for example, renewable generation and variable energy consumption.

The Contract Collaboration Problem (CCP) consists in determining a cost-minimizing contract subscription from the client to the partner that satisfies all client-side consumer demands over the time horizon, and also guarantees that each commitment taken by the client with the partner is honored. For a detailed description of the CCP models, we refer the reader to Sections 4 and 5.

## 2.2. The Real-Time Command Strategy (RTCS)

In the first level of decision, the list of engaged contracts (i.e., the solution of the CCP problem) is set. The second level of the framework is in charge of defining a Real-Time Command Strategy (RTCS) that guarantees these contracts will be honored. The RTCS operates on smart control devices, being in charge of making scheduling decisions according to instantaneous energy supply and demand fluctuations observed on customers’ premises. Thanks to the development of advanced metering and communication infrastructure, these control devices have the ability to regulate energy consumption by directly communicating to the energy supplier and to other devices in the microgrid so as to prevent system overloads. Interesting examples would be the load reduction

of a set of electric vehicle charging stations and the automatic activation of a group of electric generators.

The RTCS consists of a heuristic strategy that schedules, in real-time, the set of actions to be taken in order to properly manage the client’s microgrid. From a real-time point of view, inside each time period  $I_t \in \mathcal{I}$ , the instantaneous production/consumption of each microgrid system is measured every  $\Delta$  time units. It is also at this time scale that drivable systems are driven, i.e, every  $\Delta$  time units a scheduling decision has to be taken by the control device, embedded in the client’s microgrid, considering its state. For example, according to energy load and in real time, a group of generators (a type of *drivable system*) may be switched on during a period of higher demand and, analogously, a set of *storage systems* such as batteries can store energy during off-peak times in order to ease high demand supply in peak periods.

Regarding the energy contracts, the RTCS is in charge of deciding how much energy will be bought or sold, given each engaged contract and its minimum and maximum commitments. For instance, given a time period, if the client engages contract  $c$ , energy quotas (for buying or selling electricity) are established for each time period and, analogously, for each time slot.

The main objective of the RTCS is to reduce power consumption costs and promote load balance, while dealing with the effects of uncertainty in both production and consumption of energy. As we can expect, the RTCS operates subject to the CCP constraints, guaranteeing both contract commitments and energy balance at each moment. A full description of the real-time command strategies developed in this work is available in Section 6.

### 3. Literature Review

In this section, we highlight existing works involving the two subjects addressed in the paper: microgrid energy scheduling (RTCS) and electricity trading models (such as the CCP).

Various approaches have been proposed to optimize microgrid operational

schedules, with distinct objectives, constraints, and methods for handling uncertainty. As a consequence, different terms have been used to refer to similar real-time control mechanisms: microgrid energy scheduling, real-time scheduling, real-time control system, real-time power management, energy management policies, energy dispatching policies, microgrid energy management and operation. Some authors have also studied the islanded-mode operation of microgrids.

In this review, we will focus on grid-connected microgrids, since energy trading with the main grid is a main premise of our work. As far as grid-connected microgrids are concerned, many works have applied risk-averse optimization methods to energy scheduling, dealing with uncertainties in several model parameters: energy prices, solar power production, wind power generation, Plug-in Electric Vehicle (PEV) consumption and availability, and load demand. An extensive, but not exhaustive, list of papers on microgrid energy scheduling is presented in Table 1, including the approach used to deal with uncertain data (SO or RO), which microgrid elements are assumed to be uncertain and the type of contract with the main grid.

The common point of existing works is how the microgrid interacts with the external energy market: energy transactions are modeled through a single contract (often with the utility grid/retail market), via purchase and sale prices that may vary in time, sometimes including a minimum/maximum tradable energy amount. One exception is the work of Ottesen et al. (2013), where the prosumer can have at most two active contracts: one with a retailer and one with the grid company. In other words, flexible contract frameworks are not investigated. Such type of contract allows buying/selling from/to the main grid not only at different prices (even in the same time period), but also from/to different energy companies at the same time.

The novelty in our work is the incorporation of a multi-contract subscription framework for microgrids, based on flexible commitments. Even though such contract model is not present in existing low-voltage energy markets, it can be applied as an extension to the forward market (via an aggregator or similar energy service provider), or in local microgrid markets, following market structures

Ref	SO	RO	Uncertainty	Solution Method	Contract
Colson & Nehrir (2013)	x		PV, spot price	Decentralized multi-agents	Single (Spot market)
Duan & Zhang (2013)	x		REN, load demands	Stochastic Dynamic Programming	Single dynamic contract
Ottesen et al. (2013)	x		Energy loads, energy prices	General stochastic MILP model	1 contract with Utility grid + 1 dynamic price contract
Wu et al. (2013)	x		Wind, PEV	Scenario generation and reduction	Single (Utility grid)
Su et al. (2014)	x		Wind, PV	Two-stage stochastic model (with scenarios)	Single (Utility grid)
Huang et al. (2014)	x		REN, energy prices, energy consumption	Constrained stochastic programming; Lyapunov optimization	Single (Utility grid)
Nguyen & Crow (2016)	x		REN, load demands	Stochastic dynamic programming	Single (Utility grid)
Wu et al. (2016)	x		PEV, PV, home load demand	Stochastic Dynamic Programming	Single (Utility grid)
Mohammadi et al. (2017)	x		Wind, PEV, energy prices	Multi-objective ILP and scenario analysis	Single (Utility grid)
Zachar & Daoutidis (2017)	x		Residual load	Chance-constrained optimization	Day-ahead commitments
Van Ackooij et al. (2018)	x		PV, Wind	Bilevel stochastic MIP	Multiple contracts, but can only subscribe to one
Wu et al. (2018)	x		PEV	Stochastic Dynamic Programming	Single (Utility grid)
Zhang et al. (2012, 2013)		x	REN	Dual decomposition and distributed subgradient	Single (Spot market)
Wang et al. (2015)		x	Net demand, heat demand, and electricity price	Chance constraint approximation and RO (budget-constrained & distribution uncertainty)	Single (Utility grid)
Hussain et al. (2016)		x	CHP, electrical loads	Budget-constrained min-max robust counterpart	Single (Utility grid)
Craparo et al. (2017)		x	Wind	Scenario-robust MILP based on realistic weather forecast scenarios	Single (Utility grid)
Hu et al. (2018)		x	REN, load demand	Day-ahead scheduling with two-stage RO	Single (Utility grid)
Ruiz Duarte & Fan (2019)		x	PV	Two-stage RO with budget constraints	1 firm contract and 1 non-firm contract

Table 1: Summary of the works listed in literature review. SO (Stochastic Opt model), RO (Robust Opt model). Uncertainty: list of uncertain parameters. REN (Renewable energy production), CHP (Combined Heat and Power), PEV (Plug-in Electric Vehicle), Wind (Wind Generator), PV (Photo-Voltaic). Contract: type of contract used to buy and sell energy.

depicted in (Olivella-Rosell et al., 2018; Khorasany & Razzaghi, 2021).

To our knowledge, only two authors present research directions similar to ours. From the viewpoint of multiple energy contracts, in Van Ackooij et al. (2018) different Generation Companies can offer buy/sell contracts to the microgrid. However, although the microgrid can receive contract offers from different competing companies, it can select at most one contract for the whole time horizon. As far as contract flexibility is concerned, Zachar & Daoutidis (2017) explored the stochastic scheduling of microgrids where energy exchange must be made with day-ahead commitments. In the proposed market structure, the microgrid may be either rewarded for respecting existing commitments, or penalized for deviating too much from them. Despite this flexibility, their work assumes a single long-term contract with the utility company.

As far as RO is concerned, besides the works listed in Table 1, which directly involve microgrids, we also refer the reader to additional RO works on related problems with uncertain demand and production of electricity. The first one involves the application of constraint generation and duality-based reformulation

to solve the robust multistage Unit Commitment Problem, using both budgeted uncertainty and a customized dynamic uncertainty set (Lorca et al., 2016). The second work (Correa-Florez et al., 2019) involves an aggregator of residential prosumers, which participates in the day-ahead energy market to minimize operation costs. Budgeted uncertainty is considered in energy prices, demand and PV production, and Adjustable Robust Optimization is employed. The model takes into account energy purchases in the wholesale market, with the possibility of buying additional blocks of energy. However, no flexible commitments were considered in this framework.

#### 4. A deterministic version of the CCP

In this section, we will present a simpler, deterministic model version of the CCP, denoted as DCCP, where the value of the uncertain parameters are assumed to be known in advance. The formulation comprises each microgrid component, its operational constraints, as well as the underlying contract subscription framework. The main idea of the CCP model is to find a cost-minimizing solution which provides the client with a list of energy contracts to engage in each time period, considering the whole time horizon. In the rest of this text, time is discretized into periods as indicated by  $I_0, \dots, I_{\bar{t}-1}$  and energy units are assumed to be in kWh. Moreover, we will often write  $t$  for a time period  $I_t$ .

#### Nomenclature

##### Sets

$\mathcal{I}$	Time periods: $\mathcal{I} = \{I_0, \dots, I_{\bar{t}-1}\}$
$T$	Time period indexes: $T = \{0, \dots, \bar{t} - 1\}$
$C_t \subseteq C$	Contracts offered by partner at period $I_t$
$S_D \subseteq S$	Certain drivable systems
$S_{ND} \subseteq S$	Certain non-drivable systems
$B$	(Certain, drivable) storage systems

##### Input parameters - Partner

$v_c^t \geq 0$	fixed cost paid by the client for engaging contract $c \in C_t$ at period $I_t, \forall t \in T$
$\alpha_c^t \geq 0$	cost per energy unit consumed/provided according to contract $c \in C_t$ at period $I_t$
$\Pi_{t,c}^-$	minimal energy quota for contract $c \in C_t$ during period $I_t$
$\Pi_{t,c}^+$	maximal energy quota for contract $c \in C_t$ during period $I_t$

$\beta^t \geq 0$  cost per energy unit consumed by the client at period  $I_t$  not provided by engaged contracts,  $\forall t \in T$

**Input parameters - Client**

$\delta^t \geq 0$  length of period  $I_t$ : how many slots of  $\Delta$  time units compose this time period  
 $P_s^t$  energy consumption (< 0)/production (> 0) of  $s \in (S_D \cup S_{ND})$  during the whole time period  $I_t$

$v_s$  cost per energy unit produced (> 0)/consumed (< 0) when using system  $s \in (S_D \cup S_{ND})$

$P_s^{min,t}$  minimum energy to be produced (> 0)/consumed (< 0) by drivable system  $s \in S_D$  before the end of period  $I_t$

$v_s \geq 0$  cost of energy unit charged/discharged by storage system  $s \in B$

$u_s^{min} \geq 0$  minimal storage level of system  $s \in B$

$u_s^{max} \geq 0$  storage capacity of system  $s \in B$

$u_s^0 \geq u_s^{min}$  initial storage level (at period  $I_0$ )

$0 \leq \lambda_s \leq 1$  the loss coefficient of system  $s \in B$

$\theta_s^{abs} > 0$  maximum energy stored in  $s \in B$  during  $\Delta$  time units

$\theta_s^{ref} > 0$  rated capacity, i.e., maximum energy delivered during  $\Delta$  time units

**Model variables**

$y_c^t$   $\begin{cases} 1 & \text{if the client engages contract } c \in C_t \text{ at period } I_t \\ 0 & \text{otherwise} \end{cases}$

$q_c^t$  amount of electricity sold (< 0) / bought (> 0) by the client at time period  $I_t$  related with contract  $c \in C_t$

$0 \leq x_s^t \leq 1$  percentage of time period  $I_t$  drivable system  $s \in S_D$  is used

$g_s^t \geq 0$  energy fed into storage system  $s \in B$  during period  $I_t$

$h_s^t \geq 0$  energy consumed from storage system  $s \in B$  during period  $I_t$

$r_s^t \geq 0$  amount of energy stored in  $s \in B$  at time period  $t \in T \cup \{\bar{t}\}$

$e^t \geq 0$  extra amount of energy requested by the client (out of any engaged contract) at time period  $I_t$

Given a set of contracts offered by the partner, each contract  $c \in C_t$  is associated with a time period  $I_t$  and its fixed ( $v_c^t$ ) and variable prices ( $\alpha_c^t$ ) may vary if the period is in peak hours or off-peak. By engaging in a contract, the client must respect the established energy quotas  $\Pi_{t,c}^-$  and  $\Pi_{t,c}^+$ , that may be positive (if the client purchases energy from the partner) or negative (the client sells energy to the partner). The partner can also sell energy to the client out of any engaged contract at a specific unit price  $\beta^t$ .

The information about energy consumption (or production)  $P_s^t$  of all *drivable* and *non-drivable systems* is discretized into time periods  $I_t$ . Moreover, in the microgrid's energy scheduling, each time period  $I_t$  is further subdivided into  $\delta^t$

**time slots of size  $\Delta$** , where  $\Delta$  is an input parameter. At this time scale, the instantaneous production/consumption of each microgrid system is measured.

Each system  $s \in S_D \cup S_{ND} \cup B$  may have an associated operational cost  $v_s$  (e.g. energy produced by a fuel generator has positive cost). This cost can also be zero (e.g. consumer system such as a building). Additionally, for each drivable system  $s \in S_D$ , we define minimum requirements for energy production/consumption at time period  $I_t$ . In other words, for each consumer drivable system  $s$ ,  $P_s^{min^t} > 0$  means system  $s$  must be supplied with  $P_s^{min^t}$  units of energy before the end of time period  $I_t$  (e.g. when charging an electric car). Normally,  $P_s^{min^t} = 0$  if  $s$  is a producer drivable system.

Last but not least, the *storage systems* are a key component for the success of the contract subscription framework. A set of batteries can store energy during off-peak time periods in order to ease high demand supply in peak periods. Besides the unit cost, there are several battery-specific parameters related to the storage levels, capacity and efficiency:  $u_s^{min}$ ,  $u_s^{max}$ ,  $u_s^0$ ,  $\lambda_s$ ,  $\theta_s^{abs}$  and  $\theta_s^{ref}$ .

Based on the model variables defined above, we now present a Mixed-Integer Linear Programming (MILP) model, whose optimal solution provides the client with a commitment planning for the whole time horizon: which contracts to engage in each time period.

$$\text{Min } \sum_{t \in T} \sum_{c \in C_t} (v_c^t y_c^t + \alpha_c^t q_c^t) + \sum_{s \in S_D} v_s \sum_{t \in T} P_s^t x_s^t + \sum_{s \in B} v_s \sum_{t \in T} (g_s^t + h_s^t) + \sum_{t \in T} \beta^t e_t \quad (1)$$

$$\sum_{t' \leq t} P_s^{t'} x_s^{t'} \geq P_s^{min^t}, \forall t \in T, \forall s \in S_D : P_s^t > 0 \quad (2)$$

$$\sum_{t' \leq t} P_s^{t'} x_s^{t'} \leq P_s^{min^t}, \forall t \in T, \forall s \in S_D : P_s^t < 0 \quad (3)$$

$$h_s^t \leq r_s^t, \forall t \in T, \forall s \in B \quad (4)$$

$$r_s^0 = u_s^0, \forall s \in B \quad (5)$$

$$u_s^{min} \leq r_s^t \leq u_s^{max}, \forall t \in T \cup \{t\}, \forall s \in B \quad (6)$$

$$r_s^{t+1} = r_s^t - h_s^t + \lambda_s g_s^t, \forall t \in T, \forall s \in B \quad (7)$$

$$g_s^t \leq \theta_s^{abs} \delta^t, \forall t \in T, \forall s \in B \quad (8)$$

$$h_s^t \leq \theta_s^{ref} \delta^t, \forall t \in T, \forall s \in B \quad (9)$$

$$\Pi_{t,c}^- y_c^t \leq q_c^t \leq \Pi_{t,c}^+ y_c^t, \forall t \in T, \forall c \in C_t : \Pi_{t,c}^+ > 0 \quad (10)$$

$$\Pi_{t,c}^+ y_c^t \leq q_c^t \leq \Pi_{t,c}^- y_c^t, \forall t \in T, \forall c \in C_t : \Pi_{t,c}^- < 0 \quad (11)$$

$$\sum_{c \in C_t} q_c^t + \sum_{s \in S_{ND}} P_s^t + \sum_{s \in S_D} x_s^t P_s^t + \sum_{s \in B} \lambda_s h_s^t + e^t \geq \sum_{s \in B} g_s^t, \forall t \in T \quad (12)$$

The objective function (1) includes, respectively: (i) the fixed costs involved in the client-partner engagement through a set of contracts; (ii) the sum of costs/gains of consuming/providing the amounts of electricity predicted by the set of engaged contracts; (iii) the costs of using drivable systems; (iv) the costs of using storage systems (including depreciation); (v) the costs of consuming extra amounts of electricity not predicted in the set of engaged contracts.

There are also costs associated with the use of non-drivable systems. However, since these costs are fixed, they do not need to be included in the objective function to be minimized.

Constraints (2)-(3) ensure the minimum usage of *drivable system s*, in case it produces (2) or consumes (3) electricity. Constraints (4) restrict the amount of electricity consumed from *storage system s* during a time period to be at most the amount stored. Additionally, constraints (5)-(6) state that the initial, minimum and maximum capacities of *storage system s* must be respected. Constraints (7) determine the amount of electricity stored on *storage system s* at the next time period. It must take into account its loss coefficient  $\lambda_s$ , i.e., when storing  $g_s^t$  kWh of energy, only  $\lambda_s$  % is effectively stored in *s*. Remark that  $h_s^t$  includes the amount of energy provided by *s* as well as the energy lost during this operation. The maximum quantity of energy that can be stored by *storage system s* during a time period *t* is guaranteed by constraints (8), while constraints (9) ensure the maximum quantity of energy that can be provided by a *storage system s* during a time period *t*.

Constraints (10)-(11) establish minimum and maximum quotas for contracts. They also guarantee that a non-zero consumption/production related with a contract available at a certain time period will imply an engagement to it.

Finally, constraints (12) define the electricity balance at each time period. When calculating the energy refunded by storage systems *s*, these inequalities must take into account the amount of energy lost during discharge, therefore  $h_s^t$  must be reduced proportionally to  $\lambda_s$  %. Besides, at any time period, total consumption may be greater than the energy available from the microgrid's production, storage systems and currently engaged contracts. In this case, the



microgrid can buy additional energy  $e^t$  from the partner in order to fulfill unforeseen demand. We also assume a dissipation system is available with no cost of use associated.

We denote by MIP(DCCP) the formulation defined by objective function (1), constraints (4)–(12) and appropriated integrality and bounding constraints. With  $|T|(|S_D| + 5|B| + |C|)$  constraints and  $2|C| + |T||S_D| + 3|T||B| + |T|$  variables, this formulation is classified as a Mixed-Integer Programming (MIP) model (Wolsey & Nemhauser, 1999), whose solution can be obtained with both commercial and open-source solvers, using well-known branch-and-bound algorithms. As seen in the experiments with case study instances, the solution to the deterministic CCP is returned by CPLEX solver in less than a second.

## 5. A robust formulation of the CCP

We consider in this section the robust version of the CCP, denoted as RCCP, in which the uncertainty of non-drivable systems will be treated via Robust Optimization methods. The developed model is capable of protecting against the worst-case realization of production and consumption of electricity, within a provided uncertainty set, considering all *uncertain non-drivable systems*, denoted as  $\widehat{S}_{ND} \subseteq S$ . Once again, the model solution consists of a list of contracts to engage in each time period, for the whole time horizon.

Regarding the uncertainty in non-drivable devices' production/consumption, the only information required by the model are the lower and upper bound parameters, namely  $\{\underline{P}_s^t, \overline{P}_s^t\}$ ,  $\forall t \in T, \forall s \in \widehat{S}_{ND}$ , which can be determined via inference schemes based on historical data:

$\forall t \in T, \forall s \in \widehat{S}_{ND}$ :

$\underline{P}_s^t$	lower bound on energy consumption(<0)/production(>0) of $s$ in the whole period $t$
$\overline{P}_s^t$	upper bound on energy consumption(<0)/production(>0) of $s$ in the whole period $t$

Similarly to drivable and non-drivable devices, uncertain devices  $s \in \widehat{S}_{ND}$  also have associated operational costs  $v_s$ , per energy unit consumed/produced.

### 5.1. Definition of the uncertainty sets

In this work, we adopt a min-max criterion to assess the cost of feasible solutions to the problem. This means that we look for a solution that is feasible for each attribution of the uncertain parameters and that minimizes the cost function in the worst case scenario. The uncertain data are assumed to be varying in a given uncertainty set.

The formulation of the Robust Optimization model is connected with the definition of this uncertainty set and this definition depends on the suppositions made on the problem being solved. In our problem, the set  $\mathbf{U}(\mathbf{t}, \mathbf{s})$  describes how the uncertainty is defined.

$\forall t \in T, \forall s \in \widehat{S}_{ND}$ :

$\widehat{P}_s^t \in \mathbf{U}(\mathbf{t}, \mathbf{s})$	energy consumption(<0)/production(>0) of $s$ in the whole time period $t$
--	---

Consider a vector  $v \in \mathfrak{R}^{n \times m}$ . This text uses the vector notation  $v^i = (v_j^i; j = 1, \dots, m)$  and  $v_j = (v_i^j; i = 1, \dots, n)$ . Hence,  $\underline{P}^t = (\underline{P}_s^t; s \in \widehat{S}_{ND})$  and  $\overline{P}_s = (\overline{P}_s^t; t \in T)$ . If we presume that each uncertain parameter belongs to an interval, i.e.,  $\mathbf{U}(\mathbf{t}, \mathbf{s}) = [\underline{P}_s^t, \overline{P}_s^t]$ , the *box uncertainty set* (Soyster, 1973), denoted here by  $\mathcal{U}_{box}$ , can be defined as:  $\mathcal{U}_{box} = \times_{s \in \widehat{S}_{ND}} U_s$ , where  $U_s = [\underline{P}_s, \overline{P}_s], s \in \widehat{S}_{ND}$ .

Assuming that the uncertain parameter belongs to an interval is equivalent to say that it lies between a mean value and peak values, i.e.,

$$\mathbf{U}(\mathbf{t}, \mathbf{s}) = \{\widehat{P}_s^t = \bar{v}_s^t + \Delta_s^t \hat{v}_s^t \mid -1 \leq \Delta_s^t \leq 1\},$$

with  $\hat{v}_s^t = (\overline{P}_s^t - \underline{P}_s^t)/2$  and  $\bar{v}_s^t = \underline{P}_s^t + \hat{v}_s^t$ .

Now suppose that, given all uncertain devices  $s \in \widehat{S}_{ND}$  and time periods  $t \in T$ , at most  $\Gamma$  uncertain parameters  $\widehat{P}_s^t$  may reach peak values in the whole time horizon. We can then define the *budget uncertainty set*, studied in (Bertsimas & Sim, 2004) and largely applied (Agra et al., 2013; Lorca et al., 2016; Correa-Florez et al., 2019):

$$\mathcal{U}_\Gamma = \{\widehat{P} \in \mathcal{U}_{box} : \sum_{s \in \widehat{S}_{ND}} \sum_{t \in T} |\Delta_s^t| \leq \Gamma\}.$$

The purpose of the budget of uncertainty is to control the level of conservatism of the robust solution, in terms of deviations in the uncertain model parameters. It allows an intuitive interpretation for the decision maker, pro-

viding a trade-off between the nominal performance of the deterministic model and the risk protection of the most conservative model. Additionally, the obtained robust counterpart remains efficiently solvable, provided that the original nominal problem can be effectively solved.

In the context of the RCCP, with the objective of simplifying the model and the analysis of the obtained results, we opted for a single budget parameter  $\Gamma$ . It controls the total number of deviated parameters regarding both energy consumption ( $\hat{P}_s^t < 0$ ) or production ( $\hat{P}_s^t > 0$ ) of all uncertain devices  $s \in \hat{S}_{ND}$ , over all time periods  $t \in T$ .

### 5.2. Robust counterpart

Similarly to the DCCP, we describe a formulation for the robust version of the problem based on time decomposition, in which decisions are made for every time period  $I_t$ . The Min-Max Adjustable Robust Counterpart (ARC) formulation, used in this work, ensures feasibility of the constraints for any realization of the uncertainty, through the appropriate selection of the second stage decision variables. For more details on Adjustable RO for multi-stage optimization problems, we refer the interested reader to Gorissen et al. (2015).

In the robust version of our problem, the RCCP, variables  $y$  (defined in Section 4) are non-adjustable ones, i.e, they consist of “here and now” decisions, or first-stage variables, before having any knowledge of the actual value taken by the uncertainty. The other variables, namely  $q$ ,  $r$ ,  $h$ ,  $g$ ,  $x$  and  $e$ , are adjustable ones, i.e, they consist of “wait and see” decisions (i.e., second-stage variables) and define a set of decisions that depend on the uncertain parameters.

The Min-Max ARC, based on formulation MIP(DCCP) from Section 4, is

as follows:

$$(ARC) \min_{y_c^t, E} E \quad (13)$$

$$\begin{aligned} \text{s.t. } E &\geq \sum_{t \in T} \sum_{c \in C_t} (v_c^t y_c^t + \alpha_c^t q_c^t(\hat{P}_t)) + \sum_{s \in S_D} v_s \sum_{t \in T} P_s^t x_s^t(\hat{P}_t) \\ &+ \sum_{s \in \hat{S}_{ND}} v_s \sum_{t \in T} \hat{P}_s^t + \sum_{s \in B} v_s \sum_{t \in T} (g_s^t(\hat{P}_t) + h_s^t(\hat{P}_t)) + \sum_{t \in T} \beta^t e_t(\hat{P}_t), \forall \hat{P} \in \mathcal{U}, \end{aligned} \quad (14)$$

$$\begin{aligned} \sum_{c \in C_t} q_c^t(\hat{P}_t) + \sum_{s \in S_{ND}} P_s^t + \sum_{s \in \hat{S}_{ND}} \hat{P}_s^t + \sum_{s \in S_D} P_s^t x_s^t(\hat{P}_t) \\ + \sum_{s \in B} \lambda_s h_s^t(\hat{P}_t) + e^t(\hat{P}_t) \geq \sum_{s \in B} g_s^t(\hat{P}_t), \forall \hat{P} \in \mathcal{U}, \forall t \in T, \end{aligned} \quad (15)$$

$$h_s^t(\hat{P}_t) \leq r_s^t(\hat{P}_{t-1}), \forall \hat{P} \in \mathcal{U}, \forall t \in T, \forall s \in B, \quad (16)$$

$$r_s^0 = u_s^0, \forall s \in B, \quad (17)$$

$$u_s^{min} \leq r_s^t(\hat{P}_{t-1}) \leq u_s^{max}, \forall \hat{P} \in \mathcal{U}, \forall t \in T \cup \{\bar{t}\}, \forall s \in B, \quad (18)$$

$$r_s^{t+1}(\hat{P}_t) = r_s^t(\hat{P}_{t-1}) - h_s^t(\hat{P}_t) + \lambda_s g_s^t(\hat{P}_t), \forall \hat{P} \in \mathcal{U}, \forall t \in T, \forall s \in B, \quad (19)$$

$$g_s^t(\hat{P}_t) \leq \theta_s^{abs} \delta^t, \forall \hat{P} \in \mathcal{U}, \forall t \in T, \forall s \in B, \quad (20)$$

$$h_s^t(\hat{P}_t) \leq \theta_s^{ef} \delta^t, \forall \hat{P} \in \mathcal{U}, \forall t \in T, \forall s \in B, \quad (21)$$

$$\Pi_{t,c}^- y_c^t \leq q_c^t(\hat{P}_t) \leq \Pi_{t,c}^+ y_c^t, \forall \hat{P} \in \mathcal{U}, \forall t \in T, \forall c \in C_t : \Pi_{t,c}^+ > 0, \quad (22)$$

$$\Pi_{t,c}^+ y_c^t \leq q_c^t(\hat{P}_t) \leq \Pi_{t,c}^- y_c^t, \forall \hat{P} \in \mathcal{U}, \forall t \in T, \forall c \in C_t : \Pi_{t,c}^- < 0, \quad (23)$$

$$\sum_{t' \leq t} P_s^{t'} x_s^{t'}(\hat{P}_t) \geq P^{min}_s, \forall \hat{P} \in \mathcal{U}, \forall t \in T, \forall s \in S_D : P_s^t > 0, \quad (24)$$

$$\sum_{t' \leq t} P_s^{t'} x_s^{t'}(\hat{P}_t) \leq P^{min}_s, \forall \hat{P} \in \mathcal{U}, \forall t \in T, \forall s \in S_D : P_s^t < 0, \quad (25)$$

$$y_c^t \in \{0, 1\}, \forall t \in T, \forall c \in C_t, \quad (26)$$

$$r_s^t(\hat{P}_{t-1}), h_s^t(\hat{P}_t), g_s^t(\hat{P}_t) \geq 0, \forall \hat{P} \in \mathcal{U}, \forall t \in T, \forall s \in B, \quad (27)$$

$$e^t(\hat{P}_t) \geq 0, \forall \hat{P} \in \mathcal{U}, \forall t \in T, \quad (28)$$

$$0 \leq x_s^t(\hat{P}_t) \leq 1, \forall \hat{P} \in \mathcal{U}, \forall t \in T, \forall s \in S_D, \quad (29)$$

where  $\mathcal{U}$  is the uncertainty set chosen. For a given  $t' \in T$ , variables  $q^{t'}$ ,  $h^{t'}$ ,  $g^{t'}$ ,  $x^{t'}$ , and  $e^{t'}$  depend on the vector of uncertain parameters  $\hat{P}_{t'}$  while variables  $r^{t'}$  depend on  $\hat{P}_{t'-1}$ .

In a previous work (Levorato et al., 2019), we assumed a conservative  $\mathcal{U}_{box}$  uncertainty set and obtained preliminary computational results on a single case study instance. In the next subsection, we will explain how the dualization approach was employed to derive a robust counterpart for the  $\mathcal{U}_\Gamma$  uncertainty set. Notice that the cost associated with the use of *uncertain non-drivable systems*, given by  $\sum_{s \in \hat{S}_{ND}} v_s \sum_{t \in T} \hat{P}_s^t$ , must be included in the robust model. Different from the cost of certain non-drivable systems,  $\hat{P}_s^t$  values are not constant and vary with the uncertain parameters. Also notice that constraints (19) can be

used to eliminate variables  $h_s^t$ , reducing the set of second-stage variables.

An approach proposed in the literature to make model (ARC) tractable consists of restricting the functional relations  $q_c^t, r_s^t, g_s^t, x_s^t$  and  $e^t$  to be affine by replacing them with linear decision rules (LDR) (Ben-Tal et al., 2004). Also known as affine policies, LDRs have been commonly used in the literature as an effective approximation to multistage RO problems (Jabr, 2013; Warrington et al., 2015; Lorca et al., 2016), with each recourse decision taking the form of an affine function of the uncertain parameters.

This way, we restrict recourse variables, say  $g_s^t(\widehat{P}^t)$ , to be affinely dependent on the primitive uncertainties, considering all uncertain devices  $\varsigma \in \widehat{S}_{ND}$  and all time periods prior to  $t$ . Of course, only in very rare occasions, linear decision rules are optimal. Indeed, the main motivation for linear decision rules is its tractability. The following decision rules were applied for the set of adjustable variables in our problem:

$$r_s^t = r_{ts}^0 + \sum_{\tau=0}^{t-1} \sum_{\varsigma \in \widehat{S}_{ND}} r_{ts}^{\tau\varsigma} \widehat{P}_{\varsigma}^{\tau}, \forall t \in T \setminus \{0\} \cup \{t\}, \forall s \in B, \quad (30)$$

$$g_s^t = g_{ts}^0 + \sum_{\tau=0}^t \sum_{\varsigma \in \widehat{S}_{ND}} g_{ts}^{\tau\varsigma} \widehat{P}_{\varsigma}^{\tau}, \forall t \in T, \forall s \in B, \quad (31)$$

$$x_s^t = x_{ts}^0 + \sum_{\tau=0}^t \sum_{\varsigma \in \widehat{S}_{ND}} x_{ts}^{\tau\varsigma} \widehat{P}_{\varsigma}^{\tau}, \forall t \in T, \forall s \in S_D, \quad (32)$$

$$q_c^t = q_{tc}^0 + \sum_{\tau=0}^t \sum_{\varsigma \in \widehat{S}_{ND}} q_{tc}^{\tau\varsigma} \widehat{P}_{\varsigma}^{\tau}, \forall t \in T, \forall c \in C_t, \quad (33)$$

$$e^t = e_t^0 + \sum_{\tau=0}^t \sum_{\varsigma \in \widehat{S}_{ND}} e_t^{\tau\varsigma} \widehat{P}_{\varsigma}^{\tau}, \forall t \in T. \quad (34)$$

As seen in the next subsection, after bringing the linear decision rules to the formulation, by taking  $\mathcal{U} = \mathcal{U}_{\Gamma}$ , each constraint holding uncertain parameters is transformed by means of strong duality theory. As a result, we obtain a linear approximation to the model, called (ARC-L1). Each inequality will be characterized in terms of max/min values, and later replaced by its corresponding dual equivalent. In this process, a new set of continuous variables and a new set of constraints will be added to the formulation. This final product is a MILP model to the robust problem, which will be called MIP(RCCP), and whose solution can be obtained with commercial optimization solvers.

### 5.3. RCCP under budgeted uncertainty

Given the definition of the budget uncertainty set  $\mathcal{U}_\Gamma$ , we now present a dualization rule that can be applied to each constraint of the robust counterpart. Each ARC constraint can be written either in form (a)  $f^0 + \sum_{t \in T} \sum_{s \in \widehat{S}_{ND}} \widehat{P}_s^t f_s^t \leq 0$ , or (b)  $f^0 + \sum_{t \in T} \sum_{s \in \widehat{S}_{ND}} \widehat{P}_s^t f_s^t \geq 0$ , where  $f^0$  is the independent term and  $f_s^t$  is the term that depends on the uncertain parameters  $\widehat{P}_s^t \in \mathcal{U}_\Gamma$ . In form (a), each problem constraint can be rewritten as:

$$f^0 + \max_{\widehat{P} \in \mathcal{U}_\Gamma} \left\{ \sum_{t \in T} \sum_{s \in \widehat{S}_{ND}} \widehat{P}_s^t f_s^t \right\} \leq 0, \quad (35)$$

with the second term being reformulated as:

$$\max_{\Delta_{t,s}^+, \Delta_{t,s}^-} \left\{ \sum_s \sum_t f_s^t (\bar{v}_s^t + \Delta_{t,s}^+ \cdot \widehat{v}_s^t - \Delta_{t,s}^- \cdot \widehat{v}_s^t) : \right. \quad (36)$$

$$\Delta_{t,s}^+ + \Delta_{t,s}^- \leq 1, \quad s \in \widehat{S}_{ND}, t \in T, \quad (\mu_s^t) \quad (37)$$

$$\sum_s \sum_t (\Delta_{t,s}^+ + \Delta_{t,s}^-) \leq \Gamma, \quad (\rho) \quad (38)$$

$$\Delta_{t,s}^+ \geq 0, \quad \Delta_{t,s}^- \geq 0, \quad s \in \widehat{S}_{ND}, t \in T \} \leq 0 \quad (39)$$

Where variables  $\Delta_{t,s}^+$  and  $\Delta_{t,s}^-$  indicate that the uncertain parameter  $\widehat{P}_s^t$  has oscillated above (or below) its nominal value  $\bar{P}_s^t$ . Constraints (37) limit the oscillation according to the maximum value allowed ( $\widehat{v}_s^t$ ) and constraints (38) limit the budget of uncertainty to  $\Gamma$ .

Analogously, for each problem constraint in form (b), we derive:

$$\min_{\Delta_{t,s}^+, \Delta_{t,s}^-} \left\{ \sum_s \sum_t f_s^t (\bar{v}_s^t + \Delta_{t,s}^+ \cdot \widehat{v}_s^t - \Delta_{t,s}^- \cdot \widehat{v}_s^t) : \text{s.t. (37)-(39)} \right\} \geq 0. \quad (40)$$

The inclusion of the above robustified equations in the tractable MILP model is possible via dualization. In both cases above, dual variables  $\mu_s^t$  and  $\rho$  can be derived, along with dual objective function:  $\sum_s \sum_t \mu_s^t + \rho \cdot \Gamma + \sum_s \sum_t f_s^t \cdot \bar{v}_s^t$ .

In the first case (a), the dual constraints are:

$$\mu_s^t + \rho \geq \widehat{v}_s^t \cdot f_s^t \quad (\Delta_{t,s}^+) \quad (41)$$

$$\mu_s^t + \rho \geq |\widehat{v}_s^t \cdot f_s^t| \equiv \begin{cases} \mu_s^t + \rho \geq \widehat{v}_s^t \cdot f_s^t & (\Delta_{t,s}^+) \\ \mu_s^t + \rho \geq -\widehat{v}_s^t \cdot f_s^t & (\Delta_{t,s}^-) \end{cases} \quad (42)$$

$$\mu_s^t \geq 0, \quad \rho \geq 0 \quad (43)$$

And, in the second case (b), the dual constraints are:

$$\mu_s^t + \rho \leq \widehat{v}_s^t \cdot f_s^t \quad (\Delta_{t,s}^+) \quad (44)$$

$$\mu_s^t + \rho \leq |\widehat{v}_s^t \cdot f_s^t| \equiv \begin{cases} \mu_s^t + \rho \leq \widehat{v}_s^t \cdot f_s^t & (\Delta_{t,s}^+) \\ \mu_s^t + \rho \leq -\widehat{v}_s^t \cdot f_s^t & (\Delta_{t,s}^-) \end{cases} \quad (45)$$

$$\mu_s^t \leq 0, \quad \rho \leq 0 \quad (46)$$

In form (a), after dualization, each constraint is replaced by the following constraints in the tractable MILP model:

$$f^0 + \sum_s \sum_t \mu_s^t + \rho \cdot \Gamma + \sum_s \sum_t f_s^t \bar{v}_s^t \leq 0, \text{ and (41)-(43).}$$

While, in form (b), each constraint is replaced by constraints:

$$f^0 + \sum_s \sum_t \mu_s^t + \rho \cdot \Gamma + \sum_s \sum_t f_s^t \bar{v}_s^t \geq 0, \text{ and (44)-(46).}$$

The resulting tractable robust MILP model has  $(5 + |T| |\widehat{S}_{ND}|)(2|C| + |T| |S_D| + 3|T| |B| + |T|)$  constraints and  $|T|^2 |\widehat{S}_{ND}|(2|B| + |C| + 1) + (6|T| |S_D| + 8|C| + 14|T| |B| + |T| |C|)$  variables.

## 6. Real-time energy scheduling with the RTCS

The solution of the CCP (either the deterministic version in Section 4 or the robust version from Section 5) provides the client a decision for the first level in our framework: the contract subscription for the whole time horizon. However, for the success of the proposed contract framework, an efficient real-time energy scheduling mechanism is needed, so that distributed energy resources, storage devices and drivable loads within the microgrid are operated in a coordinated and coherent way, together with the energy exchange with the main grid.

Recall the RTCS definition given in Section 2. In order to perform energy scheduling, each time period  $I_t$  is further subdivided into  $\delta^t$  **time slots of size  $\Delta$** . At this time scale, the instantaneous production/consumption of each microgrid system is measured. For *certain* (*drivable* and *non-drivable*) systems, the consumption/production, for each time period  $I_t$ , is known beforehand. And every  $\Delta$  time units a scheduling decision has to be made by the control device, according to the state of the microgrid.

In this sense, the RTCS consists of a scheduling heuristic that, based on the microgrid state and the energy contracts engaged by the client, solves an online optimization problem, selecting in real-time the set of actions to be taken, with the objective of reducing energy consumption costs and promoting load balance, while, at the same time, dealing with the effects of uncertainty. Remark that

the solution approaches commonly used to solve off-line scheduling problems are not appropriate for the on-line scheduling case.

Since the RTCS operates according the Contract Collaboration Framework, we remark that, once the heuristic starts, the set of subscribed energy contracts  $\mathbf{y}_0$ , for the whole time horizon, has already been established. Such decision is made by the client after running one of the previously presented CCP models. According to the microgrid energy balance, the following operations must be considered: (a) turn on/off a production/consumption *drivable system*; (b) buy/sell a quantity of energy under an engaged contract; (c) recharge/retrieve energy from a *storage system*; (d) buy energy out of engaged contracts; (e) throw energy away (if remaining energy cannot be sold back to the grid). Also, a subset of actions taken in a specific moment must obey the Contract Collaboration Problem constraints.

### 6.1. Naïve RTCS policy

This section describes the most straightforward approach to perform energy scheduling. The proposed naïve control strategy can be used as a baseline strategy to schedule the use of the Battery Energy Storage Systems (BESS) and the energy exchange via contracts. The naïve strategy relies on two assumptions. First, the microgrid should only sell energy via contracts as a last resort because the selling price is typically lower than the contract buying price. Besides, most of the time, the production obtained from renewables does not match the microgrid’s energy demand. As a result, the microgrid will eventually buy energy from the power grid.

The proposed naïve RTCS policy works as follows. At each time step, the current demand for electricity is determined as the sum of the amount of energy required by the consumer drivable and non-drivable systems minus the amount of energy actually produced by the microgrid. In case the produced energy outweighs the demand, the resulting surplus is used to charge the battery. If the BESS is already full or the surplus exceeds the charging rate, the excess energy is sold via contracts. On the contrary, if existing demand goes beyond



the available produced energy, the difference is provided by discharging the battery. If the stored energy is not enough, then the remaining required energy is bought from the grid, first via available engaged contracts (provided they still have existing capacity), or bought out of any engaged contracts, possibly at a higher price.

### 6.2. Using model solution as a look-ahead policy to guide RTCS

The solution of the CCP models provide not only a list of contracts to engage, but also a set of values that can be used as a look-ahead (LA) policy to guide the RTCS energy dispatch operations, at each time period  $I_t$ . The policy is defined by the optimal value of all model variables, except  $y$  variables.

When using the deterministic model, look-ahead values are obtained directly from the model solution, while for the robust models, the LDRs (30)-(34) are used to derive the look-ahead values for the current time period  $I_{t'}$ . In Section 7, we will show that the look-ahead policies based on the robust models can effectively enhance the performance of the RTCS. Among the advantages, the better utilization of storage devices and greater protection against uncertainty, when compared to the deterministic model.

We propose different heuristics for the RTCS, each one with a distinct behavior. As previously mentioned, the RTCS operates based on a predefined set of engaged contracts, obtained from a specific CCP model solution. Therefore, in the remainder of this section, we refer to  $X$ -RTCS as the general RTCS that can be executed based on an existing CCP model solution  $X$ .

Algorithm 1 depicts the  $X$ -RTCS executed inside a given time period  $I_{t'}$ , every  $\Delta$  time units or, analogously, at each time slot  $d \in \{1, \dots, \delta^{t'}\}$ . At this time, the uncertainty concerning energy production/consumption has been revealed for all time periods before  $I_{t'}$ , and the microgrid configuration is given by its battery storage levels, drivable system requirements, load demand and renewable production. Let  $X(\mathbf{y}_0, t')$  be the  $X$  model obtained by fixing  $y = \mathbf{y}_0$  and all variables and parameters related with  $t < t'$ . The optimal solution of  $X(\mathbf{y}_0, t')$  serves as a policy for all  $t \geq t'$ . Two different parameters, named

REOPTIMIZE and GAP POLICY, define how the  $X(\mathbf{y}_0, t')$  solution will be used as a policy in the X-RTCS heuristic.

The first one concerns the usage of model  $X$ . The REOPTIMIZE option determines which model  $X$  solution will be used as a forecast tool to determine the initial quantities regarding how much energy will be consumed or how much excess energy will be sent to the grid, via engaged contracts<sup>1</sup>, and how long *drivable systems* should remain powered on. If REOPTIMIZE is enabled (line 1), model  $X$  will be reoptimized at each time period  $I_{t'}$ , for the remaining time periods  $t \geq t'$  (line 2), and the new solution obtained will guide the initial energy quantities (line 3). Otherwise, as listed on line 5, the RTCS policy will be based on the initial solution at the start of the time horizon ( $t = 1$ ), i.e., the optimal solution of  $X(\mathbf{y}_0, 1)$ .

The next step of the algorithm is the calculation of the current microgrid energy gap (i.e., total consumption *minus* total production) at the current time slot  $d$  (line 9), based on collected data regarding instantaneous energy production/consumption, minimum contract engagements, as well as model predictions regarding batteries and drivable systems (lines 6-8). We denote by  $q_c^{t',d}$  as the amount of energy that will be bought or sold via the contract  $c$  in time slot  $d$ ; and  $x_s^{t',d}$  as the percentage of time in which drivable system  $s$  will be on at time slot  $d$ . Also assume  $\hat{P}_s^{t',d}$  is an estimation of the uncertain production/consumption of device  $s$  at time slot  $d$ .

Finally, according to this information, X-RTCS must decide which additional dispatch operations will be executed to balance supply and demand, by applying a GAP POLICY (Table 2). These operations involve, for example, selling (line 15) or buying (line 24) additional energy to/from the partner, turning on/off drivable systems (lines 16&23) and interacting with an energy storage system (lines 14&25).

In summary, the combination of REOPTIMIZE and GAP POLICY parameters

---

<sup>1</sup>It is worth noting, however, that the amount of electricity bought or sold via each engaged contract may be more than the initial values proposed by the model policy, depending on the actual energy demand.

Gap	Cheapest gap policy
Positive	Cheapest storage operation (batteries/drivable/contracts)
Negative	Cheapest retrieval operation (batteries/drivable/contracts)
Gap	Conservative gap policy
Positive	Store energy surplus in batteries, then use sell contracts
Negative	Buy from engaged contracts first, then use batteries

Table 2:  $X$ -RTCS policy executed at each time slot  $d$  (inside period  $I_{t'}$ ), according to the microgrid energy gap, defined as  $\sum(\text{Production}) - \sum(\text{Consumption})$ . A positive gap (+) means there is energy surplus in the current time slot, while a negative gap (−) represents lack of energy (more power needs to be bought from the partner or produced by the microgrid).

yield 4 different look-ahead heuristics, whose behavior is determined by which CCP model predictions are used (from reoptimized model or not), along with a strategy to either fulfill demands greater than the microgrid’s own production (negative gap) or use the available energy surplus (positive gap).

Remark that the algorithm takes into account the cost of purchasing additional blocks of energy (negative imbalance) and the revenue from selling surplus energy (positive imbalance) due to deviations with respect to the forecast of energy contract usage, made in the beginning of  $X$ -RTCS. Additionally, the amount of electricity bought out of any contract  $e(\cdot)$  presumes an indirect penalization on price, since they are less attractive than settled day-ahead prices.

## 7. Experimental results

This section sets up a realistic microgrid and conducts simulations with different sets of scenarios, comprising uncertain electricity production and consumption in a given time horizon. The main objective is to evaluate the impact of adopting a robust approach for engaging in flexible energy contracts. This is achieved through the performance assessment of the RTCS approaches proposed in the previous section, based on contract decisions taken by either the deterministic or the robust CCP model solution.

### 7.1. Computational environment and simulation details

The mathematical models and numerical simulations were coded in Julia 1.6.0 using CPLEX solver 20.1.0, and their source code is available at [https://github.com/levorato/ccp\\_rtcs](https://github.com/levorato/ccp_rtcs). All experiments were performed on a workstation with an Intel Xeon CPU X5355  $\times$  8 with 64 GB RAM, under Ubuntu

---

**Algorithm 1:** RTCS algorithm that runs at each time slot  $d \in \{1, \dots, \delta^{t'}\}$ , inside time period  $I_{t'}$ .

---

**Input:** CCP model CCPM, initial CCPM solution  $X(\mathbf{y}_0, 1)$ , GAP POLICY, REOPTIMIZE  
**Result:** Set of policies  $q_c(\cdot), x_s(\cdot), h_s(\cdot), e(\cdot)$

- 1 **if** REOPTIMIZE is enabled **then**
- 2     Reoptimize CCPM with  $t_0 := t'$  and fix engaged contracts  $\bar{\mathbf{y}} = \mathbf{y}_0$ ;
- 3     Let  $\{q^{t'}, x^{t'}, g^{t'}, h^{t'}\}$  be the reoptimized CCPM solution at  $t = t_0 = t'$ ;
- 4 **else** // Use initial CCP model solution at  $t_0 = 1$
- 5     Let  $\{q^{t'}, x^{t'}, g^{t'}, h^{t'}\}$  be the initial CCPM solution at  $t = t'$ ;
- 6  $q_c^{t',d} := \lceil q_c^{t'} / \delta^{t'} \rceil, \forall c \in C_{t'};$                      // Initial contract usage according to  $\mathbf{y}_0$
- 7  $x_s^{t',d} := \max \left[ x_s^{t'}, \frac{P^{min,t'}}{P^{max,t'}} \right], \forall s \in S_D;$      // Power drivable according to CCP solution
- 8  $h_s^{t',d} := \lceil h_s^{t'} / \delta^{t'} \rceil; g_s^{t',d} := \lceil g_s^{t'} / \delta^{t'} \rceil;$      // Use batteries according to CCP solution  
      /\* Sum energy consumption/production for all devices (certain and uncertain) \*/
- 9  $gap := \sum_{s \in \hat{S}_{ND}} \hat{P}_s^{t',d} + \sum_{s \in S_{ND}} \frac{P_s^{t'}}{\delta^{t'}} + \sum_{c \in C_{t'}} q_c^{t',d} + \sum_{s \in S_D} \frac{x_s^{t',d} P_s^{t'}}{\delta^{t'}} + \sum_{s \in S_B} (h_s^{t',d} - g_s^{t',d});$
- 10 **if**  $gap > 0$  **then** // energy left over
- 11     **if** GAP POLICY = cheapest **then**
- 12         Execute dispatch operations (Charge batteries, Sell via contracts, Power drivable consumers) following smallest energy cost first;
- 13     **else** // conservative GAP POLICY
- 14          $gap := \text{Charge-batteries}(\{s \in S_B\});$
- 15          $gap := \text{Sell-energy-surplus-via-contracts}(\{c \in C_{t'} : \Pi_{t',c}^- < 0\});$
- 16          $gap := \text{Power drivable consumers}(\{s \in S_D : P^{min,t'}_s < 0\});$
- 17          $e_{t',d} := 0;$
- 18         Throw remaining energy away;
- 19 **else** // Negative gap, need for additional energy
- 20     **if** GAP POLICY = cheapest **then**
- 21         Execute operations (Turn on drivable producer, Use batteries, Consume from contracts, Consume out of contract) according to smallest cost first;
- 22     **else** // conservative GAP POLICY
- 23          $gap := \text{Turn-on-drivable-producer-devices}(\{s \in S_D : P^{min,t'}_s > 0\});$
- 24          $gap := \text{Consume-energy-via-contracts}(\{c \in C_{t'} : \Pi_{t',c}^- > 0\});$
- 25          $gap := \text{Discharge-batteries}(\{s \in S_B\});$
- 26          $e_{t',d} := gap;$                      // Consume remaining energy out of contracts if needed

---

18.04 LTS. As defined in Section 6.2, each RTCS heuristic can use either the deterministic or the robust CCP model solution as input. We denote by **Det-RTCS** the RTCS based on the deterministic model, and **Rob-RTCS** the one based on the robust budgeted model. The RTCS simulation is based on sets of realistic scenarios from the case study defined in this section.

Remember that, in order to obtain a deterministic solution for the CCP model, it is necessary to establish a fixed value for the uncertain parameters. In this study, we solved the deterministic model by using three sets of values for uncertain parameters  $\hat{P}_s$  of each system  $s \in \hat{S}_{ND}$ .

### *7.2. Microgrid in a research building in Tsukuba, Japan*

This case study involves the microgrid of a research building in Tsukuba, Japan. A multiyear dataset (Vink et al., 2019) provides microgrid statistics in full details (every second) and summarized (per hour), for the period between april 2015 and april 2018. Supplied data includes the Battery Energy Storage System (BESS) installed (active power, voltage, current, state of charge), the power generation from the four operating solar arrays, as well as purchased electricity (voltage, active power), solar irradiance, list of holidays and electricity prices (including surcharges).

Four problem instances were generated, one for each season of the year. Thus the lower and upper bounds for uncertain consumption and production were calculated as a function of the historical data for the corresponding season.

### *7.3. Problem instance generation*

The considered planning horizon comprises 24 time periods of 1 hour, each one with  $\delta^t = 6$ . Given all periods, a total of 457 contracts were proposed, inspired by Électricité de France price distribution (EDF, 2021), allowing the client to buy electricity from the partner at different quantities and costs.

Concerning uncertain devices demand and production of electricity at each time period  $t$ , historical data of the microgrid is used to calculate the lower and upper bounds of these values. Moreover, instead of applying simple min/max approach, we use the 10th and 90th quantiles to determine the  $P_{min}$  and  $P_{max}$  values, which guarantees robustness against outliers. The determination of BESS kWh price is based on the cost model of Börjesson & Larsson (2018).

### *7.4. RTCS simulation and scenario types*

Based on the production and consumption history of the Tsukuba microgrid, the simulation objective is twofold: to evaluate how the solutions provided by the two CCP models proposed (robust and deterministic) behave under uncertainty, and to assess the performance of the RTCS policies defined in Section 6.2.

A particular scenario contains, for each *uncertain system*, the realization of the uncertain electricity production (or consumption) values for each time slot, over the whole time horizon. Given a list of engaged contracts (previously obtained with the solution of the CCP model), the simulation iterates over each time step, executing the chosen RTCS policy. As explained in the previous section, at this point, real-time energy scheduling actions are taken, according to the current state of the microgrid and the realization of energy production and consumption values. Among these values, the ones concerning the *uncertain systems* are obtained through the given scenario data in the current simulation.

For the Tsukuba microgrid, an individual set of scenarios was generated for each of the four seasonal instances, based on real values of PV production and building consumption provided in the dataset. The spring instance scenarios, for example, encompass all information recorded between March 20th until June 21st, given the dataset’s 3-year time horizon.

In summary, for each microgrid instance, the simulation process consists in testing, the RTCS policies based on each CCP model solution. The combination of 2 types of gap policy (Cheapest and Conservative), with or without model reoptimization, yields a total of 4 possible *X*-RTCS procedures for each model *X*, deterministic or robust. Simulation is then performed by executing each pair of model *X* and *X*-RTCS heuristic on the proposed microgrid instances and their associated scenario groups. For each of the 4 seasonal Tsukuba instances, simulation will be executed on a specific scenario set from each season.

### *7.5. Performance of the robust solution method*

The study performed in this section analyses several cost and reliability metrics obtained from simulations of the proposed RTCS policies. By mimicking the real-time operation of the microgrid energy management system, each simulation was based on a specific solution provided by either the robust or the deterministic CCP model.

The robust CCP model under budgeted uncertainty was tested with six  $\Gamma$  budget parameter values (0%, 20%, 40%, 60%, 80% and 100%). They indicate

Instance	Deterministic / $\Phi$			Robust budget / $\Gamma$					
	0	50	100	0	20	40	60	80	100
Autumn	19,969.98	26,273.60	32,531.61	25,984.11	29,981.41	31,527.87	32,186.66	32,300.27	32,302.23
	0.07 s	0.25 s	0.36 s	0.71 s	189.20 s	209.69 s	86.03 s	64.91 s	57.86 s
Spring	18,345.28	24,429.74	30,534.44	24,161.60	27,899.25	29,398.48	30,125.96	30,294.75	30,294.95
	0.15 s	0.31 s	0.32 s	0.30 s	241.17 s	55.88 s	81.47 s	40.48 s	50.57 s
Summer	22,281.03	29,954.69	37,364.42	29,611.22	34,129.95	36,082.87	36,960.79	37,132.68	37,132.68
	0.33 s	0.29 s	0.32 s	0.84 s	2159.94 s	738.91 s	603.36 s	294.62 s	263.40 s
Winter	20,443.66	27,183.29	33,728.24	26,895.68	31,111.05	32,670.23	33,394.60	33,482.34	33,482.90
	0.04 s	0.25 s	0.28 s	0.68 s	229.54 s	68.91 s	75.76 s	60.53 s	54.43 s

Table 3: Robust *vs.* Deterministic model result comparison for different budget parameters. The first value indicates the objective function value obtained, followed by the time spent (in seconds) to obtain the optimal solution. CPLEX default optimality gap of  $10^{-4}$  was applied.

the proportion of the maximum allowed deviation of uncertain parameters regarding production or consumption of energy, as defined in Section 5.1. As a baseline for comparison, the deterministic CCP model was tested with 3 different sets of values regarding uncertain devices. When  $\Phi = 0\%$ , the model is based on the most optimistic scenario, assuming minimal consumption and maximal production for uncertain consumer and producer devices, respectively. The exact opposite situation is represented by  $\Phi = 100\%$ , apparently the most pessimistic one. Finally, the scenario where  $\Phi = 50\%$  depicts the middle interval, with average values of uncertain devices. Bearing in mind that the  $\Gamma$  and  $\Phi$  values used to parametrize the deterministic and robust models have different meanings, a general comparison will be conducted in this section to determine which model behaves best under uncertainty.

The solution statistics for each model are presented on Table 3. The obtained results show that, when solving the first-stage problem to determine the list of contracts to engage, optimal solutions for robust models with different budget parameter values can be obtained in less than an hour with an 8-core CPU.

Regarding the simulation results, according to the season of the year, for each of the 4 RTCS policies proposed in the previous section, Tables 4 and 5 present statistical measures based on the operational cost (Cost Avg, Cost Std, Cost CVaR), as well as Out of Contract (OC) energy consumption cost (OC Cost Avg), penalty frequency (i.e., the proportion of time periods where OC consumption occurred) and the State of Charge (SOC) of the microgrid’s BESS (SOC Avg and SOC Std). In robust and deterministic CCP models, higher

		Deterministic / $\Phi$			Robust budget / $\Gamma$						
		Variable	0%	50%	100%	0%	20%	40%	60%	80%	100%
autumn	cheapest	Cost Avg (\$)	94,758.0	27,638.0	31,791.0	49,191.6	34,128.8	27,919.7	29,490.5	40,486.3	31,938.6
		Cost Std (\$)	55,760.3	3,077.8	477.1	26,486.9	6,898.7	2,182.1	1,772.7	12,741.9	4,977.2
		Cost CVaR (\$)	179,591.2	32,662.8	32,382.9	92,132.1	45,220.2	31,554.8	32,396.3	60,409.8	39,906.4
	cheapest+ReOpt	OC Cost Avg (\$)	73,516.4	406.5	0.0	17,677.2	5,623.2	99.0	102.2	12,506.7	3,540.6
		Penalty Freq (%)	76.4	3.5	0.0	16.3	5.8	0.3	0.3	14.2	3.4
		SOC Avg (%)	38.2	67.7	91.7	68.2	69.8	68.2	73.4	71.9	72.5
	conservative	Cost Avg (\$)	94,486.2	27,367.2	31,223.2	46,781.5	31,941.4	27,338.6	27,530.0	39,762.5	30,758.4
		Cost Std (\$)	55,872.6	3,271.5	622.1	26,155.9	7,286.9	2,530.4	2,453.3	13,421.8	5,539.0
		Cost CVaR (\$)	179,581.4	32,607.8	32,091.1	90,519.4	43,902.0	31,479.3	31,510.4	60,727.0	39,705.3
	conservative+ReOpt	OC Cost Avg (\$)	73,128.5	406.5	0.0	15,949.0	5,121.0	99.0	99.0	13,163.7	3,457.0
		Penalty Freq (%)	75.8	3.5	0.0	15.9	6.4	0.3	0.3	16.2	4.0
		SOC Avg (%)	40.2	68.4	91.6	69.1	68.7	69.9	70.9	70.5	74.2
naive	Cost Avg (\$)	93,504.6	27,858.4	31,849.2	47,212.1	33,243.9	28,002.5	29,553.9	39,614.5	31,312.5	
	Cost Std (\$)	56,354.0	3,004.8	555.6	25,330.0	6,529.3	2,117.0	1,738.0	11,875.6	4,533.3	
	Cost CVaR (\$)	179,582.4	32,682.6	32,650.3	90,514.8	44,291.2	31,461.5	32,398.7	59,054.6	38,917.0	
naive+ReOpt	OC Cost Avg (\$)	72,042.4	392.2	0.0	15,911.4	4,617.2	78.6	79.9	11,514.0	2,795.1	
	Penalty Freq (%)	77.8	3.6	0.0	18.4	7.6	0.3	0.3	16.3	4.0	
	SOC Avg (%)	43.4	77.7	93.4	71.9	75.7	78.7	81.9	75.7	80.1	
cheapest	Cost Avg (\$)	93,207.7	27,552.1	31,300.5	45,754.8	31,276.0	27,424.1	27,561.9	37,929.5	30,126.7	
	Cost Std (\$)	56,490.5	3,187.0	709.6	25,098.8	6,823.9	2,460.5	2,479.6	12,288.9	5,000.4	
	Cost CVaR (\$)	179,577.0	32,662.5	32,374.0	88,850.8	42,866.4	31,477.5	31,600.6	58,263.8	38,498.1	
cheapest+ReOpt	OC Cost Avg (\$)	71,714.2	381.8	0.0	15,134.2	4,310.1	77.1	79.7	11,125.2	2,713.5	
	Penalty Freq (%)	77.8	3.6	0.0	18.4	7.6	0.3	0.3	16.3	4.0	
	SOC Avg (%)	44.7	80.2	93.8	73.2	75.3	81.8	81.6	76.0	82.3	
conservative	Cost Avg (\$)	94,924.7	31,022.1	33,244.7	50,149.3	35,176.8	32,654.4	32,699.1	41,556.7	35,122.0	
	Cost Std (\$)	55,737.6	1,885.5	443.0	24,725.5	5,770.0	864.4	830.7	10,828.7	3,570.1	
	Cost CVaR (\$)	179,606.9	33,874.3	33,871.2	90,187.1	45,006.2	33,929.1	33,900.6	59,656.9	41,025.8	
conservative+ReOpt	OC Cost Avg (\$)	73,858.1	280.1	0.0	17,219.9	4,297.9	42.2	38.2	10,412.0	2,650.5	
	Penalty Freq (%)	77.8	3.2	0.0	14.4	5.5	0.1	0.1	14.1	3.3	
	SOC Avg (%)	31.7	76.6	94.3	71.6	87.0	94.6	94.2	92.0	93.9	
naive	Cost Avg (\$)	82,186.0	49,631.0	29,808.7	104,241.0	30,524.7	26,182.7	27,256.6	28,428.7	28,471.7	
	Cost Std (\$)	44,527.0	12,653.1	310.9	32,307.5	4,890.4	1,823.3	2,598.0	831.8	1,643.7	
	Cost CVaR (\$)	144,445.2	68,773.0	30,209.9	147,380.1	38,129.8	29,027.2	31,491.0	29,776.1	31,088.5	
naive+ReOpt	OC Cost Avg (\$)	60,979.9	23,133.2	0.2	62,076.8	5,773.3	0.0	1,497.9	0.0	346.1	
	Penalty Freq (%)	76.1	23.7	0.1	43.9	5.6	0.0	1.9	0.0	1.9	
	SOC Avg (%)	36.1	58.6	91.6	36.3	58.7	61.1	58.1	72.6	67.0	
cheapest	Cost Avg (\$)	82,052.9	49,300.1	29,471.5	97,740.2	28,074.3	26,046.1	26,759.9	26,380.9	27,470.1	
	Cost Std (\$)	44,570.9	12,899.3	438.3	32,312.2	4,783.8	1,961.2	2,634.4	1,723.1	3,021.3	
	Cost CVaR (\$)	144,425.1	68,774.0	30,128.9	144,888.6	36,043.9	29,058.2	31,084.1	29,043.4	32,189.3	
cheapest+ReOpt	OC Cost Avg (\$)	60,764.1	23,014.2	0.2	55,391.8	4,274.0	0.0	1,066.2	0.0	1,191.8	
	Penalty Freq (%)	75.5	23.9	0.1	43.9	5.5	0.0	2.3	0.0	2.7	
	SOC Avg (%)	38.2	58.1	90.5	63.4	62.2	64.2	65.4	62.6	63.1	
conservative	Cost Avg (\$)	81,254.4	48,523.9	29,985.3	103,804.9	30,307.6	26,365.0	27,148.5	28,550.6	28,585.7	
	Cost Std (\$)	45,007.2	12,686.5	438.6	32,620.3	4,665.6	1,762.3	2,319.9	890.3	1,388.0	
	Cost CVaR (\$)	144,404.3	68,682.4	30,671.3	147,554.6	37,881.0	29,071.7	30,992.7	29,975.4	30,815.2	
conservative+ReOpt	OC Cost Avg (\$)	59,869.0	22,171.6	0.2	61,622.5	5,214.9	0.0	1,011.7	0.0	356.2	
	Penalty Freq (%)	76.9	25.7	0.1	43.9	6.9	0.0	2.3	0.0	3.6	
	SOC Avg (%)	40.6	64.0	95.4	38.3	66.0	74.7	66.4	81.6	74.4	
naive	Cost Avg (\$)	80,876.6	48,324.4	29,689.7	97,190.6	28,015.7	26,261.2	26,799.5	26,654.3	26,944.2	
	Cost Std (\$)	45,122.8	12,837.6	574.8	31,950.5	4,427.5	1,941.8	2,278.1	1,693.2	2,370.5	
	Cost CVaR (\$)	144,691.0	68,648.3	30,595.9	144,014.4	35,301.6	29,166.0	30,302.0	29,204.7	30,752.9	
naive+ReOpt	OC Cost Avg (\$)	59,446.2	22,154.8	0.2	54,914.1	3,936.4	0.0	626.5	0.0	490.8	
	Penalty Freq (%)	76.9	25.7	0.1	43.9	6.9	0.0	2.3	0.0	3.6	
	SOC Avg (%)	42.7	63.4	95.5	63.8	71.1	81.8	80.5	78.5	75.4	
cheapest	Cost Avg (\$)	82,254.6	47,094.5	32,054.0	102,186.3	33,056.5	32,106.1	31,836.7	32,405.1	31,565.9	
	Cost Std (\$)	44,485.8	9,188.1	230.2	30,518.9	3,437.6	215.9	778.6	200.8	949.0	
	Cost CVaR (\$)	144,446.5	61,597.8	32,409.6	144,268.3	38,840.6	32,439.3	33,026.5	32,705.1	32,975.9	
cheapest+ReOpt	OC Cost Avg (\$)	61,162.3	19,660.5	0.0	58,143.1	4,547.8	0.0	422.8	0.0	292.0	
	Penalty Freq (%)	76.8	23.3	0.0	41.4	4.7	0.0	1.3	0.0	1.9	
	SOC Avg (%)	31.7	61.1	92.0	49.6	84.7	93.3	94.3	96.1	86.4	
conservative	Cost Avg (\$)	82,254.6	47,094.5	32,054.0	102,186.3	33,056.5	32,106.1	31,836.7	32,405.1	31,565.9	
	Cost Std (\$)	44,485.8	9,188.1	230.2	30,518.9	3,437.6	215.9	778.6	200.8	949.0	
	Cost CVaR (\$)	144,446.5	61,597.8	32,409.6	144,268.3	38,840.6	32,439.3	33,026.5	32,705.1	32,975.9	
conservative+ReOpt	OC Cost Avg (\$)	61,162.3	19,660.5	0.0	58,143.1	4,547.8	0.0	422.8	0.0	292.0	
	Penalty Freq (%)	76.8	23.3	0.0	41.4	4.7	0.0	1.3	0.0	1.9	
	SOC Avg (%)	31.7	61.1	92.0	49.6	84.7	93.3	94.3	96.1	86.4	
naive	Cost Avg (\$)	82,254.6	47,094.5	32,054.0	102,186.3	33,056.5	32,106.1	31,836.7	32,405.1	31,565.9	
	Cost Std (\$)	44,485.8	9,188.1	230.2	30,518.9	3,437.6	215.9	778.6	200.8	949.0	
	Cost CVaR (\$)	144,446.5	61,597.8	32,409.6	144,268.3	38,840.6	32,439.3	33,026.5	32,705.1	32,975.9	
naive+ReOpt	OC Cost Avg (\$)	61,162.3	19,660.5	0.0	58,143.1	4,547.8	0.0	422.8	0.0	292.0	
	Penalty Freq (%)	76.8	23.3	0.0	41.4	4.7	0.0	1.3	0.0	1.9	
	SOC Avg (%)	31.7	61.1	92.0	49.6	84.7	93.3	94.3	96.1	86.4	

Table 4: Robust vs. Deterministic RTCS performance comparison for autumn and spring scenario groups. *Cost Avg* is the average scenario cost over all simulations. *Cost Std* represents the standard deviation of scenario cost. *Cost CVaR* is the conditional value at risk of scenario cost at 80% confidence level (i.e., the average scenario cost of the 20% highest scenario costs). *OC Cost Avg* is the average cost from Out of Contract (OC) energy consumption. *Penalty Freq* is the proportion of time periods with OC consumption. *SOC Avg* and *SOC Std* are the average and standard deviation of BESS State Of Charge (SOC).



Instance / RTCS Policy		Deterministic / $\phi$			Robust budget / $\Gamma$						
		Variable	0%	50%	100%	0%	20%	40%	60%	80%	100%
summer	cheapest	Cost Avg (\$)	125,414.5	31,732.4	36,431.7	53,796.2	52,252.5	33,014.1	60,577.1	33,982.6	33,113.3
		Cost Std (\$)	54,258.0	3,317.8	369.2	17,148.2	16,370.9	1,874.9	21,842.2	1,440.8	1,814.3
		Cost CVaR (\$)	204,123.3	37,232.9	36,896.1	79,873.1	75,714.4	36,167.0	92,785.6	36,483.6	36,171.1
	cheapest+ReOpt	OC Cost Avg (\$)	93,388.0	221.9	1.0	17,614.9	18,616.6	1.0	33,416.7	1.0	1.0
		Penalty Freq (%)	70.9	0.8	0.0	8.7	11.0	0.0	23.7	0.0	0.0
		SOC Avg (%)	34.3	63.4	92.4	58.1	63.3	68.4	62.9	74.5	67.9
	conservative	SOC Std (%)	8.8	28.3	17.2	25.9	29.9	29.1	27.1	28.4	29.1
		Cost Avg (\$)	125,259.3	31,504.4	35,613.8	49,974.0	49,528.7	31,405.1	59,809.0	31,626.9	32,008.3
		Cost Std (\$)	54,481.0	3,488.4	595.8	18,412.7	16,658.7	2,718.4	21,816.3	2,575.5	2,340.0
	cheapest+ReOpt	Cost CVaR (\$)	204,123.3	37,171.2	36,521.0	79,164.2	73,993.1	35,856.7	91,683.2	35,873.6	35,929.4
		OC Cost Avg (\$)	93,235.6	220.7	1.0	15,242.8	16,537.6	1.0	32,584.1	1.0	1.0
		Penalty Freq (%)	70.9	0.8	0.0	8.4	12.1	0.0	25.6	0.0	0.0
conservative	SOC Avg (%)	34.5	65.9	91.6	65.0	63.8	64.3	65.4	64.5	66.4	
	SOC Std (%)	8.9	26.8	17.5	26.8	27.8	27.6	26.4	28.3	28.4	
	Cost Avg (\$)	125,181.1	31,889.2	36,510.3	49,404.7	51,224.0	33,145.8	59,447.1	34,224.9	33,211.4	
conservative+ReOpt	Cost Std (\$)	54,554.2	3,106.7	491.9	17,468.4	16,023.4	1,897.4	21,113.8	1,527.3	1,821.0	
	Cost CVaR (\$)	204,123.3	36,890.4	37,270.4	77,266.5	74,756.1	36,311.4	91,313.2	36,792.5	36,245.3	
	OC Cost Avg (\$)	93,142.6	158.4	0.1	14,771.1	17,549.9	0.1	31,747.3	0.1	0.1	
naive	Penalty Freq (%)	72.1	0.8	0.0	8.7	12.9	0.0	25.7	0.0	0.0	
	SOC Avg (%)	34.9	77.9	94.9	70.5	65.6	79.0	66.3	83.3	79.7	
	SOC Std (%)	10.4	26.2	14.4	26.5	29.1	25.9	27.0	24.6	25.8	
conservative+ReOpt	Cost Avg (\$)	125,082.1	31,637.1	35,707.4	48,639.4	49,046.9	31,559.6	58,676.6	31,816.6	32,118.8	
	Cost Std (\$)	54,692.1	3,250.4	713.3	16,917.4	16,422.3	2,717.0	21,118.5	2,551.9	2,347.4	
	Cost CVaR (\$)	204,123.3	36,870.8	36,884.8	75,526.3	73,555.5	35,934.5	90,419.7	35,994.2	35,996.9	
naive	OC Cost Avg (\$)	93,047.6	133.7	0.1	14,219.1	16,191.2	0.2	31,278.8	0.1	0.1	
	Penalty Freq (%)	72.1	0.8	0.0	8.7	12.9	0.0	25.7	0.0	0.0	
	SOC Avg (%)	35.0	81.4	94.9	73.0	66.1	79.6	67.6	77.5	77.9	
conservative+ReOpt	SOC Std (%)	10.5	24.2	14.3	24.4	28.4	25.2	26.2	26.9	27.2	
	Cost Avg (\$)	122,920.1	33,652.3	34,979.3	51,728.6	51,780.1	34,840.8	61,909.9	34,979.3	34,979.3	
	Cost Std (\$)	56,068.6	2,576.3	1,351.5	16,305.2	15,575.6	1,384.6	20,688.6	1,351.5	1,351.5	
naive	Cost CVaR (\$)	204,128.2	37,882.7	37,337.4	76,893.5	74,149.4	37,233.1	92,283.5	37,337.4	37,337.4	
	OC Cost Avg (\$)	91,216.4	186.9	1.0	14,372.6	17,575.8	1.0	31,260.6	1.0	1.0	
	Penalty Freq (%)	71.7	0.7	0.0	7.9	11.1	0.0	23.7	0.0	0.0	
cheapest	SOC Avg (%)	34.0	82.0	84.2	82.9	75.0	85.5	75.4	84.2	84.2	
	SOC Std (%)	7.2	23.5	23.8	24.0	27.1	23.2	25.6	23.8	23.8	
	Cost Avg (\$)	132,265.2	35,756.3	32,997.6	62,654.2	42,897.5	34,654.3	40,181.0	41,840.9	31,675.9	
cheapest+ReOpt	Cost Std (\$)	64,239.2	4,334.7	382.5	25,296.3	11,876.2	6,460.1	9,289.5	9,835.9	1,171.8	
	Cost CVaR (\$)	215,657.7	42,303.1	33,578.3	95,339.4	59,003.5	43,499.2	52,670.7	55,120.2	33,598.4	
	OC Cost Avg (\$)	111,139.4	7,027.7	0.0	32,233.9	13,672.9	5,318.1	16,950.4	18,490.6	1.6	
conservative	Penalty Freq (%)	93.0	7.2	0.0	17.1	10.1	3.3	7.0	11.3	0.0	
	SOC Avg (%)	34.1	56.2	89.4	44.7	56.4	55.1	58.4	58.7	65.2	
	SOC Std (%)	8.8	27.0	19.8	18.0	27.4	26.8	28.1	27.8	30.1	
cheapest+ReOpt	Cost Avg (\$)	132,087.0	35,405.6	32,419.3	58,703.7	41,105.0	34,444.8	39,065.3	41,098.7	29,745.7	
	Cost Std (\$)	64,429.2	4,388.0	640.3	26,873.9	12,113.2	6,674.4	9,627.6	10,318.8	2,253.5	
	Cost CVaR (\$)	215,657.7	42,219.5	33,477.1	95,114.4	58,130.2	43,445.9	52,505.1	55,465.4	33,106.9	
conservative+ReOpt	OC Cost Avg (\$)	110,906.4	6,705.5	0.0	28,288.4	12,632.4	5,507.2	15,631.1	17,970.9	1.6	
	Penalty Freq (%)	92.7	7.0	0.0	16.5	12.0	4.0	8.2	12.5	0.0	
	SOC Avg (%)	34.7	60.3	88.3	59.7	59.4	59.9	61.8	60.4	60.0	
naive	SOC Std (%)	9.5	25.9	20.0	25.2	26.2	26.7	26.6	26.2	26.7	
	Cost Avg (\$)	132,038.9	35,177.8	33,159.8	59,530.0	41,745.8	34,138.1	39,218.5	40,828.1	31,802.2	
	Cost Std (\$)	64,453.9	3,880.3	519.4	25,427.1	11,655.2	5,903.9	8,912.2	9,403.4	1,204.6	
conservative	Cost CVaR (\$)	215,657.3	41,198.2	34,014.7	93,555.5	58,392.5	42,776.1	51,993.8	54,310.1	33,725.3	
	OC Cost Avg (\$)	110,873.7	6,205.0	0.2	29,091.6	12,353.5	4,631.4	14,886.9	16,461.3	0.2	
	Penalty Freq (%)	93.9	7.3	0.0	17.1	12.1	4.0	8.2	12.5	0.0	
cheapest	SOC Avg (%)	34.8	69.6	93.3	54.5	62.1	64.8	66.4	66.3	75.4	
	SOC Std (%)	10.8	27.7	16.3	23.4	27.7	27.3	28.2	27.5	26.4	
	Cost Avg (\$)	131,898.3	34,852.4	32,632.3	56,418.3	40,123.6	33,560.3	38,056.8	39,418.6	29,871.2	
cheapest+ReOpt	Cost Std (\$)	64,618.6	3,718.8	771.1	25,152.3	11,584.9	5,966.3	8,894.6	9,461.0	2,237.5	
	Cost CVaR (\$)	215,657.3	40,431.2	33,902.8	91,735.7	57,040.2	42,124.8	50,968.4	53,244.2	33,161.3	
	OC Cost Avg (\$)	110,708.5	5,977.7	0.2	25,970.7	11,474.1	4,397.6	13,880.9	15,464.9	0.2	
conservative+ReOpt	Penalty Freq (%)	93.9	7.3	0.0	17.1	12.1	4.0	8.2	12.5	0.0	
	SOC Avg (%)	35.5	74.4	93.6	65.4	63.9	70.5	70.1	70.0	74.4	
	SOC Std (%)	11.8	25.4	16.0	25.2	27.1	26.1	26.4	26.3	25.6	
naive	Cost Avg (\$)	132,574.1	37,499.6	33,394.3	57,904.2	43,047.4	37,680.1	41,547.7	42,897.5	33,514.3	
	Cost Std (\$)	64,059.4	2,859.5	875.8	24,685.5	10,564.7	5,178.4	8,051.1	8,416.8	875.8	
	Cost CVaR (\$)	215,659.6	42,050.3	34,880.6	93,695.3	58,027.3	45,129.7	52,614.1	54,524.4	34,990.1	
conservative+ReOpt	OC Cost Avg (\$)	111,612.8	6,121.0	0.6	25,515.2	11,529.1	5,037.4	13,619.6	15,150.6	0.6	
	Penalty Freq (%)	93.9	6.9	0.0	14.2	10.0	3.3	6.9	11.2	0.0	
	SOC Avg (%)	31.8	72.5	87.3	74.1	77.8	86.9	83.7	83.3	87.3	
naive	SOC Std (%)	0.2	27.0	21.8	23.5	25.6	22.6	25.2	24.9	21.8	

Table 5: Robust vs. Deterministic RTCS performance comparison for summer and winter scenario groups. *Cost Avg* is the average scenario cost over all simulations. *Cost Std* represents the standard deviation of scenario cost. *Cost CVaR* is the conditional value at risk of scenario cost at 80% confidence level (i.e., the average scenario cost of the 20% highest scenario costs). *OC Cost Avg* is the average cost from Out of Contract (OC) energy consumption. *Penalty Freq* is the proportion of time periods with OC consumption. *SOC Avg* and *SOC Std* are the average and standard deviation of BESS State Of Charge (SOC).

values of  $\Gamma$  or  $\Phi$  parameters, respectively, ensure improved system reliability through elevated protection against the realization of worst-case scenarios, but at the expense of increased overall cost. The above measures allow a trade-off analysis between operational cost and system reliability, which can be applied by the decision-maker to select the most appropriate model.

For the autumn season, except for the naïve RTCS policy, remark that **Rob-RTCS** solution with  $\Gamma = 40\%$  significantly improves not only the operational cost (*Cost Avg* and *Cost Std*), but also microgrid’s reliability (*Cost CVaR* metric), when compared to **Det-RTCS** solutions. In particular, when considering the best economic performance of **Det-RTCS** (*Cheapest+ReOpt* policy with  $\Phi = 50\%$ ), **Rob-RTCS** with  $\Gamma = 40\%$  achieves a reduction of 0.1% in *Cost Avg*, 22.7% in *Cost Std* and 3.5% in *Cost CVaR*.

In spring season instance, the look-ahead **Rob-RTCS** policies with  $\Gamma = 40\%$  and  $\Gamma = 80\%$  outperform the deterministic counterparts in average cost and CVaR cost metrics. When compared to the previous set of scenarios, **Rob-RTCS** performance is further improved, with  $\Gamma = 40\%$  and  $\Gamma = 80\%$  budget-based RTCS achieving the best economic performance (*Cost Avg*), with zero OC cost and thus zero penalty frequency. In this case, when compared to the **Det-RTCS** models whose policy has the lowest average cost (*Cheapest+ReOpt*), the **Rob-RTCS** with  $\Gamma = 40\%$  is 17.6% cheaper on average, with a 3.6% decrease in *Cost CVaR*.

For summer, the naïve policy is not able to offer improved results when coupled with the robust CCP model. On the other hand, the robust solutions with  $\Gamma \in \{40\%, 80\%, 100\%\}$  provide the best protection for all look-ahead RTCS policies, when compared to their deterministic counterparts. In particular, the robust solution for  $\Gamma = 40\%$  coupled with *Cheapest+ReRopt* RTCS presents the best observed economic and reliability values (*Cost Avg* = 31,405.1 and *Cost CVaR* = 35,856.7), as well as low levels of OC Cost and zero penalty frequency. It is worth noting that, besides having elevated PV electricity production, energy consumption reaches its highest levels during this season, according to the dataset.

Last, in winter season, it is possible to observe an interesting case where the maximum hedge (**Rob-RTCS** with  $\Gamma = 100\%$ ) represents the best option from the viewpoint of worst-case protection as well as economic performance. The best results were obtained with model re-optimization enabled (either *Cheapest+ReRopt* or *Conservative+ReRopt* RTCS). The robust model with  $\Gamma = 100\%$  presents the lowest *Cost CVaR* values among all models tested. It also provides the cheapest average costs (*Cost Avg*), considering all robust and deterministic models simulated. Once again, the robust-based naïve policy is not able to offer improved results when compared to **Det-RTCS**.

A statistical analysis was also performed to assess the cost difference between each pair of simulations, considering every combination of CCP model and RTCS policy. For this purpose, we applied the Wilcoxon signed-rank test (Wilcoxon, 1945), a non-parametric alternative to the paired Student's t-test, which does not depend on the assumption that the data is normally distributed. This test is based upon the ranks of the paired differences of measurements, and the *null hypothesis*  $H_0$  is that two related paired samples come from the same distribution. If valid,  $H_0$  indicates that there is no tendency for the outcome in one group of simulations to be higher or lower than in the other group. In a pair-wise comparison with a significance level  $\alpha = 0.05$ , considering all pairs of RTCS simulations, in only 3 cases it is not possible to reject the *null hypothesis*. These cases are related with the autumn, spring and summer instances, with no significant statistical difference when comparing the scenario costs of the *Conservative+ReOpt* RTCS based either on the **Det-RTCS** solution with  $\Phi = 50\%$  or on the **Rob-RTCS** with  $\Gamma = 40\%$ . All other simulation comparisons yielded P-values inferior to 0.05, which indicates there is enough evidence to reject the null hypothesis and conclude that the tested samples were likely drawn from populations with differing distributions.

As a final remark, we refer the reader to the last two measures in Tables 4 and 5. According to the average and standard deviation of BESS State Of Charge, the robust-based policies rely more on the use of batteries to regulate the microgrid's system load than **Det-RTCS**.

### 7.6. Best options for CCP model and RTCS policy

The presented results confirm the overall superiority of the RTCS simulations derived from the robust CCP model results, according to the value of the budgeted uncertainty parameter  $\Gamma$ . Such value will depend on the scenario type and, therefore, the season of the year. For the microgrid under study, an intermediate value of  $\Gamma = 40\%$  proved to be the best parameter option for the robust model during spring, summer and autumn, while the maximum hedge ( $\Gamma = 100\%$ ) fits best during winter season. It is worth noting that only the **Rob-RTCS** policies which incorporated the look-ahead mechanism obtained improved results when compared to the deterministic-based policies.

As a complimentary evaluation, based on each season and the best performing robust CCP models presented above, we now investigate the differences among the proposed RTCS policies. Once again, we turn ourselves to Tables 4 and 5, restricting our analysis to fixed values of  $\Gamma$ . For each combination of season and  $\Gamma$  value, we split the policies into 3 groups: naïve, look-ahead without model re-optimization (ReOpt) and look-ahead with re-optimization applied.

As far as the robust models are concerned, it is possible to observe that the naïve policy is not able to perform well according to cost and reliability metrics, and its simulation results are inferior to those obtained by the look-ahead policies. Regarding LA policies, both *average* and *CVaR* values of scenario cost improve in re-optimization-based policies, when compared to non-re-optimized ones. As an example, considering the summer instance, re-optimized models provide an improvement of 3% in average scenario cost and 1% in *CVaR*. Out of Contract (OC) costs also decrease in most cases. One possible explanation for this behaviour is related to how the look-ahead policy works when the CCP model is re-optimized. At each time period, the LA mechanism updates the values regarding uncertain energy parameters and linear decision rules, based on a new run of the optimization model. Using these updated predictions inside the RTCS policy seems to be more cost-effective than not using them.

A second analysis, based on Pareto frontier, can also be used to determine the best-performing policy. In Figure 2, we plot the standard deviation of




Figure 2: Winter instance: daily cost std and cost average obtained with simulations of cheapest, cheapest+ReOpt, conservative, conservative+ReOpt and naive policies, based on either deterministic or robust budget models with  $\Phi = 0\%, 50\%, 100\%$  and  $\Gamma = 0\%, 20\%, 40\%, 60\%, 80\%, 100\%$ , respectively.

the daily cost (x-axis) versus the average of this cost (y-axis) for deterministic and robust model policies, where each point denotes a specific value of  $\Phi$  or  $\Gamma$ , respectively. On each curve, the right most point corresponds to  $\Phi = 0\%$  in the deterministic-based policies or  $\Gamma = 0\%$  in the robust-based ones. Note that every point of each curve can be strictly improved in both average and std of cost by changing to a different value of  $\Gamma$ , without the need to trade off between average and std of the cost. In other words, each point is dominated by the points to its left. Therefore, the left-most part of each curve shows the Pareto frontier of cost average *vs.* cost standard deviation performance of the associated model policy. This evaluation framework can be applied to choose a suitable value of  $\Phi$  or  $\Gamma$ , making sure the system operates on the Pareto frontier.

For the winter instance, this means that, to retain the same level of average cost, the *robust budget model with conservative+ReOpt policy* achieves the lowest std (i.e., the highest reliability); or, conversely, to maintain the same level of std (i.e., reliability), this policy incurs the lowest average cost. That is, *robust budget / conservative+ReOpt* dominates every other policy.




Figure 3: Cumulative total costs and out-of-contract (OC) costs of the best deterministic (Det) and robust (Rob) CCP models (and associated policies) of each season, obtained after simulation over the whole time horizon (from January 2015 until May 2018).

Finally, in Figure 3, we present a graph which highlights some advantages of the robust model in the long run, by comparing the accumulated costs obtained after simulating the best set of deterministic and robust CCP models and policies for each season instance, over the whole time horizon (from January 2015 until May 2018). In this analysis, at the end of the simulation time horizon, the system running with the robust model decisions incurs in no out-of-contract costs as well as significantly cheaper accumulated total cost, 21% less when compared to the best deterministic model.

## 8. Concluding remarks

This work presented the Contract Collaboration Problem (CCP), a multi-contract energy trading framework based on flexible commitments, coupled with a Real-Time Command Strategy (RTCS) for usage in microgrid energy trading and scheduling. As the main component, we developed a robust model under

budgeted uncertainty which provides protection against the worst-case realization of the microgrid’s production and consumption of electricity, by presenting a cost-effective contract commitment planning for a given time horizon.

A case study was conducted on a real microgrid, with a total of four problem instances, one for each season of the year. Monte-Carlo simulations were used to assess the performance of the proposed CCP robust model solution (against the deterministic alternative), when used as input for real-time energy scheduling strategies. Relying on a set of real-world-inspired energy purchase contracts, simulation results have confirmed the efficacy of different robust-based RTCS strategies, according to scenario types. For specific protection levels, the robust RTCS was able to dominate the deterministic RTCS in all operational cost and system reliability metrics.

The main conclusions can be highlighted as follows. The CCP robust model under budgeted uncertainty provides a pool of solutions, with different protection levels, the decision-maker can choose from. The effectiveness of each robust solution will depend on the microgrid’s load profile and renewable production, which vary according to the season of the year.

There are essentially three avenues for future research. The first one is application oriented and comprises additional testing with selling contracts. In this sense, the energy exchange between multiple microgrids could be seen as a game-theoretic model. The second avenue would be extending the methodology itself, considering alternative ways of representing uncertainty in the robust program, in addition to forecasting techniques that have added improved results in similar problems. In particular, reinforcement learning could prove useful inside the RTCS, with the objective of making better decisions on energy-related operations. For example, the scheduling heuristic could predict which kind of operation would be better suited at a given period (e.g. store or sell surplus energy; retrieve from storage or buy from engaged contracts). Finally, a third path involves model refinements, such as the addition of ramping constraints for generators and an improved battery efficiency and degradation model.

## Acknowledgments

Research conducted during a visiting period at Avignon Université by means of a Doctoral Exchange Program sponsored by CAPES Foundation, Ministry of Education, Brazil (Process No.: 88881.187708/2018-01).

## References

- Agra, A., Christiansen, M., Figueiredo, R. M. V., Hvattum, L. M., Poss, M., & Requejo, C. (2013). The robust vehicle routing problem with time windows. *Computers & OR*, *40*, 856–866.
- Aussel, D., Brotcorne, L., Lepaul, S., & von Niederhäusern, L. (2020). A trilevel model for best response in energy demand-side management. *European Journal of Operational Research*, *281*, 299–315.
- Ben-Tal, A., Goryashko, A., Guslitzer, E., & Nemirovski, A. (2004). Adjustable robust solutions of uncertain linear programs. *Mathematical Programming*, *99*, 351–376.
- Bertsimas, D., & Sim, M. (2004). The price of robustness. *Operations Research*, *52*, 35–53.
- Börjesson, P., & Larsson, P. (2018). *Cost models for battery energy storage systems*. Bachelor's thesis KTH, Energy Technology.
- Cazalet, E., De Marini, P., Price, J., Woychik, E., & Caldwell, J. (2016). Transactive energy models. *NIST transactive energy challenge: business and regulatory models working group*, (pp. 1–44).
- Colson, C. M., & Nehrir, M. H. (2013). Comprehensive Real-Time Microgrid Power Management and Control With Distributed Agents. *IEEE Transactions on Smart Grid*, *4*, 617–627. doi:10.1109/TSG.2012.2236368.
- Correa-Florez, C. A., Michiorri, A., & Kariniotakis, G. (2019). Comparative analysis of adjustable robust optimization alternatives for the participation of aggregated residential prosumers in electricity markets. *Energies*, *12*, 1019.
- Craparo, E. et al. (2017). A robust optimization approach to hybrid microgrid operation using ensemble weather forecasts. *Applied Energy*, *201*, 135–147. doi:10.1016/j.apenergy.2017.05.068.
- Duan, L., & Zhang, R. (2013). Dynamic contract to regulate energy management in microgrids. *2013 IEEE International Conference on Smart Grid Communications, SmartGridComm 2013*, (pp. 660–665). doi:10.1109/SmartGridComm.2013.6688034.
- EDF (2021). *EDF - Fiche descriptive de l'offre «Tarif Bleu»*. URL: [https://particulier.edf.fr/content/dam/2-Actifs/Documents/Offres/Grille\\_prix\\_Tarif\\_Bleu.pdf](https://particulier.edf.fr/content/dam/2-Actifs/Documents/Offres/Grille_prix_Tarif_Bleu.pdf) (accessed June 16, 2021).
- Gorissen, B. L., Yanikoğlu, I., & den Hertog, D. (2015). A practical guide to robust optimization. *Omega (United Kingdom)*, *53*, 124–137. doi:10.1016/j.omega.2014.12.006. arXiv:1501.02634.
- Hu, W., Wang, P., & Gooi, H. B. (2018). Toward optimal energy management of microgrids via robust two-stage optimization. *IEEE Transactions on Smart Grid*, *9*, 1161–1174. doi:10.1109/TSG.2016.2580575.
- Huang, Y. et al. (2014). Adaptive electricity scheduling in microgrids. *IEEE Transactions on Smart Grid*, *5*, 270–281. doi:10.1109/TSG.2013.2282823. arXiv:arXiv:1301.0528v1.



- Hussain, A. et al. (2016). Optimal operation of tri-generation microgrids considering demand uncertainties. *International Journal of Smart Home*, 10, 131–144. doi:10.14257/ijsh.2016.10.10.13.
- Jabr, R. A. (2013). Adjustable robust opf with renewable energy sources. *IEEE Transactions on Power Systems*, 28, 4742–4751.
- Joe-Wong, C., Sen, S., Ha, S., & Chiang, M. (2012). Optimized day-ahead pricing for smart grids with device-specific scheduling flexibility. *IEEE Journal on Selected Areas in Communications*, 30, 1075–1085. doi:10.1109/JSAC.2012.120706.
- Khorasany, M., & Razzaghi, R. (2021). Microgrids and local markets. *Microgrids: Advances in Operation, Control, and Protection*, (pp. 151–177).
- Lasseter, R., & Paigi, P. (1998). Microgrid: a conceptual solution. In *2004 IEEE 35th Annual Power Electronics Specialists Conference (IEEE Cat. No.04CH37551)* (pp. 4285–4290). IEEE volume 1998-June. doi:10.1109/PESC.2004.1354758.
- Livorato, M., Figueiredo, R., Frota, Y., Jouglet, A., & Savourey, D. (2019). Real-time command strategies for smart grids based on the robust contract-based collaboration problem. In *International Network Optimization Conference-INOC 2019*.
- Lorca, A., Sun, X. A., Litvinov, E., & Zheng, T. (2016). Multistage adaptive robust optimization for the unit commitment problem. *Operations Research*, 64, 32–51.
- Mitter, S., Dahleh, M., & Roozbehani, M. (2010). Dynamic Pricing and Stabilization of Supply and Demand in Modern Power Grids. *Smart Grid Communications (SmartGridComm)*, (pp. 543–548).
- Mohammadi, S. et al. (2017). Optimally operating microgrids in the presence of electric vehicles and renewable energy resources. *Smart Grid Conference, SGC 2015*, (pp. 66–72). doi:10.1109/SGC.2015.7857392.
- Morstyn, T., Teytelboym, A., & McCulloch, M. D. (2019). Bilateral contract networks for peer-to-peer energy trading. *IEEE Transactions on Smart Grid*, 10, 2026–2035. doi:10.1109/TSG.2017.2786668.
- Narayan, A., & Ponnambalam, K. (2017). Risk-averse stochastic programming approach for microgrid planning under uncertainty. *Renewable Energy*, 101, 399–408.
- Nguyen, T. A., & Crow, M. L. (2016). Stochastic Optimization of Renewable-Based Microgrid Operation Incorporating Battery Operating Cost. *IEEE Transactions on Power Systems*, 31, 2289–2296. doi:10.1109/TPWRS.2015.2455491.
- Olivella-Rosell, P. et al. (2018). Optimization problem for meeting distribution system operator requests in local flexibility markets with distributed energy resources. *Applied Energy*, 210, 881–895. doi:10.1016/j.apenergy.2017.08.136.
- Ottesen, S. et al. (2013). Demand side operational flexibility - A holistic stochastic optimization model for flexible consumers and prosumers. *IET Conference Publications*, 2013, 10–13. doi:10.1049/cp.2013.0954.
- Ruiz Duarte, J. L., & Fan, N. (2019). Operations of a microgrid with renewable energy integration and line switching. *Energy Systems*, 10, 247–272. doi:10.1007/s12667-018-0286-8.
- Siano, P. (2014). Demand response and smart grids – a survey. *Renewable and sustainable energy reviews*, 30, 461–478.

- Soyster, A. L. (1973). Convex programming with set-inclusive constraints and applications to inexact linear programming. *Operations research*, 21, 1154–1157.
- Su, W., Wang, J., & Roh, J. (2014). Stochastic energy scheduling in microgrids with intermittent renewable energy resources. *IEEE Transactions on Smart Grid*, 5, 1876–1883. doi:10.1109/TSG.2013.2280645.
- Tal, A. B., Golany, B., Nemirovski, A., & Vial, J.-P. (2003). Supplier-retailer flexible commitments contracts: A robust optimization approach, .
- Van Ackooij, W., De Boeck, J., Detienne, B., Pan, S., & Poss, M. (2018). Optimizing power generation in the presence of micro-grids. *European journal of operational research*, 271, 450–461.
- Vink, K., Ankyu, E., & Koyama, M. (2019). Multiyear microgrid data from a research building in tsukuba, japan. *Scientific data*, 6, 1–9. doi:10.1038/sdata.2019.20.
- Wang, R., Wang, P., & Xiao, G. (2015). A robust optimization approach for energy generation scheduling in microgrids. *Energy Conversion and Management*, 106, 597–607. doi:10.1016/j.enconman.2015.09.066.
- Warrington, J., Hohl, C., Goulart, P. J., & Morari, M. (2015). Rolling unit commitment and dispatch with multi-stage recourse policies for heterogeneous devices. *IEEE Transactions on Power Systems*, 31, 187–197.
- Wilcoxon, F. (1945). Individual comparisons by ranking methods. *Biometrics Bulletin*, 1, 80–83. URL: <http://www.jstor.org/stable/3001968>. doi:10.2307/3001968.
- Wolsey, L. A., & Nemhauser, G. L. (1999). *Integer and combinatorial optimization* volume 55. John Wiley & Sons.
- Wu, T. et al. (2013). Coordinated energy dispatching in microgrid with wind power generation and plug-in electric vehicles. *IEEE Transactions on Smart Grid*, 4, 1453–1463. doi:10.1109/TSG.2013.2268870.
- Wu, X., Hu, X., Yin, X., & Moura, S. J. (2018). Stochastic Optimal Energy Management of Smart Home With PEV Energy Storage. *IEEE Transactions on Smart Grid*, 9, 2065–2075. doi:10.1109/TSG.2016.2606442.
- Wu, X. et al. (2016). Stochastic control of smart home energy management with plug-in electric vehicle battery energy storage and photovoltaic array. *Journal of Power Sources*, 333, 203–212. doi:10.1016/j.jpowsour.2016.09.157.
- Zachar, M., & Daoutidis, P. (2017). Microgrid/Macrogrid Energy Exchange: A Novel Market Structure and Stochastic Scheduling. *IEEE Transactions on Smart Grid*, 8, 178–189. doi:10.1109/TSG.2016.2600487.
- Zhang, Y., Gatsis, N., & Giannakis, G. B. (2012). Robust distributed energy management for microgrids with renewables. *IEEE SmartGridComm 2012*, (pp. 510–515). doi:10.1109/SmartGridComm.2012.6486036.
- Zhang, Y., Gatsis, N., & Giannakis, G. B. (2013). Robust energy management for microgrids with high-penetration renewables. *IEEE Transactions on Sustainable Energy*, 4, 944–953. doi:10.1109/TSTE.2013.2255135.