



Integrated metrology devices dedicated to transient Harman measurement of silicon nano-meshes

Hafsa Ikzibane, Jon Canosa, Emmanuel Dubois, Jean-François Robillard

► To cite this version:

Hafsa Ikzibane, Jon Canosa, Emmanuel Dubois, Jean-François Robillard. Integrated metrology devices dedicated to transient Harman measurement of silicon nano-meshes. Nanoscale and Microscale Heat Transfer VII - Eurotherm, May 2022, Palermo, Italy. hal-03870513

HAL Id: hal-03870513

<https://hal.science/hal-03870513>

Submitted on 24 Nov 2022

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

Integrated metrology devices dedicated to transient Harman measurement of silicon nano-meshes

Hafsa Ikzibane¹, J. Canosa¹, Emmanuel Dubois¹ and Jean-François Robillard¹

¹ Univ. Lille, CNRS, Centrale Lille, Junia, Univ. Polytechnique Hauts-de-France, UMR 8520 - IEMN – Institut d’Electronique de Microélectronique et de Nanotechnologie, F-59000 Lille, France

In thermoelectricity, silicon nanostructures represent an interesting alternative to conventional thermoelectric materials due to Si abundance, non-toxic nature and its compatibility with CMOS technology. Researchers have investigated methods to enhance the silicon figure of merit zT by increasing the σ/κ ratio; decreasing the thermal conductivity κ by (i) using nanometric structure such as thin membranes [1,2,3] or nanowires [4,5], (ii) roughening [5,6], (iii) oxidization of the surface [7] achieved relatively low value of κ . Yet, few experimental measurements of zT in crystalline silicon nano-objects were presented with important data dispersion (Figure 1). Usually, the thermoelectric figure of merit is obtained through independent measurement of materials transport properties (κ , σ and S). The uncertainty of zT can easily reach 50% considering that each parameter has an uncertainty of 5% to 20% [8]. Harman’s technique [9] is a simple and rapid method to measure zT directly in bulk materials. In this work, we propose an adaptation of the transient Harman technique to suspended crystalline nanomembranes. Additionally, following [10], a correction factor taking into account radiation, contact resistances and Joule effect is determined. Finally, we present a device implementation of the method that enable direct access to zT through purely electrical measurements without relying on separate measurements of transport parameters.




Figure 1: Reported values of zT for crystalline silicon planar configurations.

- [1] J. Tang *et al.*, Nano Lett. **10**, pp. 4279–4283 (2010).
- [2] M. Haras *et al.*, IEEE Electron Device Letters, **37**, 1358 (2016).
- [3] P. Ferrando-Villalba *et al.*, Nanomaterials, **9**, 653 (2019).
- [4] A. I. Boukai, *et al.*, Nature, **451**, 168–171 (2008).
- [5] A. I. Hochbaum *et al.*, Nature, **451**, 163–167 (2008).
- [6] X. Huang *et al.*, ACS Appl. Mater. Interfaces, **11**, 34394–34398 (2019).
- [7] A. George *et al.*, ACS Appl. Mater. Interfaces, **11**, 12027 (2019).
- [8] G. J. Snyder and E. S. Toberer, Nat. Mater., **7**, 7105–114, (2008).
- [9] T. C. Harman, J. Appl. Phys., **29**, 1373–1374 (1958).
- [10] B. Kwon *et al.*, Rev. Sci. Instrum. **85**, 045108 (2014).