



HAL
open science

Design and implementation of an experimental DC microgrid for energy self-sufficient isolated sites

Olivia Bory Devisme, Frédéric Aicalapa, Denis Genon-Catalot, Pierre-Olivier Lucas de Peslouan, Jean-Pierre Chabriat

► To cite this version:

Olivia Bory Devisme, Frédéric Aicalapa, Denis Genon-Catalot, Pierre-Olivier Lucas de Peslouan, Jean-Pierre Chabriat. Design and implementation of an experimental DC microgrid for energy self-sufficient isolated sites. Journées couplées GDR SEEDS JCGE 2022, Jun 2022, Le Croisic, France. hal-04079688

HAL Id: hal-04079688

<https://hal.science/hal-04079688>

Submitted on 24 Apr 2023

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

Design and implementation of an experimental DC microgrid for energy self-sufficient isolated sites

Olivia BORY DEVISME*¹, Frédéric ALICALAPA¹, Denis GENON-CATALOT², Pierre-Olivier LUCAS DE PESLOUAN¹, Jean-Pierre CHABRIAT¹

*Contact : olivia.bory-devisme@univ-reunion.fr


¹ ENERGY-lab, Université de la Réunion, 15 Av. René Cassin CS 92003, 97400 Saint-Denis Cedex 9, La Réunion, France
² LCIS, Université de Grenoble, 50 rue Barthélémy de Laffemas CS 10054, 26902 Valence cedex 9, France

ABSTRACT


In the context of **climate change**, the French law on energy transition for green growth (LTECV) has set a target of **electrical autonomy** for non-interconnected areas such as Reunion Island by 2030. Despite the significant increasing use of electricity produced by **solar panels**, the energy losses due to transport and the multiple conversions of sources from direct current (DC) to alternating current (AC) and vice versa, considerably reduce the **electrical yield**. If we go back to **Edison's proposal**, a DC electrical architecture has many advantages in the case of local energy production since energy losses in conversions and transport are considerably **reduced**. In order to **quantify** precisely with measures potential energy gains of a DC-DC architecture in comparison to a classical DC-AC-DC architecture, currently deployed for isolated sites, the objectives of this project are to deploy a **DC measurement bench not backed up** by generators and then develop a **predictive EMS (Energy Management System)** including data from environmental indoor and outdoor sensors and PoE (Power Over Ethernet) drivers for each equipments.

Keywords : DC microgrid, solar energy, storage, isolated sites, PoE (Power Over Ethernet), EMS (Energy Management System).



COMPARATIVE TESTS PLANNED



DC EXPERIMENTAL TEST BENCH



RESULTS AND PERSPECTIVES



First measurements carried out made it possible to highlight a percentage of **62%** of the energy consumption linked to conversions for lighting, within a **DC-AC-DC** electrical architecture. The perspectives of the project consist in including in the EMS other types of electrical loads and propose a **predictive control model** based on the available **solar resource**. This model will also have to integrate **hybrid storage** (battery, hot water, hydrogen reserve) in order to optimize the battery drain.

Note : 50% is the average value fixed by drivers to reach a light comfort between 300 and 500 lux, depending of dimming light and presence during the day.