



**HAL**  
open science

## Applied superconductivity for the electric grid

Bruno Douine, Kévin Berger, Ghazi Hajiri, Yanis Laïb, Loïc Queval, Frederic Trillaud

► **To cite this version:**

Bruno Douine, Kévin Berger, Ghazi Hajiri, Yanis Laïb, Loïc Queval, et al.. Applied superconductivity for the electric grid. Symposium on Advanced Technologies in Electrical Systems (SATES 2023), Mar 2023, Arras, France. hal-04147725

**HAL Id: hal-04147725**

**<https://hal.science/hal-04147725v1>**

Submitted on 1 Jul 2023

**HAL** is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.



## Applied superconductivity for the electric grid

Bruno DOUINE<sup>1</sup>, Kevin BERGER<sup>1</sup>, Ghazi HAJIRI<sup>1</sup>, Yanis LAIB<sup>1</sup>, Loïc QUEVAL<sup>2</sup>, Frédéric TRILLAUD<sup>3</sup>

<sup>1</sup>Université de Lorraine, GREEN, F-54000 Nancy, France. <sup>2</sup>Université Paris-Saclay, CentraleSupélec, GeePs, 91192 Gif-sur-Yvette, France. <sup>3</sup>Instituto de Ingeniería, National Autonomous University of Mexico, Mexico.

[bruno.douine@univ-lorraine.fr](mailto:bruno.douine@univ-lorraine.fr)

**Objective** – This paper discusses the application of high temperature superconducting (HTS) devices in the electric grid. It first introduces the commercial HTS materials commonly used for grid applications. Then, three superconducting devices are discussed: the HTS cable to transmit high power at low voltage, the superconducting fault current limiter (SFCL) used in AC and DC power systems to limit fault currents, and the superconducting magnetic energy storage (SMES) to store energy. Some current projects, particularly in France, are presented.

**Keywords** – High temperature superconductor, electric grid, HTS cable, Superconducting fault current limiter, Superconducting magnetic energy storage.

### 1. Introduction

In this short paper, the two main types of HTS materials used for power system applications are introduced. Then, three HTS devices for the electric grid that are at the early stage of commercialization are presented: the HTS power cable, the Superconducting Fault Current Limiter (SFCL) and the Superconducting Magnetic Energy Storage (SMES).

### 2. HTS materials for the electric grid

There are two main types of HTS materials used for power system applications: BSCCO and REBCO [1]. They come either in bulk or in tape form. In this article, we focus only on HTS tapes because they form the basis of coils and cables. BSCCO and REBCO HTS tapes have different architectures: BSCCO tapes consist of BiSrCaCuO filaments embedded in a silver matrix, while REBCO tapes consist of different layers including a micrometer thick REBaCuO layer (RE for Rare earth). They can both be used at 77 K, the temperature of liquid nitrogen (LN<sub>2</sub>), which has the particularity of being an electrical insulator.




Figure 1 - Left: BSCCO tapes from Sumitomo, Japan. Middle: REBCO tape from Fujikura, Japan. Right: REBCO tapes from SuperOx, Russia.

### 3. HTS devices for the electric grid

The HTS power cable is a popular application of HTS materials for power systems. This is illustrated by various projects around the world [2,3]: LIPA, Ampacity, COMED, Superlink, etc. A French project named SuperRail between

SNCF Réseau, Nexans, Absolut System, GREEN and GeePs is ongoing. The goal of this project is to install a DC HTS cable system to feed the Montparnasse railway station in Paris. The structure of the HTS cable is illustrated in figure 2. It will be made with commercial REBCO tapes.



Figure 2 - View of the SuperRail DC HTS power cable (3500 A, 1500 V) [11].

The resistive Superconducting Fault Current Limiter (r-SFCL) has a strong industrial potential. It consists of a long length of HTS tapes wound as a non-inductive coil (Figure 3). The HTS changes from a superconducting state to a resistive state when the current passes a threshold, called critical current. Today, it is mainly used in AC grids [4-6]. A French project between GeePs, RTE and GREEN in collaboration with the Institute of Engineering of the UNAM, in Mexico, has been carried out to study the feasibility of using the SFCL as a Superconducting Power filter in DC grids [7-10].




Figure 3 - Left: non-inductive coil for SFCL ( $\phi 690$  mm) [10]. Right: Inductive coil for SMES ( $\phi 240$  mm) [12].


The Superconducting Magnetic Energy Storage (SMES) is one of the solutions to store electric energy in the electric grid. The idea is to inject a current into a large inductive superconducting coil (Figure 3) to store the energy as magnetic energy. By short-circuiting the coil by a superconducting switch, the current can flow without losses. The Institut Néel/G2Elab is working on the realization of REBCO magnets, within the framework of the BOSSE project, which aims at the realization of a REBCO magnet of 12 T / 1 MJ used as SMES [12].

## 4. Results and discussions

The current cost of HTS tapes remains an obstacle for industrial applications for power grids, but the prospects for reducing this cost in the medium term are very promising and the cost can be balanced by the technical aspects. Beyond that, the HTS device is sometimes the only technical solution for the application requirements.

## 5. Bibliography

- [1] A. P. Malozemoff, J. Mannhart, and D. Scalapino, "High temperature superconductors get to work," *Physics Today*, pp. 41–47, Apr. 2005.
- [2] J. F. Maguire, F. Schmidt, F. Hamber, and T. Welsh, "Development and demonstration of a long length HTS cable to operate in the long island power authority transmission grid," *IEEE Trans. Appl. Supercond.*, vol. 15, no. 2, pp. 1787–1792, Jun. 2005.
- [3] H. Takigawa et al., "The installation and test results for Albany HTS cable project," *Physica C*, no. 463, pp. 1127–1131, 2017.
- [4] S. Elschner et al., "ENSYSTROB—Resistive fault current limiter based on coated conductors for medium voltage application," *IEEE Trans. Appl. Supercond.*, vol. 21, no. 3, pp. 1209–1211, Jun. 2011.
- [5] S. Elschner et al., "ENSYSTROB—Design, manufacturing and test of a 3-phase resistive fault current limiter based on coated conductors for medium voltage application," *Physica C*, vol. 482, pp. 98–104, 2012.
- [6] M. Noe, A. Hobl, P. Tixador, L. Martini, and B. Dutoit, "Conceptual design of a 24 kV, 1 kA resistive superconducting fault current limiter," *IEEE Trans. Appl. Supercond.*, vol. 22, no. 3, id. 5600304, Jun. 2012.

- 
- [7] G. B. Huang, B. Douine, K. Berger, G. Didier, I. Schwenker, and J. Lévêque, "Increase of stability margin in embedded DC electric grid with superconducting stabilizer," *IEEE Trans. Appl. Supercond.*, vol. 26, no. 4, id. 5000304, Jun. 2016.
- [8] L. Quéval, F. Trillaud, B. Douine, "DC grid stabilization using a resistive superconducting fault current limiter," *Intl. Conf. on Components and Systems for DC grids (COSYS-DC 2017)*, Grenoble, France, Mar. 2017.
- [9] F. Trillaud, B. Douine, and L. Quéval, "Superconducting power filter for aircraft electric DC grids," *IEEE Trans. Appl. Supercond.*, vol. 31, no. 5, id. 3700405, Aug. 2021.
- [10] B. Douine, L. Quéval, F. Trillaud, S. Fawaz, H. Menana, I. Schwenker, O. Despouys, and N. Ivanov, "Characterization of a Superconducting Power Filter for Embedded Electrical Grid Application," *IEEE Trans. On Appl. Supercond.*, vol. 32, no. 4, Jun. 2022.
- [11] "Première mondiale à la gare Montparnasse : Nexans installe des câbles supraconducteurs pour renforcer et sécuriser l'alimentation électrique," Jun. 2022. [online: <https://www.nexans.fr/fr/newsroom/news/details/2022/06/a-world-first-in-France-at-montparnasse-train-station-nexans-installs-superconducting-cables.html>]
- [12] A.-J. Vialle, "Towards very high energy density insulated Rare-EarthBaCuO magnets" PhD thesis, Université Grenoble Alpes, Institut Néel, Grenoble, France, 2022.