

# A switching control strategy based on alkalinity to optimize biogas outflow in the start-up of an anaerobic digester

C.E. Robles Rodriguez, Eric Latrille, Jérôme Harmand, V Alcaraz-González, Víctor Alvarez-González, J P Steyer

# ► To cite this version:

C.E. Robles Rodriguez, Eric Latrille, Jérôme Harmand, V Alcaraz-González, Víctor Alvarez-González, et al.. A switching control strategy based on alkalinity to optimize biogas outflow in the start-up of an anaerobic digester. 11th IWA conference on instrumentation control and automation, Sep 2013, Narbonne, France. hal-04188385

# HAL Id: hal-04188385 https://hal.science/hal-04188385

Submitted on 25 Aug 2023

**HAL** is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers. L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

# A switching control strategy based on alkalinity to optimize biogas outflow in the start-up of an anaerobic digester

C.E. Robles-Rodríguez\*\*, E. Latrille\*, J. Harmand\*, V. Alcaraz-González\*\*, V. González-Álvarez\*\*, J.P. Steyer \*

\* INRA, UR0050, Laboratoire de Biotechnologie de l'Environment, Avenue des Etangs, F-11100, Narbonne, France, <u>eric.latrille@supagro.inra.fr</u>, steyer@supagro.inra.fr

\*\*Department of Chemical Engineering, CUCEI-University of Guadalajara, 1454. Blvd. M. García Barragán, CP. 44430. Guadalajara, Jalisco, México, <u>ceroblesro@gmail.com</u>, victor.alcaraz@cucei.udg.mx

#### Abstract

This paper deals with the control of the start-up phase in anaerobic digestion systems by using monitoring parameters already implemented that have been coupled to the control law. Methane yield, as well as methane flow rate, and the ratio of intermediate over total alkalinity have been used as control parameters. These measurements have been included in a switching control strategy to drive the process toward a steady state in which biogas production is optimized avoiding accumulation of volatile fatty acids. Experimental validation of this control strategy has been performed from the results obtained using a 358 litter fixed bed anaerobic digester treating industrial winery wastewater.

Keywords: Switching control; alkalinity ratio; methane flow rate, anaerobic digestion.

### **INTRODUCTION**

It is well know that anaerobic digestion (AD) is a very well adapted biological process for treating agricultural wastewater. AD indeed has several benefits: (i) capability of reducing organic matter; (ii) low operational costs; (iii) small space requirements; and (iv) low sludge production. These features offer widespread opportunities for nutrient and energy recovery. Several monitoring and automatic control strategies have been proposed over the years to optimize AD processes. They include, for example, fuzzy logic (Estaben *et al.*, 1997), robust adaptive control by using interval observers (Alcaraz-González *et al.*, 2005), total alkalinity control (Mendez-Acosta *et al.*, 2010) and adaptive control with unknown kinetics (Mailleret *et al.*, 2004). Steyer *et al.*, (2006) have described different control configurations that are directly linked to data, models, and knowledge of the process. Moreover, in those configurations their performance were analyzed regarding their efficiency in rejecting disturbances, changes of set-points, and their capability of managing non linearities and uncertainties.

Most of the control strategies have been validated for AD processes operated in continuous mode for a long time, but only few of them have been applied to the startup phase. The typical start-up phase has been shown to be very long (several weeks or even months, depending on what process technology is used) with a strong impact on the performance and stability of the reactor (Michaud *et al.*, 2002). In order to monitor the optimal operation of the start-up phase, methane yield has been suggested as a good indicator. Some values of methane yield can be found for soft drinks (Borja and Banks, 1994), and wine distillery wastewater in different conditions (Balaguer *et al.*, 1997).

Regarding the start-up phase, Sbarciog *et al.*, (2012) have proposed a simple control strategy by switching the dilution rate between a maximum and a minimum value to optimize the biogas production. This approach implies the use of the model AM2

proposed by Bernard *et al.*, (2001a) to calculate an optimal dilution rate  $(D_{opt})$  which is reached at the equilibrium point.

Other control parameters that have been used to monitor AD processes are the ratio of total alkalinity (TA), partial alkalinity (PA) or intermediate alkalinity (IA) over volatile fatty acids (VFA) concentration. The control of these parameters enable to guarantee the buffer capacity of the system due to bicarbonate concentration and to maintain the pH close to neutral (Boe, *et al.*, 2010). Different ratios have been considered in the literature. For instance, the ratio VFA/TA has been established to take values of 0.1 to 0.35 (Zickefoose and Hayes, 1976); the ratio IA/PA has been established as IA/PA< 0.3 (Ripley *et al.*, 1986); and the ratio IA/TA as IA/TA  $\leq$  0.3 (Bernard *et al.*, 2001b). Hence, following the control law proposed by Sbarciog *et al.*, (2012) and taking into account that in the start-up phase there is a low production of  $CO_2$ , this work proposes a higher but more conservative value of the ratio IA/TA as another control parameter to optimize the biogas outflow and avoid accumulation of volatile fatty acids.

### **MATERIALS AND METHODS**

# Anaerobic digestion system

The pilot plant used in this study consisted in a continuous anaerobic fixed-bed reactor with a total volume of 0.358 m<sup>3</sup>. The anaerobic digester is jacketed and connected to a heating system allowing temperature control. A recirculation system going from the bottom to the top was used to improve stirring conditions and to avoid gas accumulation inside the digester. The pilot plant is instrumented and automated using ODIN software (INRIA, Sophia-Antipolis, France). Raw industrial winery wastewater was used to feed the system. The operation conditions were set to a controlled temperature of  $35^{\circ}$ C and a pH of 6.8. Volatile fatty acid concentrations were measured by Anasense<sup>TM</sup> titrimeter sensor.

# Design of the control law

The aim of the control law proposed in this paper is to reach a stable steady state in which the coexistence of the two bacterial populations is possible together with high COD removal efficiency levels and a high biogas production. High dilution rates help to achieve this purpose, but the start-up of a bioreactor at this condition can lead the system to VFA accumulation. Hence, low dilution rates must be used to operate the start-up, which can lead to a low biogas production. In this work we propose the use of the ratio  $\alpha$ =IA/TA as a measurement of the operational stability in order to prevent accumulation of VFA.

Three values of dilution rates (D) have been predetermined as follows:  $D_{minTA}=0.15$ ,  $D_{min}=0.3$ , and  $D_{max}=0.5$ , where the first one represents a low dilution rate to avoid VFA accumulation due to the maximum ratio  $\alpha_{max}=(IA/TA)_{max}$ ; and the other two are the ones proposed by Sbarciog *et al.*, (2012).

The switching strategy is based on the two following conditions:

- [1] The ratio  $\alpha$  must be maintained below  $\alpha_{max}$  ( $\alpha < \alpha_{max}$ ).
- [2] Methane flow rate must not decrease more than 10% when [1] is fulfilled.

In order to avoid the wash out of the methanogenic bacteria at the early start-up, the bioreactor is initially operated at  $D_{min}$  until [1] or [2] faults. It is important to remark that this control law is based mainly on the ratio IA/TA. Therefore, if condition [1] is not fulfilled, the dilution rate is reduced to  $D_{minTA}$  and the system is operated under

this condition until [1] is reached again. Thus, the control law is only based on methane flow rate (condition [2]) by switching D between  $D_{max}$  and  $D_{min}$ .

The success of this strategy depends on the proper choice of the predetermined dilution rates, the value of  $\alpha_{max}$ , and the threshold fixed in condition [2]. Moreover, a moving mean was used to filter the maximum methane flow rate when switching from  $D_{max}$  to  $D_{min}$  in order to prevent a high frequency bang-bang behaviour.

### **RESULTS AND DISCUSSION**

The control law was implemented in the digester start-up for a time period of 49 days. The ratio  $\alpha_{max}$  was set to 0.4 at the beginning. This value is close to the one proposed by Ripley *et al.*, 1986 for normal operating conditions. However, it was changed to 0.6 in day 6 in order to compensate the effect of the low production of  $CO_2$  (see Figure 1, days 9 to 24). In this figure, there are 2 maintenance periods identified as M1 and M2.



Figure 2 (a) VFA concentration through the action of control law. (b) Input and output conditions of organic matter (COD).

After M1, the control law was evaluated regarding the parameter  $\alpha$ . Even though the system was operated with  $D_{minTA}$ , VFA concentration increased (see Figure 2 (a)). Thus,  $D_{minTA}$  was set to zero and  $\alpha$  was changed to 0.55 in order to guarantee a value below 5000 mEq/L of VFA. The switching strategy was tested changing the inflow concentration of COD. The combined effect of both control variables is shown from day 41 to 49. These results show that methane outflow was not increased to a maximum because the average dilution rate was maintained in low values.

Furthermore, when pH was regulated and a ratio of  $\alpha = 0.55$  was considered, the system was stabilized giving high efficiencies of COD removal of 70%.

# CONCLUSIONS

The switching strategy shows that it is possible to use free model control laws to guarantee stability in the start-up of anaerobic digesters. An optimal value for IA/TA was found to be IA/TA≤0.55 when pH is controlled and low dilution rates are used. Besides, it was demonstrated that the chosen monitoring parameters are efficient, but their capability can be optimized combining them in experimental implementation. For this control law it was observed that methane flow rate is robust instead of maximized when it is subjected to disturbances.

# ACKNOWLEDGES

This work was partially supported by Projects BITA-PIRSES-GA-2011-295170, CB-2008-01/101971 and FORDECYT/116655.

# REFERENCES

- Alcaraz-González, V.; Harmand, J.; Rapaport, A.; Steyer, J.; González-Álvarez, V. and Pelayo-Ortiz, C. 2005. Application of a Robust Internal Observer to an Anaerobic Digestion Process. *Dev. Chem. Eng. Mineral Process.* 13, 267-278.
- Balaguer, M.; Vincent, M. and Paris, J. 1997. A comparison of different support materials in anaerobic fluidized bed reactors for the treatment of vinasses. *Environ Technol.* **18**, 539-544
- Bernard, O.; Hadj-Sadok, Z.; Dochain, D.; Genovesi and Steyer, J.P. 2001a. Dynamical Model development and parameter identification of an anaerobic wastewater treatment process. *Biotech. Bioeng.* **75**, 424-438.
- Bernard, O.; Polit, M.; Hadj-Sadok, Z.; Pengov, M.; Dochain, D.; Estaben, M. and Labat, P. 2001b. Advanced monitoring and control of anaerobic wastewater treatment plants: software sensors and controllers for an anerobic digester *Wat. Sci. Technol.* **43**(7), 175-782.
- Boe K., Batstone D.J., Steyer J.P. and Angelidaki I. 2010. State indicators for monitoring the anaerobic digestion process, *Water Research*. **44(20)**, 5973-5980.
- Borja, R. and Banks, C. 1994. Kinetics of anaerobic digestion of soft drink wastewater in immobilized cell bioreactors *Chem. Tech. Biotechnol*, **60**, 327-334.
- Estaben, M.; Polit, M. and Steyer, J. 1997. Fuzzy control for an anaerobic digester. *Cont. Eng. Pract.* **5**(**9**), 1303-1310.
- Mailleret, L.; Bernard, O. and Steyer, J. 2004. Robust nonlinear adaptive control for bioreactors with unknown kinetics. *Automatica*. **40(8)**, 1379-1385.
- Michaud, S.; Bernet, N.; Buffière, P.; Roustan, M. and Moletta, R. 2002. Methane yield as a monitoring parameter for the start-up of anaerobic fixed film reactors. *Wat. Res.* **36**, 1385-1391.
- Ripley, L.; Boyle, W. and Converse, J. 1986. Improved alkalimetric monitoring for anaerobic digestion of high-strength wastes. *Wat Pollut. Control Fed.* **58**(**5**), 406-411.
- Sbarciog, M.; Moreno, J. and Vande-Wouwer, A. 2012. A Biogas-based switching control policy for anaerobic digestion systems. *Preprints of the 8th IFAC Symposium on advanced control of chemical processes*. 603-608.
- Steyer, J.; Bernard, O.; Bastone, D. and Angelidaki, I. 2006. Lessons learnt from 15 years of ICA in anaerobic digesters. *Water Sci Technol.* **53** (**4-5**), 25-33.
- Zickefoose, C. and Hayes, R. 1976. Anaerobic sludge digestion: Operations manual. *Office of water program operations*. US Environmental Protection Agency.