



HAL
open science

Multi-technique analysis, correlation between ultrasound and x-ray diffraction on commercial cells

Benjamin Mercier-Guyon, Corentin Renais, Maxime Servajon, Morian Sonnet, David Wasyłowski, Sandrine Lyonnard, Claire Villeveille

► To cite this version:

Benjamin Mercier-Guyon, Corentin Renais, Maxime Servajon, Morian Sonnet, David Wasyłowski, et al.. Multi-technique analysis, correlation between ultrasound and x-ray diffraction on commercial cells. International Society of Electrochemistry (ISE) - 2023, Sep 2023, Lyon, France. hal-04290284

HAL Id: hal-04290284

<https://hal.science/hal-04290284>

Submitted on 16 Nov 2023

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

Multi-technique analysis, correlation between ultrasound and x-ray diffraction on commercial cells

Benjamin Mercier-Guyon^a, Corentin Renais^a, Maxime Servajon^a, Morian Sonnet^b, David Wasylowski^b,
Sandrine Lyonard^c & Claire Villevieille^a

a- Univ. Grenoble Alpes, Univ. Savoie Mont Blanc, CNRS, Grenoble INP, LEPMI, 38000 Grenoble, France

b- Chair for Electrochemical Energy Conversion and Storage Systems, Institute for Power Electronics and Electrical Drives (ISEA), RWTH Aachen University, Jägerstrasse 17-19, 52066 Aachen, Germany

c- Université Grenoble Alpes, CEA, CNRS, IRIG, SyMMES, Grenoble, France

Benjamin.mercier-guyon@grenoble-inp.fr

Li-ion batteries currently dominate the electrochemical systems market but still suffer from ageing problems. Being able to determine the State of Health (SOH) of batteries is a critical need¹ to ensure user safety. Many studies on the ageing of battery materials have already been carried out, using multiple techniques, in particular using large scale facilities. These analyses allow operando monitoring of degradation mechanisms, but they are very long and difficult to set up²⁻³ and unfortunately cannot be used for use to monitor the day-to-day real-life conditions.

Ultrasound technology, which has been already widely used in many industrial sectors such as nuclear⁴ and medical⁵, has many advantages such as simple to implement, inexpensive, and enable non-destructive & *operando* measurements, allowing "*in vivo*" monitoring of the battery. However, it is difficult to know what an ultrasonic sensor can detect in a battery, whether it can determine the state of ageing of a battery and, above all, if the results obtained can be linked to any structural or morphological changes.

The objective of the study is therefore to correlate the analysis of ultrasound signals with X-ray diffraction measurements at the synchrotron (BM02 line at ESRF) in *operando* mode as a function of electrochemistry. For this purpose, a commercial cell composed of multiple electrodes of LiNi_{0.6}Mn_{0.2}Co_{0.2}O₂ (NMC 622) versus graphite (Z-stacking) was paired with an ultrasound sensor. X-ray diffractograms were acquired at several cycling rate and also during relaxation periods. The aim was to correlate the structural evolutions as a function of the charge/discharge rate and as a function of the ultrasound signal signature.

After checking if there is no beam damage on the sample, we were able to follow the evolution of the position of the two main reflections of the materials: the NMC (003) and the graphite (002) as a function of the lithiation rate (SOC) (Figure 1a).




Figure 1. a) X-ray diffractogram acquired on the complete cell; b) Correlation between the electrochemical signal (derived from the galvanostatic curve) and the ultrasound signal

As can be seen in Figure 1b, we can correlate the electrochemical signal (derivative curve) to the change in the lattice parameters of graphite and NMC and to the time of flight (ToF) of the ultrasound showing that ultrasound can be an excellent non-destructive sensor to track structural changes within battery during cycling.

Through this talk, we will be presenting the methodology employed to correlate the results between XRD and ultrasound, as well as the additional techniques used to determine ageing parameters (impedance, X-ray tomography, dilatometer measurement, etc...).

(1) W. Zhou, *et al.*, *Machines*, 10, 7, (2022)

(2) D. Atkins, *et al.*, *Adv. Energy Mater.* 12, (2022)

(3) C. Villevieille, *et al.*, *J. Mater. Chem. A*, 2, (2014)

(4) J. Richard, *et al.*, *Biomed. Opt. Express* 6, (2015)

(5) A. Juengert, *et al.*, *AIP Conference Proceedings* 1949, (2018)

(6) Q. Liu, *et al.*, *J. Phys. Chem. Lett.* 9, 18, (2018)

(7) C. Quilty, *et al.*, *J. Phys. Chem. C* 124,15, (2020)