



HAL
open science

Robust Design of Microgrids using Component Models with Different Level of Accuracy

Corentin Boennec, Bruno Sareni, Sandra Ulrich Ngueveu

► **To cite this version:**

Corentin Boennec, Bruno Sareni, Sandra Ulrich Ngueveu. Robust Design of Microgrids using Component Models with Different Level of Accuracy. OIPE 2023 (17th International Workshop on Optimization and Inverse Problems in Electromagnetism), Sep 2023, Graz, Austria. hal-04367497

HAL Id: hal-04367497

<https://hal.science/hal-04367497v1>

Submitted on 30 Dec 2023

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

Robust Design of Microgrids using Component Models with Different Level of Accuracy

Corentin BOENNEC*, Bruno SARENI* and Sandra-Ulrich NGUEVEU**

* LAPLACE, UMR CNRS-INPT-UPS, Université de Toulouse, 2 rue Camichel, 31 071 Toulouse, France

E-mail: boennec@laplace.univ-tlse.fr, sareni@laplace.univ-tlse.fr

** LAAS CNRS, CNRS, INPT, Université de Toulouse, 7 avenue du Colonel Roche, 31 031 Toulouse, France

e-mail address : ngueveu@laas.fr

Abstract. Robust design of microgrids is a complex optimization process requiring multiple simulations in order to integrate uncertainty variables associated with the system environment or design models. In this context, having sufficiently accurate models that are compatible with the optimization algorithms and associated computational costs represents a real challenge. In this paper, we illustrate this through the robust design of a simple microgrid with electrochemical storage. Based on battery models that couple energy efficiency and aging, we develop an approach for choosing the right level of precision to match the microgrid's optimization criteria or constraints.

Keywords: Integrated Optimal Design, Robust Design, Microgrids, Battery Storage, Aging

INTRODUCTION

The techno-economic optimization of electrical microgrids represents a real challenge since it requires integrating both the energy efficiency of components and their aging, as well as the uncertain nature of certain parameters (production or consumption scenarios, value of operational and capital expenditure costs, model fidelity) [1,2]. In this context, the development of suitable robust design approaches takes on its full meaning. The complexity of such approaches requires the use of simplified models ensuring a good compromise between accuracy and CPU time in compliance with the optimization techniques used. In this paper, we show in particular how to determine in microgrid design the right level of model accuracy, using the example of battery models that include energy efficiency and aging.

ROBUST DESIGN FORMULATION

The robust optimization problem associated with the microgrid design is defined as:

$$\min_{d \in D} \sum_{s \in S} \frac{NPV(d, s)}{\text{card}(S)} \quad \text{s. t.} \quad \sum_{s \in S} \frac{\delta_{\varphi}(RES(d, s))}{\text{card}(S)} \geq \beta \quad \text{with } \delta_{\varphi}(x) = \begin{cases} 1 & \text{if } x \geq \varphi \\ 0 & \text{otherwise} \end{cases}$$

It consists in finding the microgrid design within a space design D which minimizes the NPV (Net Present Value) on average over all considered scenarios S of PV production and load consumption, while ensuring a level φ of self-sufficiency for a least a fraction of β scenarios. The NPV is obtained by adding investment and operating costs over the microgrid lifetime. This is a conditional value of risk (CVaR) formulation [3], which incorporates uncertainties while providing flexibility in self-sufficiency and robustness.

CASE STUDY

The case study is a small microgrid including PV production, electrochemical storage and load consumption, connected to a main grid. Production and consumption data are generated by Markov models based on the Ausgrid data from [4]. The electrochemical storage can be represented using two energy models and four aging models with varying levels of accuracy/complexity.

A simple heuristic is implemented for the energy management, charging the battery in case of PV surplus, discharging it in case of PV deficit and using the main grid only in extreme cases (i.e. battery fully charged or empty). The robust sizing of this simple microgrid is investigated using a Sobol sequence [5] for the PV and battery sizes lying in the respective ranges of [0, 100 kWp] and [0, 160 kWh]. A number of $S=16$ scenarios is considered in the robust design formulation with a threshold of $\beta=15/16$ for ensuring robustness.

The figure 1 illustrates a comparison of microgrid sizing results for different levels of self-sufficiency using two battery models: a non-linear reference model based on a variable efficiency according to the C-rate coupled with aging (including calendar aspects, Rainflow cycling and Solid Electrolyte Interface degradation [6]) is compared with a coarse linearizable model considering a fixed efficiency and an aging based on exchanged energy. In particular, the results show the importance of taking into account the degradation of battery parameters during aging (especially the loss of battery capacity) and enable us to identify a linearizable model that can be easily used without loss of accuracy in MILP (Mixed Integer Linear Programming) optimization processes.




Figure 1: Constraint satisfaction front line comparison. The results show a good agreement between the fine battery model coupling energy efficiency and aging (leftward triangles) with a coarse linearizable one of lower complexity (rightward triangles)

REFERENCES

- [1] Z.K Pecenak, M. Stadler, P. Mathiesen, K. Fahy & J. Kleissl. Robust design of microgrids using a hybrid minimum investment optimization. *Applied Energy*, vol. 276, 2020, p. 115400.
- [2] M. Moncecchi, C. Brivio, S. Mandelli, & M. Merlo. Battery energy storage systems in microgrids: Modeling and design criteria. *Energies*, Vol. 13, n° 8, 2020, p. 2006.
- [3] R.T. Rockafellar, S. Uryasev. Conditional value-at-risk for general loss distributions. *Journal of Banking & Finance*, Vol. 26, n°7, 2002, pp. 1443–1471.
- [4] Ratnam, E.L., Weller, S.R., Kellett, C.M., Murray, A.T.: Residential load and rooftop pv generation: an australian distribution network dataset. *International Journal of Sustainable Energy*, Vol. 36, n°8, 2017, pp. 787–806.
- [5] I.M. Sobol. On the distribution of points in a cube and the approximate evaluation of integrals. *USSR Computational Mathematics and Mathematical Physics*, Vol.7, n°4, 1967, pp. 86–112.
- [6] B. Xu, A. Oudalov, A. Ulbig, G. Andersson, D.S. Kirschen, D.S. Modeling of Lithium-Ion Battery Degradation for Cell Life Assessment. *IEEE Transactions on Smart Grid*, Vol. 9, n°2, 2018, pp. 1131–1140.