

# A Review on Mode Transition Strategies between Grid-Connected and Standalone Operation of Voltage Source Inverters-Based Microgrids

Jihed Hmad, Allal El Moubarek Bouzid, Abdelhakim Saim, Hafedh Trabelsi

### ▶ To cite this version:

Jihed Hmad, Allal El Moubarek Bouzid, Abdelhakim Saim, Hafedh Trabelsi. A Review on Mode Transition Strategies between Grid-Connected and Standalone Operation of Voltage Source Inverters-Based Microgrids. Energies, 2023, 16 (13), pp.5062. 10.3390/en16135062 . hal-04391408

## HAL Id: hal-04391408 https://hal.science/hal-04391408

Submitted on 12 Feb 2024

**HAL** is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers. L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.





### **A Review A Review on Mode Transition Strategies between Grid-Connected and Standalone Operation of Voltage Source Inverters-Based Microgrids**

Jihed Hmad <sup>1</sup>,\*, Azeddine Houari <sup>2</sup>,\*<sup>(D)</sup>, Allal El Moubarek Bouzid <sup>3</sup><sup>(D)</sup>, Abdelhakim Saim <sup>2</sup><sup>(D)</sup> and Hafedh Trabelsi <sup>1</sup>

- <sup>1</sup> CES Laboratory, University of Sfax, National School of Engineering of Sfax, Sfax 3038, Tunisia; hafedh.trabelsi@enis.rnu.tn
- <sup>2</sup> IREENA Laboratory, University of Nantes, 44602 Saint-Nazaire, France; abdelhakim.saim@univ-nantes.fr
- <sup>3</sup> Icam School of Engineering, Toulouse Campus, 75 av. de Grande Bretagne, CS 97615, CEDEX 3, 31076 Toulouse, France; allal.bouzid@icam.fr
- \* Correspondence: jihed.hmad@enis.tn (J.H.); azeddine.houari@univ-nantes.fr (A.H.)

**Abstract:** Microgrids technologies are seen as a cost effective and reliable solution to handle numerous challenges, mainly related to climate change and power demand increase. This is mainly due to their potential for integrating available on-site renewable energy sources and their flexibility and scalability. The particularity of microgrids is related to their capacity to operate in synchronization with the main grid or in islanded mode to secure the power supply of nearby end-users after a grid failure thanks to storage solutions and an intelligent control system. The most critical operating case occurs when a sudden transition from grid-connected (GC) to stand-alone operation (SA) happens. During the transition, the system experiences abrupt changes that can result in a malfunction of the control system and a possible failure of the power system. The transition issue attracted considerable attention from researchers. Indeed, many research works are proposed to address this issue by proposing detection and transition techniques that ensure a smooth transition at the islanding time. Although there are several approaches to dealing with this issue, a categorization of the proposed methods in the literature and their differences is useful to assist engineers and researchers working on this topic. Thus, this study proposes a comprehensive review to summarize these approaches and point out their advantages and limitations.

**Keywords:** microgrids; distributed generation systems; voltage source inverters; islanding; mode transition control; seamless transition; grid-connected; stand-alone

#### 1. Introduction

The operation of the electrical power system is experiencing considerable mutations due to increasing energy demand, electricity market liberalization, fossil fuel scarcity, and the environmental impact of conventional generation methods. Consequently, the conventional electrical power system is not able to meet the balance between energy demand and production and face the aforementioned challenges [1]. Moreover, the mastery and evolution of technologies related to the exploitation of different energy sources and renewable energy sources in particular are pushing ahead the development of new power system paradigms [2]. To face these challenges, a competitive solution consists of producing energy based on the integration of more Distributed Generation (DG). These power challenges are transmuting the conventional electrical power generation concept and introducing an incipient trend coming mainly from the interconnection of distributed generation resources and the electric distribution system [1–4].

Benefits of a coupled DG-electric distribution system include:

- Reduced greenhouse gas emissions;
- Better energy system efficiency;



Citation: Hmad, J.; Houari, A.; Bouzid, A.E.M.; Saim, A.; Trabelsi, H. A Review on Mode Transition Strategies between Grid-Connected and Standalone Operation of Voltage Source Inverters-Based Microgrids. *Energies* 2023, *16*, 5062. https:// doi.org/10.3390/en16135062

Academic Editor: Ahmed Abu-Siada

Received: 26 May 2023 Revised: 16 June 2023 Accepted: 19 June 2023 Published: 29 June 2023



**Copyright:** © 2023 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (https:// creativecommons.org/licenses/by/ 4.0/).

- Increased system reliability;
- Reduced congestion in distribution and transmission on the traditional power system;
- Services provision, such as voltage support and demand response;
- Increased integration of micro-generation systems along with the existing power generation schemes;
- Bidirectional power flow that offers more energy utilization flexibility.

As the characteristics of DG units are different, connecting them to a distribution system requires the use of power electronic interfaces. These interfaces allow the user to control the instantaneous injection of power. Thus, high-power quality can be achieved through an appropriate control system [5–9].

In order to intensify DG integration into the grid, the development of the microgrid (MG) concept is of interest, as it can integrate multiple interconnected DG types, storage systems, and loads. The microgrid concept is introduced as a promising solution to remedy many technical challenges and benefit from the potential of DGs, notably renewable energy resources [7,10–15]. Currently, the MG concept has numerous definitions; one universal definition considers MGs as a platform for incorporating various DG resources with minimum disturbances to the main utility grid or to local loads. It is also seen as a small-scale demonstrator for Smart Grid development [7,16]. It is expected that new functionalities related to grid technologies and modern electric applications will open other horizons for the development of MG systems, such as the development of MG clusters and Smart Grid applications [10,11].

Figure 1 illustrates the basic architecture of a typical grid interactive AC MG. The use of DG units and MGs offers several benefits linked mainly to environmental and technoeconomic aspects [14]. In addition, it improves reliability and power supply security, especially for isolated areas [13–15,17,18]. Therefore, these new paradigms are rapidly developing along with the technological development of power electronics interfaces and power generation systems. Thanks to these developments, the exploitation of renewable energy sources and storage systems becomes easier within the framework of DGs and MGs.



Utility Grid

Figure 1. Typical architecture of grid interactive microgrid.

Microgrids can operate in Grid-Connected "GC" or Stand-Alone "SA" mode. Thus, MGs should be able to operate in mode transition between GC and SA. In other words,

MGs should be controlled to provide GC and SA functions and to ensure smooth mode transition [8,9,16,19–25].

In the GC mode, the amplitude and frequency of the output inverter voltage are fixed by the main grid. Under fault conditions, DG units and local loads are isolated from the rest of the grid and need to operate in SA mode. In islanded MG, i.e., SA mode, the inverter control system is responsible for regulating the voltage characteristics (frequency and amplitude) [26–29]. Nevertheless, between GC and SA, there is a short period of time where the bus voltage is neither regulated by the inverter controller nor fixed by the main grid, which may result in a decrease in power quality and load malfunction [8,9,22,23,26]. This situation may result in abrupt changes in system state variables, which can affect the whole system [22,30].

Hence, increasing electric supply resilience is a major challenge that arises especially for MG applications, which accelerates the development of advanced control and protection mechanisms. This issue presents a potential new research horizon for many research and development program directions [31–36].

Thus, the goal for MG systems is to be able to function in complement with the utility grid and thus function in GC and SA modes and achieve smooth mode transition. This enthusiasm is reflected in a significant number of studies to remedy the widespread concern about mode transition topics (i.e., relieve the undesirable transient effect). Indeed, the problems experienced during the transition phase mainly concern frequency and voltage disruptions [25]:

- An abrupt variation at the frequency level easily drives disturbances into the output angle of the DG inverter, which is contributing to the destabilization of the total MG system;
- An abrupt variation at the voltage or current level leads to system destruction, notably at the local critical load.

In the literature, various control strategies have been proposed in order to handle mode transition [3,4,16,24]. Developed control strategies aim to guarantee a seamless disconnection or connection between all connected DG units and the utility [8,9,22–24]. By reviewing some papers in this field, we observed that these strategies can be classified into five families depending on their control mechanisms [37–59]. The main motivation of this work is to give an overview of the existing control strategies that focus on mode transition. These control strategies are classified and thoroughly discussed, with a focus on their advantages and/or disadvantages.

This paper reviews different control strategies that deal with mode transition in DG and MG applications. Section 2 presents the typical configuration of MGs and describes the essentials of the hierarchical control strategy used in these applications. Section 3 focuses on the tertiary control layer and performs a review of the modes of operation of MG. Section 4 highlights a detailed outline for each transition control strategy and proposes the classification of these control methods. Section 5 clarifies viewpoints for the near future to be addressed by researchers. Finally, Section 6 underlines the main conclusions reached in this review.

#### 2. Methodology and Scope

The review article presented in this manuscript highlights literature pertaining to the islanding function in microgrids. The islanding function is recognized as one of the key advantages offered by microgrids. The graphic paper is represented in Figure 2.

Initially, a pilot study was carried out to understand the basic concepts of microgrid frameworks. Typical MG functions and components with detailed descriptions of hierarchical controls are provided (Figures 3 and 4). This is followed by an overview of the many MG demonstrators deployed all over. An overview of the existing MG systems is proposed in Table 1, providing various details such as geographical location, type of loads, types of generation sources used, the existence of energy storage systems, and the operation modes of the targeted MG. Before delving into the islanding function, specifically focusing on

the detection and management of unplanned islanding. Therefore, as shown in Figure 4, the focus of the review highlighted in this manuscript was to emphasize more on the microgrid operation modes GC and SA and the transition between those operation modes. Following this, a set of keywords relating to islanding conditions, such as the concept, types, islanding detection methods (IDM), and relevant standards, were identified. This rigorous review sheds light on islanding conditions, particularly the challenges associated with unintentional islanding and their quantitative risks, including material damage and economic losses. This systematic review process began with a pilot study, which allowed the authors to gain a preliminary understanding of the progress made in the field of islanding detection standards and methods in MGs. Therefore, the analysis encompassed the control system evaluation for all microgrid operation modes, facilitating a comparison of strategies employed in the smooth transition process. The review of the control transition structure uncovers distinct physical divisions and compares the strategies employed in the microgrid concept. Upon reviewing the control transition structure, it becomes evident that there is a clear physical division and a comparison of strategies employed in the MG concept. The transition control approaches can be broadly classified into five types in Table 5 and Figure 10, Figure 11, Figure 12, Figure 13 and Figure 14: unified control, switch process, feedforward control, droop control, and dispatching unit.



Figure 2. Graphical representation in the review in this paper.







Figure 4. A hierarchical control structure for a microgrid.

	Project Name Ref.	Situation	Organization	MG Type	Load Application	DGs	Control	Storage System	Operation
	Santa Rita Jail [60–62]	Dublin, California	CERTS, RDSI	AC	University	PV, diesel, fuel cell	Decentralized	Lion battery	GC with seamless Islanding
	Borrego Springs [61]	Sand Diego county California	RDSI, ARRA	AC	Residential, commercial and industrial	Diesel, PV	Decentralized	Lion battery Three feeders, batteries, and home storage units	Manuel islanding
	The Navy Yard [60]	Philadelphia	АМ	AC	Residential	Gas/diesel turbines, PV and fuel cell	Decentralized	Community solar and energy storage	GC
US	Fort Collins [63]	Fort Collins, Colorado	FordZED, RDSI	Hybrid	Residential	PV, CHP, micro turbines, fuel cells, diesel	Decentralized	Thermal Storage	GC/SA
	Illinois Institute of Technologies [64,65]	Chicago, Illinois	Perfect Power initiative, RDSI	AC	Residential	Gas turbines, PV, wind, diesel	Decentralized	Follow battery	GC/SA
	Colonias [66,67] Texas		State Energy Conservation Office (SECO),Texas Engineering Experiment Station, Xtreme Power	AC	-	Pv, wind, diesel	Centralized	No	GC
	University of Miami Testbed [68]	Florida,	University of Miami	DC	University, residential	PV, fuel cell	Decentralized	battery	GC/SA

**Table 1.** MG implementation around the world.

Load **Project Name Ref.** Situation Organization MG Type DGs Control Storage System Operation Application GC with Battery Benchmark Low Centralized and PV, wind, fuel **Microgrids Project** Athens, Greece seamless AC Residential Voltage [69] cell decentralized Flywheel transient Centralized Residential, Samso Island, Government and Wind and Samso Island [70] Model Predictive Battery GC/SA AC pumping thermal PV Denmark citizens Control Residential, More Microgrids GC/SA Microturbine Ílhavo Municipal AC Centralized, dual Lisbon, Portugal pumping and Project and EDP With Swimming-Pool No Diesel generator control Distribuição power circuit transition [71] Battery, Super Labein PV, wind, diesel Centralized, PO More Microgrids Derio, Spain Capacitor GC Experimental Hybrid University and microturbine, control Project Flywheel Center [72] EU Residential, ISET and University of GC/SA Kassel, Commercial Kassel Institute for AC PV, wind, diesel, Centralized Master Demotec [73] Battery With Germany CHP electrical energy slave control Industrial transition technology University of University of Seville Residential, Spain PV, fuel cell DC Battery SA Decentralized HybLab Seville [74] motor StatoilHydro and Hydrogen GC Utsira Wind [75] Norway AC Residential wind Centralized Enercon storage Power Matching Groningen, PV, micro-CHP, KEMA AC Centralized EVs GC Residential City [73–76] Netherlands wind Manchester, Horizon [77] H2Ope AC CHP, wind, PV Centralized --England Gazi University [78] Ankara, Turkey Gazi University AC University PV, wind, diesel Centralized SA Battery

	Project Name Ref.	Situation	Organization	МG Туре	Load Application	DGs	Control	Storage System	Operation
	Kyoto Eco Energy [79]	Japan	NEDO	AC	Residential	PV, wind, fuel cell, bigas	Centralized	Battery	GC
	Fukuoka [80]	Japan	Smart Energy Laboratory	DC	Home	Wind, PV	-	Battery	SA
	FC-CHP-based Japan Plant Osaka [81]		-	AC	Hot water supply	Fuel-cell- combined heat Centralized Battery and power (FC-CHP)		Battery	GC
	Akagi [82]	Japan	NEDO	AC	Commercial/ind	ustrial Diesel	Centralized	No	GC
Asia	INER Testbed [83]	Taiwan	Institute of Nuclear Energy Research	AC	Motor	PV, wind, diesel, gas turbine	Decentralized	Battery	GC
	Subax [84]	China	-	AC	Residential	PV, wind, diesel, gas	Decentralized	Battery	SA
	HFUT Microgrid [85]	China	Lab-in Hefei University of Technology	AC	Static, load	PV, wind, fuel cell, hydro, gas	Centralized	Battery	GC/SA with seamless operation
	Singapure Pulau ubin [86]	Singapore	-	AC	Domestic application	PV, diesel	Decentralized	Battery	GC
	Jeju Island [87]	South Korea	Korea Smart Grid Association and Korea Electro technology Research Institute	AC	-	PV, Wind, fuel cell, Diesel	-	Battery	GC
	Qatar climate conditions [88]	Doha Qatar	Qatar Foundation	Hybrid	Residential/com	mercial PV	Decentralized	Lithium-ion battery storage system	GC

	Project Name Ref.	Situation	Organization	MG Type	Load Application	DGs	Control	Storage System	Operation
	Lucingweni [89]	South Africa	Nersa	Hybrid	Residential	PV, wind, diesel	Decentralized	Battery	SA
	Solar power projects [90]	South Africa	SAG institutions	AC	Rural urban	PV and CPV	-	-	GC
	Optimum isolated hybrid microgrid [91]	Fez, Morocco	-	Hybrid	Residential Rural area	PV, wind, diesel	Centralized	Battery	SA
Africa	Manar microgrid Project [92]	Tunisia	CROM and DSR	AC	Building (Five apartments)	PV	Centralized	Lithium-ion Battery and supercapacitor	GC
	Smart microgrid in sub-Saharan Africa [93]	Nigeria	-	Hybrid	Rural electrification	PV, diesel generator	Centralized	Battery	SA
	Coral Bay [94]	Western	-	AC	Residential/ commercial	Wind, diesel generator	Centralized	Lithium battery	SA
	CSIRO Energy Center [95]	Newcastle	-	AC	Residential (domestic loads)	Wind, PV	-	Battery	GC
Australia	QUT Microgrid [96]	Queensland	-	DC	University applications	Fuel cell, PV,	Decentralized	Battery	SA
	Flinders island microgrid [97]	Flinders	-	AC	Residential Commercial Industrial	Wind, solar and diesel generator	Centralized	Battery	SA

Therefore, the analysis encompasses the control system evaluation for all microgrid operation modes, facilitating a comparison of strategies employed in the smooth transition process. The review of the control transition structure uncovers distinct physical divisions and compares the strategies employed in the microgrid concept. Upon reviewing the control transition structure, it becomes evident that there is a clear physical division and a comparison of strategies employed in the MG concept. The transition control approaches can be broadly classified into five types in Table 5 and Figures 10–14: unified control, switch process, feedforward control, droop control, and dispatching unit. One of the main objectives of the review article is to highlight the use of control approaches to address the transition problem in MGs. The study examines future trends regarding the transition process in microgrids.

#### 3. Microgrid Frameworks

This section conducts a thorough literature review on the conceptual and operational aspects related to MGs. Figure 3 presents the typical functions and components of MGs. In addition, in order to achieve high levels of robustness, resilience, and reliability throughout all operational states and transitions, different control and management strategies need to be implemented. The theoretical field of sustainable transitions has grown rapidly in recent years [95,98–103], and various disciplines such as economics, sociology, economic geography, and engineering are committed to the development of new grid paradigms. In this sense, there are many MG demonstrators deployed all over. An overview of the existing MG systems is proposed in Table 1. Different information in relation to the geographical situation, type of loads, types of generation sources used, the existence of energy storage systems, and the operation modes of the targeted MG are listed in this table. As mentioned in Table 1, some energy development organizations realized their own MG projects, such as CERTS in the US [104], NEDO in New Mexico in collaboration with Japan [105], and MG projects in Europe as simulation and demonstration platforms [77].

The microgrid market in South America is experiencing rapid growth as well. According to a research report released by Triton Market Research, the Latin American microgrid market is projected to achieve a compounded annual growth rate of 10.61% between 2022 and 2028 [106]. This explains the existence of various laboratories and test systems dedicated to microgrids in South America. In [107], a concise portrayal of each microgrids general information, characteristics, and components. Additionally, it incorporates a discourse on the progress made in distributed generation within the Latin American region (in Brazil, Ecuador, Argentina, Mexico, Chile, Peru, etc.).

Currently, multiple demonstration and pilot projects are actively integrating renewable energy sources into isolated microgrid systems. These initiatives, discussed in [108], specifically focus on incorporating renewable energy resources into microgrids that serve remote communities in Canada. For instance, ongoing initiatives in Northern Ontario, such as Deer Lake and Fort Severn, involve the deployment of photovoltaic (PV) and hybrid systems to decrease reliance on diesel fuel. Additionally, the remote mine located in Diavik, Northwest Territories, has implemented a wind farm to reduce fuel consumption, whereas the Northwest Territories Power Corporation has installed a solar and battery system in Colville Lake. Additionally, research was conducted on the utilization of ocean energy. However, in 2020, Canada launched the Ocean Energy Smart Grid Integration Project, with the aim of integrating ocean energy into isolated microgrids on remote islands. The Pacific Regional Institute for Marine Energy Discovery at the University of Victoria received a grant of USD 730,000 to develop a microgrid powered by wave energy for Nootka Island [109].

Taking into account a country's own needs, strategies, priorities, and assets that can be different from one region to another, different MG concepts can be developed. As a result, advancements in these technologies depend on the specificities, priorities, and potential of each country. Therefore, the majority of the MGs developed have at least one of the following aims:

- ✓ Provide an appropriate remedy for delivering electricity to remote areas where it is difficult to connect rural communities, which is the case in many developing countries and isolated areas. Some cases can be found in Africa (Lucingweni, Diakha Medina), Asia (India, Vietnam, Nepal, Koh Jik, Sri-Lanka), and Europe (Akkan, Macedonia) [77,105,110];
- For Europeans, the major concern is to develop energy communities in terms of renewable energy integration rates, i.e., integrating as much renewable energy on a large scale [99]. To achieve this, several EU countries have ambitious goals to decarbonize their energy systems (reduce gas emissions by 80–95% compared with 1990 by 2050). To achieve these goals, new policies and directions have been made to increase renewable energy production (mostly solar and wind energy) [100]. For example, in Feldheim, Germany, the power supply is 100% renewable [95]. To achieve a transition to 100% renewable energy by 2050, in Denmark, appropriate energy policies have been made to improve the energy efficiency of the residential sector [101]. In addition, numerous research programs focused on MGs' development have been launched within EU research frameworks, such as the DISPOWER project or the MORE MI-CROGRIDS project, in order to develop advanced control schemes (decentralized and centralized control) and communication protocols. In this direction, many universities and technological institutes have also developed their own MG to carry out experiments while they are self-producers (Manchester, Aalborg, Fraunhofer, Chalmers, Illinois) [102].
- ✓ The security of supply remains a major concern in the US in case of war or disaster [65]. The US Department of Defense focuses on the deployment of MGs in hot spots. The Navigant research predicts that the annual MGs implementation spending by the US Department of Defense is expected to exceed USD 1 billion annually by 2026 [65,111]. In this sense, many communities in the US have ambitious targets for the transition toward more renewable energy production, mainly from solar and wind energy. In this context, some initiating projects have been launched within US research frameworks., e.g., Sandia National Laboratories and the University of Buffalo have applied the social burden of power outages method in two projects to date [112].

#### 4. Microgrid Control

Depending on its application, architecture complexity, scale, and component technologies, a microgrid controller can be structured on different levels with different objectives and timescales [113]. Commonly, three hierarchical levels, described in Figure 4, are defined [113–117]: (i) The primary level deals with the on-line control of the local outputs (voltage, current). It also ensures power sharing in the presence of multiple DG units. This control level is close to the physical system and does not depend on communication facilities. The control dynamics at this layer are around milliseconds. (ii) The secondary level, which requires communication facilities, is mainly dedicated to supervision and power management. It ensures the transfer of information and consignments between the primary and tertiary control levels. The time of operation at this level ranges from milliseconds to minutes. (iii) The tertiary level, as an offline control, is more related to energy planning and grid service provision such as voltage-frequency stabilization and maximizing the economic gains of the microgrids. The dynamics of this last level range from hours to days. Hereafter, additional information on the control levels roles, especially with regard to the management of transient modes (islanding and reconnection to the grid), are given.

□ **Primary level control:** based on local measures, primary control performs the local bus voltage stabilization and current control inside the microgrid. Furthermore, power sharing between the DG units based on droop techniques is used to modify the inner loop references. This level confers inertia to the DG units and allows for eliminating circulating currents that are a threat to the materials, such as power electronic devices. To ensure complete microgrid integration, the primary control

should include algorithms to manage islanding events and, therefore, handle the inerrant overcurrent that arises from an accidental transition between the operating modes. The transition management algorithm should ensure a fast reconfiguration of the control references (a few milliseconds) without abrupt discontinuities in the control references in order to achieve a smooth transition.

- Secondary level control: This level uses communication facilities to ensure power management between the units and can be classified as centralized or distributed. This stage for handling power-sharing inaccuracies by providing voltage and frequency deviations to the primary control. Moreover, it can incorporate several management functions such as forecasting uncertainties, correcting the power consignments to exploit the intraday market, and ensuring the battery's state of charge management. From an operating mode perspective, this level is mainly associated with the management of microgrid reconnection to the main grid. The synchronization process can take a few minutes. It can also manage load shedding to maintain the power balance between production and consumption inside the microgrids, especially in off-grid operations. Once the utility grid is restored, the active synchronization algorithm will be initiated to reconnect the microgrid to the main grid. Ensuring uninterrupted power supply and minimizing rush currents, the seamless transition strategy from the SA mode to the GC mode holds immense importance. During the active synchronization (AS) process from the IS mode to the GC mode, it is crucial for the point of common coupling (PCC) to synchronize with the utility grid in terms of voltage amplitude, frequency, and phase in order to achieve a smooth transition. Thus, the active synchronization compensation signals  $\Delta \omega^*$  and  $\Delta v^*$  are given.
- □ **Tertiary level control:** This control level is mainly concerned with offline energy scheduling in order to satisfy objectives that are often related to techno-economic efficiency optimization. The optimization is carried out within a long- or mediumterm time horizon (a 24 h planning horizon is the most common). The purpose of this optimal planning is to estimate the best set-points, which are transmitted to the operational level (secondary control), to exploit the degrees of freedom used to control the system under study, based on the day-ahead market, storage capacities, demand-side forecasts and flexibility, and all renewable production forecasts. Regarding operation modes, this level is used to prepare large-scale operations such as the preparation of storage elements and/or schedule load shedding to absorb transient disturbances and stabilize voltage frequency and amplitude, particularly during peak consumption times. This level can also be used to prepare the assistance operations as a black-start grid to recover from a blackout and for the planning of maintenance operations.

As a summary of the role of the different stages in operating modes, (i) the tertiary level exploits and plans microgrid capacities to absorb the transient disturbances of the grid and maintain stable frequency and voltage magnitudes. It can also use microgrids to assist the main grid in recovering from a blackout. The secondary level is the link between the tertiary and the primary control and is devoted to the connection and synchronization of microgrids to the main grid. It can also ensure load shedding to maintain power balance inside clusters of microgrids. The primary level ensures securing operation under fast transient modes, such as a non-scheduled islanding.

#### 5. MG Functionality and Operation Modes

Microgrids can operate in two main modes: grid connected and off grid. Microgrids also incorporate additional functionalities for transient mode management between the two main modes, namely, islanding transitions and grid reconnections [118]. The MG operation modes are depicted in Figure 5. In the following, a description of the specificities of the MG operating modes is given.



Figure 5. MG functionality and operation modes.

#### 5.1. Transition Problems and Related Issues

A Microgrid transition between the GC and SA modes is a promising alternative, providing greater availability and flexibility. Transition smoothness remains highly challenging, due to the fact that it heavily depends on control strategy and the corresponding parameters [31]. However, a successful transition between grid connected and standalone is a considerable challenge for many researchers because existing methods are still not entirely satisfactory.

Methods of transition prevention have been studied. Figure 6 is a graph of IEEE conferences and journals published in the GC and SA operating modes between 2000 and 2023. From 2006 onwards, it shows that there is increased interest in the transition between microgrid operating modes.



**Figure 6.** IEEE-published papers on microgrid operating in GC, SA, and their transition modes, 2000–2023.

One of the crucial operations for the energy sustainability and load balancing of the microgrid system is the transition issue between the grid-connected mode and the islanding mode. The technical problem underlying this is that the output inverter is supported by the main grid during GC and controlled by the local inverter. However, during the transition between those operation modes, the voltage magnitude and frequency are not supported by the grid nor by the inverter. This operation state, if not strictly monitored, can easily cause a whole MG operation problem, which could result in damage to or the destruction of equipment [4].

Furthermore, a stable transition between those operation modes is a vital concern because it can cause both voltage peaks across the local load and peak currents to the main utility. Therefore, a provision of transparent transient conditions from grid-connected mode to island mode or vice versa is a necessity [32]. This consideration highlights the performance of the microgrid control system. Another significant issue is strongly linked to a specified modeling of the transition dynamics between both operation modes. This is usually the basis of the interactions between the electrical power distribution and the penetration of all DG inverters. Energy management and load scheduling are issues of prime concern in this regard. In other words, guaranteed uninterruptible power supplies. Thus, two major deficiencies can be summarized from the existing transition method [33,34]:

- A sudden alteration in inverter operating mode, for instance, will cause the inverter to switch from current control to voltage control as soon as islanding failure is present;
- A controller's parameters are chosen based on practice and experience. Otherwise, an efficient and systematic checking method does not exist.

A careful examination of the dynamic transient state behavior of microgrids shows that the real technical challenges can be summarized as [32–35]:

- The sensible load that must always be supplied;
- The sensible load must be protected against any abrupt power variation (mainly voltage frequency).

Accordingly, during the transition period, it is essential for the control system to implement adequate precautions that smooth out undesirable disturbances, such as voltage spikes and rush currents. These precautions aim to prevent excessive voltages and ensure stable operation throughout the entire transition process.

#### 5.2. GC Mode

In normal operation (GC mode), the microgrid is expected to follow the rules of the utility without being involved in the main power supply function. This approach is adopted in the microgrid functioning principle for continuous and stable electric power system operation.

Furthermore, in this operating mode, the microgrid can export its excess power to the main grid or draw power from it. As a result, the microgrid must have the ability to control the fluctuation of active and reactive power flows while monitoring the energy storage state [36,119]. When designing and developing the microgrid control system, several significant issues related to the grid-connected (GC) mode should be considered. These concerns can be summarized as follows [120,121]:

- The system dynamics need to be fixed to a large extent due to the small size of the distribution units;
- Typically, the dynamic response of the control signals is slow whenever there is a variation in the output power;
- To improve system stability, a virtual inertia should be incorporated into the control loops of each power electronic interface;
- The uncontrolled grid-injected power flow: at the PCC, the fluctuation of active and reactive power is sensitive to the utility grid's state [122].

#### 5.3. Islanding Detection

#### 5.3.1. Islanding Detection: Concept

According to IEEE 1547 of 2008, an "island into the electric power system" is defined as "a condition in which a part of the system comprising the DGs system and local load is isolated from the rest of the electric grid under a grid failure or loss at the PCC. Furthermore, this island acts as a local production resource and continues to supply power to local loads" [123]. Islanding can typically be intentional or unintentional (unplanned). Intentional islanding is planned in advance and occurs during maintenance operations. Numerous publications have raised concerns about unplanned islands. In fact, multiple factors could lead to unintentional islanding, including [123–126]:

- A fault on the area electric power system, causing a disconnecting device to open, but the fault is not detected by the PV inverter or by local distributed energy resource protection devices;
- Utility switching of distribution lines and loads; intentional disconnection of the distribution line for utility service or repair;
- Distribution line and load switching by utility services; intentional disconnection of the utility grid for utility service or repair;
- Equipment failure that results in the unintentional opening of a disconnecting device;
- Bad actor with malicious intent;
- Human error;
- An act of nature.

As a general rule, planned islanding does not have negative consequences, as they are anticipated and managed during and after disconnection from the main utility. However, unplanned islanding is caused by an unforeseen disturbance in the system. Incorrect detection of such situations can lead to serious problems. These problems mainly concern safety hazards, power quality, voltage, and frequency stability. They may result in significant risks of damage to utility equipment or customer-connected loads due to transient conditions occurring between the islanding event and the eventual disconnection of the DG inverter from the grid. [125,127].

Moreover, when islanding mode disappears and the DG system needs to reconnect, the inverter is likely be out of synchronization, which can result in damage to local devices and loads due to the phase difference between the output inverter and the main grid [128].

#### 5.3.2. Quantification of Risk of Islanding

When quantifying the damage caused by an islanding condition, several metrics come into play, including the overall outage duration, loss, and lost energy. These metrics indeed correlate with overall welfare loss. However, there are other factors to consider as well [129–131].

- ✓ The occurrence of a blackout directly results in economic harm. Processes are disrupted, production batches are lost, and manual restarts are required, among other factors. Prolonged islanding, particularly when power is out, poses a special challenge because freezing can cause severe damage to customer property. Furthermore, they endanger critical components of the energy supply system, such as power plants and heating networks. According to the US president's council [130,131], the average annual cost of partial power outages caused by severe weather ranges between USD 18 billion and USD 33 billion. The cost can be much higher in a year with record-breaking storms (in 2008, for example, the year of Hurricane Ike, weather-related outages cost the economy between USD 40 billion and USD 75 billion). Therefore, preparing for the challenges posed by climate change necessitates investment in 21st-century technology that improves grid resilience and reliability. This is why the American Recovery Act allotted USD 4.5 billion for smart grid investments. In [132], a simulation dynamic model in Costa Rica demonstrated that islanding resulted in significant economic losses (USD 92,780/h);
- ✓ The extent of damage escalates significantly when an outage surpasses the backup system's design capacity for critical facilities. Moreover, as backup power depletes, certain components of the power system may gradually become unavailable. For instance, in Germany, approximately 150,000 interruptions lasting more than 3 min are recorded annually for low-voltage (LV) end customers. However, these substantial numbers, however, only marginally increase the System Average Interruption Duration Index by about 2 min per year per end customer at the LV level. The overall duration index is approximately 12–15 min per year, excluding extreme event (resilience-related) outages from these general reliability statistics [130,133].

#### 5.3.3. Islanding Detection: Standardization

As DG's deployment progresses, a higher level of penetration will be achieved, where unintentional islanding could pose a serious risk to the power system's safe and reliable operation. These factors have been highlighted as critical concerns in power research programs, which explain the intense focus on unintentional microgrid islanding in several research projects [134]. Consequently, numerous standards have been developed by many countries for all grid-tied DG inverters [135].

These standards are established by various commissions primarily to enhance safety and quality factors, address islanding issues, and address electromagnetics. The most relevant international organizations in this regard include the IEEE in the United States (Institute of Electrical and Electronics Engineers), the IEC in Switzerland (International Electrotechnical Commission), and the DIN and VDE (DKE) in Germany (German Commission for Electrical, Electronic, and Information Technologies). Figure 7 showcases the widely used standards and their specifications for grid-connected DG systems [135–137].



Figure 7. Standards and specification.

All of the standard requirements require detecting islanding conditions as soon as the island indicator takes place and ceases to energize the utility grid. The voltage, frequency, and power quality requirements for disconnection are specified in Tables 2 and 3, respectively. The reconnection standard is outlined in Table 4.

IEEE 15	547 Std.	IEC617	727 Std.	VDE 0126-1-1 Std.		
Voltage Rang (%)	Clearing Time (s)	Voltage Rang (%)	Clearing Time (s)	Voltage Rang (%)	<b>Clearing Time (s)</b>	
V < 50	0.16	V < 50	0.10			
$50 \le V < 88$	2	$50 \le V < 85$	2.00	110 . 17 . 110	0.2	
110 < V < 120	1	110 < V < 135	2.00	110 < V < 110		
V > 120	0.16	V > 135	0.05			
Frequency rang (Hz)	Clearing time (s)	Frequency rang (Hz)	Clearing time (s)	Frequency rang (Hz)	Clearing time (s)	
59.3 < <i>f</i> < 60.5	0.16	$f_{n-1} < f < f_{n+1}$	0.1	57.5< <i>f</i> < 50.2	0.2	

**Table 3.** Disconnection power quality standard.

IEEE 1547 Std.		IEC61727 Std.		VDE 0126-1-1 Std.		
		DC current injection	limits			
I <sub>DC</sub> < 0.5% of the rated RMS current	0.16	I <sub>DC</sub> < 0.5% of the rated RMS current	0.10	I <sub>DC</sub> < 1% of the rated RMS current	0.2	

IEEE 1547	7 Std.		IEC61727 Std.		VD	E 0126-1-1 Std.			
Voltage Harmonics limits									
Harmonic order	h < 11	11 < h< 17	17 < h< 23	23 < h< 35	35 < h	Totale Harmonic Distorsion THD (%)			
%	4.0	2.0	1.5	0.6	0.3	5.0			

Table 4. Reconnection standards.

IEEE 1547	IEC61727
88 < v < 110%	88 < v < 110% and
and	59.3 < f < 60.5 (Hz) and
59.3 < f < 60.5 (Hz)	Delay standby Delay minimum 3 min.

#### 5.3.4. Islanding Detection Methods (IDM)

The study of Islanding Detection Methods (IDMs) in the field of DG has been presented under different names over the years. These names include islanding detection, non-islanding, anti-islanding (AI), and unintentional islanding [125]. In the literature, several IDMs have been proposed to effectively detect the islanding mode. To evaluate each IDM, some performance indices are utilized, reflecting accuracy, speed, and effectiveness criteria. These indices typically include the Non-Detection Zone (NDZ), Detection Time (DT), and impact on power quality [138,139].

On the other hand, certain studies have highlighted the broad generalization capability of IDMs concerning topology adaptation [132,140,141]. A smart and passive technique for detecting islanding events that can adapt to various conditions including changes in grid topology was proposed in [140]. In [132], a novel approach called the Topology Identification Matrix Method was devised specifically for a microgrid system featuring a dynamic network. In this study, a fault protection strategy based on a multi-agent system was implemented to effectively coordinate the protection measures. In the same vein, a hybrid IDM based on two passive IDMs, namely, rate of change in active power and rate of change in reactive power, was proposed for an 11 kV Malaysian distribution system in [141]. The performance of this IDM was validated in the PSCAD environment for various scenarios, including islanding detection, fault analysis, quality factor evaluation, load fluctuations, DG tripping, grid topology, and non-detection zone (NDZ) range assessment.

Typically, IDMs can be classified into two categories based on the location of detection: local methods at the converter side and remote methods at the grid side [125]. Figure 8 illustrates the IDM groups along with their specific strengths and weaknesses.

- □ **Remote methods:** these methods rely on communication between the output inverter and grid. Versus local methods, remote techniques demonstrate excellent performance, particularly for multiple inverter systems. They exhibit a negligible NDZ, no impact on power quality, high reliability, and easy implementation. However, these methods require a communication infrastructure and additional peripherals, such as sensors and telecommunication devices on both the utility and DG sides. Consequently, these methods can be quite expensive, especially for small systems;
- □ **Local detection methods:** these methods primarily rely on continuous monitoring of system parameters at the PCC, including current, voltage, frequency, and harmonics. The concept behind local methods is that islanding mode can be easily detected when these parameters exceed the threshold values specified by standards. Local methods can be further categorized into three types: passive, active, and hybrid. Figure 9 shows the overall flowchart of locale IDMs. Passive, active, and hybrid methods are briefly outlined as follows [125,127,128,135–139].



Figure 8. IDM Classification and performances.



Figure 9. Overall design of IDM: passive, active, and hybrid flowchart.

19 of 41

Passive techniques: These methods were among the first to be developed. They involve the direct measurement and comparison of parameter fluctuations at the Point of Common Coupling (PCC) against the required threshold. Passive methods offer several advantages, such as easy implementation, no degradation in power quality, fast detection time, and low cost. However, their main limitation is the larger Non-Detection Zone (NDZ).

Active methods: These methods are mainly designed to overcome the limitations of passive methods. The concept behind active methods involves perturbing feedback and then observing the response. In active methods, a small disturbance signal is injected into the parameters at the Point of Common Coupling (PCC) to accelerate the system's convergence towards its limits. Essentially, it involves intentionally destabilizing the Distributed Generation (DG) system when islanding occurs. This small disturbance signal become significant once the utility is disconnected, indicating an islanding condition. Compared to passive methods, active methods enhance the precision of islanding detection with a very small or even zero Non-Detection Zones (NZDs). However, the implementation complexity of these techniques increases due to the additional circuit used to generate periodic disturbance signals. In addition, introducing periodic disturbance signals into the system can impact power quality and system stability.

Hybrid methods: Hybrid methods have been developed to address the challenges faced by active and passive strategies while retaining their respective advantages. These methods combine active and passive techniques to improve the efficiency of islanding detection. Typically, the active method is implemented only when an islanding condition is suspected by the passive technique. Hybrid methods have proven successful in reducing the Non-Detection Zone (NDZ) while minimizing the degradation in power quality compared to other conventional local techniques. However, it tends to increase with hybrid methods, as they combine the detection times of both active and passive approaches.

#### 5.4. Standalone Mode

In the islanding operation, the whole microgrid will function autonomously (appointed equally SA mode); therefore, it must have enough power capability to provide the total load power demand [142]. Furthermore, a disturbance that requires a feeder to work individually may also happen. This is inaccurate power sharing due to the unbalanced feeder impedances. Usually, local loads are sensitive to any voltage variation. Hence, to achieve a successful standalone operation, the MG scheduling must have enough local generation to meet the demands of the sensitive loads, whereas the sensitive loads will rely on the utility supply [143]. These considerations provide a significant advantage to the microgrid concept, as it offers greater flexibility in dealing with disturbances and emergency conditions. This enhances the system's reliability and ensures the security of local loads.

The IEEE 1547 standard outlines several advantages of using SA operations, as highlighted in points [143,144]. These benefits can be summarized as follows: enhancing reliability for customers, minimizing costs, mitigating overload issues in the electric supply system, resolving power quality problems, and facilitating maintenance operations on power system components without disrupting service to end-users.

However, during the SA operating mode, the microgrid is faced with the imperative task of addressing the following crucial issues:

- $\checkmark$  Power balancing between supply and demand;
- $\checkmark$  Provide a stable voltage and frequency;
- $\checkmark$  Acceptable power quality;
- ✓ Intercommunication between system components.

#### 5.5. Reconnection

After the end of the islanding disturbances, the DG inverter will reconnect to the utility to resume normal operation in the GC mode. During this operational mode, the major challenge is to ensure seamless synchronization with the required standard. Achieving a

smooth reconnection is mainly focused on the efficiency of the synchronization process. Therefore, in the MG control design, important consideration should be given to the synchronization system [145]. Thus, achieving a smooth and successful reconnection evidently means that the adopted synchronization process should be enabled to avoid large "zero" inrush currents during the pre-synchronization process [146,147].

Among those methods is a novel virtual torque (VT) and virtual flux linkage (VFL) synchronizing process that has been designed to enable a reliable seamless reconnection [148]. The proposed method permits a synchronizing torque command to the frequency control loop and minimizes the overshoot inverter output and its counterparts on the AC bus. In [149], a three-phase SRF PLL has been proposed to achieve smooth re-synchronization to the grid without affecting the microgrid voltage during the transition period for a residential microgrid community.

According to the standards listed in Table 4, a microgrid system must meet certain synchronization criteria. In the literature, numerous synchronization algorithms have been investigated as guidelines for grid-connected inverter control [150]. The most popular system is the Phase Locked Loop (PLL) system. It is used to estimate the phase and frequency of the main grid (e.g., extract the phase, amplitude, and frequency of the grid voltage). Various synchronization schemes are typically designed based on PLL systems such as enhanced PLL (EPLL: Enhanced Phase Looked-Loop), PLL with SOGI-PLL, Synchronous Reference Frame-PLL (SRL PLL), and other strategies such as Frequency Locked Loop (FLL) as well as their derivatives (SOGI-FLL, MSOGI-FLL, SOSF-FLL, etc.) [151–153].

To select the appropriate synchronization process, several performance criteria need to be considered, including frequency and phase overshoot, computational complexity, dynamic response under faults, and accurate estimation under system uncertainties (such as unbalanced faults, harmonics, phase jumps, etc.). The performance synchronization techniques are typically evaluated based on the following aspect [37,151–153]:

- $\checkmark$  Fast and accurately detect the grid voltage status (e.g., phase, amplitude, and frequency);
- ✓ Robustness against noises, stationary and transient disturbances;
- ✓ The ability to follow the amplitude variations in the network voltage in the event of a voltage drop;
- ✓ Precisely performed where the system frequency varies rapidly due to the grid voltage inertia;
- ✓ High filtering performance in the event of harmonic distortions;
- ✓ The feasibility of hardware and software implementations.

#### 6. Smooth Transition Strategies Classification

For all DGs connected to the utility, the main challenge for the control system is to establish not only a control strategy for the GCs and SAs but also endure the highest transition-related peaks. Thus, the control system must take into account both microgrid operation modes while, at the same time, guaranteeing a smooth transition between them. Therefore, the transition between the control structures for different operating modes was a hindrance for the multi-functional converter in a MG system, owing to the contradiction of input, output, and disturbance in the control diagram [154]. In this context, numerous transition approaches were proposed to alleviate the transition effect [38–58]. By reviewing state-of-the-art literature, we have seen that these strategies can be broadly classified into different categories based on their control structure. The following key subsections provide a detailed overview of each transition control structure. Additionally, Table 5 presents a comprehensive outline of a typical concept and its application, highlighting the feasibility of the main transition schemes.

MG Type	Control Technique	Control Variables	Valid	lation Exp.	Advantages		Disadvantages	Tran. Groups	Ref./Years										
	Voltage controlled (VSI)	Voltage phase and magnitude	<ul> <li>✓</li> </ul>		<ul> <li>Achieve smooth transition between GC and SA.</li> <li>islanding detection capability without NDZ.</li> <li>Fault tolerant capability during GC operation.</li> </ul>	-	Instability issue during SA in reason to reactive power loop. Instability question can be faced due to lack of coordination with other DG.	Feedforward	[59] (2019)										
	Grid interactive PWM	Load voltage and grid current	Load voltage			<ul> <li>Applicable for single-phase, grid-connected DG inverter.</li> <li>Supply uninterruptible power to local loads under grid failure.</li> <li>Easy to implement.</li> </ul>	- -	Significant voltage/current spikes during transient state. An additional cost due to the use of multiples sensors. System response degrade.	Switch	[155] (2023)									
ual converter case			V	V	<ul> <li>Compensate the voltage and current spikes existing in [95].</li> <li>Positive and negative capacitor cycles are used.</li> <li>Keep power level across loads during transition phasor.</li> </ul>	-	Complex and expensive implementation due to additional circuits/capacitors.	Switch	[156] (2022)										
Individ	PLL-based sequence	Grid voltage	V	v	V	v	V	v	~	~	v	v	V	~	<ul> <li>Support transition between GC and SA through modified technique.</li> <li>Load shedding flowchart to attain islanding detection.</li> <li>Beconnection canability using</li> </ul>	-	High oscillation in grid current and output voltage during reconnection. System capacity and reliability reduced due to disconnection of non-critical load. System response degrades significantly under	Feedforward	[157] (2019)
	Load shedding scheme	and current		<ul> <li>resynchronization flowchart.</li> <li>PLL generates the reference phase during SA mode.</li> </ul>	-	distorted and unbalanced grid voltage conditions. Complex implementation of PLL system.		[158] (2019)											
	Self- synchronizing synchronverter	Error and grid angle	r	v	<ul> <li>Does not require a dedicated synchronization system.</li> <li>Improve system performance.</li> <li>Relieve computational burden.</li> </ul>	- - -	Does not require a dedicated synchronization system. System response degrades due to requirement of synchronizing time. Reactive power disturbance in SA mode. Requires modification into control system during transition phase.	Switch	[159] (2019)										

<b>Table 5.</b> A summary of examples of a smooth transition strategy.	

MG	Control	Control	Valid	ation	Advantages		Dicadvantages	Tran.	Pof Noam
Туре	Technique	Variables	Sim.	Exp.	Auvantages		Disavantages	Groups	Kel./ leals
	Virtual torque/virtual flux-based synchronizing technique	Synchronizing virtual flux and torque command	~		<ul> <li>Effective universal synchronization into both phase and voltage magnitude level.</li> <li>Simple implementation.</li> <li>Unified synchronizing technique.</li> </ul>	- -	Does not require a dedicated synchronization. The synchronization controller is highly sensitive to gain value. The inherent property of synchro-converter causing degradation in system response.	Unified	[31] (2019)
	Indirect current control	Capacitor voltage and phase angle	~	•	<ul> <li>Simple implementation.</li> <li>Unified synchronization technique.</li> <li>Voltage loop adjusted output current in two operating modes.</li> </ul>	-	During transient state, grid current can be distorted by a DC offset or a wrong value.	Unified	[160] (2019)
Individual converter case	SVPWM control Dither synchronization signal	RMS line to line value nominal grid angle	V	•	<ul> <li>Transitions between operating modes without a controllable switch and with only one set of sensors.</li> <li>An attractive configuration for inexpensive small systems.</li> </ul>	-	The peak current exceeds the acceptable level during the transition. During transient time intervals, the grid angle is affected by some distortion for several cycles.	Unified	[161] (2022)
	Model Predictive Control (MPC)-based objective function	Active, reactive, and voltage output inverter	v	۷	<ul> <li>Fast response fluctuation due to non-linear controller.</li> <li>Seamless transition due to use of phase adjustment and grid synchronization procedure.</li> <li>Synchronization without PLL system.</li> </ul>	-	System performance affected by mismatches between model fed values and actual values of LC filter.	Switch	[162] (2017)
	Parallel V/I control for power Uninterruptible Power Supply (UPS)	Current and voltage output inverter	V		<ul> <li>Attain smooth transition.</li> <li>A power failure detection circuit ensures that the power fed to the local load remains regulated by BESS.</li> </ul>	-	UPS cannot operate autonomously in parallel with another DG system. UPS cannot be used for MG applications.	Droop Switch	[163] (2009)
	Frequency and voltage synchronization flowchart	Capacitor current Grid voltage			<ul> <li>Unified controller that regulates used for both operation modes.</li> <li>Faster response.</li> <li>Transition without additional switching.</li> </ul>	-	Unmodified dynamics power control because it is fixed by droop control. The adopted voltage control strategy is highly sensible to short circuits and grid failure.	Droop Unified	[164] (2021)

MG	Control	Control	Valid	lation	Advantages	Disadvantages	Tran.	Dof Nooro
Туре	Technique	Variables	Sim.	Exp.	Auvantages	Disauvaillages	Groups	Ker./ Years
	Linear- integration- method-based on droop characteristic	Nominal active and reactive power	v	V	<ul> <li>MG operation based on droop control to avoid critical communications (more reliable withe less communications).</li> <li>Seamlessly transfer based on droop characteristic adjustment.</li> </ul>	<ul> <li>Attaining synchronization at other than rated load condition leads to power unbalanced.</li> <li>Slow controller response causing low power quality.</li> <li>Accurate droop characteristics (V-f) tracking not achieved</li> </ul>	Droop control	[165] (2020)
Multiple converters cases	Hybrid voltage source inverter with Dispatching Unit (DU)	Output frequency and voltage magnitude	v	v	<ul> <li>During transient state, dispatch unit provides power drop, guaranteeing a stable transition.</li> <li>Power fluctuations between inverter are regulated without communication.</li> <li>Improved power quality.</li> </ul>	<ul> <li>Expensive solution due to the additional DU cost.</li> <li>During transition phase, power losses are compensated only by the DU, which is made under stress operations.</li> <li>System reliability is low</li> </ul>	Dispatching unit	[53] (2015)
	Active feed-back compensator and droop control	Output inverter voltage, current, and frequency.	V		<ul> <li>Seamless transition is attained by adjusting the droop coefficients.</li> <li>Unified controllers for both operation modes.</li> <li>Capability to ride through grid faults.</li> <li>Can adopted for dispatchable as well as non-dispatchable system.</li> </ul>	<ul> <li>Large mismatches notable for low-power systems, due to the small deviation introduced into droop coefficients.</li> <li>Slow control response, which affects power quality during transient states.</li> </ul>	Droop Unified	[ <mark>166</mark> ] (2019)
	Enhanced power flow control suing SRF-PLL	Grid voltage and frequency	v	v	<ul> <li>Seamless mode transition maintained without extra sensors.</li> <li>Mitigate the impact of grid fluctuation through Feedforward of grid frequency and voltage magnitude during GC mode.</li> <li>Enhance system stability along with the identical power flow control.</li> <li>Improves control accuracy by voltage amplitude compensator.</li> </ul>	<ul> <li>The system instability is highly sensitive to sudden variations at the voltage phase.</li> <li>Controller design is critical due feedforward terms.</li> </ul>	Feedforward	[120] (2016)

MG Type	Control Technique	Control Variables	Validation		Advantages	Disadvantages		Tran.	Ref /Voars
			Sim.	Exp.	Auvantages		Disuavantages	Groups	Nel./ lears
Multiple converters cases	Modified linear voltage compensator	Output voltage, current, and current capacitor	v	v	<ul> <li>Achieve seamless transition.</li> <li>High capacity to suppress voltage, current, and frequency spikes during transition phase.</li> <li>Enhanced dynamic performance by adding more damping.</li> <li>Easy to implement.</li> </ul>	-	The overall system stability can be affected by the herein feedforward terms. Design parameters are sensitive.	Switch	[30] (2019)
	BESS-assisted, modified control	PCC voltage of each node Sudden load current	v	v	<ul> <li>Smooth disconnection/reconnection without affecting the microgrid voltage during transition period.</li> <li>System stability is increased due to transient free operation during the local load disturbances occurring.</li> <li>Compensates for the unbalanced current and harmonic current issues.</li> <li>Reactive power, harmonics, and unbalanced load currents issues are compensated for by modified power control technique.</li> <li>High power quality across loads.</li> </ul>	-	Large capacity of storage system required. Expensive implementation and maintenance.	Switch	[149] (2018)
	Windowing factor-based grid synchronizing control	Grid voltage and phase angle	V	V	<ul> <li>Synchronization without PLL system.</li> <li>Higher power quality under nonlinear load.</li> <li>During transition jump, frequency and phase issues are avoided.</li> <li>Increased system reliability and performance flexibility.</li> </ul>	-	Difficult implementation because the parameter control design is highly sensitive to value of window factors and gains.	Switch	[167] (2018)
	Droop control norms ( <i>V/f</i> set-points of the MG are agreed)	Real and reactive output power demands.	V		<ul> <li>Unified control and power circuit for GC and SA mode.</li> <li>Accurate power sharing.</li> <li>During GC mode current faults are limited due to current limiting introduced into inverter.</li> </ul>	-	High bandwidth communication with DCs system is required. System design complex due mainly to large computational burden.	Droop Unified	[168] (2015)

MG Type	Control Technique	Control Variables	Validation		Advantages	Disadvantasas	Tran.	
			Sim.	Exp.	Advantages	Disadvantages	Groups	Kef./Years
Multiple converters cases	Active synchronization using a tertiary mode supervisory control	Active syn- chronization compensation Signals (voltage amplitude and frequency)	v		<ul> <li>Seamless transition modes are achieved with systematic hierarchical control frame.</li> <li>Reduced processing burden on the control system.</li> <li>Provides a cost-effective method for a practical microgrid.</li> </ul>	<ul> <li>Complex implementation.</li> <li>Compromise between system response time and data transfer capacity of the communication channel.</li> <li>Requires local neighbor-to-neighbor interaction with a sparse distributed communication network.</li> </ul>	Unified	[33] (2018)
	Uninterruptible- Power-Supply- based control	Output inverter: current and voltage	v	V	<ul> <li>Achieving seamless transfer between GC and SA modes.</li> <li>Facilitating smooth transition between battery charging and</li> <li>discharging modes due to dc link voltage controller that sets the active power demand.</li> <li>High power quality across local loads.</li> </ul>	<ul> <li>High stress on the uninterruptible</li> <li>power supply unit.</li> <li>Failure of uninterruptible.</li> <li>Power supply unit can compromise the MG stability.</li> <li>Expensive implementation.</li> </ul>	Droop- Switch	[169] (2022)
	Virtual Oscillator Control (VOC)-based grid synchronization	Scaling factor, filter parameters L and C	v	v	<ul> <li>Unified seamless transition between different modes without the need for changing controllers.</li> <li>Increased damping response during transition mode.</li> <li>Achieve superior synchronization and convergence (power sharing accuracy).</li> <li>Improved power quality through notch filter which suppress harmonic currents.</li> </ul>	<ul> <li>Microgrid stability is highly related to VOC controller response, i.e., fast variations in VOC lead to entire MG instability.</li> <li>Controller design is highly sensitive to gain values.</li> <li>Design of higher layer controllers is very tedious.</li> </ul>	Droop unified	[170] (2019)

#### 6.1. Strategy Based on Switch Process Scheme

#### 6.1.1. Switch Process in the Control Loop

As its name implies, this schematic control is conceived based on a Static Control Switch (SCS) process positioned at the control system between the two functional modes. Figure 10 depicts the general control structure of the SCS. This global control structure is composed of two cascaded control loops separated locally by the SCS process.



Figure 10. Block diagram of the SCS smooth transition structure.

Indeed, the SCS is assigned to change the mode of control from the current controller to the voltage controller. During the GC mode, the DG inverter is operational as a current source based solely on the current controller loop. As soon as an islanding condition is detected through the adopted AI flowchart, the SCS is actuated to bring about a change in the controller system, which means connecting the cascade voltage loop. Consequently, the inverter functions as a voltage source. This control strategy is considered as a conventional method [38].

The performance of this strategy can be enhanced by accelerating the SCS process. This, in fact, emphasizes that the transition performance is significantly influenced by the performance of the anti-islanding algorithm, particularly its speed and accuracy.

Numerous current studies have been performed to deal with the transition issue based on the SCS process strategy [38–43]. In [38], a smooth transition approach based on SCS was proposed for a three-phase DG inverter application. The controller loops (current and voltage) in this strategy were designed using two PI regulators. This approach was studied experimentally and theoretically for both control modes (GC and SA modes) and during the transition phase. Similar transition strategies were achieved in [39,171,172]. In [39], a switch selector was placed between the GC controller and the SA controller. The proportional resonant controller (PR) was utilized for both controller modes in a single-phase microgrid application. In [171], a power-electronics-based, bidirectional solid state transfer switch (SSTS) was employed for seamless disconnection and reconnection of the DFIG stator in a hybrid microgrid (solar, wind, and battery). A novel Petri recurrent wavelet fuzzy neural network (PetriRWFNN) was proposed in [172] as a replacement to the conventional PI controller to achieve seamless switching and grid reconnection responses in the microgrid.

An enhanced transition from the SA mode to the GC mode using process control switching was designed for DG systems [40]. During the GC mode, the proposed method employed combination of a PI regulator and a Luenberger observer to regulate the power fluctuation on the main grid. During the transition phase, a super-twisting algorithm

technique was utilized to ensure the load voltage control and handle the non-linear characteristics of the DG-inverter, resulting in a smooth transition phase with minimal disturbance effects. Another strategy based on switching SCS for GC and SA mode in smart distribution systems was explored in [41]. This method relied on the SCS action and investigated three different approaches, including power drooping current controlled, power drooping voltage controlled, and current drooping voltage controlled. The characteristics of these approaches were studied and analyzed. In [42], a predictive voltage controller, a predetermined sinusoidal waveform detection, and an intermediate current compensator were incorporated to enhance the dynamic response of the static switch in single-phase microgrid applications. This proposal enabled grid fault detection, reduced the turn-off delay of the SCS, and achieved a rapid steady state in the SA mode.

A flexible, controller-algorithm-based synchronization system, which allowed easy adaptation of the operation mode, was designed in [43]. This algorithm was implemented and tested for the micro-wind system. In [26], a novel smooth transition technique between the GC and SA modes was proposed based on a robust control scheme for a modular multilevel converter (MMC) interfacing with a PV generator. This control scheme enabled a seamless and rapid transition from standalone to the GC mode and vice versa. The control scheme was simulated using MATLAB/Simulink, and the simulation results were validated using an OPAL-RT OP4510 real-time simulator.

To facilitate smooth transitions between MG operation modes by dampening power, frequency, voltage, and current signals, a strategy based on a supplementary controller using Port-Controlled Hamiltonian (PCH) modeling and control in a synchronous reference frame (SRF) was designed in [131]. This work proposed a systematic approach for injecting damping into Higher-Relative-Degree (HRD) states of inverters, in addition to relative-degree-one (RD1) states.

#### 6.1.2. Switch at the Dispatching Unit Level

Among the common proposed industrialized transition techniques proposed in the literature, one technique relies on the use of an additional DG system, often a dedicated storage unit, to achieve a smooth transition [58]. The principle of this strategy involved using a supplementary energy unit to relieve the state transient; otherwise, boost current or voltage during the transition phase. Figure 11 illustrates the general overview of the dispatching unit strategy. However, there are two main limitations to the use of this solution. Firstly, it incurs additional costs due to the supplementary mechanism. Secondly, this strategy is only applicable in regions with very low grid frequency variations, typically within the range of 0.02 Hz [51].

Various recent research works propose dispatching resources as technical solutions to remedy transition issues [52–54,130,173–175]. To attenuate the transient effect, a dispatch unit (DU: "Dispatch Unit") was introduced for the application of several inverters [53]. During the disconnection from the GC mode to the SA mode, the DU manages power imbalances by absorbing or injecting the necessary amount of power. Similarly, during reconnection, the DU can adjust its output power to match the voltage of the distribution network and microgrid (MG).

On the same principle, the authors in [53] utilized a generator set "Diesel Generator" to enhance the hybrid MG (photovoltaic plus wind). With the proposed approach, the microgrid operated satisfactorily in island mode, in grid-connected mode, and during the process of synchronization and desynchronization with the main grid. In [54], a resistive-type fault current limiter suggested by the storage unit was employed to improve the transient phase performance of a microgrid during faults. In [130], a Monte Carlo method with probability distribution functions was proposed to calculate the probability of a successful islanding transition in a microgrid. This method was useful for assessing the impact of various devices that could be used to reduce the likelihood of an unsuccessful islanding transition. The method's success was validated by analyzing the islanding transition of a hybrid RE-storage-diesel microgrid using either a storage unit system (Battery Energy Storage System or Flywheel Energy Storage). In [174], a smooth transition during planned and unplanned islanding and reconnection was facilitated by the energy storage system (ESS) as the main facilitator, utilizing state-saving techniques, active synchronization, and emergency dispatch. A rule-based dispatch was proposed, given the priority to the diesel generator and then the storage, based on the state-of-charge of the ESS.



Figure 11. Block diagram of the dispatching smooth transition structure.

The potential of the storage system to stabilize power fluctuations and enable load shifting capabilities by supplying voltage and frequency references to all other generators has been implemented and tested using the HIL test bench for the recommended microgrid (MG) topology, following the required IEEE standard. The storage system's potential to stabilize power fluctuations and enable load shifting capabilities by providing voltage and frequency references to other generators was implemented and tested using a Hardwarein-the-Loop (HIL) test bench, following the required IEEE standard for the recommended microgrid topology.

In [175], similar work was investigated for a hydro-powered microgrid to achieve a smooth island transition. A PI-based droop frequency controller was proposed for the Battery Energy Storage System (BESS).

#### 6.2. Strategy Based on Voltage Feedforward Scheme

The second group of strategies aimed at addressing the transition issue involves the use of an additional feedforward compensator. The primary principle of this control structure group is to incorporate an anticipatory voltage loop alongside the current loop when a fault in the utility grid occurs. The general block diagram of the feedforward control strategy is depicted in Figure 12.

As the feedforward control is classified as neither robust nor adaptive, this control group has limited performance in mitigating the transition problem. Furthermore, implementing the feedforward scheme necessitates extensive knowledge of system parameters.

Addressing the transition problem through feedforward action has been the subject of several studies [32,44–46]. In [32], a sophisticated control strategy based on a feedforward voltage loop was proposed to protect critical local loads under grid fault trips. The proposed strategy involved adding a feedforward voltage control loop to the current controller loop in order to mitigate the overvoltage stress of renewable energy and the critical load under



the grid fault. The smooth operation of the DG inverter was validated through experimental implementation using a real-time digital simulator.

Figure 12. Block diagram of the feedforward smooth transition structure.

In [44], an improved seamless transition flowchart based on a phase-locked loop process was proposed for a three-phase grid connected inverter between the GC and SA operations. The current controller and the feedforward voltage controller were both designed to achieve smooth mode transfer under an overvoltage condition. The control method involved adjusting the PLL process based on the operation mode, synchronizing the output inverter voltage to the grid voltage in GC operation, and generating an angle with the desired frequency during SA mode. This proposed operating sequence ensured seamless PLL increases without sudden jumps, even during voltage drops and mode transitions. In [45], a similar transfer was made based on PLL, and feedforward voltage was used to avoid the transition's negative effects on a three-phase, smart-grid-connected PV inverter. The proposed control scheme combined rotating reference frame theory (d-q axis) and ensured that the outputs of the d-q voltage control loop were connected to those of the d-q current control loop to maintain consistency at the transition moment. The PLL-based approach was used to minimize the negative effects of the transition.

In the context of micro- or nano-grids, a flexible feedforward control solution was established by employing a large-bandwidth triple-loop control structure [46]. The controller's multi-loop architecture enabled effective management of the GC and SA operation modes. Additionally, two nested deadbeat-type controllers were adopted to regulate the inner loop variables and minimize disturbances during the transition phase.

#### 6.3. Strategy Based on a Unified Control Scheme

#### 6.3.1. Unified Scheme without Droop Control Method

Transition control without reconfiguration at the control structure, also called unified control, was developed in various research works [51]. The general objective of this approach was to utilize the voltage control loop as a reference current generator during the GC mode and as a voltage regulator during the SA mode. The typical process of unified control is illustrated in Figure 13.

**DG** inverter

DC

VSI

 $R_1$ 





Figure 13. Block diagram of a unified smooth transition structure.

As expected, compared to other transition structures, this method does not require modification at the control level. Consequently, the speed and accuracy of the anti-islanding algorithm are not extremely critical for achieving better transition performance. However, this structure suffers from certain disadvantages. In the SA mode, the output voltage is regulated to the extreme limit of the allowable voltage range due to the utilization of the saturation stage. Additionally, this control strategy typically requires an additional control element, which increases the complexity of its implementation.

Variants of the universal control scheme have been proposed as remedies for transition problems [47–52,173,176]. In [47], the authors designed an indirect current control loop with an applied voltage loop for a three-phase DG inverter for seamless transfer. In addition, the bandwidth voltage loop was expanded by incorporating an inner capacitor current loop. With this approach, the voltage controller was automatically activated or deactivated according to the operation mode. The theoretical analysis was checked by simulation and experimental results.

A similar work was presented in [48], where the previous approach was enhanced by introducing a feedforward load current. This improvement focused on improving the waveform quality of both the grid current in GC mode and the load voltage in SA mode.

To improve the transition performance, a proportional resonant (PR)-based indirect control scheme was proposed for a 4.5 kw grid-connected inverter [49]. The PR controller was described for both controller loops, aiming to improve the transition performance.

In [164], a three-phase universal controller (UC3) was proposed for flexible microgrids, ensuring operation in all operation modes without reconfiguration of the control structure. UC3 enabled control of active and reactive powers while providing voltage and frequency support. Furthermore, the synchronization system was integrated into the control structure, which explained the agile and robust responses and the reduced transient phase impact. In [51], the authors proposed a unified control and power management system for a hybrid PV-battery application with DC and AC charging buses. The proposed method successfully regulated the voltage on both DC and AC buses, achieved a smooth transition between the grid-connected and island-connected operating modes, and automatically balanced power flows into the system under different operating modes, regardless of disturbances.

In [52], for achieving a seamless state transition, a nonlinear-simplex algorithm was proposed for searching the optimal controller parameters with the aim of minimizing voltage deviation. The proposed control improved voltage stability and phase synchronization under state transition. The effectiveness of the proposed control strategy was checked through PSCAD/EMTDC and RTDS simulators. Similarly, in [176], a simplified model of

an industrial facility microgrid was developed and simulated using RTDS Technologies' real-time digital simulator. The study focused on proposing and evaluating the performance of an IEC 61850 Generic Object-Oriented Substation Event Protocol (GOOSE)-based control strategy for managing the transition of the microgrid from the grid-connected to the island mode.

In [173], the investigation explored the diversity and connection between control structures in different operating modes of a microgrid. A unified inner loop based on 2-DOF (Two-Degrees-of-Freedom) theory was introduced, allowing all operating modes of the converter in the microgrid to share the same inner loop. This approach eliminated the need for reconfiguring the entire control structure when switching between operation modes and instead adjusted the inner referring instructions. The simulation and experimental results from a low-voltage prototype model were presented to validate the efficiency of the proposed strategy. The findings provided a theoretical and practical foundation for future experiments in high-voltage applications.

#### 6.3.2. Unified Scheme with Droop Control Method

The principles of droop techniques have been widely applied to the parallel operation of DG inverters, incorporating voltage and/or current control loops. This approach can be applied to all the control scenarios mentioned earlier [58]. Figure 14 shows the general block diagram of the control strategy employing the droop regulator. However, a significant limitation of this strategy is its poor dynamic performance, as the bandwidth of the external droop control loop is considerably lower than that of the internal voltage loop.



Figure 14. Block diagram of droop smooth transition structure.

Researchers in [55] proposed a droop control to ensure robust operation of an MG with a smooth transition. In the GC and SA modes, the inverters used the droop control method to regulate the actual power flow without any external communication being required between them. Building upon this principle, the authors in [56] presented a smooth transition based on a droop control for several inverters connected to the networks. In addition, a virtual inductance loop was designed to reduce oscillating current due to the mode transfer between the SA and GC modes. The proposed method effectively improved the transient response of the current to an acceptable level without triggering the system's protection mechanisms.

In the literature [55,58,154,177–182], a unified control structure for automatic transition based on the droop command was proposed for multiple inverters. When the grid was available, the inverters operated in current control mode by injecting energy into the grid.

32 of 41

In the event of a grid failure, all inverters automatically switch to droop control mode to achieve proportional power sharing and return to connected control mode when grid availability is restored. Unlike existing control methods, the proposed strategy eliminated the need for communication-based supervisory control or a dedicated storage facility to achieve a seamless mode transition.

Studies such as [58,154,177–183] used non-conventional controllers to achieve a smooth transition between the GC and SA. In [58], a unified fuzzy droop trajectory was proposed for scheduling reference trajectories for ensuring seamless transfer operations without reconfiguration of the control structure. Indeed, the voltage regulator was activated and deactivated automatically according to the designer's fuzzy droop and the operating mode. Similarly, in order to achieve equal power sharing among parallel inverters during the transition of a microgrid (without significant oscillations, overshoots, or circulating currents between inverters), a novel hybrid control scheme was proposed. This scheme combined a unified robust droop controller (URDC) with a quasi-proportional resonant (QPR) regulator for parallel DG inverters [183]. Furthermore, an improved adaptive estimator for the reference current magnitude was integrated to accommodate dynamic load variations. A compulsory turn-off strategy based on the fuzzy logic control of the converter output voltage was proposed in [177]. Instead of detecting the polarity of the voltage or current, the strategy applied a variable reverse voltage across the conducting thyristor by dynamically adjusting the output voltage reference instruction and closed-loop control parameters based on the changing rate. In [178], the authors presented an intelligent transition control system for operating a 4 KW PV application in both the GC and SA modes. The approach was developed using machine learning (ML) algorithms and a hybrid control strategy. Initially, an ANN algorithm was trained in the simulation environment with various scenarios in SA and GC modes. Furthermore, the inverter control action was performed based on the trained classifier output to perform the transition and achieve both SA and GC controls. Within the same smooth transition with intelligent control tasks, numerous research works were created. By combining control techniques, inverse droop control, virtual impedance control, and current control, an intelligent coordinated control strategy based on the Adaptive Neuro-Fuzzy Inference system [180] was developed. To recover the voltage and frequency magnitudes to their nominal values versus all deviations, an intelligent approach based on brain-emotional learning (BEL) was proposed in [174]. Additionally, a Levenberg–Marquardt (LM)-algorithm-based Artificial Neural Network (ANN) was investigated for PV systems [176].

Other research papers have addressed concerns by focusing on predictive control methods. In [179], a novel hybrid control strategy for energy storage through model predictive controllers and a two-degree-of-freedom algorithm was proposed to realize a seamless microgrid with a unified control structure. The predictive controller model was adopted to reduce the control layer's PWM module. When switching microgrid operation modes, the smooth transition of the microgrid's voltage and frequency was realized in the application layer by adding decoupling inductance and introducing microgrid voltage and angular frequency feedforward compensation to carry out P-Q and modified droop controls. Similarly, a Predictive Fuzzy Logic-Based Energy Management System was used to determine the system's operation mode based on real-time data to establish smooth mode variations [181]. The proposed strategy was developed using a Dual Pulse (DP) optimization methodology for a magnetically coupled microgrid with 20 different grid-connected and off-grid operation modes.

#### 7. Future Trends

As presented in previous sections, several technical solutions have been developed for the detection and transition management of islanding in microgrids. Beyond the algorithmic aspects, economic and regulatory challenges and technological opportunities should be taken into account to successfully integrate detection and transition management solutions into the microgrids to be installed.

- □ **Economic Challenges:** The complexity of the islanding function can significantly increase investment and infrastructure costs compared to mini-grids that do not include this functionality and can thus be more cost-competitive. The costs and added value of islanding functionalities must, therefore, be estimated and promoted to encourage investors to adopt the full set of microgrid features;
- □ **Regulatory Challenges:** In addition to the question of the economic viability of microgrids, it remains difficult to define if they are private or if they have to respond to a public service mission. The regulatory framework can be different from state to state or even from region to region, which makes the transition functionalities completely justified in an open regulatory framework and less justified in a limited framework.

The regulatory framework and business models need to be studied to assess the extent to which transition functions should be integrated.

- □ **Technology Opportunities:** Nowadays, several technologies, either at the material level or at the communication level, can be applied to upgrade microgrid performances in the face of unexpected events such as unplanned islanding. Likewise, the rapidly advancing field of remote sensing and monitoring technology offers valuable assistance in implementing seamless transition strategies. Remote sensing technology in particular serves as a significant means of gathering data with benefits such as quick, extensive, and continuous monitoring capabilities while being less constrained. Consequently, this enables the regular extraction and monitoring of information pertaining to desired problems [184];
- Development of Digital Technologies: The emergence of low-cost, high-performance processors and IoT devices enables the design and implementation of improved solutions for the monitoring and transiting mode management of microgrids. Real-time data collection can play an important role in dealing with these challenges, thanks to technological advancements in communication and IoT devices. Hence, precise data forecasting, scenario generation, and artificial intelligence (AI) models based on historical data are all promising methods for developing a smooth transition. In this context, the incorporation of new technologies and numerous intelligent algorithms such as reinforcement learning, stochastic-based algorithms, deep learning, and heuristic optimization algorithms;
- □ **Superconducting Materials:** The use of superconducting cables and storages that have current-limiting characteristics can be an interesting solution in high-power microgrid applications [185–187]:
  - Superconducting cables can absorb short-circuit energy; thus, there are fewer overvoltage spikes during the interruption process;
  - Superconducting cables have a very fast response time to faults. As a result, vacuum circuit breakers do not need to open as rapidly, thus reducing the constraints linked to switching stress;
  - The SES can absorb short-circuit energy; hence, there are fewer over-voltage spikes during the interruption process.

#### 8. Conclusions

This paper provided a comprehensive overview of the literature concerning the islanding function, which is one of the added values of microgrids. For this purpose, a brief reminder on microgrids and hierarchical controls was given before focusing on the islanding functions involving the detection and management of unplanned islanding.

This review will aid in developing future MGs to include a control structure, guaranteeing mode transition disturbance mitigation through early control schemes. To the authors' knowledge, this is the first time that an exhaustive MG review covering all the transition control structures associated with microgrid systems has been performed. Various definitions and descriptions from the literature have been compiled in this paper. A deep review of the microgrid frameworks and microgrid functionalities has been presented. Moreover, we shall pay particular attention to islanding conditions (concept, types, IDM, and standard). This rigorous review highlighted islanding conditions, in particular the issues with unintentional islanding and their quantitative risks (material damage and economic losses). The control system analysis for all MG operation modes provided a comparison of the smooth transition strategy process. A review of the control transition structure revealed a distinct physical division as well as a comparison of the strategies involved in the MG concept. The transition control approaches were broadly classified into five types (unified control, switch process, feedforward control, droop control, and dispatching unit), and the techniques proposed in each category were extensively compared. The results of each transition strategy's analysis and review were suitably summarized and classified in Table 5 and Figures 9-13, allowing for a comprehensive overview of the main design options and relevant issues involved in each control scheme. On the whole, based on the preceding discussion, it is possible to conclude that each proposed transition strategy had its own set of characteristics, benefits, drawbacks, and applications. Major potentials such as design simplicity, additional cost, application control, reconfiguration at the control structure, and resiliency improvement have been highlighted. Finally, the future trends for the transition process in MGs are discussed. The operation of MGs is still the main topic of future research, notably with technological advancements: intelligent algorithms and superconducting storage systems as solutions for developing a smooth MG transition.

**Author Contributions:** Conceptualization, J.H. and A.H.; methodology A.H. and H.T.; software, J.H. and A.H.; validation, A.H., A.E.M.B. and A.S.; formal analysis, A.H. and H.T.; resources, J.H. and A.H.; data curation, A.H., A.E.M.B. and A.S.; writing—original draft preparation, J.H., A.H., A.E.M.B. and A.S.; writing—review and editing, J.H., A.H., A.E.M.B. and A.S.; visualization, J.H. and H.T.; supervision, A.H. and H.T. All authors have read and agreed to the published version of the manuscript.

Funding: This research received no external funding.

Data Availability Statement: Not applicable.

Conflicts of Interest: The authors declare no conflict of interest.

#### References

- Dagar, A.; Pankaj, G.; Vandana, N. Microgrid protection: A comprehensive review. *Renew. Sustain. Energy Rev.* 2021, 149, 111401. [CrossRef]
- Xiang, Y.; Cai, H.; Liu, J.; Zhang, X. Techno-economic design of energy systems for airport electrification: A hydrogen-solar-storage integrated microgrid solution. *Appl. Energy* 2021, 283, 116374. [CrossRef]
- Roslan, M.; Hannan, M.; Ker, P.J.; Uddin, M. qMicrogrid control methods toward achieving sustainable energy management. *Appl. Energy* 2019, 240, 583–607. [CrossRef]
- Andishgar, M.H.; Gholipour, E.; Hooshmand, R.-A. An overview of control approaches of inverter-based microgrids in islanding mode of operation. *Renew. Sustain. Energy Rev.* 2017, 80, 1043–1060. [CrossRef]
- Arfeen, Z.A.; Khairuddin, A.B.; Larik, R.M.; Saeed, M.S. Control of distributed generation systems for microgrid applications: A technological review. *Int. Trans. Electr. Energy Syst.* 2019, 29, e12072. [CrossRef]
- 6. van der Walt, H.L.; Bansal, R.C.; Naidoo, R. PV based distributed generation power system protection: A review. *Renew. Energy Focus* **2018**, *24*, 33–40. [CrossRef]
- Han, Y.; Li, H.; Shen, P.; Coelho, E.A.A.; Guerrero, J.M. Review of active and reactive power sharing strategies in hierarchical controlled microgrids. *IEEE Trans. Power Electron.* 2016, *3*, 2427–2451. [CrossRef]
- Zeb, K.; Uddin, W.; Khan, M.A.; Ali, Z.; Ali, M.U.; Christofides, N.; Kim, H.J. A comprehensive review on inverter topologies and control strategies for grid connected photovoltaic system. *Renew. Sustain. Energy Rev.* 2018, 94, 1120–1141. [CrossRef]
- 9. Hirsch, A.; Parag, Y.; Guerrero, J. Microgrids: A review of technologies, key drivers, and outstanding issues. *Renew. Sustain. Energy Rev.* **2018**, *90*, 402–411. [CrossRef]
- 10. Razavi, S.E.; Rahimi, E.; Javadi, M.S.; Nezhad, A.E.; Lotfi, M.; Shafie-khah, M.; Catalão, J.P. Impact of distributed generation on protection and voltage regulation of distribution systems: A review. *Renew. Sustain. Energy Rev.* 2019, 105, 157–167. [CrossRef]
- 11. Mohammed, A.; Refaat, S.S.; Bayhan, S.; Abu-Rub, H. Ac microgrid control and management strategies: Evaluation and review. *IEEE Power Electron. Mag.* 2019, *6*, 18–31. [CrossRef]
- 12. Faisal, M.; Hannan, M.A.; Ker, P.J.; Hussain, A.; Mansor, M.B.; Blaabjerg, F. Review of energy storage system technologies in microgrid applications: Issues and challenges. *IEEE Access* 2018, *6*, 35143–35164. [CrossRef]

- 13. Rajesh, K.S.; Dash, S.S.; Rajagopal, R.; Sridhar, R. A review on control of ac microgrid. *Renew. Sustain. Energy Rev.* 2017, 71, 814–819. [CrossRef]
- Davison, M.J.; Summers, T.J.; Townsend, C.D. A review of the distributed generation landscape, key limitations of traditional microgrid concept & possible solution using an enhanced microgrid architecture. In Proceedings of the 2017 IEEE Southern Power Electronics Conference (SPEC), Puerto Varas, Chile, 4–7 December 2017; IEEE: Piscataway, NJ, USA, 2017; pp. 1–6.
- 15. Yoldaş, Y.; Önen, A.; Muyeen, S.M.; Vasilakos, A.V.; Alan, İ. Enhancing smart grid with microgrids: Challenges and opportunities. *Renew. Sustain. Energy Rev.* 2017, 72, 205–214. [CrossRef]
- 16. Bandeiras, F.; Pinheiro, E.; Gomes, M.; Coelho, P.; Fernandes, J. Review of the cooperation and operation of microgrid clusters. *Renew. Sustain. Energy Rev.* **2020**, *133*, 110311. [CrossRef]
- 17. Dehghanpour, K.; Nehrir, H. Real-time multiobjective microgrid power management using distributed optimization in an agent-based bargaining framework. *IEEE Trans. Smart Grid* 2017, *9*, 6318–6327. [CrossRef]
- Llanos, J.; Olivares, D.E.; Simpson-Porco, J.W.; Kazerani, M.; Saez, D. A novel distributed control strategy for optimal dispatch of isolated microgrids considering congestion. *IEEE Trans. Smart Grid* 2019, 10, 6595–6606. [CrossRef]
- 19. Wang, Y.; Li, Y.; Cao, Y.; Tan, Y.; He, L.; Han, J. Hybrid AC/DC microgrid architecture with comprehensive control strategy for energy management of smart building. *Int. J. Electr. Power Energy Syst.* **2018**, *101*, 151–161. [CrossRef]
- Arif, M.; Saad, B.; Hasan, M.A. Microgrid architecture, control, and operation. In *Hybrid-Renewable Energy Systems in Microgrids*; Woodhead Publishing: Delhi, India, 2018; pp. 23–37.
- 21. Hang, Y.; Niu, S.; Zhang, Y.; Jian, L. An integrated and reconfigurable hybrid AC/DC microgrid architecture with autonomous power flow control for nearly/net zero energy buildings. *Appl. Energy* **2020**, *263*, 114610.
- 22. Lou, G.; Gu, W.; Wang, J.; Wang, J.; Gu, B. A unified control scheme based on a disturbance observer for seamless transition operation of inverter-interfaced distributed generation. *IEEE Trans. Smart Grid* 2017, *9*, 5444–5454. [CrossRef]
- López, M.A.G.; de Vicuña, J.L.G.; Miret, J.; Castilla, M.; Guzmán, R. Control strategy for grid-connected three-phase inverters during voltage sags to meet grid codes and to maximize power delivery capability. *IEEE Trans. Power Electron.* 2018, 33, 9360–9374. [CrossRef]
- D'Silva, S.; Shadmand, M.B.; Abu-Rub, H. Microgrid Control Strategies for Seamless Transition Between Grid-Connected and Islanded Modes. In Proceedings of the 2020 IEEE Texas Power and Energy Conference (TPEC), College Station, TX, USA, 6–7 February 2020; pp. 1–6.
- 25. Yadav, M.; Pal, N.; Saini, D.K. Microgrid Control, Storage, and Communication Strategies to Enhance Resiliency for Survival of Critical Load. *IEEE Access* 2020, *8*, 169047–169069. [CrossRef]
- 26. Mahmoud, A.A.; Hafez, A.A.; Yousef, A.M.; Gaafar, M.A.; Orabi, M.; Ali, A.F. Fault-tolerant modular multilevel converter for a seamless transition between stand-alone and grid-connected microgrid. *IET Power Electron.* **2023**, *16*, 11–25. [CrossRef]
- 27. Chun, Z.; Chen, M.; Wang, Z. Study on control scheme for smooth transition of micro-grid operation modes. *Power Syst. Prot. Control.* **2011**, *39*, 1–5.
- Arafat, N.; Palle, S.; Sozer, Y.; Husain, I. Transition control strategy between standalone and grid-connected operations of voltage-source inverters. *IEEE Trans. Ind. Appl.* 2012, 48, 1516–1525. [CrossRef]
- Gonzales-Zurita, Ó.; Clairand, J.M.; Peñalvo-López, E.; Escrivá-Escrivá, G. Review on multi-objective control strategies for distributed generation on inverter-based microgrids. *Energies* 2020, 13, 3483. [CrossRef]
- 30. Ganjian-Aboukheili, M.; Shahabi, M.; Shafiee, Q.; Guerrero, J.M. Seamless transition of microgrids operation from grid-connected to islanded mode. *IEEE Trans. Smart Grid* 2019, *11*, 2106–2114. [CrossRef]
- 31. D'Silva, S.; Shadmand, M.; Bayhan, S.; Abu-Rub, H. Towards grid of microgrids: Seamless transition between grid-connected and islanded modes of operation. *IEEE Open J. Ind. Electron. Soc.* **2020**, *1*, 66–81. [CrossRef]
- 32. Tran, T.-V.; Chun, T.-W.; Lee, H.-H.; Kim, H.-G.; Nho, E.-C. PLL-based seamless transfer control between grid-connected and islanding modes in grid-connected inverters. *IEEE Trans. Power Electron.* **2013**, *29*, 5218–5228. [CrossRef]
- 33. Hou, X.; Sun, Y.; Lu, J.; Zhang, X.; Koh, L.H.; Su, M.; Guerrero, J.M. Distributed hierarchical control of AC microgrid operating in grid-connected, islanded and their transition modes. *IEEE Access* 2018, *6*, 77388–77401. [CrossRef]
- 34. Jia, L.; Zhu, Y.; Du, S.; Wang, Y. Analysis of the transition between multiple operational modes for hybrid AC/DC microgrids. *CSEE J. Power Energy Syst.* 2018, 4, 49–57. [CrossRef]
- 35. Cagnano, A.; De Tuglie, E.; Mancarella, P. Microgrids: Overview and guidelines for practical implementations and operation. *Appl. Energy* **2020**, *258*, 114039. [CrossRef]
- Jiang, Q.; Xue, M.; Geng, G. Energy management of microgrid in grid-connected and stand-alone modes. *IEEE Trans. Power Syst.* 2013, 28, 3380–3389. [CrossRef]
- 37. Sun, Y.; de Jong, E.C.W.; Wang, X.; Yang, D.; Blaabjerg, F.; Cuk, V.; Cobben, J.F.G. The impact of PLL dynamics on the low inertia power grid: A case study of Bonaire Island power system. *Energies* **2019**, *12*, 1259. [CrossRef]
- 38. Balaguer-Alvarez, I.J.; Supatti, U.; Rivera, J.G.C.; Peng, F.Z. Seamless Transitions between Grid-Connected and Stand-Alone Operations of Distributed Generation in Microgrids. *Int. J. Eng. Res. Dev.* **2014**, *10*, 6–16.
- 39. Qinfei, S.; Guerrero, J.M.; Jing, T.; Vasquez, J.C.; Yang, R. An islanding detection method by using frequency positive feedback based on FLL for single-phase microgrid. *IEEE Trans. Smart Grid* **2017**, *8*, 1821–1830.

- Aillane, A.; Dahech, K.; Chrifi-Alaoui, L.; Chouder, A.; Damak, T.; Hadjkaddour, A.; Bussy, P. The Design and Processor-In-The-Loop Implementation of a Super-Twisting Control Algorithm Based on a Luenberger Observer for a Seamless Transition between Grid-Connected and Stand-Alone Modes in Microgrids. *Energies* 2023, 16, 3878. [CrossRef]
- Ashabani, S.M.; Mohamed, Y.A.R.I. New family of microgrid control and management strategies in smart distribution grids— Analysis, comparison and testing. *IEEE Trans. Power Syst.* 2014, 29, 2257–2269. [CrossRef]
- 42. Lo, K.Y.; Chen, Y.M. Design of a Seamless Grid-Connected Inverter for Microgrid Applications. *IEEE Trans. Smart Grid* 2019, 11, 194–202. [CrossRef]
- 43. Teodorescu, R.; Blaabjerg, F. Flexible control of small wind turbines with grid failure detection operating in stand-alone and grid-connected mode. *IEEE Trans. Power Electron.* **2004**, *19*, 1323–1332. [CrossRef]
- 44. Hwang, T.S.; Park, S.Y. A seamless control strategy of a distributed generation inverter for the critical load safety under strict grid disturbances. *IEEE Trans. Power Electron.* 2013, 28, 10. [CrossRef]
- Harirchi, F.; Simões, M.G.; Babakmehr, M.; Al-Durra, A.; Muyeen, S.M. Designing smart inverter with unified controller and smooth transition between grid-connected and islanding modes for microgrid application. In Proceedings of the Industry Applications Society Annual Meeting, Addison, TX, USA, 18–22 October 2015; IEEE: Piscataway, NJ, USA, 201; pp. 1–7.
- Liu, Q.; Caldognetto, T.; Buso, S. Seamless Mode Transitions for Triple-Loop Controlled Interlinking Converters. In Proceedings of the 19th Workshop on Control and Modeling for Power Electronics (COMPEL), Padua, Italy, 25–28 June 2018; IEEE: Piscataway, NJ, USA, 2018; pp. 1–7.
- 47. Liu, Z.; Liu, J. Indirect current control based seamless transfer of three-phase inverter in distributed generation. *IEEE Trans. Power Electron.* **2014**, *29*, 3368–3383. [CrossRef]
- Liu, Z.; Liu, J.; Zao, Y. A unified control strategy for three-phase inverter in distributed generation. *IEEE Trans. Power Electron.* 2014, 29, 1176–1191. [CrossRef]
- Lim, K.; Choi, J. PR based indirect current control for seamless transfer of grid-connected inverter. In Proceedings of the IEEE 8th International Power Electronics and Motion Control Conference (IPEMC-ECCE Asia), Hefei, China, 22–26 May 2016; pp. 3749–3755.
- 50. Ghartemani, M.K.; Khajehoddin, S.A.; Piya, P.; Ebrahimi, M. Universal Controller for Three-Phase Inverters in a Microgrid. *IEEE J. Emerg. Sel. Top. Power Electron.* **2016**, *4*, 1342–1353. [CrossRef]
- 51. Yi, Z.; Dong, W.; Etemadi, A.H. A unified control and power management scheme for pv-battery-based hybrid microgrids for both grid-connected and islanded modes. *IEEE Trans. Smart Grid* **2018**, *9*, 6. [CrossRef]
- 52. Li, Y.; Fu, L.; Meng, K.; Dong, Z.Y.; Muttaqi, K.M.; Du, W. Autonomous Control Strategy for Microgrid Operating Modes Smooth Transition. *IEEE Access* 2020, *8*, 142159–142172. [CrossRef]
- 53. Arafat, M.N.; Elrayyah, A.; Sozer, Y. An effective smooth transition control strategy using droop-based synchronization for parallel inverters. *IEEE Trans. Ind. Appl.* 2015, *51*, 2443–2454. [CrossRef]
- 54. Zheng, F.; Deng, C.; Chen, L.; Li, S.; Liu, Y.; Liao, Y. Transient performance improvement of microgrid by a resistive superconducting fault current limiter. *IEEE Trans. Appl. Supercond.* 2015, 25, 5602305. [CrossRef]
- 55. Singh, B.; Pathak, G.; Panigrahi, B.K. Seamless Transfer of Renewable-Based Microgrid Between Utility Grid and Diesel Generator. *IEEE Trans. Power Electron.* **2017**, *33*, 8427–8437. [CrossRef]
- 56. Hu, S.H.; Lee, T.L.; Kuo, C.Y.; Guerrero, J.M. A Riding-through Technique for Seamless Transition between Islanded and Grid-Connected Modes of Droop-Controlled Inverters. *Energies* **2016**, *9*, 732. [CrossRef]
- 57. Kulkarni, O.V.; Doolla, S.; Fernandes, B.G. Mode transition control strategy for multiple inverter-based distributed generators operating in grid-connected and standalone mode. *IEEE Trans. Ind. Appl.* **2017**, *53*, 5927–5939. [CrossRef]
- 58. Jihed, H.; Azeddine HHafedh, T.; Mohamed, M. Fuzzy logic approach for smooth transition between grid-connected and stand-alone modes of three-phase DG-inverter. *Electr. Power Syst. Res.* **2019**, *175*, 105892.
- 59. Yazdani, S.; Ferdowsi, M.; Shamsi, P. Internal model based smooth transition of a three-phase inverter between islanded and grid-connected modes. *IEEE Trans. Energy Convers.* **2019**, *35*, 405–415. [CrossRef]
- 60. Wang, J.; Pratt, A.; Prabakar, K.; Miller, B.; Symko-Davies, M. Development of an integrated platform for hardware-in-the-loop evaluation of microgrids prior to site commissioning. *Appl. Energy* **2021**, *290*, 116755. [CrossRef]
- 61. Jamil, N.; Qassim, Q.S.; Bohani, F.A.; Mansor, M.; Ramachandaramurthy, V.K. Cybersecurity of Microgrid: State-of-the-Art Review and Possible Directions of Future Research. *Appl. Sci.* **2021**, *11*, 9812. [CrossRef]
- 62. Konidena, R.; Sun, B.; Bhandari, V. Missing discourse on microgrids–The importance of transmission and distribution infrastructure. *Electr. J.* **2020**, *33*, 106727. [CrossRef]
- 63. Rickerson, W.; Zitelman, K. Valuing Resilience for Microgrids: Challenges, Innovative Approaches, and State Needs; Report for National Association of State Energy Officials (NASEO) and the National Association of Regulatory Utility Commissioners (NARUC); Microgrids State Working Group: Arlington, Virginia, 2022.
- 64. Wang, H.; Yan, Z.; Shahidehpour, M.; Xu, X.; Zhou, Q. Quantitative evaluations of uncertainties in multivariate operations of microgrids. *IEEE Trans. Smart Grid* 2020, *11*, 2892–2903. [CrossRef]
- 65. Feng, W.; Jin, M.; Liu, X.; Bao, Y.; Marnay, C.; Yao, C.; Yu, J. A review of microgrid development in the United States–A decade of progress on policies, demonstrations, controls, and software tools. *Appl. Energy* **2018**, 228, 1656–1668. [CrossRef]
- Modarresi, M.S.; Abada, B.; Sivaranjani, S.; Xie, L.; Chellam, S. Planning of survivable nano-grids through jointly optimized water and electricity: The case of Colonias at the Texas-Mexico border. *Appl. Energy* 2020, 278, 115586. [CrossRef]

- 67. de Oliveira, G.C.; Bertone, E.; Stewart, R.A. Challenges, opportunities, and strategies for undertaking integrated precinct-scale energy–water system planning. *Renew. Sustain. Energy Rev.* 2022, 161, 112297. [CrossRef]
- Ebrahim, A.F.; Elsayad, N.; Mohammed, O.A. Medium Voltage DC Testbed: A Hardware Based Tool to Integrate DC Microgrids/Nanogrids to the Utility Infrastructure. In Proceedings of the 2018 IEEE Industry Applications Society Annual Meeting (IAS), Portland, OR, USA, 23–27 September 2018; IEEE: Piscataway, NJ, USA, 2018.
- Parol, M.; Wójtowicz, T.; Księżyk, K.; Wenge, C.; Balischewski, S.; Arendarski, B. Optimum management of power and energy in low voltage microgrids using evolutionary algorithms and energy storage. *Int. J. Electr. Power Energy Syst.* 2020, 119, 105886. [CrossRef]
- 70. Carli, R.; Dotoli, M.; Jantzen, J.; Kristensen, M.; Ben Othman, S. Energy scheduling of a smart microgrid with shared photovoltaic panels and storage: The case of the Ballen marina in Samsø. *Energy* **2020**, *198*, 117188. [CrossRef]
- 71. Gouveia, C.; Moreira, C.; Rua, D.; Lopes, J.P. Microgrid Demonstration Projects and Pilot Sites. In *Microgrids Design and Implementation*; Springer: Cham, Switzerland, 2019; pp. 407–445.
- 72. Yusof, M.F.M. Enrollment Issue, Power Energy Management Approach and Structure of Control of Renewable Energy Microgrid: A Review. *Int. J. Eng. Technol. Sci.* 2019, *6*, 12–27. [CrossRef]
- 73. Cabello, G.; Navas, S.; Vázquez, I.; Iranzo, A.; Pino, F. Renewable medium-small projects in Spain: Past and present of microgrid development. *Renew. Sustain. Energy Rev.* 2022, *165*, 112622. [CrossRef]
- Jordskar, D. Planning of Residential Microgrid Community with Technical and Economic Analysis. Master's Thesis, University of Agder, Kristiansand, Norway, 2018.
- Sami, M.S.; Abrar, M.; Akram, R.; Hussain, M.M.; Nazir, M.H.; Khan, M.S.; Raza, S. Energy Management of Microgrids for Smart Cities: A Review. *Energies* 2021, 14, 5976. [CrossRef]
- Hosseinnia, H.; Nazarpour, D.; Talavat, V. Utilising reliability-constrained optimisation approach to model microgrid operator and private investor participation in a planning horizon. *IET Gener. Transm. Distrib.* 2018, 12, 5798–5810. [CrossRef]
- Ju, L.; Zhang, Q.; Tan, Z.; Wang, W.; Xin, H.; Zhang, Z. Multi-agent-system-based coupling control optimization model for micro-grid group intelligent scheduling considering autonomy-cooperative operation strategy. *Energy* 2018, 157, 1035–1052. [CrossRef]
- Civlez, M.; Demirtas, M.; Cetinbas, I.; Akinc, H. Security Applications for Reliable Energy Management in a Microgrid. In Proceedings of the 2020 International Conference on Electrical, Communication, and Computer Engineering (ICECCE), Istanbul, Turkey, 12–13 June 2020; IEEE: Piscataway, NJ, USA, 2020.
- Abdulkarim, A.; Faruk, N.; Oloyode, A.O.; Olawoyin, L.A.; Popoola, S.I.; Abdullateef, A.I.; Ibrahim, O.; Surajudeen-Bakinde, N.T.; Abdelkader, S.M.; Morrow, J.D.; et al. State of the art in research on optimum design, reliability and control of renewable energy microgrids. *ELEKTRIKA-J. Electr. Eng.* 2018, *17*, 23–35. [CrossRef]
- Yoshida, Y.; Farzaneh, H. Optimal design of a stand-alone residential hybrid Microgrid system for enhancing renewable energy deployment in Japan. *Energies* 2020, 13, 1737. [CrossRef]
- Tushar, W.; Yuen, C.; Saha, T.K.; Morstyn, T.; Chapman, A.C.; Alam, M.J.E.; Hanif, S.; Poor, H.V. Peer-to-peer energy systems for connected communities: A review of recent advances and emerging challenges. *Appl. Energy* 2021, 282, 116131. [CrossRef]
- Akagi, S.; Yoshizawa, S.; Ito, M.; Fujimoto, Y.; Miyazaki, T.; Hayashi, Y.; Tawa, K.; Hisada, T.; Yano, T. Multipurpose control and planning method for battery energy storage systems in distribution network with photovoltaic plant. *Int. J. Electr. Power Energy Syst.* 2020, 116, 105485. [CrossRef]
- 83. Martin-Martínez, F.; Sánchez-Miralles, A.; Rivier, M. A literature review of Microgrids: A functional layer based classification. *Renew. Sustain. Energy Rev.* 2016, 62, 1133–1153. [CrossRef]
- Hossain, E.; Kabalci, E.; Bayindir, R.; Perez, R. Microgrid testbeds around the world: State of art. *Energy Convers. Manag.* 2014, 86, 132–153. [CrossRef]
- Bertolotti, V.; Procopio, R.; Rosini, A.; Bracco, S.; Delfino, F.; Soh, C.B. Energy Management System for Pulau Ubin Islanded Microgrid Test-bed in Singapore. In Proceedings of the 2020 IEEE International Conference on Environment and Electrical Engineering and 2020 IEEE Industrial and Commercial Power Systems Europe (EEEIC/I&CPS Europe), Madrid, Spain, 9–12 June 2020; IEEE: Piscataway, NJ, USA, 2020.
- 86. Yoo, Y.; Jang, G.; Lee, J.; Jung, S. Stochastic forecast error estimation of high PV penetration system considering net-load/PV decoupling for microgrid operation. *IET Renew. Power Gener.* 2022, *16*, 2152–2162. [CrossRef]
- 87. Cen, Z.; Kubiak, P.; López, C.M.; Belharouak, I. Demonstration study of hybrid solar power generation/storage micro-grid system under Qatar climate conditions. *Sol. Energy Mater. Sol. Cells* **2018**, *180*, 280–288. [CrossRef]
- 88. Mabaso, M. A Systematic Literature Review of Hybrid Renewable Energy Micro-Grids in South Africa and Neighbouring Countries; Stellenbosch University: Stellenbosch, South Africa, 2017.
- 89. Boussetta, M.; Motahhir, S.; El Bachtiri, R.; Allouhi, A.; Khanfara, M.; Chaibi, Y. Design and embedded implementation of a power management controller for wind-PV-diesel microgrid system. *Int. J. Photoenergy* **2019**, 2019, 8974370. [CrossRef]
- 90. Dhifli, M.; Lashab, A.; Guerrero, J.M.; Abusorrah, A.; Al-Turki, Y.A.; Cherif, A. Enhanced Intelligent Energy Management System for a Renewable Energy-Based AC Microgrid. *Energies* **2020**, *13*, 3268. [CrossRef]
- 91. Nnaji, E.C.; Adgidzi, D.; Dioha, M.O.; Ewim, D.R.; Huan, Z. Modelling and management of smart microgrid for rural electrification in sub-saharan Africa: The case of Nigeria. *Electr. J.* **2019**, *32*, 106672. [CrossRef]

- Arceo, A.; Biswas, W.K.; John, M. Eco-efficiency improvement of Western Australian remote area power supply. J. Clean. Prod. 2019, 230, 820–834. [CrossRef]
- 93. Farrelly, M.; Tawfik, S. Engaging in disruption: A review of emerging microgrids in Victoria, Australia. *Renew. Sustain. Energy Rev.* **2020**, *117*, 109491. [CrossRef]
- Spertino, F.; Ciocia, A.; Di Leo, P.; Fichera, S.; Malgaroli, G.; Ratclif, A. Toward the complete self-sufficiency of an NZEBS microgrid by photovoltaic generators and heat pumps: Methods and applications. *IEEE Trans. Ind. Appl.* 2019, 55, 7028–7040. [CrossRef]
- 95. Koirala, B.P.; Koliou, E.; Friege, J.; Hakvoort, R.A.; Herder, P.M. Energetic communities for community energy: A review of key issues and trends shaping integrated community energy systems. *Renew. Sustain. Energy Rev.* 2016, 56, 722–744. [CrossRef]
- El-Bidairi, K.S.; Nguyen, H.D.; Jayasinghe, S.; Mahmoud, T.S.; Penesis, I. A hybrid energy management and battery size optimization for standalone microgrids: A case study for Flinders Island, Australia. *Energy Convers. Manag.* 2018, 175, 192–212. [CrossRef]
- Nikkhah, S.; Sarantakos, I.; Zografou-Barredo, N.M.; Rabiee, A.; Allahham, A.; Giaouris, D. A Joint Risk-and Security-Constrained Control Framework for Real-Time Energy Scheduling of Islanded Microgrids. *IEEE Trans. Smart Grid* 2022, 13, 3354–3368. [CrossRef]
- 98. Eto, J.H.; Lasseter, R.; Klapp, D.; Khalsa, A.; Schenkman, B.; Illindala, M.; Baktiono, S. *The Certs Microgrid Concept, as Demonstrated at the Certs/Aep Microgrid Test Bed*; US Department of Energy: Berkeley, CA, USA, 2018; Volume 53.
- Veilleux, G.; Potisat, T.; Pezim, D.; Ribback, C.; Ling, J.; Krysztofiński, A.; Ahmed, A.; Papenheim, J.; Pineda, A.M.; Sembian, S.; et al. Techno-economic analysis of microgrid projects for rural electrification: A systematic approach to the redesign of Koh Jik off-grid case study. *Energy Sustain. Dev.* 2020, 54, 1–13. [CrossRef]
- 100. Warneryd, M.; Håkansson, M.; Karltorp, K. Unpacking the complexity of community microgrids: A review of institutions' roles for development of microgrids. *Renew. Sustain. Energy Rev.* 2020, 121, 109690. [CrossRef]
- 101. Busch, H.; McCormick, K. Local power: Exploring the motivations of mayors and key success factors for local municipalities to go 100% renewable energy. *Energy Sustain. Soc.* **2014**, *4*, 5. [CrossRef]
- 102. Drysdale, D.; Mathiesen, B.V.; Paardekooper, S. Transitioning to a 100% renewable energy system in Denmark by 2050: Assessing the impact from expanding the building stock at the same time. *Energy Effic.* **2019**, *12*, 37–55. [CrossRef]
- 103. Hossain, A.; Pota, H.R.; Hossain, J.; Blaabjerg, F. Evolution of microgrids with converter-interfaced generations: Challenges and opportunities. *Int. J. Electr. Power Energy Syst.* 2019, 109, 160–186. [CrossRef]
- Piesciorovsky, E.C.; Smith, T.; Ollis, T.B. Protection schemes used in North American microgrids. *Int. Trans. Electr. Energy Syst.* 2020, 30, e12461. [CrossRef]
- 105. Motjoadi, V.; Bokoro, P.N.; Onibonoje, M.O. A review of microgrid-based approach to rural electrification in South Africa: Architecture and policy framework. *Energies* **2020**, *13*, 2193. [CrossRef]
- Triton Market Research. Latin America Microgrid Market 2022–2028. Available online: https://www.marketresearch.com/Triton-Market-Research-v4232/LatinAmerica-Microgrid-32339072/ (accessed on 14 June 2023).
- 107. Rey, J.M.; Vera, G.A.; Acevedo-Rueda, P.; Solano, J.; Mantilla, M.A.; Llanos, J.; Saez, D. A review of microgrids in latin america: Laboratories and test systems. *IEEE Lat. Am. Trans.* **2022**, *20*, 1000–1011. [CrossRef]
- Ocean Energy Smart Grid Integration Project Reaches Full-Scale Testing. BMT. Available online: https://www.bmt.org/news/20 22/ocean-energy-smart-grid-integration-project-reachesfull-scale-testing/ (accessed on 14 June 2023).
- 109. Nasr-Azadani, E.; Su, P.; Zheng, W.; Rajda, J.; Canizares, C.; Kazerani, M.; Veneman, E.; Cress, S.; Wittemund, M.; Manjunath, M.R.; et al. The Canadian renewable energy laboratory: A testbed for microgrids. *IEEE Electrif. Mag.* 2020, *8*, 49–60. [CrossRef]
- Hartani, M.A.; Hamouda, M.; Abdelkhalek, O.; Mekhilef, S. Impacts assessment of random solar irradiance and temperature on the cooperation of the energy management with power control of an isolated cluster of DC-Microgrids. *Sustain. Energy Technol. Assess.* 2021, 47, 101484.
- 111. Giraldez Miner, J.I.; Flores-Espino, F.; MacAlpine, S.; Asmus, P. Phase I Microgrid Cost Study: Data Collection and Analysis of Microgrid Costs in the United States. No. NREL/TP-5D00-67821; National Renewable Energy Lab. (NREL): Golden, CO, USA, 2018.
- Navigant Research Report Finds Annual Microgrid Implementation. Available online: https://www.businesswire.com/ news/home/20171031005328/en/Navigant-Research-Report-Finds-Annual-Microgrid-Implementation-Spending-by-US-Department-of-Defense-Expected-to-Exceed-1-Billion-in-2026 (accessed on 29 September 2022).
- 113. Wu, Y.; Wu, Y.; Guerrero, J.M.; Vasquez, J.C.; Li, J. AC Microgrid Small-Signal Modeling: Hierarchical control structure challenges and solutions. *IEEE Electrif. Mag.* 2019, 7, 81–88.
- 114. Meng, L.; Luna, A.; Díaz, E.R.; Sun, B.; Dragicevic, T.; Savaghebi, M. Flexible system integration and advanced hierarchical control architectures in the microgrid research laboratory of Aalborg University. *IEEE Trans. Ind. Appl.* **2015**, *52*, 1736–1749. [CrossRef]
- Alam, M.N.; Chakrabarti, S.; Ghosh, A. Networked microgrids: State-of-the-art and future perspectives. *IEEE Trans. Ind. Inform.* 2018, 15, 1238–1250. [CrossRef]
- 116. Hou, X.; Han, H.; Zhong, C.; Yuan, W.; Sun, Y.; Su, M. A unified distributed control for grid-connected and islanded modes in multi-bus AC microgrid. In Proceedings of the IECON 2017—43rd Annual Conference of the IEEE Industrial Electronics Society, Beijing, China, 29 October–1 November 2017; IEEE: Piscataway, NJ, USA, 2017; pp. 2377–2382.
- Abhishek, A.; Ranjan, A.; Devassy, S.; Verma, B.K.; Ram, S.K.; Dhakar, A.K. Review of hierarchical control strategies for DC microgrid. *IET Renew. Power Gener.* 2020, 14, 1631–1640.

- Palizban, O.; Kauhaniemi, K.; Guerrero, J.M. Microgrids in active network management–part II: System operation, power quality and protection. *Renew. Sustain. Energy Rev.* 2014, 36, 440–451. [CrossRef]
- 119. Zhang, C.; Lin, W.; Ke, D.; Sun, Y. Smoothing tie-line power fluctuations for industrial microgrids by demand side control: An output regulation approach. *IEEE Trans. Power Syst.* 2019, *34*, 3716–3728. [CrossRef]
- 120. Deng, Y.; Tao, Y.; Chen, G.; Li, G.; He, X. Enhanced power flow control for grid-connected droop-controlled inverters with improved stability. *IEEE Trans. Ind. Electron.* **2016**, *64*, 5919–5929. [CrossRef]
- 121. Wu, W.; Zhou, L.; Chen, Y.; Luo, A.; Dong, Y.; Zhou, X.; Xu, Q.; Yang, L.; Guerrero, J.M. Sequence-impedance-based stability comparison between VSGs and traditional grid-connected inverters. *IEEE Trans. Power Electron.* **2018**, *34*, 46–52. [CrossRef]
- Chen, Y.; Xie, Z.; Zhou, L.; Wang, Z.; Zhou, X.; Wu, W.; Yang, L.; Luo, A. Optimized design method for grid-current-feedback active damping to improve dynamic characteristic of LCL-type grid-connected inverter. *Int. J. Electr. Power Energy Syst.* 2018, 100, 19–28. [CrossRef]
- 123. Gupta, O.H.; Tripathy, M.; Sood, V.K. Islanding detection scheme for converter-based DGs with nearly zero non-detectable zone. *IET Gener. Transm. Distrib.* **2019**, *13*, 5365–5374. [CrossRef]
- Kim, M.S.; Haider, R.; Cho, G.J.; Kim, C.H.; Won, C.Y.; Chai, J.S. Comprehensive review of islanding detection methods for distributed generation systems. *Energies* 2019, 12, 837. [CrossRef]
- 125. Jarraya, I.; Hmad, J.; Trabelsi, H.; Houari, A.; Machmoum, M. An Online Grid Impedance Estimation Using Recursive Least Square For Islanding Detection. In Proceedings of the 2019 16th International Multi-Conference on Systems, Signals & Devices (SSD), Istanbul, Turkey, 21–24 March 2019; IEEE: Piscataway, NJ, USA, 2019; pp. 193–200.
- 126. Braun, M.; Hachmann, C.; Haack, J. Blackouts, restoration, and islanding: A system resilience perspective. *IEEE Power Energy Mag.* **2020**, *18*, 54–63. [CrossRef]
- Ahmad, K.N.E.K.; Selvaraj, J.; Rahim, N.A. A review of the islanding detection methods in grid-connected PV inverters. *Renew. Sustain. Energy Rev.* 2013, 21, 756–766. [CrossRef]
- Koohi-Kamali, S.; Rahim, N.A. Coordinated control of smart microgrid during and after islanding operation to prevent under frequency load shedding using energy storage system. *Energy Convers. Manag.* 2016, 127, 623–646. [CrossRef]
- Executive Office of the President. Council of Economic Advisers. Economic Benefits of Increasing Electric Grid Resilience to Weather Outages. The Council. 2013. Available online: https://www.scirp.org/(S(351jmbntvnsjt1aadkposzje))/reference/ referencespapers.aspx?referenceid=1689889 (accessed on 25 May 2023).
- Colorado, P.J.; Suppioni, V.P.; Filho, A.J.S.; Salles, M.B.C.; Grilo-Pavani, A.P. Security Assessment for the Islanding Transition of Microgrids. *IEEE Access* 2022, 10, 17189–17200. [CrossRef]
- 131. Azimi, S.M.; Lotfifard, S. Supplementary Controller for Seamless Transitions Between Microgrids Operation Modes. *IEEE Trans.* Smart Grid **2021**, 12, 2102–2112. [CrossRef]
- 132. Ananda, S.A.; Gu, J.-C.; Yang, M.-T.; Wang, J.-M.; Chen, J.-D.; Chang, Y.-R.; Lee, Y.-D.; Chan, C.-M.; Hsu, C.-H. Multi-agent system fault protection with topology identification in microgrids. *Energies* **2016**, *10*, 28. [CrossRef]
- 133. Fernández-Porras, P.; Panteli, M.; Quirós-Tortós, J. Intentional controlled islanding: When to island for power system blackout prevention. *IET Gener. Transm. Distrib.* 2018, 12, 3542–3549. [CrossRef]
- Narang, D.; Gonzalez, S.; Ingram, M. A Primer on the Unintentional Islanding Protection Requirement in IEEE Std 1547-2018. No. NREL/TP-5D00-77782; National Renewable Energy Lab. (NREL): Golden, CO, USA, 2022.
- 135. Rhili, S.; Trabelsi, H.; Hmad, J. Modeling of a single-phase grid-connected photovoltaic system. In Proceedings of the 2017 18th International Conference on Sciences and Techniques of Automatic Control and Computer Engineering (STA), Monastir, Tunisia, 21–23 December 2017; IEEE: Piscataway, NJ, USA, 2017.
- 136. Chatterjee, S.; Kumar, P.; Chatterjee, S. A techno-commercial review on grid connected photovoltaic system. *Renew. Sustain. Energy Rev.* **2018**, *81*, 2371–2397. [CrossRef]
- 137. Chkioua, A.; Hmad, J.; Abid, H.; Trabelsi, H.; Houari, A.; Machmoum, M. Design and performance analysis of different resonance passive-damping solutions for LCL filter-based grid-interfaced DG inverter. In Proceedings of the 2019 19th International Conference on Sciences and Techniques of Automatic Control and Computer Engineering (STA), Sousse, Tunisia, 24–26 March 2019; IEEE: Piscataway, NJ, USA, 2019.
- 138. Zamani, R.; Golshan, M.E.H.; Alhelou, H.H.; Hatziargyriou, N. A novel hybrid islanding detection method using dynamic characteristics of synchronous generator and signal processing technique. *Electr. Power Syst. Res.* 2019, 175, 105911. [CrossRef]
- 139. Li, C.; Cao, C.; Cao, Y.; Kuang, Y.; Zeng, L.; Fang, B. A review of islanding detection methods for microgrid. *Renew. Sustain. Energy Rev.* **2014**, *35*, 211–220. [CrossRef]
- 140. Menezes, T.S.; Fernandes, R.A.; Coury, D.V. Intelligent islanding detection with grid topology adaptation and minimum nondetection zone. *Electr. Power Syst. Res.* 2020, *187*, 106470. [CrossRef]
- 141. Jhuma, U.K.; Ahmad, S.; Ahmed, T. A Novel Approach for Secure Hybrid Islanding Detection Considering the Dynamic Behavior of Power and Load in Electrical Distribution Networks. *Sustainability* **2022**, *14*, 12821. [CrossRef]
- 142. Mahmood, H.; Michaelson, D.; Jiang, J. Accurate reactive power sharing in an islanded microgrid using adaptive virtual impedances. *IEEE Trans. Power Electron.* 2014, *30*, 1605–1617. [CrossRef]
- 143. Hemmati, M.; Mohammadi-Ivatloo, B.; Abapour, M.; Anvari-Moghaddam, A. Optimal chance-constrained scheduling of reconfigurable microgrids considering islanding operation constraints. *IEEE Syst. J.* **2020**, *14*, 5340–5349. [CrossRef]

- 144. Tran, T.S.; Nguyen, D.T.; Fujita, G. The analysis of technical trend in islanding operation, harmonic distortion, stabilizing frequency, and voltage of islanded entities. *Resources* **2019**, *8*, 14. [CrossRef]
- 145. Khadem, S.K.; Basu, M.; Conlon, M.F. Intelligent islanding and seamless reconnection technique for microgrid with UPQC. *IEEE J. Emerg. Sel. Top. Power Electron.* 2014, *3*, 483–492. [CrossRef]
- Sun, Y.; Zhong, C.; Hou, X.; Yang, J.; Han, H.; Guerrero, J.M. Distributed cooperative synchronization strategy for multi-bus microgrids. Int. J. Electr. Power Energy Syst. 2017, 86, 18–28. [CrossRef]
- 147. Wu, J.; Zhuo, F.; Zhu, C.; Wang, Z.; Yi, H.; Wei, T. Parameters design of pre-synchronization for multiple virtual synchronous generator based microgrid. In Proceedings of the 2019 IEEE Applied Power Electronics Conference and Exposition (APEC), Anaheim, CA, USA, 17–21 March 2019; IEEE: Piscataway, NJ, USA, 2019; pp. 3184–3188.
- 148. Ramezani, M.; Li, S.; Musavi, F.; Golestan, S. Seamless transition of synchronous inverters using synchronizing virtual torque and flux linkage. *IEEE Trans. Ind. Electron.* 2019, 67, 319–328. [CrossRef]
- 149. Talapur, G.G.; Suryawanshi, H.M.; Xu, L.; Shitole, A.B. A reliable microgrid with seamless transition between grid connected and islanded mode for residential community with enhanced power quality. *IEEE Trans. Ind. Appl.* **2018**, *54*, 5246–5255. [CrossRef]
- 150. Kim, H.-J.; Lee, Y.-S.; Han, B.-M.; Yoon, Y.-D. New scheme for seamless operation for stand-alone power systems. *Energies* **2016**, *8*, 457. [CrossRef]
- 151. Hamrouni, N.; Jraidi, M.; Dhouib, A.; Cherif, A. Design of a command scheme for grid connected PV systems using classical controllers. *Electr. Power Syst. Res.* 2017, 143, 503–512. [CrossRef]
- 152. Golestan, S.; Guerrero, J.M.; Vasquez, J.C.; Abusorrah, A.M.; Al-Turki, Y. Abusorrah, and Yusuf Al-Turki. A study on three-phase FLLs. *IEEE Trans. Power Electron.* **2018**, *34*, 213–224. [CrossRef]
- 153. Ali, Z.; Christofides, N.; Hadjidemetriou, L.; Kyriakides, E.; Yang, Y.; Blaabjerg, F. Three-phase phase-locked loop synchronization algorithms for grid-connected renewable energy systems: A review. *Renew. Sustain. Energy Rev.* 2018, 90, 434–452. [CrossRef]
- 154. Roselyn, J.P.; Ravi, A.; Devaraj, D.; Venkatesan, R.; Sadees, M.; Vijayakumar, K. Intelligent coordinated control for improved voltage and frequency regulation with smooth switchover operation in LV microgrid. *Sustain. Energy Grids Netw.* 2020, 22, 100356. [CrossRef]
- 155. Sadeque, F.; Sharma, D.; Mirafzal, B. Seamless Grid-Following to Grid-Forming Transition of Inverters Supplying a Microgrid. In Proceedings of the 2023 IEEE Applied Power Electronics Conference and Exposition (APEC), Orlando, FL, USA, 19–23 March 2023; IEEE: Piscataway, NJ, USA, 2023.
- 156. Patra, S.; Basu, M. Double-layered droop control-based frequency restoration and seamless reconnection of isolated neighboring microgrids for power sharing. *IEEE J. Emerg. Sel. Top. Power Electron.* 2022, 10, 6231–6242. [CrossRef]
- 157. Puchalapalli, S.; Singh, B. A novel control scheme for wind turbine driven DFIG interfaced to utility grid. *IEEE Trans. Ind. Appl.* **2020**, *56*, 2925–2937. [CrossRef]
- 158. Borkute, R.; Malwar, N. Control for grid connected and intentional islanding of distributed power generation. *Int. J. Trend Sci. Res. Dev.* **2019**, *3*, 333–336. [CrossRef]
- 159. A Awal, M.; Yu, H.; Tu, H.; Lukic, S.M.; Husain, I. Hierarchical control for virtual oscillator based grid-connected and islanded microgrids. *IEEE Trans. Power Electron.* 2019, *35*, 988–1001. [CrossRef]
- El-Ebiary, A.H.; Attia, M.A.; Marei, M.I. An Adaptive Unified Seamless Control Strategy for Distributed Generator Inverter. In Proceedings of the 2019 IEEE Conference on Power Electronics and Renewable Energy (CPERE), Aswan, Egypt, 23–25 October 2019; IEEE: Piscataway, NJ, USA, 2019.
- Meng, X.; Guo, H.; Wang, X.; He, M.; Liu, J. Seamless Transition for Parallel Inverters with Novel Self-Adaptive Hybrid Controller and Presynchronization Unit. *IEEE J. Emerg. Sel. Top. Power Electron.* 2022, 10, 5819–5832. [CrossRef]
- Li, X.; Zhang, H.; Shadmand, M.B.; Balog, R.S. Model predictive control of a voltage-source inverter with seamless transition between islanded and grid-connected operations. *IEEE Trans. Ind. Electron.* 2017, 64, 7906–7918. [CrossRef]
- 163. Guerrero, J.M.; Vasquez, J.C.; Matas, J.; Castilla, M.; de Vicuna, L.G. Control strategy for flexible microgrid based on parallel line-interactive UPS systems. *IEEE Trans. Ind. Electron.* **2008**, *56*, 726–736. [CrossRef]
- 164. Sowa, I.; Tran, T.T.; Heins, T.; Raisz, D.; Monti, A. An average consensus algorithm for seamless synchronization of andronov-hopf oscillator based multi-bus microgrids. *IEEE Access* **2021**, *9*, 90441–90454. [CrossRef]
- 165. Zhang, Q.; Zhuang, X.; Liu, Y.; Wang, C.; Guo, H. A novel control strategy for mode seamless switching of PV converter in DC microgrid based on double integral sliding mode control. *ISA Trans.* **2020**, *100*, 469–480. [CrossRef]
- 166. Mi, Y.; Chen, X.; Ji, H.; Ji, L.; Fu, Y.; Wang, C.; Wang, J. The coordinated control strategy for isolated DC microgrid based on adaptive storage adjustment without communication. *Appl. Energy* **2019**, 252, 113465. [CrossRef]
- 167. Kumar, S.; Singh, B. Seamless operation and control of single-phase hybrid PV-BES-utility synchronized system. *IEEE Trans. Ind. Appl.* **2018**, *55*, 1072–1082. [CrossRef]
- 168. Micallef, A.; Apap, M.; Spiteri-Staines, C.; Guerrero, J.M. Single-phase microgrid with seamless transition capabilities between modes of operation. *IEEE Trans. Smart Grid* 2015, *6*, 2736–2745. [CrossRef]
- Araujo, L.S.; Brandao, D.I. Self-adaptive control for grid-forming converter with smooth transition between microgrid operating modes. Int. J. Electr. Power Energy Syst. 2022, 135, 107479. [CrossRef]
- 170. Chandak, S.; Rout, P.K. The implementation framework of a microgrid: A review. *Int. J. Energy Res.* 2021, 45, 3523–3547. [CrossRef]

- 171. Das, S.; Singh, B. An Islanded Hybrid AC/DC Microgrid with Seamless Transition Capabilities. In Proceedings of the 2021 IEEE Industry Applications Society Annual Meeting (IAS), Vancouver, BC, Canada, 10–14 October 2021; IEEE: Piscataway, NJ, USA, 2021.
- 172. Tan, K.-H.; Tseng, T.-Y. Seamless switching and grid reconnection of microgrid using petri recurrent wavelet fuzzy neural network. *IEEE Trans. Power Electron.* 2021, *36*, 11847–11861. [CrossRef]
- 173. Wan, J.; Hua, W.; Wang, B. A Unified Inner Current Control Strategy Based on the 2-DOF Theory for a Multifunctional Cascade Converter in an Integrated Microgrid System. *Sustainability* **2022**, *14*, 5074. [CrossRef]
- 174. Sun, C.; Joos, G.; Ali, S.Q.; Paquin, J.N.; Rangel, C.M.; Al Jajeh, F.; Novickij, I.; Bouffard, F. Design and real-time implementation of a centralized microgrid control system with rule-based dispatch and seamless transition function. *IEEE Trans. Ind. Appl.* **2020**, 56, 3168–3177. [CrossRef]
- 175. Sunjaq, A.; Chen, P.; Bongiorno, M.; Majumder, R.; Svensson, J. Frequency Control by BESS for Smooth Island Transition of Hydro-Powered Microgrid. *TechRxiv* 2022. [CrossRef]
- Westman, J.; Hadidi, R.; Fox, J.C.; Leonard, J.; Harrell, A. Controller hardware-in-the-loop testing of an IEC 61850 GOOSE based control for seamless transition of a microgrid between island and grid-connected modes. *IEEE Trans. Ind. Appl.* 2020, 57, 61–69. [CrossRef]
- 177. Wan, J.; Hua, W.; Wang, B. Compulsory islanding transition strategy based on fuzzy logic control for a renewable microgrid system. *Math. Probl. Eng.* 2021, 2021, 9959222. [CrossRef]
- 178. Khan, M.A.; Haque, A.; Kurukuru, V.S.B. Intelligent transition control approach for different operating modes of photovoltaic inverter. *IEEE Trans. Ind. Appl.* 2021, *58*, 2332–2340. [CrossRef]
- 179. Zheng, F.; Lin, X.; Lin, Y.; Zhang, Y.; Zhang, Y. Design of a novel hybrid control strategy for ES grid-connected inverter for smooth microgrid transition operation. *IEEE Access* 2019, *7*, 171950–171965. [CrossRef]
- Jafari, M.; Malekjamshidi, Z.; Zhu, J.; Khooban, M.-H. A novel predictive fuzzy logic-based energy management system for grid-connected and off-grid operation of residential smart microgrids. *IEEE J. Emerg. Sel. Top. Power Electron.* 2018, *8*, 1391–1404. [CrossRef]
- 181. Yeganeh, M.S.O.; Oshnoei, A.; Mijatovic, N.; Dragicevic, T.; Blaabjerg, F. Intelligent Secondary Control of Islanded AC Microgrids: A Brain Emotional Learning-based Approach. *EEE Trans. Ind. Electron.* **2022**, *70*, 6711–6723. [CrossRef]
- 182. Venkatesan, A.K.; Natarajan, S.K. Stability Enhancement of PV Powered Microgrid using Levenberg-Marquardt Algorithm Based Intelligent Controller Under Grid-connected Mode. *Distrib. Gener. Altern. Energy J.* 2022, 37, 361–380. [CrossRef]
- 183. Aboushal, M.; Moustafa, M.M.Z. A new unified control strategy for inverter-based micro-grid using hybrid droop scheme. *Alex. Eng. J.* **2019**, *58*, 1229–1245. [CrossRef]
- Kondoro, A.; Ben Dhaou, I.; Tenhunen, H.; Mvungi, N. Real time performance analysis of secure IoT protocols for microgrid communication. *Future Gener. Comput. Syst.* 2021, 116, 1–12. [CrossRef]
- 185. Stoll, C.P.; Hug, F. Beam breakup simulations for the Mainz Energy recovering Superconducting Accelerator MESA. *J. Phys. Conf. Ser.* **2019**, *1350*, 012111. [CrossRef]
- Fard, A.K.; Wang, B.; Avatefipour, O.; Dabbaghjamanesh, M.; Sahba, R. Superconducting Fault Current Limiter Allocation in Reconfigurable Smart Grids. *arXiv* 2019, arXiv:1905.02324.
- 187. Xiang, B.; Liu, Z.; Wang, C.; Nan, Z.; Geng, Y.; Wang, J.; Yanabu, S. DC interrupting with self-excited oscillation based on the superconducting current-limiting technology. *IEEE Trans. Power Deliv.* **2017**, *33*, 529–536. [CrossRef]

**Disclaimer/Publisher's Note:** The statements, opinions and data contained in all publications are solely those of the individual author(s) and contributor(s) and not of MDPI and/or the editor(s). MDPI and/or the editor(s) disclaim responsibility for any injury to people or property resulting from any ideas, methods, instructions or products referred to in the content.