



HAL
open science

Applications of miniature sensors to indoor air quality

Alexandre Caron, Benjamin Hanoune, Nathalie Redon, Patrice Coddeville

► **To cite this version:**

Alexandre Caron, Benjamin Hanoune, Nathalie Redon, Patrice Coddeville. Applications of miniature sensors to indoor air quality. Journée des doctorants IREPSE, Jul 2015, Villeneuve d'Ascq, France. hal-04427969

HAL Id: hal-04427969

<https://hal.science/hal-04427969v1>

Submitted on 31 Jan 2024

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

Applications of miniature sensors to indoor air quality

Alexandre Caron^{1,2}, Benjamin Hanoune¹, Nathalie Redon², Patrice Coddeville²

¹Physicochimie des Processus de Combustion et de l'Atmosphère (PC2A), UMR 8522 CNRS/Lille 1, F-59655, Villeneuve d'Ascq, France


²Departement Sciences de l'Atmosphère et Génie de l'Environnement (SAGE), Mines Douai, F-59508, Douai Cedex, France

Indoor air quality (IAQ)

- Time spent in indoor environments > 80 %
- Numerous indoor emission sources
- Pollution patterns different from outdoors
- VOCs concentration higher (2 to 10 times) than outdoors
- Estimated cost of indoor air pollution in France: ~19 billion €/year
- French Thermal Regulation 2012:
 - Primary energy consumption below 50 kW/m²/an
 - High thermal insulation and airtightness
 - Controlled ventilation systems


Our sensors

Specific sensors



SensorBox with 3 electrochemical sensors, 1 NDIR and 1 PID sensors


Non-specific sensors



Array of 6 sensors metal-oxide semi-conducting materials = electronic nose


Real-time monitoring of indoor pollutants?

- Standard air quality systems, such as online gas analyzers or chromatographs : bulky, noisy, heavy, expensive...
- Alternative method: **electronic gas sensors networks** : small, easy to use, low cost , short response time
- Questions: qualitative/quantitative, sensitivity, accuracy, calibration, interferences, data treatment...?




Characterization of indoor air quality in a low energy school building

- Mermaid program:** Experimental and Modeling Characterizations of Indoor Air Quality in Low Energy Public Buildings
 - Identification of the main pollutants in LEPB
 - Highlighting of sources and sinks of pollutants
 - Influence of environmental conditions, type of materials ...
 - Model development considering physical and chemical processes
- 140 m³ classroom of a Low Energy Junior High School in North of France during **2 intensive measurement campaigns** (April-May 2014 and February-March 2015)




- 5 semi-conductor systems (1 to 5)
- 3 electrochemical devices (A to C)
- 1: ceiling/extraction
- 2&A: on the floor
- 3&B-4: 80 cm above the ground
- 5&C: ceiling/ventilation

Installation of the sensors in the classroom (2015)



Semi-conductor sensors (2014)



Specific sensors (2015, module C)

Conclusions

- Sensors data agree with data from reference analyzers
- Real time measurements of indoor and outdoor pollutants
- Impact of ventilation status on IAQ

To do ...

- Best combination of selective and non-selective sensors ?
- Data treatment to extract pollutant signature ?