

How to apply digital function interconnection requirements into a SCADA environment for Industry 4.0?

Pascal Vrignat, Christophe Charrière, Manuel Avila, Florent Duculty, Stéphane Begot, Jean-Christophe Bardet

▶ To cite this version:

Pascal Vrignat, Christophe Charrière, Manuel Avila, Florent Duculty, Stéphane Begot, et al.. How to apply digital function interconnection requirements into a SCADA environment for Industry 4.0?. IICE, Apr 2024, Dublin (virtual), Ireland. hal-04536535

HAL Id: hal-04536535 https://hal.science/hal-04536535

Submitted on 8 Apr 2024

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers. L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

How to apply digital function interconnection requirements into a SCADA environment for Industry 4.0?

Pascal Vrignat^{a*}, Christophe Charrière^a, Manuel Avila^a, Florent Duculty^a, Stéphane Begot^a and Jean-Christophe Bardet^a

^a Univ. Orléans, PRISME, EA 4229, F45072, Orléans, France

*Corresponding author: PRISME Laboratory, MCDS Team, University of Orleans, 2 av. François Mitterrand 36000 Châteauroux, France. Email: pascal.vrignat@univ-orleans.fr

Abstract

This work presented consists of automatically managing a real process based on different manufacturing recipes. The data is routed over a digital network (Local Area Network) and encapsulated in an OPC UA protocol. The homothetic process is a chemical system consisting of different baths for surface treatment of metal objects. Recipes can be loaded automatically from Excel files. Each Excel file has been adapted with a script in Visual Basic for Applications (VBA). The various recipes are available in read-write format. Under these conditions, the process manager can process all data in an adapted human-machine interface solution. The control system is managed by a Schneider Electric PLC (Modicon M340). The program embedded in the PLC is developed in the EcoStruxure Control Expert software environment (CEI 61131-3). This 28-hours assignment is for 2nd year Bachelor students. It responds perfectly to the current needs of industry. In this context, students can acquire new skills in the context of the connected factory and in a Supervisory Control and Data Acquisition (SCADA) environment. A specific collaboration with a software publisher (Skkynet) and our University enables the use of a client/server gateway for OPC UA protocol. This official partnership agreement allows our University to use a software package that is normally very expensive, but which is totally free under these conditions.

1. Introduction

The work presented in this paper outlines a project validated with students in their second year of a bachelor's degree program in Electrical Engineering and Industrial Computing (28 hours' work). This technical endeavor is integrated into a Project-Based Learning methodology [1], [2], [3]. The technical objectives to be validated are numerous and demanding:

- Provide a contextualization of the "Surface finishing" function within a real industrial context.

- Examine the "Surface finishing " system proposed in this work, encompassing its control and operational components.
- Develop a model of the system utilizing functional analysis and an "Octopus" type diagram.
- Justify specific technical choices and propose alternative approaches capable of fulfilling the same function and requirements.
- Identify components depicted on the electrical diagram of the system.
- Analyze the existing program and adapt it to align with the new operational requirements.
- Perform tests to validate the new program. This new program can be implemented using various strategies (SFC, LD, ST, FBD [4]). Provide a comprehensive verification strategy (coherent checklist) for this purpose.
- Identify and map the architecture of the industrial network being utilized.
- Capture and analyze data accessible via the PLC on the OPC UA communication channel [5].
- Research and develop a "Traceability (Reporting)" solution tailored for the manager of the "Surface treatment" line within an Excel environment (OPC UA client).
- Investigate and develop a solution for managing manufacturing recipes catered to the "Surface finishing" line manager within an Excel environment (OPC UA client).

This project encompasses several technical resources:

- A "Surface finishing" homothetic system.
- Control Expert (Control-command configuration & development of the program for the PLC).
- PRONETA (network sniffer and network administration) [6].
- Advanced IP Scanner (network sniffer).
- UA Expert (Sniffer, Item OPC UA).
- OPC UA Expert Configuration (OPC UA communication channel configuration).
- Cogent DataHub (OPC UA Client/Server).
- Excel & VB Macro (OPC UA Client, development of the "Reporting" HMI traceability solution).

2. The technical context of work

After various research projects, the task involves formalizing a study summary to present the function within the context of real industrial needs. This formalism could be presented on a one-page A4 format. Initially, the system will represent a "Surface treatment" line for aluminum parts to be treated. Five treatment baths are available. The parts are installed on transfer bars and are moved from bath to bath by a robot. Chromating (Alodine) is a surface treatment for aluminum widely used for its anti-corrosive and electrically conductive properties, as well as its excellent adhesion to paints and adhesives. This treatment can be applied to all aluminum surfaces (Figure 1, Figure 2). Before chromating, the aluminum surface must be carefully cleaned and deoxidized. The different stages of Passivation: Degreasing => Rinsing => Pickling=> Rinsing => Chromating (Alodine) => Rinsing.




Figure 1 Simple presentation of the operating part of the system




Figure 2 Position of detectors and actuators

The system has various inputs and outputs (digital). Details are given in Figure 3, Figure 4. The parts list for the various components and the various electrical diagrams for the system are available. After consulting the technical documentation of the system, this assessment emerges as one of the essential tasks that students must undertake.

Reference points / Inputs	PLC Adress	Description
Bp1	%10.2.14	BP Init = "Initial position" pushbutton
Bp2	%I0.2.15	Go up in "Manual" mode
Bp3	%10.3.0	Go down to "Manual" mode
Bp5	%10.3.2	Cycle "start" push-button
Bp6	%10.3.3	Translate left to manual
Bp7	%10.3.4	Translate right to manual
Com-Auto	%I0.3.14	Automatic operation switch
Under voltage	%I0.3.12	Undervoltage operating section
Low	%10.2.3	Bottom bracket
Тор	%10.2.2	Top bracket
Poste_0	%10.3.10	Carriage at station 0
Poste_1	%10.2.6	Carriage at station 1
Poste_2	%10.2.7	Slide at station 2
Poste_3	%10.2.8	Trolley to station 3
Poste_4	%10.2.5	Trolley to station 4
Poste_5	%10.2.4	Trolley to station 5
Poste_6	%10.3.11	Trolley to station 6

Figure 3 Inputs

Reference points / Outputs EV Kmdrive Kmright Kmleft H1 H2	PLC Adress %Q0.1.6 %Q0.1.2 %Q0.1.0 %Q0.1.7 %Q0.1.5 %Q0.1.4	Description Mounting bracket Switching on the drive Move right Move leftLED 1 Led 1 Led 2
---	--	---

Figure 4 Outputs

3. Develop a control/command function based on the real needs of manufacturers

The overarching objective of the work outlined in this subsection is encapsulated in Figure 5. This endeavor involves utilizing two files (Excel models) to fulfill present demands regarding system Controlcommand and traceability. Within this framework, the automatic loading of diverse settings and instructions in the form of a recipe will be executed automatically under the supervision of the production line controller [7].




Figure 5 General system management principle




Figure 6 Layer of the communication network

Part of the industrial network architecture and the principle of communication and services are depicted in Figure 6. Students will be tasked with managing static IP addresses. Figure 7 illustrates the development that requires validation to furnish the line operator with pertinent information regarding the operation of the system (development of a Human Machine Interface). The system information is consolidated within a spreadsheet-type environment. A notable aspect of this environment is its capability to leverage a wide array of functions already implemented in libraries (such as conditional formatting, histograms, pie charts, mathematical calculations, ...).

X I Excel




Figure 7 Organization of user pages for complete traceability of the application

4. The principle of managing recipes

A basic program is provided to the students, allowing the system to operate in a precise mode while adhering to a potentially configurable manufacturing recipe. The objective of the task is to adjust different recipes on demand by specifying the required position based on the relative position of the carriage managing translations (Left-Right) and determining the soaking time delay according to the number of containers. These values must be extracted from a prefilled table. Figure 8 outlines the general principles to be followed for modifying this program. Figure 9 (a and b) illustrates the principle of managing a table and its associated numerical values (setpoint, identifier, ...).




Figure 8 The general principle for managing a recipe




Figure 9 Principle of table management

5. A few examples of results

In order to meet the technical requirements of the task, students must validate various software layers with specific configurations. This task demands a high level of rigor and thorough analysis of the digital data routed over the network. Figure 10 describe the configuration of the OPC UA access point in the "EcoStructure OPC UA Server Expert Configuration tool" software environment.

Edit View Service Settings	н	elp				
🖬 🔝 🦓 🕶 🔛 🛄 🖉 🕹	_					
Device overview Default devices titings Diagnostic Simulation PAC Software Communication Communication Security)	DevExample_1				
0		Device name	DevExample_1		Device name:	DevExample
		Device address 1	MBT: 10.0.2.21/U			
		Device address 2				
F	Ð	General				
		Topological objects	Populate			
		Symbol table file				
		Symbol table file				
		PLC Embedded Data	Using Data Dictionary		No Communication Break	
			Using Data Dictionary	O Symbol table	No Communication Break	
		PLC Embedded Data		O Symbol table		
		PLC Embedded Data Preload settings	○ No Preload	○ Symbol table	Device	

Figure 10 Configuring the OPC UA access point with the PLC

Figure 11 specifies whether it is possible to declare a certificate in OPC UA communication. This certification enables data encryption with specific key generations. No certificate will be present in your application.

👹 EcoStruxure OPC UA Server Expert C	onfiguration tool	
File Edit View Service Setting	is Help	
🛍 🖻 🎒 🗕 🗞 T 🖬 🖽 T 🍕		
Devices Device overview	8	
	SecurityPolicy	Allow "None"
☐-@ Settings ☐ Diagnostic	Anonymous user token	Allow
	X509 user token	Allow
Communication	User authentication	Activate
- iggi Security	Certificate Revocation Check	🗌 Enable
	Rejected Certificate Store	

Figure 11 Configuring the OPC UA access point with the PLC

After completing the configuration, you should keep this software open. Next, launch the "EcoStructure OPC UA Server Expert" software environment. This software should automatically provide an address based on computer's static IP address (see Figure 12). If the configuration is correct, communication with the OPC UA channel of the PLC, along with the loading of its "nodes" (data), should Start (see Figure 13).

File He		JA Server Expert			>
Server End	oint URLs	opc.tcp://pwrignat:49152/OPCUAServerExpert		_	
iagnostics					
EcoStruxu affinity: 0xF		Server Expert V2.1.4904.2 started on Microsoft Windows NT 10.0.19044.0 2009 x64 (Native). Active I	ogical processors:	12. Proces	ssor
01/04/202 01/04/202 01/04/202 01/04/202 01/04/202 01/04/202 01/04/202 01/04/202 01/04/202 01/04/202 01/04/202 01/04/202 01/04/202 01/04/202 01/04/202 01/04/202 01/04/202	3 15:23:41 3 15:23:42 3 15:23:43 3 15:23:45 3 15:23:45	202 Alab DerCampie, 1 elentifiel 202 Alab DerCampie, 1 elentifiel 202 Alab DerCampie, 1 elentifiel 201 Alab DerCampie, 1 elensitel 201 Alab DerCampie, 1		: License	

Figure 12 Configuring the OPC UA access point with the PLC


scovery Advance	d	
Server Information		
Endpoint Url	opc.tcp://pvrignat:49152/OPCUAServerExpert	
Reverse Connect		
Security Settings		
Security Policy	None	•
Message Security Mode	None	•
Authentication Setti	ngs	
Anonymous		
Username		Store
Password		
Certificate		
Private Key		
Session Settings		
Session Name		

The EcoStructure OPC UA Server Expert environment must remain active throughout the remainder of the task. Sniffing the selected "Item" data in OPC language is crucial. This work allows for the verification of all information transmitted by the PLC. For this task, you must utilize the software UaExpert. The various configurations are provided in the figures below (see Figure 14 and Figure 15).

Add Server	?
nfiguration Name opc.tcp://pvrignat:49152/OPCUAServer	Expert
Discovery Advanced	
Endpoint Filter: No Filter	
🔍 Local	
🗸 😒 Local Network	
> 🔮 Microsoft Terminal Services	
> 🔮 Microsoft Windows Network	
Web Client Network	
V 💽 Reverse Discovery	
Souther state of the state o	y >
V 💽 Custom Discovery	
Ouble click to Add Server >	
✓ ⊘ Recently Used	
est	•
opc.tcp://pvrignat:49152/OPCUAServer8	expert
Authentication Settings	
Authentication Settings Anonymous	
	Store
Anonymous	Store
Anonymous Username Password	Store
Anonymous Username Password Certificate	Store
Anonymous Username Password	Store
Anonymous Username Password Certificate	Store
Anonymous Username Password Certificate	Store

Figure 14 Configuration with the "UaExpert" software

Figure 13 Declaration of the access point by the



onined Automation Datzpert - The OPC onlined Architecture Che	nt - coning_oA_cAPera			- 0	^
File View Server Document Settings Help					
D 💋 🕞 👩 💿 🗢 🗕 🔿 🗙 🔦 🤱	8 K 🛄				
Project Ø ×	. Date Access, View				6 ×
✓	# Server Node Id Display Name Valu	e Datatype urce Timestar iver Timestan S	🧿 🚽 📐 🐵		0
✓	1 opc.tcp://pv NS2[String] Bp1 false	Boolean 1625:29.155 1625:29.281 Go Int16 16:16:35:381 16:16:35:568 Go	Attribute	Value	^
opc.tcp://pvrignat:49152/OPCUAServerExpert ① Documents	2 opc.tcp://pv., NS2[String]., yop 10	Int16 16:16:35.381 16:16:35.568 Go	V Nodeld	ns=2.s=0.DevExample_1lyop	Specific area for
Data Access View			NamespaceIndex	2	Specific area for
-	Item content cons	ultation area	IdentifierType Identifier	String	
	item content cons	unation area	NodeClass	0.DevExample_1lyop Variable	consulting item
	(by Drag and Drop	١	RrowseName	2. "vop"	U U
	(by Diag and Diop	/	DisplayName	", 'yop"	contents
			Description		
			WriteMask UserWriteMask	0	
			RolePermissions	BadAttributeIdIrvalid (0x80350000)	
				BadAttributeIdInvalid (0x80350000)	~
hilkers Jame Z H		1	References		2 -
G No Highlight			G w & & Forward *		9
Root			Reference Target Displ	whame	
v 🗅 Adjante			HasTypeDe DataitemTyp		
Y 🗅 DA				ful for non elementary data types	
DevExample_1 Becific				me, as known by the programming tool	
> aret				a variable, may be elementary, structured, function-block, section,	
Auto Item recove	ry area		HasProperty The free strin HasProperty The topolog		
E > 🛥 Bas	ry area		HasProperty Time Stamp		
> • Bp1			inductoperty time stamp	co creat support	
> • 8p2 > • 8p3					
A Bod					
L		1			

Figure 15 Verification of the data made available by the PLC in the "UaExpert" software

Cogent DataHub (OPC UA client/server (Figure 5) after its configuration allows you to retrieve all the data made available by the PLC (Figure 16). Figure 17 describes the principle of connection between Excel and Cogent DataHub.

😥 Cogent DataHub Prop	iétés V9.0.10.747 x86				- 🗆 ×
Sénéral UA OPC UA	Configuration de l'architecture unifiée OPC (UA)				
DA OPC DA A&E OPC AE	Client OPC UA	Configurer OPC UA Data Access Server X			
← Tunnel/Miroir ··→ Pont Pont Redondance	S Non connexion Domaine Statit Endpoint ✓ OPCUA000 default Create Session opc:txp://192.168.110.4840 ✓ OPCUA001 default Running opc:txp://lysinast.49152/OPCUASt	Nom de la connexion: OPCL		✓ Ø ₽	Ajputer Modifier
Base de données		Endpoint URL: opc.to		2/OPCUAServerExpert	Bupprimer
 ⊘ WebView Sient MQTT 		Politique de sécurité: None Type de jeton utilisateur: Anony	mous	~	
MQTT Broker MB Modbus Historien Email/SMS	b.	Identité de l'utilisateur: Toujours accepter le certificat de Continuer à accepter le certificat Do not disconnect when the serve	de serveur lorsqu		
Caméra Sys. Moniteur	Fe2	Transfert de données Taux de mise à jour maximal (millise Méthode de lecture:	condes):	1000 © Asynchronous Read ~ Swnchronous Write ~	
Remote Config	Serveur OPC UA Agir en tant que serveur OPC UA:	Méthode d'écriture: Synchronous Write Taille de la file d'attente des éléments surveillés: 1 Nombre maximal d'éléments de requête: 500	1		
 Securité Licences E+H E+H Fieldgate 	Protocole Port Encodage des Image opectop 51310 Binary Imap 51311 Binary.Xml Imap 51312 Binary.Xml	Ne transmettre que des données Naccepte pas les données nulle Créer plusieurs abonnements à	s de ce serveur	à ce serveur Avancée	Avancée Modifier le port
	L'ordinateur nom / IP: pvrignat Nom du Endpoint: Cogen/DataHub/DataAccess	Sélection de l'article Charger tous les nœuds Domaine de données; defau		nner manwellement les nœuds Configurer les nœuds	finel dens le presse-popiers
	Statut: Running Sessions: 0 Abonnements: 0 Certificats rejetés: 0 #000000000000000000000000000000000000			OK Annuler	Statutiserveur
	Certificats temporaires: 0 /control Géren/es.certificats	Obtenir les informations de conne	ixion est termin	ée	

Figure 16 Configuration and provision of data by the PLC




Figure 17 Connection between Cogent DataHub and Excel

6. Some results with Excel and the Human-Machine Interface (HMI)

Figures 18, 19 and 20 present a development set that was proposed by a group of students (HMI part). In this context, they demonstrated and validated the initial requirements proposed in this work. These results meet the constraints outlined in Figure 7 satisfactorily.



Figure 18 Excel Home page




Figure 19 Excel recipes page




Figure 20 Excel reporting page

7. Conclusion

This work carried out with students demonstrates that our university's technological and scientific training is intended to respond to the needs and challenges associated with Industry 4.0. We have also shown that the transmission of knowledge and skills can be based on a so-called "PBL" pedagogy. In this topic, students have also made significant progress in terms of skills associated with industrial computing. Studying and implementing real-technical solutions also helps to motivate students. At the end of the project, each group presents its work, respecting the different technical delivery phases of a project.

8. References

- Y.-H. Wang, "Integrating games, e-books and AR techniques to support project-based science learning," *Educational Technology* & Society, vol. 23, no. 3, pp. 53-67, 2020.
- [2] T. K. Chiu, C. S. Chai, P. J. Williams, and T.-J. Lin, "Teacher professional development on self-determination theory– based design thinking in STEM education," *Educational technology & society*, vol. 24, no. 4, pp. 153-165, 2021.
- [3] P. Vrignat, M. Avila, P. Marangé, and F. Kratz, "University Education Adapts to Industry 4.0 Topic," in *International Conference on Remote Engineering and Virtual Instrumentation*, 2023, pp. 689-701: Springer.

- [4] R. Ramanathan, "The IEC 61131-3 programming languages features for industrial control systems," in 2014 world automation congress (wac), 2014, pp. 598-603: IEEE.
- [5] M. H. Schwarz and J. Börcsök, "A survey on OPC and OPC-UA: About the standard, developments and investigations," in 2013 XXIV International Conference on Information, Communication and Automation Technologies (ICAT), 2013, pp. 1-6: IEEE.
- [6] G. Ferreira Peña, "Back-end development of a Profinet-based data collector application and final deployment," 2018.
- [7] P. Vrignat, B. Roblès, M. Avila, and F. Kratz, "OPC UA: examples of digital reporting applications for current industrial processes," *DEStech Transactions on Engineering and Technology Research*, no. ecar, 2018.