



# The power balance equation for converter control - Application to a three-level neutral point clamped rectifier

Manon Doré, Yassine Ariba, Germain Garcia

## ► To cite this version:

Manon Doré, Yassine Ariba, Germain Garcia. The power balance equation for converter control - Application to a three-level neutral point clamped rectifier. Methods and Algorithms for the Control of Complex Systems, Aug 2024, Banyuls-sur-mer, France. hal-04735611

HAL Id: hal-04735611

<https://hal.science/hal-04735611v1>

Submitted on 14 Oct 2024

**HAL** is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.


L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

# The power balance equation for converter control

Application to a three-level neutral point clamped rectifier [1]

Manon Doré, Yassine Ariba, Germain Garcia - LAAS-CNRS, INSA, Toulouse, France

## Neutral point clamped (NPC) rectifier model




- Assume **balanced signals**:  $e_a + e_b + e_c = 0$  and  $i_a + i_b + i_c = 0$
- Modeling of **switches**: **boolean variables**,  $u_{ij} = 1 \Leftrightarrow$  phase  $i$  is connected to point  $j$   
 $\Rightarrow$  9 control variables,  $u = [u_{ap} \ u_{ao} \ u_{an} \ u_{bp} \ u_{bo} \ u_{bn} \ u_{cp} \ u_{co} \ u_{cn}]$
- For  $i = a, b, c$ ,  $u_{ip} + u_{io} + u_{in} = 1 \Rightarrow$  27 possible values of  $u$ , defined in  $\mathcal{U}_{\text{com}}$
- Using Kirchhoff's laws, we obtain a **bilinear model**

$$\begin{cases} L \begin{bmatrix} \dot{i}_a \\ \dot{i}_b \\ \dot{i}_c \end{bmatrix} = \begin{bmatrix} e_a \\ e_b \\ e_c \end{bmatrix} - r_L \begin{bmatrix} i_a \\ i_b \\ i_c \end{bmatrix} - \frac{1}{3} \begin{bmatrix} 2 & -1 & -1 \\ -1 & 2 & -1 \\ -1 & -1 & 2 \end{bmatrix} \left( \begin{bmatrix} u_{ap} \\ u_{bp} \\ u_{cp} \end{bmatrix} v_1 - \begin{bmatrix} u_{an} \\ u_{bn} \\ u_{cn} \end{bmatrix} v_2 \right) \\ C \dot{v}_1 = u_{ap} i_a + u_{bp} i_b + u_{cp} i_c - \frac{v_1 + v_2}{R} - \frac{v_1}{r_C} \\ C \dot{v}_2 = -(u_{an} i_a + u_{bn} i_b + u_{cn} i_c) - \frac{v_1 + v_2}{R} - \frac{v_2}{r_C} \end{cases}$$

- Using Clarke-Concordia transform  $\mathcal{C}$ , we obtain a bilinear state-space model of the form

$$\begin{bmatrix} g_\alpha \\ g_\beta \end{bmatrix} = \mathcal{C} \begin{bmatrix} i_a \\ i_b \\ i_c \end{bmatrix} \quad \begin{cases} \dot{x} = A(u)x + B_0 v_{in}, \quad x = \begin{bmatrix} i_\alpha \\ i_\beta \\ v_+ = v_1 + v_2 \\ v_- = v_1 - v_2 \end{bmatrix} \\ y = C_0 x \end{cases} \quad v_{in} = \begin{bmatrix} e_\alpha = V_{\alpha\beta} \cos(\omega t) \\ e_\beta = V_{\alpha\beta} \sin(\omega t) \end{bmatrix}$$

## Control



### Inner loop - argmin control [2]

- Quadratic stability condition:**  $\exists P = P^T > 0$  for  $Q_C > 0$  s.t.  $\forall u \in \mathcal{U}_{\text{com}}$
- Argmin control law:** For  $V = e^T Pe$ ,  $u$  minimizes  $\dot{V}(e, u)$ , s.t.  $e = 0$  where  $e = x - x_{\text{ref}}$  is asymptotically stable for

$$u \in \underset{d \in \mathcal{U}_{\text{com}}}{\operatorname{argmin}} e^T P (A(d)x + B_0 v_{in})$$

### Outer loop - Integral action

- The system is affected by constant perturbations on the load  $\Delta y$ /input voltages  $\Delta V_{\alpha\beta}$
- Assume inner loop is much faster than the outer loop.
- The outer loop with an **integral action** adapt  $I_{\alpha\beta}$  with an extra term

$$\Delta I_{\alpha\beta}(t) = K_I \int_0^t (y_{\text{ref}} - y(u)) du \quad \text{s.t.} \quad \begin{bmatrix} i_{\alpha\text{ref}}(t) \\ i_{\beta\text{ref}}(t) \end{bmatrix} = \begin{bmatrix} (I_{\alpha\beta} + \Delta I_{\alpha\beta}) \cos(\omega t) \\ (I_{\alpha\beta} + \Delta I_{\alpha\beta}) \sin(\omega t) \end{bmatrix}$$

- Evaluating the power balance equation (1) with  $i_\alpha = (I_{\alpha\beta} + \Delta I_{\alpha\beta}) \cos(\omega t)$ ,  $i_\beta = (I_{\alpha\beta} + \Delta I_{\alpha\beta}) \sin(\omega t)$ ,  $v_+ = y_{\text{ref}} - \Delta v_+$  et  $v_- = 0 - \Delta v_-$ , taking into account (2) and retaining first order terms, we get the **transfer function**

$$G_{v_+}(s) = \frac{\Delta v_+}{\Delta I_{\alpha\beta}} = \frac{\frac{(V_{\alpha\beta} - 2r_L I_{\alpha\beta}) R_{\text{eq}}}{y_{\text{ref}}}}{1 + \frac{R_{\text{eq}} C}{2} s} := \frac{K}{1 + Ts}$$

- Then, the open-loop transfer function is  $\frac{KK_I}{s(1 + Ts)}$ . For example, a phase margin of  $\frac{\pi}{3}$  is obtained in closed-loop for  $K_I = \frac{2}{3KT} = \frac{4y_{\text{ref}}}{3R_{\text{eq}}^2 C (V_{\alpha\beta} - 2r_L I_{\alpha\beta})}$ .

## References

- M. Dore, Y. Ariba, and G. Garcia, "Observer-based switched control of the three level neutral point clamped rectifier," in 2023 62nd IEEE Conference on Decision and Control (CDC), pp. 3580–3585, 2023.
- G. Deaecto, J. Geromel, F. Saldanha Garcia, and J. Pomilio, "Switched affine systems control design with application to DC-DC converters," Control Theory & Applications, IET, vol. 4, pp. 1201–1210, Aug. 2010.

## Power balance equation

- Converters are power electronics systems using switches and storage elements to modulate electrical energy
- Energy exchanges and system trajectories are constrained by the **power balance equation**

$$P_{\text{sources}} - P_{\text{stored}} - P_{\text{losses}} - P_{\text{load}} = 0$$

- For inductors and capacitors, the stored power is

$$P_L = L \dot{i}_L i_L \quad P_C = C \dot{v}_C v_C$$

- As the state variables are usually inductor currents and capacitor voltages, the power balance equation **can be derived from the state-space model**.
- The power balance equation is a **powerful tool for reference design and control**

## Reference design

- Using the state-space model of the converter, we retrieve its power balance equation:

$$Li_\alpha \dot{i}_\alpha + Li_\beta \dot{i}_\beta + \frac{C}{2} (v_+ \dot{v}_+ + v_- \dot{v}_-) = e_\alpha i_\alpha + e_\beta i_\beta - r_L (i_\alpha^2 + i_\beta^2) - \frac{v_-^2}{2r_C} - \frac{v_+^2}{2R_{\text{eq}}} \quad (1)$$

- Control objectives :

- Ensuring an unit power factor (voltages/currents in phase)
- Stabilize  $y$  to a reference  $y_{\text{ref}}$
- Balanced capacitors voltages

$$x_{\text{ref}}(t) = \begin{bmatrix} I_{\alpha\beta} \cos(\omega t) \\ I_{\alpha\beta} \sin(\omega t) \\ y_{\text{ref}} \\ 0 \end{bmatrix}$$

- Evaluating (1) with  $x = x_{\text{ref}}$  for  $y_{\text{ref}} < V_{\alpha\beta} \sqrt{\frac{R_{\text{eq}}}{2r_L}}$ , we get

$$0 = -r_L I_{\alpha\beta}^2 + V_{\alpha\beta} I_{\alpha\beta} - \frac{y_{\text{ref}}^2}{2R_{\text{eq}}} \quad (2)$$

$$\Leftrightarrow I_{\alpha\beta} = \frac{V_{\alpha\beta}}{2r_L} \left( 1 \pm \sqrt{1 - \frac{2r_L y_{\text{ref}}^2}{V_{\alpha\beta}^2 R_{\text{eq}}}} \right)$$

## Simulation

Parameter	Value	Parameter	Value
$L$	15 mH	$r_L$	0.4 Ω
$C$	1500 μF	$r_C$	20 kΩ
$E$	72 V	$R$	30 Ω
$y_{\text{ref}}$	150 V	$\omega$	100π rad/s

