



**HAL**  
open science

## On MPC-based Strategies for Optimal Voltage References in DC Microgrids

Pol Jané-Soneira, Ionela Prodan, Albertus Malan, Sören Hohmann

► **To cite this version:**

Pol Jané-Soneira, Ionela Prodan, Albertus Malan, Sören Hohmann. On MPC-based Strategies for Optimal Voltage References in DC Microgrids. 2023 European Control Conference (ECC), Jun 2023, Bucharest, France. pp.1-6, 10.23919/ECC57647.2023.10178379 . hal-04861086

**HAL Id: hal-04861086**

**<https://hal.science/hal-04861086v1>**

Submitted on 2 Jan 2025

**HAL** is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

# On MPC-based Strategies for Optimal Voltage References in DC Microgrids

Pol Jané-Soneira, Ionela Prodan, Albertus J. Malan, and Sören Hohmann

**Abstract**—Modern power systems are characterized by low inertia and fast voltage dynamics due to the increase of sources connecting via power electronics and the removal of large traditional thermal generators. Power electronics are commonly equipped with fast controllers that are able to reach a desired voltage setpoint within seconds. In this paper, we propose and compare two approaches using Model Predictive Control (MPC) to compute optimal voltage references for the power electronic devices in order to minimize the losses in a DC microgrid: i) a traditional setpoint-tracking MPC which receives a previously computed optimal setpoint; ii) an economic MPC which does not require a priori computed setpoints. We show that the economic MPC outperforms the setpoint-tracking MPC in simulations with the CIGRE benchmark system when multiple load disturbances occur. Some insights and discussions related to the stability of the closed-loop system using its dissipativity properties are highlighted for both approaches.

## I. INTRODUCTION

In the last years, DC microgrids (MGs) have become technically feasible due to the recent advances in semiconductor converter technology [1]. Furthermore, they have the potential to prevail over their AC counterparts in the future due to their higher efficiency, the more natural interface to most distributed generation units (DGUs), renewable energy sources (RESs), storages and loads [1], [2]. In addition, DC MGs are significantly simpler to regulate, since the frequency control becomes unnecessary [2]. The problem of maintaining constant voltage levels in DC MGs under varying load conditions is well studied in literature and it is called primary control. On the one hand, droop-based methods [3], [4] are widely-used decentralized approaches and exhibit favorable properties such as (limited) power-sharing. Several improvements such as nonlinear, adaptive or dead-band droop have also been proposed, as summarized in [5]. However, these methods show load-dependent voltage deviation and steady-state voltage offsets, which need to be compensated by a higher level control. On the other hand, passivity-based controllers tackling the shortcomings of droop-based approaches have been proposed recently [6], [7]. These regulators achieve an offset-free regulation of a

given voltage reference and exhibit advantageous plug-and-play properties for DGUs while guaranteeing overall asymptotic stability via passivity. Similar stability properties can only be achieved with droop-based methods by simplifying the system models with questionable assumptions and approximations [4]. However, these passivity-based controllers necessitate a secondary control to achieve power-sharing or coordination.

Secondary control architectures, built on top of droop-controlled or passivity-based controlled DGUs, differ considerably in their purpose and nature. The secondary control of droop-controlled DGUs is typically a proportional-integral controller, which is used for compensating unwanted voltage drifts. It can be implemented in a centralized, decentralized or distributed manner using consensus protocols [5], [8]. In contrast to droop-based methods, passivity-based primary controllers do not necessitate a secondary control layer in order to restore the desired or feasible voltage levels [6], [7], [9]. With a secondary control layer freed from ensuring stability and feasibility, it can focus on providing suitable voltage references in order to pursue other objectives, such as minimizing power losses or costs, or achieving power-sharing. In [10], a secondary controller for achieving proportional current sharing is proposed. Similarly, [11] proposes DC power sharing whilst also taking unactuated agents into account. These methods are able to guarantee convergence to a desirable steady-state employing passivity theory. However, as it is the case for the secondary control architectures for droop-based controllers, the dynamic performance for reaching this steady-state is not considered, i.e., voltage overshoots damaging MG components may occur. Furthermore, similar to the primary passivity-based controllers, they cannot take into account actuator or state constraints.

Model Predictive Control (MPC) for DC MGs is an emerging research topic since it allows considering state and input constraints [12]. Many approaches consider an MPC-based secondary control for droop-controlled DC MGs [13]–[16]. However, since they require droop-based primary controllers, these approaches do not allow a plug-and-play operation of DGUs. Other approaches attempt to directly control the Buck converter voltage without an underlying primary controller [17]. However, the filter dynamics necessitate a sampling time in the microseconds range, which makes an online solution of the MPC optimization problem feasible only for small MGs and short optimization horizons [17]. Recently, economic MPC has been applied to power systems in [18], [19]. However, these approaches consider simplified AC systems, and the results are not applicable to low inertia DC

P. Jané-Soneira, Albertus J. Malan and S. Hohmann are with the Institute of Control Systems, Karlsruhe Institute of Technology (KIT), 76131, Karlsruhe, Germany. Corresponding author is P. Jané-Soneira, pol.jane@kit.edu. This work has been partly funded by Germany's Federal Ministry for Economic Affairs and Energy within the project RegEnZell (reference number 0350062C)

I. Prodan is with the Univ. Grenoble Alpes, Grenoble INP<sup>†</sup>, LCIS, F-26000, Valence, France, (e-mail: ionela.prodan@lcis.grenoble-inp.fr).<sup>†</sup>Institute of Engineering and Management Univ. Grenoble Alpes. I. Prodan's research benefited from the support of the FMJH Program PGMO and from the support to this program from EDF.

power systems as considered in this work.

*Contributions:* We propose a secondary control architecture using MPC for DC MGs with passivity-based primary controllers, which is able to guarantee constraint satisfaction while minimizing an objective function. In particular, we propose two different receding horizon controller designs: i) a classic setpoint-tracking MPC, for which we propose a Lyapunov function for any MG configuration and hence proof stability using established methods; ii) an economic MPC with better closed-loop performance. Furthermore, we provide extensive simulation results on a realistic benchmark system and a thorough comparison of both MPC-based approaches.

The remainder of this paper is structured as follows. In Section 2, the system model for which we design the MPC-based secondary control, comprising the physical system endowed with passivity-based primary controllers, is presented. The tracking and economic MPC designs are described in Section 3. In Section 4, we present extensive simulation results comparing both approaches in the nominal case and when disturbances are present. Finally, we draw conclusions and outline future research directions in Section 5.

*Notation:* Lowercase letters  $x \in \mathbb{R}^n$  represent vectors, and uppercase letters  $X \in \mathbb{R}^{n \times n}$  represent matrices. The transpose of a vector  $x \in \mathbb{R}^n$  is written as  $x^\top$ . The vector  $x = \text{col}\{x_i\}$  and matrix  $X = \text{diag}\{x_i\}$  are the  $n \times 1$  column vector and  $n \times n$  diagonal matrix of the elements  $x_i$ ,  $i = 1, \dots, n$ , respectively. Let  $I_n$  denote the  $n \times n$  identity matrix and  $\text{Spec}(X)$  the spectrum of matrix  $X$ . A directed graph is denoted by  $\mathcal{G}(\mathcal{V}, \mathcal{E})$ , where  $\mathcal{V}$  is the set of nodes and  $\mathcal{E} \subset \mathcal{V} \times \mathcal{V}$  the set of edges. The cardinality for a set  $\mathcal{V}$  is denoted by  $|\mathcal{V}|$ . The incidence matrix  $M \in \mathbb{R}^{|\mathcal{V}| \times |\mathcal{E}|}$  is defined as  $M = (m_{ij})$  with  $m_{ij} = -1$  if edge  $e_i \in \mathcal{E}$  leaves node  $v_j \in \mathcal{V}$ ,  $m_{ij} = 1$  if edge  $e_i \in \mathcal{E}$  enters node  $v_j \in \mathcal{V}$ , and  $m_{ij} = 0$  otherwise. The Hadamard (element-wise) product of  $x$  and  $y$  is denoted by  $x \circ y$ .

## II. SYSTEM MODEL

In this paper, we consider a set  $\mathcal{V}$  of  $n = |\mathcal{V}|$  electrical buses connected via a set  $\mathcal{E}$  of  $m = |\mathcal{E}|$  electrical lines. The network topology is described with the graph  $\mathcal{G}(\mathcal{V}, \mathcal{E})$ , where  $\mathcal{V}$  are the nodes and  $\mathcal{E}$  the edges. Fig. 1 shows such a MG with  $n = 11$  nodes and  $m = 12$  lines. In the next subsections, we derive the models of the components of the DC MG, i.e. the electrical buses and the power lines. In Subsection II-C, we show favorable passivity properties of the overall MG system. To conclude the section, we propose a model reduction, discretize the system and provide a Lyapunov function which holds for any MG topology, which is necessary for the MPC design in Section III.

### A. Distributed generation unit (DGU)

A graphical representation of a bus is shown in Fig. 2. It is composed of a Buck converter supplying a voltage  $v_{t,i} \in \mathbb{R}_{\geq 0}$ , a load with current  $i_{l,i} \in \mathbb{R}$ , and a filter with the resistance  $R_{f,i} \in \mathbb{R}_{>0}$ , inductance  $L_{f,i} \in \mathbb{R}_{>0}$  and capacitance  $C_{f,i} \in \mathbb{R}_{>0}$ . We idealize the Buck converter with




Fig. 1. Graphical representation of the meshed CIGRE benchmark MG [20] with  $n = 11$  nodes and  $m = 12$  power lines.




Fig. 2. Electric scheme of a bus including a DGU and a load.

the widespread averaging model, by which we disregard the switching behavior [21]. The dynamics for every bus  $i \in \mathcal{V}$  are described with the states  $v_i$  and  $i_{f,i}$ , which describe the node voltage and filter current by

$$C_{f,i} \dot{v}_i = i_{f,i} - i_{l,i}(v_i) - i_{\text{ext},i} \quad (1a)$$

$$L_{f,i} \dot{i}_{f,i} = v_{t,i} - R_{f,i} i_{f,i} - v_i, \quad (1b)$$

where  $i_{\text{ext},i}$  is the cumulative current injected by interconnecting lines. The DGUs at the nodes are equipped with a passivity-based primary voltage controller as in [6], which regulates  $v_i$  to a reference voltage  $v_{\text{ref},i}$ . The controller adds a state  $e_i \in \mathbb{R}$  to the system for the integral action, and employs a state feedback  $v_{t,i} = k_i^\top [v_i, i_{f,i}, e_i]^\top$  with  $k_i \in \mathbb{R}^3$ . The node dynamics with the passivity-based voltage controller are

$$C_{f,i} \dot{v}_i = i_{f,i} - i_{l,i}(v_i) - i_{\text{ext},i} \quad (2a)$$

$$L_{f,i} \dot{i}_{f,i} = \alpha_i v_i + \beta_i i_{f,i} + \gamma_i e_i \quad (2b)$$

$$\dot{e}_i = v_{\text{ref},i} - v_i, \quad (2c)$$

where

$$\alpha_i = \frac{k_{1,i} - 1}{L_{f,i}}, \quad \beta_i = \frac{k_{2,i} - R_{f,i}}{L_{f,i}}, \quad \gamma_i = \frac{k_{3,i}}{L_{f,i}}.$$

are controller parameters. In this work, we assume a time-varying resistive load, i.e.

$$i_{l,i}(v_i) = Y_i(t)v_i, \quad (3)$$

where  $Y_i \in \mathbb{R} > 0$  is the load admittance. In the following, we present an important result from [6] which will prove

instrumental for the MPC stability analysis. It states that choosing the control parameters according to [6], the node dynamics are passive w.r.t. the input-output pair  $(-i_{\text{ext},i}, v_i)$ . This allows to interconnect arbitrarily many nodes by (passive) lines while guaranteeing stability for constant voltage references  $v_{\text{ref},i}$ .

*Proposition 1 ([6]):* Let  $[\bar{v}_i, \bar{i}_{f,i}, \bar{e}_i]$  be an equilibrium point of (2) and define the error variables  $\tilde{v}_i = v_i - \bar{v}_i$ ,  $\tilde{i}_{f,i} = i_{f,i} - \bar{i}_{f,i}$  and  $\tilde{e}_i = e_i - \bar{e}_i$ . System (2) is equilibrium independent passive w.r.t. the input-output pair  $(-i_{\text{ext},i}, \tilde{v}_i)$  for any  $v_{\text{ref},i} > 0$  with the storage function  $S_i : \mathbb{R}^3 \rightarrow \mathbb{R}_{\geq 0}$

$$S_i(\tilde{v}_i, \tilde{i}_{f,i}, \tilde{e}_i) = \begin{bmatrix} \tilde{v}_i \\ \tilde{i}_{f,i} \\ \tilde{e}_i \end{bmatrix}^\top \begin{bmatrix} C_{f,i} & 0 & 0 \\ 0 & \frac{\beta_i}{\omega_i} & \frac{\gamma_i}{\omega_i} \\ 0 & \frac{\gamma_i}{\omega_i} & \frac{\alpha_i \gamma_i}{\omega_i} \end{bmatrix} \begin{bmatrix} \tilde{v}_i \\ \tilde{i}_{f,i} \\ \tilde{e}_i \end{bmatrix} \quad (4)$$

if the control parameters are chosen such that

$$k_{1,i} < 1 \quad (5)$$

$$k_{2,i} < R_{f,i} \quad (6)$$

$$0 < k_{3,i} < \frac{1}{L_{f,i}}(k_{1,i} - 1)(k_{2,i} - R_{f,i}). \quad (7)$$

*Proof:* The proof can be found in [6]. ■

## B. Power Line

The power lines are modeled with the pi equivalent circuit [22], which is shown in Fig. 3. It is composed of a series inductance  $L_{1,j} \in \mathbb{R}_{>0}$  and resistance  $R_{1,j} \in \mathbb{R}_{>0}$ , and two parallel capacitances  $\frac{C_{1,j}}{2} \in \mathbb{R}_{>0}$ . Note that the line capacitance is connected in parallel to the bus filter capacitance of the busses which the line is interconnecting. Hence, only one capacitor with a capacitance being the sum of both can be considered. Furthermore, since the capacitance of typical filter capacitors [6], [23] are higher than line capacitances of medium voltage power lines [20] by several orders of magnitude, the line capacitors can be neglected. The dynamics for line  $j \in \mathcal{E}$  interconnecting nodes  $k, l \in \mathcal{V}$  are thus described by

$$L_{1,j} \dot{i}_{L,i} = -R_{1,j} i_{L,j} + v_{\Delta j}, \quad (8)$$

where  $v_{\Delta j} = v_l - v_k$  is the input and  $v_k, v_l$  are the bus voltages. The next proposition serves as an important building block towards an overall Lyapunov function in Subsection II-C.




Fig. 3. Graphical representation of a line in the pi equivalent circuit.

*Proposition 2 ([24]):* Let  $[\bar{i}_{L,j}, \bar{v}_{\Delta,j}]$  be an equilibrium point of (8) and define  $\tilde{i}_{L,j} = i_{L,j} - \bar{i}_{L,j}$ ,  $\tilde{v}_{\Delta,j} = v_{\Delta,j} - \bar{v}_{\Delta,j}$ . System (8) is equilibrium independent strictly passive w.r.t.

the input-output pair  $(\tilde{i}_{L,j}, \tilde{v}_{\Delta,j})$  with the storage function  $S_j : \mathbb{R} \rightarrow \mathbb{R}_{\geq 0}$

$$S_j(\tilde{i}_{L,j}) = L_{1,j} \tilde{i}_{L,j}^2. \quad (9)$$

*Proof:* The proof is given in [24]. ■

*Remark 1:* For static power lines, i.e. if the inductance is neglected, system (8) is still strictly passive w.r.t. the same input-output pair, since it represents an offset-free strictly monotonically increasing map [25].

In the next subsection, the stability of the overall system is investigated, after which we dwell on the model reduction and discretization for using the model for the MPC design.

## C. Overall System

A group of  $n = |\mathcal{V}|$  independent buses is described by

$$C_t \dot{v} = i_f - Y(t)v - i_{\text{ext}} \quad (10a)$$

$$L_t \dot{i}_f = \alpha v + \beta i_f + \gamma e \quad (10b)$$

$$\dot{e} = v_{\text{ref}} - v \quad (10c)$$

where  $\alpha = \text{diag}\{\alpha_i\}$ ,  $\beta = \text{diag}\{\beta_i\}$  and  $\gamma = \text{diag}\{\gamma_i\}$  contain the control parameters,  $C_t = \text{diag}\{C_{f,i}\}$ ,  $R_t = \text{diag}\{R_{f,i}\}$ ,  $L_t = \text{diag}\{L_{f,i}\}$  and  $Y = \text{diag}\{Y_i\}$  are the filter, load and line parameters, and  $v = \text{col}\{v_i\}$ ,  $i_f = \text{col}\{i_{f,i}\}$  and  $e = \text{col}\{e_i\}$  are the stacked states of each DGU  $i \in \mathcal{V}$ . A group of  $m = |\mathcal{E}|$  power lines is described by the equations

$$L_1 \dot{i}_L = -R_1 i_L + v_{\Delta}, \quad (11)$$

where  $i_L = \text{col}\{i_{L,j}\}$ ,  $v_{\Delta} = \text{col}\{v_{\Delta,j}\}$  are the stacked states and inputs, and  $R_1 = \text{diag}\{R_{1,j}\}$  and  $L_1 = \text{diag}\{L_{1,j}\}$  the parameters of each power line  $j \in \mathcal{E}$ . The interconnection of the buses  $i \in \mathcal{V}$  and the power lines  $j \in \mathcal{E}$  according to the graph  $\mathcal{G}(\mathcal{V}, \mathcal{E})$  is described by the incidence matrix  $M \in \mathbb{R}^{n \times m}$  as defined in Section I. In particular, the voltage drop over the power lines  $v_{\Delta} \in \mathbb{R}^m$  can be described with the voltages of the buses they are connected to, i.e.

$$\text{col}\{v_{\Delta,j}\} = v_{\Delta} = M^\top v = M^\top \text{col}\{v_i\}. \quad (12)$$

The current drawn from bus  $i \in \mathcal{V}$  is the sum of the currents through lines connected to bus  $i$ , i.e.,

$$\text{col}\{-i_{\text{ext},i}\} = -i_{\text{ext}} = -M i_L = -M \text{col}\{i_{L,j}\}. \quad (13)$$

According to [6, Lemma 1], this constitutes a skew-symmetric interconnection. Having described the interconnection, the whole MG composed of  $n = |\mathcal{V}|$  nodes interconnected by  $m = |\mathcal{E}|$  lines obeys the dynamics

$$C_t \dot{v} = i_f - Y(t)v - M i_L \quad (14a)$$

$$L_t \dot{i}_f = \alpha v + \beta i_f + \gamma e \quad (14b)$$

$$\dot{e} = v_{\text{ref}} - v \quad (14c)$$

$$L_1 \dot{i}_L = -R_1 i_L + M^\top v. \quad (14d)$$

The following result about the stability of the interconnected system paves the way for proving stability of the closed-loop system with MPC.

*Proposition 3:* Consider a system of independent buses and lines as in (10) and (11) interconnected through

(12) and (13) as in (14). A Lyapunov function of the interconnected system for any  $v_{\text{ref}} > 0$  is given by

$$V(\tilde{x}) = \sum_{i \in \mathcal{V}} S_i(\tilde{v}_i, \tilde{i}_{f,i}, \tilde{e}_i) + \sum_{j \in \mathcal{E}} S_j(\tilde{i}_{L,j}) \quad (15)$$

with  $x = \text{col}\{\tilde{v}_i, \tilde{i}_{f,i}, \tilde{e}_i, \tilde{i}_{L,j}\}$ .

*Proof:* System (10) is passive w.r.t.  $(-\tilde{i}_{\text{ext}}, \tilde{v})$  with storage function  $S_{\text{bus}} = \sum S_i(\tilde{v}_i, \tilde{i}_{f,i}, \tilde{e}_i)$ , which follows trivially from Prop. 1, since the bus dynamics in (10) are independent. Applying the same reasoning, system (11) is strictly passive w.r.t.  $(\tilde{v}_{\Delta}, \tilde{i}_{L,j})$  with storage function  $S_{\text{lines}} = \sum S_j(\tilde{i}_{L,j})$  by Prop. 2. From (15), it holds that

$$\dot{V} = \sum_{i \in \mathcal{V}} \dot{S}_i(\tilde{v}_i, \tilde{i}_{f,i}, \tilde{e}_i) + \sum_{j \in \mathcal{E}} \dot{S}_j(\tilde{i}_{L,j}) \quad (16a)$$

$$< -\tilde{i}_{\text{ext}}^{\top} \tilde{v} + \tilde{i}_{L,j}^{\top} \tilde{v}_{\Delta j} \stackrel{(12),(13)}{=} 0. \quad (16b)$$

The inequality in (16b) follows from the passivity of (10) and the strict passivity of (11) as in Prop. 1 and Prop. 2. The last equality follows from the skew symmetric interconnection (12) and (13). ■

Note that the Lyapunov function holds for an arbitrary number of interconnected buses and lines, as long as the DGU controllers fulfill Prop. 1.

#### D. Model reduction and discrete time model for MPC

The MG model in (14) contains very fast dynamics, especially the power lines in (14d)<sup>1</sup>. This requires very small step sizes when describing these dynamics as a discrete time system, which may compromise the real time optimization of the MPC. The solution adopted here is to neglect the inductances in the lines, i.e. to use the quasi-stationary line approximation [17], [26]. With this approximation, the MG dynamics can be described with

$$C_t \dot{v} = i_f - Y(t)v - MR_1^{-1}M^{\top}v \quad (17a)$$

$$L_t \dot{i}_f = \alpha v + \beta i_f + \gamma e \quad (17b)$$

$$\dot{e} = v_{\text{ref}} - v. \quad (17c)$$

These equations capture the dynamics of the passivity-based controlled DGUs interconnected with lossy static lines. Note that (15) is also a Lyapunov function for (17), since Prop. 3 still applies due to the passivity properties of static lines (see Remark 1). System (17) is rewritten compactly in state-space representation with

$$A = \begin{bmatrix} -C_t^{-1}(Y + MR_1M^{\top}) & C_t^{-1} & 0 \\ L_t^{-1}\alpha & L_t^{-1}\beta & L_t^{-1}\gamma \\ -I & 0 & 0 \end{bmatrix} \in \mathbb{R}^{3n \times 3n}$$

$$B = \begin{bmatrix} 0 & 0 & I \end{bmatrix}^{\top} \in \mathbb{R}^{3n \times n}$$

and discretized using the forward Euler method with the step size  $h$

$$x(k+1) = A_k x(k) + B_k u(k) \quad (18)$$

<sup>1</sup>The power line dynamics constitute a first order lag with a time constant of  $T = \frac{L_{1,j}}{R_{1,j}}$ , which takes values around  $10^{-6}$  for typical medium voltage power lines [23].

with  $x(k) = \text{col}\{v(k), i_f(k), e(k)\}$ ,  $u = v_{\text{ref}}(k)$ ,  $A_k = I + hA$  and  $B_k = hB$ . Furthermore, the assumption of piece-wise constant system parameters (i.e. loads) during the discretization time is made. The following proposition ensures the existence of a Lyapunov function for the discrete time system (18), which way paves the way to apply the classical stability theorems for predictive controllers [27].

*Proposition 4:* Let  $\lambda_i = a_i + jb_i \in \text{Spec}(A)$ . There exists a  $h_{\text{max}} = \min_i -\frac{2a_i}{a_i^2 + b_i^2} \in \mathbb{R}_{>0}$  for which the system (18) with any step size  $h < h_{\text{max}}$  is asymptotically stable. Moreover, a Lyapunov function  $V_d(x(k)) = x(k)^{\top} P x(k)$  for system (18) exists and can be computed by solving the semidefinite programming problem

$$P > 0, \quad A_k^{\top} P A_k + P < 0. \quad (19)$$

*Proof:* If  $\lambda_i = a_i + jb_i \in \text{Spec}(A)$ , then  $h\lambda_i + 1 \in \text{Spec}(I + hA)$ . From Prop. 3, we know that  $a_i < 0$ . From  $|h\lambda_i + 1| < 1$  for all  $i$  follows  $h_{\text{max}} = \min_i -\frac{2a_i}{a_i^2 + b_i^2}$ . ■

### III. OPTIMAL VOLTAGE REFERENCES

In this section, we present the controller design used for finding suitable voltage references such that (i) the power line losses are minimized, (ii) constraint satisfaction is guaranteed, and (iii) stability is achieved. We propose first to use the classical, setpoint-tracking MPC [27], which requires the prior computation of optimal setpoints. By using the well studied tracking MPC theory, we provide a formal stability proof using the results of Prop. 4. Secondly, we design an equivalent economic MPC, which is shown to be superior in performance than the classical tracking MPC. For the economic MPC we limit ourselves to the study the closed-loop stability by simulations in Section IV.

#### A. Tracking MPC

In this method, we compute the optimal steady-state node voltages  $v^*(k)$  in advance which is given as a setpoint to the tracking MPC. The tracking MPC then computes a  $u(k)$  such that the node voltages  $v$  follow the setpoint  $v^*$ . The optimal steady-state voltages are computed solving the (open loop) optimization problem

$$\text{Opt}_{\text{ss}}(k) := \begin{cases} \min_v & v^{\top} Q_{\text{loss}} v \\ \text{s. t.} & p + Y_{\text{ad}} v \circ v = 0, \\ & v \in \mathbb{V} \\ & p \in \mathbb{P} \end{cases} \quad (20)$$

in which  $v^{\top} Q_{\text{loss}} v = v^{\top} M R_1^{-1} M^{\top} v \geq 0$  represent the line losses in the system and  $p = \text{col}\{p_i\} \in \mathbb{R}^n$  is the power infeed of a DGU to the bus. The constraints in (20) represent the power flow equations, described through the nodal admittance matrix  $Y_{\text{ad}}$  [22], and the voltage  $\mathbb{V} \subset \mathbb{R}^n$  and power constraints  $\mathbb{P} \subset \mathbb{R}^m$ , which may be different for each bus and DGU. Note that the matrix  $Y_{\text{ad}}$  contains, apart from the line admittances, also the time-varying loads in (3). With an estimation of the loads in the next time steps, this optimization problem is solved for some time steps in advance and  $v^*(k) \in \arg \min \text{Opt}_{\text{ss}}(k)$  is obtained. Such an optimal setpoint computation is typically performed every

few minutes, and a controller ensures that the steady-state is held using feedback control.

For the feedback controller, we propose to use a setpoint-tracking MPC. Having  $v^*(k)$ , tracking MPC is defined as

$$\text{MPC}_{\text{track}} := \begin{cases} \min & \sum_{k=1}^{N-1} \left\{ \Delta v(k)^\top Q \Delta v(k) + \right. \\ & \left. \Delta u(k)^\top R \Delta u(k) \right\} + V_N(\Delta v(N)) \\ \text{s. t.} & x(k+1) = A_k(k)x(k) + b_k u(k), \\ & x(k) \in \mathbb{X} \\ & u(k) \in \mathbb{U} \\ & k \in \{1, \dots, N\}, \end{cases} \quad (21)$$

with  $\Delta v(k) = v(k) - v^*(k)$ ,  $\Delta u(k) = u(k) - v^*(k)^2$ ,  $R = \eta I_n \in \mathbb{R}^{n \times n}$ ,  $\eta \in \mathbb{R}_{>0}$  and  $Q = I_n \in \mathbb{R}^{n \times n}$ , is employed to compute the optimal voltage references  $u = v_{\text{ref}}$  which leads to minimal losses by considering the DGU, filter, the lines and loads. The constraints for the state and input variables in (21) represent the voltage and current constraints, whereas the controller state (17c) is not constrained. The matrices  $Q$  and  $R$  penalize the deviation of the voltage  $v$  and reference voltage  $v_{\text{ref}}$  to the optimal steady-state  $v^*$ . The following theorem states how to choose the terminal costs  $V_N(\Delta v(N))$  such that closed-loop stability is ensured.

*Theorem 1:* The closed-loop system composed of (18) with the feedback law  $u(k) = u^*(1)$ ,  $u^*(\tau) = \arg \min \text{MPC}_{\text{track}}$  with  $\tau = \{1, \dots, N\}$  is asymptotically stable if the terminal costs are chosen  $V_N(\Delta v(N)) = x(N)^\top P x(N)$  with  $P$  as in Prop. 4.

*Proof:* Since the terminal cost  $V_N(x(k)) = x(k)^\top P x(k)$  is a Lyapunov function for all  $x(k) \in \mathbb{R}^{3n}$ , asymptotic stability without the need of terminal constraints follows directly from the classic setpoint-tracking MPC theory [27, Sec. 3.7.2.2]. ■

*Remark 2:* The optimal voltage setpoint for the tracking MPC is considered to be piece-wise constant for the tracking MPC. This is a classic assumption in MPC and is valid if the optimal setpoint computation is sufficiently slow compared to the system dynamics. Since the optimal setpoint computation is typically performed every few minutes and the step size of the MG dynamics in Prop. 4 takes values of few milliseconds, this assumption is admissible and the setpoint-tracking MPC theory applies.

### B. Economic MPC

In this approach, we solve the optimization problem

$$\text{MPC}_{\text{econ}} := \begin{cases} \min_u & \sum_{k=1}^N v(k)^\top Q_{\text{loss}} v(k) \\ \text{s. t.} & x(k+1) = A_k(k)x(k) + b_k u(k), \\ & x(k) \in \mathbb{X} \\ & u(k) \in \mathbb{U} \\ & k \in \{1, \dots, N\}, \end{cases} \quad (22)$$

<sup>2</sup>Note that the input leading to the equilibrium point  $v^*$  is  $u = v^*$ .




Fig. 4. Comparison of setpoint tracking and economic MPC from a procedural perspective

with  $Q_{\text{loss}}$  as in (20) at every time step and apply only the first control action  $u^*(1)$ . Hereby, the traditional control structure of computing the optimal setpoint and controlling it by feedback setpoint-tracking MPC is combined into a single feedback structure, see Fig. 4. Thus, it is not necessary to compute or know the optimal setpoint in advance, it results from the control action. It can therefore react immediately to load changes without having to compute new steady-state optimal setpoints, which is an advantage when dealing with volatile RES. However, since the objective function is not convex w.r.t. the optimal setpoint to be stabilized<sup>3</sup>, the mature theory about classical setpoint-tracking MPC does not hold [28]. The approach falls under the class of economic MPC.

In this work, the stability of economic MPC is demonstrated through simulations in the following section<sup>4</sup>. In particular, we show that economic MPC outperforms the classical control structure for predictive controllers composed of an optimal setpoint computation and a stabilizing setpoint-tracking MPC.

## IV. SIMULATION RESULTS

In this section, simulation results for the closed-loop system with the tracking MPC (21) and the economic MPC (22) are presented. We show that the economic MPC achieves slightly better performance than the tracking MPC in the nominal case, whereas a significant performance increase is observed when disturbances unforeseen by the optimal setpoint computation in (20) occur.

The MG considered in this work is based on the CIGRE medium voltage benchmark system, since it represents the network topology of a typical distribution system, and it is aimed to serve as a benchmark system for voltage control studies [20]. It is composed of 11 nodes and 12 power lines and shows a meshed structure (see Fig. 1). Since the benchmark system is conceived as an AC system, typical

<sup>3</sup>Here, we are not penalizing the deviations to a setpoint, and the cost is not necessarily decreasing until the setpoint is reached [28].

<sup>4</sup>Note that economic MPC is an active field of research, with almost no theoretical results when applied to power systems [18], [28].

DC system parameters are taken from [23] for the lines and DGU filters. The step size is chosen to be  $h = 10$  ms for both MPCs, for which Prop. 4 is fulfilled. The optimization horizon is set to  $N = 300$ , which corresponds to 3 s. For the tracking MPC, new optimal setpoints are computed every 30 seconds. The parameter  $\eta$  is set to  $\eta = 10^{-2}$  in order to achieve a better voltage tracking.

In the following, we compare both MPC approaches in the nominal case, i.e. when the load is known with no error, and in the case when load disturbances occur. Especially, we compute the transmission losses achieved in each scenario in order to assess the closed-loop performance in Section IV-C.

#### A. Scenario 1: Nominal Case

First, the nominal case is considered, where the load is assumed to be known with no error by the predictive controllers and the steady-state optimization (20) for the tracking MPC. The load during the simulation time is shown in Fig. 5. At time  $t = 30$  s, a load step occurs in all nodes. The load step time is chosen to be at the same time when new optimal setpoints are computed for the tracking MPC, such that the MPC always receives the optimal setpoints. Note that in real applications, the optimal setpoints will likely not be computed at the same time as the load changes. The scenario presented here is hence the best case scenario for the tracking MPC in order to allow a fair comparison with the economic MPC. The node voltages in the MG with the




Fig. 5. Load at each bus over the simulation time in the nominal case.

tracking MPC and the economic MPC are shown in Fig. 6. The dot-dashed lines are the optimal setpoints computed by the steady-state optimization (20). Due to voltage, current or power flow constraints in (20), different voltage references that induce power flows through the lines are necessary. In the case of tracking MPC, the node voltages follow the optimal setpoints (dot-dashed) accurately. Since the optimal setpoints of the voltages are computed with (20) and lead to minimal power line losses, the closed-loop behavior with the tracking MPC is (only) steady-state optimal. Only during transients, i.e. when load steps occur, considering the system dynamics for the explicit task of minimizing losses instead of regulating a setpoint may improve performance. The economic MPC achieves the optimal steady-state voltages (dot-dashed) without requiring a priori voltage setpoints. The node voltages with the economic MPC are identical to the voltages with the tracking MPC, except for the time around the load step.




Fig. 6. Microgrid bus voltages when using a tracking MPC (above) and an economic MPC (below) in the nominal case.

The line losses resulting from the node voltages are computed for comparing the performance of tracking and economic MPC. The economic MPC achieves 0.2% less transmission losses than the tracking MPC in the nominal case (viz. Table I). This improvement is due to a better transient behavior during the load step at  $t = 30$  s. In the case of the tracking MPC, since the deviations are penalized, the node voltages follow the steps arising from the setpoint  $v^*(k)$  which changes once at  $t = 30$  s. This is, however, not optimal w.r.t. minimizing the losses. On the other hand, the economic MPC does not minimize the deviations to some setpoint, it chooses the input on the basis of minimizing the losses, also during transients. Thus, it achieves a better performance. This effect is assumed to gain importance when disturbances occur. Thus, in the next subsection, the performance of both receding horizon control approaches will be compared for the case when disturbances in the load occur.

#### B. Scenario 2: Disturbances

In the following, load variations are considered in order to highlight the performance of economic MPC. We consider three types of disturbances, 1) unknown load steps, 2) load noise and 3) a line failure. The unknown load steps and load noise are depicted in Figs. 7 and 9, respectively. The unknown load steps occur in Nodes 2 and 6, while the load noise occurs only in Node 1. Since the predictive controllers need a prediction of the load over the optimization horizon, it is assumed that the actual load is measured and considered to be constant over the optimization horizon of 3 s. The optimal setpoint computation in (20) is assumed to not have knowledge about these measurable disturbances, since it computed the optimal setpoints in advance. The

voltage trajectories are reported in this section, while the performance comparison is made in Section IV-C.

1) *Unknown load steps*: The node voltages in the MG equipped with both predictive controllers can be seen in Fig. 8. The tracking MPC still achieves an acceptable regulating behavior when the load step occurs, since it penalizes the deviations to that given setpoint. However, note that the optimal setpoint computed in advance is no longer optimal due to the load steps, which are not known in advance and not considered in (20). On the other hand, the node voltages set by the economic MPC differ w.r.t. the setpoints from (20) when the disturbances occur. Since the economic MPC does not minimize the deviations to a given setpoint and instead directly minimizes the losses, a new but optimal steady-state arises.




Fig. 7. Predicted (dot-dashed) and real load in the case of unknown steps in Node 2 and 6.




Fig. 8. Microgrid bus voltages when using a tracking MPC (above) and an economic MPC (below) under an unknown load step.

2) *Load noise*: The node voltages in the MG with both receding horizon controllers in the case of load noise are shown in Fig. 10. The voltages set by the tracking MPC show significant oscillations around the given optimal setpoints. In

contrast, the node voltages produced by the economic MPC are smooth and slightly differ from the optimal steady-state voltages computed in advance, as expected.




Fig. 9. Predicted (dot-dashed) and real load in the case of load noise in Node 1.





Fig. 10. Microgrid bus voltages when using a tracking MPC (above) and an economic MPC (below) under unknown load noise.

3) *Line failure*: In the scenario of a line failure, the line between Node 3 and 8 fails at time  $t_{\text{fail}} = 20\text{s}$  and is unavailable thereafter. The line failure is assumed to be measurable and known by the predictive controllers, but not by the optimal setpoint computation in (20) which happens in advance. The node voltages in the MG with both predictive controllers in the case of a line fail can be seen in Fig. 11. The tracking MPC minimizes the deviation to the provided setpoint (dot-dashed line), which is not optimal for the new MG topology. The voltages when using the economic MPC converge to a new steady-state, which is optimal under the new MG configuration.

### C. Performance comparison

The performance increase of the economic MPC w.r.t. the tracking MPC is shown in Table I. It shows the reduction of






Fig. 11. Microgrid bus voltages when using a tracking MPC (above) and an economic MPC (below) under a line failure.

transmission losses for the described scenarios normalized to the transmission losses from the economic MPC. The economic MPC achieves a better performance in all cases. The increase in performance depends clearly on the severity of the disturbance. The small disturbance from the load noise shows a 2.6 % less transmission losses. For greater disturbances, the reduction increases to 9.3 % (load step), and 15.6 % (line failure). Thus, greater disturbances yield greater performance benefits from the economic MPC, since the optimal voltages differ more from the a priori calculated setpoints. Since the economic MPC does not need to compute any optimal setpoint in advance, it has a clear advantage also in terms of computation and enjoys a simpler feedback control structure naturally achieving the optimal setpoints as a result of the control action.

TABLE I

PERFORMANCE INCREASE OF ECONOMIC MPC OVER TRACKING MPC IN DIFFERENT SCENARIOS

Scenario	Performance increase of economic MPC
Nominal	0.2 %
Unknown load steps	9.3 %
Unknown load noise	2.6 %
Line failure	15.6 %

## V. CONCLUSION

This paper presents two MPC-based controllers for computing optimal voltage references for a DC MG with passivity-based primary controllers. An asymptotically stabilizing setpoint-tracking MPC is designed, and stability is proven by considering the passivity properties of the DC

MG with the primary controller. Furthermore, we present an economic MPC controller which outperforms the traditional control scheme composed of optimal steady-state computation and setpoint-tracking MPC.

Future work may concern the rigorous stability proofs of the economic MPC for DC MGs. Dropping the necessity of computing a priori optimal setpoints is a key advantage of economic MPC which can be exploited for distributed control of large scale energy systems.

## REFERENCES

- [1] A. T. Elsayed *et al.*, ‘DC microgrids and distribution systems: An overview’, *Electric Power Syst. Research*, 2015.
- [2] J. J. Justo *et al.*, ‘AC-microgrids versus DC-microgrids with distributed energy resources: A review’, *Renewable and Sustainable Energy Reviews*, 2013.
- [3] J. M. Guerrero *et al.*, ‘Hierarchical control of droop-controlled AC and DC microgrids—A general approach toward standardization’, *IEEE Trans. on Ind. Electron.*, 2010.
- [4] J. Zhao and F. Dörfler, ‘Distributed control and optimization in DC microgrids’, *Automatica*, 2015.
- [5] F. Gao *et al.*, ‘Primary and secondary control in DC microgrids: a review’, *J. of Modern Power Syst. and Clean Energy*, 2019.
- [6] P. Nahata *et al.*, ‘A passivity-based approach to voltage stabilization in DC microgrids with ZIP loads’, *Automatica*, 2020.
- [7] K. Laib *et al.*, ‘Decentralized stability conditions for DC microgrids: Beyond passivity approaches’, *Automatica*, 2023.
- [8] J. W. Simpson-Porco *et al.*, ‘Secondary Frequency and Voltage Control of Islanded Microgrids via Distributed Averaging’, *IEEE Trans. on Ind. Electron.*, 2015.
- [9] F. Strehle *et al.*, ‘A Scalable Port-Hamiltonian Approach to Plug-and-Play Voltage Stabilization in DC Microgrids’, in *IEEE Conf. on Control Technology and Applicat.*, 2020.
- [10] P. Nahata *et al.*, ‘Consensus-Based Current Sharing and Voltage Balancing in DC Microgrids With Exponential Loads’, *IEEE Trans. on Control Syst. Technol.*, 2022.
- [11] A. J. Malan *et al.*, ‘Distributed coordination of physically-interconnected multi-agent systems with actuated and unactuated agents’, *European J. of Control*, 2022.
- [12] J. Hu *et al.*, ‘Model predictive control of microgrids—An overview’, *Renewable and Sustainable Energy Reviews*, 2021.
- [13] Z. Karami *et al.*, ‘Decentralized Model Predictive Control of DC Microgrids With Constant Power Load’, *IEEE J. of Emerging and Selec. Topics in Power Electron.*, 2021.
- [14] T. V. Vu *et al.*, ‘Model predictive control for power control in islanded DC microgrids’, in *Ann. Conf. of the IEEE Ind. Electron. Soc.*, 2015.
- [15] D. R. Kishore and T. V. Muni, ‘Efficient energy management control strategy by model predictive control for standalone dc micro grids’, in *AIP Conf. Proc.*, AIP Publishing LLC, 2018.
- [16] G. Lou *et al.*, ‘Distributed MPC-Based Secondary Voltage Control Scheme for Autonomous Droop-Controlled Microgrids’, *IEEE Trans. on Sustainable Energy*, 2017.
- [17] N. Noroozi *et al.*, ‘Model predictive control of DC microgrids: current sharing and voltage regulation’, *IFAC-PapersOnLine*, 2018.
- [18] Y. Jia *et al.*, ‘Optimal load frequency control for networked power systems based on distributed economic MPC’, *IEEE Trans. on Syst., Man, and Cybernetics*, 2020.
- [19] J. Köhler *et al.*, ‘Real time economic dispatch for power networks: A distributed economic model predictive control approach’, in *Ann. Conf. on Decision and Control*, 2017.

- [20] K. Rudion *et al.*, 'Design of benchmark of medium voltage distribution network for investigation of DG integration', in *2006 IEEE Power Eng. Soc. General Meeting*, 2006.
- [21] R. D. Middlebrook and S. Cuk, 'A general unified approach to modelling switching-converter power stages', in *IEEE Power Electron. Specialists Conf.*, 1976.
- [22] J. Machowski *et al.*, *Power system dynamics: stability and control*. John Wiley & Sons, 2020.
- [23] M. Tucci *et al.*, 'A Decentralized Scalable Approach to Voltage Control of DC Islanded Microgrids', *IEEE Trans. on Control Syst. Technol.*, 2016.
- [24] B. Brogliato *et al.*, *Dissipative systems analysis and control*. Springer London, 2007.
- [25] H. K. Khalil, 'Nonlinear systems third edition', *Patience Hall*, 2002.
- [26] V. Venkatasubramanian *et al.*, 'Fast time-varying phasor analysis in the balanced three-phase large electric power system', *IEEE Trans. on Autom. Control*, 1995.
- [27] D. Q. Mayne *et al.*, 'Constrained model predictive control: Stability and optimality', *Automatica*, 2000.
- [28] M. A. Müller and F. Allgöwer, 'Economic and distributed model predictive control: Recent developments in optimization-based control', *J. of Control, Measurement, and Syst. Integration*, 2017.